



PT	DESCRIPTION	QTY.	SYMBOL	REMARKS
1	PURGENEER	1	PIV-6	5-50 SCFH
2	DRAFT GAUGE	1	PI-13	
3	SELECTOR VALVE	5	PV-1 THRU 10	
4	DIAL THERMOMETER	2	TI-4,5	
5	DAMPER OPERATOR	2	TV-2	
6	TEMP. RECORDING CONTROLLER	2	TR-1,2	HONEYWELL DR 4500A
6B	THERMOCOUPLE TYPE J	2	TE-1A,2A	DUAL ELEMENT
7	I/P TRANSDUCER	2	I/P-1,2	
9	STEAM CONTROL VALVE	1	TV-1	3/4" NPT
14B	THERMOCOUPLE TYPE J	1	TE-3, 3A	DUAL ELEMENT
20	DIFFERENTIAL PRESSURE GAUGE	1	PI-7	0-2" W.C.
21	DIFFERENTIAL PRESSURE GAUGE	1	PI-8	0-4" W.C.
22	DIFFERENTIAL PRESSURE GAUGE	1	PI-9	0-3" W.C.
23	DIFFERENTIAL PRESSURE GAUGE	1	PI-10	0-1" W.C.
24	DIFFERENTIAL PRESSURE GAUGE	1	PI-11	BY CUSTOMER
25	DIFFERENTIAL PRESSURE GAUGE	1	PI-12	BY CUSTOMER
26	SELECTOR VALVE	2	PV-11,12	BY CUSTOMER
21-30	ZERO SPEED SWITCH	1	ZS-14	

ABOVE PARTS SUPPLIED BY WYSSMONT UNLESS OTHERWISE NOTED.  
 ALL INTERCONNECTING WIRING AND PIPING SUPPLIED AND INSTALLED BY PURCHASER UNLESS OTHERWISE NOTED.  
 EXHAUST SYSTEM SHOULD BE SIZED 20 - 30% HIGHER THAN VALUES SHOWN

— PROCESS CONNECTION  
 — PNEUMATIC SIGNAL  
 — ELECTRICAL SIGNAL  
 — PROCESS LINE BY CUSTOMER

○ LOCALLY MOUNTED DEVICE  
 ◐ PANEL MOUNTED DEVICE  
 ◑ DEVICE MOUNTED INSIDE PANEL

**CERTIFIED**  
 JUL 10 1998  
 WYSSMONT COMPANY, INC.  
 1470 Bergen Blvd.  
 Dept. 0001, New Jersey 07032

PLEASE RETURN 1 PRINT WITH YOUR COMMENTS AND APPROVAL BY 07/24/98. USE EXPRESS MAIL RETURNS AFTER THIS DATE MAY INCUR DELAYS IN FABRICATION AND DELIVERY.

REV.	BY	DATE	DESCRIPTION	APP'VD.
A	VG	07/08/98	REVISED PER CUSTOMER COMMENTS AND 6/11/98 LETTER	JU

RECOMMENDED TURBO DRYER INSTRUMENTATION AND CONTROL

WYSSMONT COMPANY, Inc.  
 FORT LEE, NEW JERSEY

CUST. P.O.: 13805MW	SCALE: NONE	REV. DRAWN BY: SM 1/30/98
WYSSMONT REF: (J384) 501-98002	DWG. NO. J384-062	CHECKED BY: JU 2/9/98
This drawing is the property of WYSSMONT CO. INC. and is not to be reproduced or used to furnish any information for making of drawings or apparatus except where provided for by agreement with said company.		APP'VD. BY:

S:\R12\_DWGS\62\384-062.DWG