


JOB. NO. \_\_\_\_\_ DATE 8-17-78 P.O. 1607-009  
DEPT. GLYCOL EQPT. NO. 21-08-025  
VENDOR HUGHES ANDERSON  
MFR. \_\_\_\_\_  
EQPT. USED FOR STRIPPER REBOILER

100288



NOTE!

FOR: HOUSTON CHEMICAL CO.  
BEAUMONT, TEXAS



| DESIGN DATA                           |              |               |   | NOZZLE DATA                                                   |       |                |              | GENERAL NOTES                                                                                                                                                                                                                                                                                                                       |                              | CERTIFIED CORRECT FOR FABRICATION |  |  |
|---------------------------------------|--------------|---------------|---|---------------------------------------------------------------|-------|----------------|--------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|-----------------------------------|--|--|
| DESIGN PRESS (H.W.P.)                 | 75 PSI       | 75 PSI        | A | 6"                                                            | 150°  | R.F.           | INLET        | 1. DESIGN & CONSTRUCTION SHALL BE IN ACCORDANCE WITH:                                                                                                                                                                                                                                                                               | BY: <i>A.S. Hansen</i>       | DATE: 10/21/75                    |  |  |
| TEST PRESS.                           | 115 PSI      | 115 PSI       | B | 2 1/2"                                                        | 150°  | R.F.           | OUTLET       | (A) SECTION VIII 1972 EDITION OF THE ASME CODE, DIV. 1 & SO STAMPED BY (B) TEMA "B" (C) CUST. SPECS.                                                                                                                                                                                                                                | CUST.: SCIENTIFIC DESIGN CO. |                                   |  |  |
| DESIGN TEMPERATURE                    | 340°F        | 290°F         | D | 4"                                                            | 150°  | R.F.           | OUTLET       | 2. ALL BOLT HOLES TO STRADDLE EB.                                                                                                                                                                                                                                                                                                   | DEST.: BEAUMONT, TEXAS       |                                   |  |  |
| CORROSION ALLOWANCE                   | 1/16"        | —             | E | 1"                                                            | 150°  | R.F.           | VENT TAILING | 3. SPOT X-RAY CHANNEL SHALL.                                                                                                                                                                                                                                                                                                        | CUST. PO.: 1607-007          |                                   |  |  |
| NUMBER OF PASSES                      | 1            | 2             | F | 3/4"                                                          | —     | N.P.T.         | VENT PLUG    | 4. ONE SPARE SET OF GASKETS REQ'D.                                                                                                                                                                                                                                                                                                  | ITEM: E-1407                 |                                   |  |  |
| TUBE SURFACE (ERR)                    | 7135 SQ. FT. | —             | G | —                                                             | —     | N.P.T.         | DRAIN PLUG   | 5. UNLUBRICATED CONTENT SHALL NOT EXCEED 25 PPM FOR TEST WATER ON STD. SPEC. PARTS.                                                                                                                                                                                                                                                 | SERVICE: STRIPPER REBOILER   |                                   |  |  |
| TUBES: 109-1 1/2" x 16.6000 15A-24934 | —            | —             | H | 3/4"                                                          | 3000° | CPLG           | VENT PLUG    | 6. Near white blast/SSPC-SP10 on all carbon stl. nozzles, flanges, supports & channel cover and apply one coat of inorganic zinc rich primer (PPG #UC-46745 & 46) 3 mils min. D.F.T. 1st coat to be high solids epoxy (PPG #UC-42203) light gray 5 mils min. D.F.T. Top coat to be Aquapox (PPG #UC-42207) white 2 mils min. D.F.T. | SERIAL: 1825                 |                                   |  |  |
| ESTIMATED WEIGHT EACH                 |              |               |   | NOZZLES A,B,C,D EQUIPPED WITH 2-3/4-6.0000 CPLGS (PLUG & CO). |       |                |              | FILE: 291-75                                                                                                                                                                                                                                                                                                                        |                              |                                   |  |  |
| DRY WGT. 39.000 LBS 39.600 LBS        |              |               |   | 2RS RMS FINISH ON FLANGE FACE.                                |       |                |              | HUGHES-ANDERSON ENGINEERING CORP. TULSA, OKLAHOMA                                                                                                                                                                                                                                                                                   |                              |                                   |  |  |
|                                       |              |               |   |                                                               |       |                |              | DRAWING TITLE OUTLINE DIMENSIONAL                                                                                                                                                                                                                                                                                                   |                              |                                   |  |  |
|                                       |              |               |   |                                                               |       |                |              | WORK ORDER 1825                                                                                                                                                                                                                                                                                                                     |                              | NUMBER REQ'D. ONE                 |  |  |
| DR. KEN                               |              | DATE 10/20/75 |   | SIZE 5" x 8"                                                  |       | DRAWING NUMBER |              |                                                                                                                                                                                                                                                                                                                                     |                              |                                   |  |  |
| CK. Jim                               |              | SCALE NONE    |   | TYPE BCL                                                      |       | 1825-01        |              |                                                                                                                                                                                                                                                                                                                                     |                              |                                   |  |  |

*(Handwritten notes at bottom of page)*

FOREIGN PRINT FILE  
HOUSTON CHEMICAL COMPANY  
DIVISION OF  
PPG INDUSTRIES, INC.  
BEAUMONT, TEXAS 77704

JOB. NO. DATE 2/18/77 P.O. 1607-009  
DEPT. Glycol EQPT. NO. 21-08-025  
VENDOR Hughes-Anderson  
MFR.  
EQPT. USED FOR Stripper Reboiler

100288



VIEW A-A Baffles  
3-REQD. CUT AAA - 50 TAP  
3-REQD. CUT BBB - 50 TAP

FINAL DESIGN

3-22-76

Job # 1607  
Item E-1607

| NO. | REQD. | "X"   | NO. | REQD. | "X"   | REQD. | "X" |
|-----|-------|-------|-----|-------|-------|-------|-----|
| 1   | 6     | 3'-0" | 1   | 6     | 3'-0" | 1     | 6   |
| 2   | 1     | 5'-9" | 2   | 1     | 5'-9" | 2     | 1   |
| 3   | 10    | 2'-8" | 3   | 10    | 2'-8" | 3     | 10  |
| 4   | 16    | 5'-5" | 4   | 16    | 5'-5" | 4     | 16  |

- NOTES:
1. DRILL 1/64" DIA. HOLES FOR TUBES.
  2. DRILL 1/16" DIA. HOLES FOR TIE RODS.
  3. DEBURR ALL TUBE HOLES.
  4. REMOVE ALL SHARP CORNERS ON Baffles.

| HUGHES-ANDERSON ENGINEERING CORP. |              |                  |         |
|-----------------------------------|--------------|------------------|---------|
| TULSA, OKLAHOMA                   |              |                  |         |
| DRAWING TITLE BUNDLE DETAILS      |              | NUMBER REQD. ONE |         |
| WORK ORDER 1825                   |              | DRAWING NUMBER   |         |
| DR. TAA                           | DATE 2/23/76 | SIZE 52 x 20     | 1025-01 |
| CK. MII                           | SCALE        | TYPE B2          |         |

**FORM U-1 MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS**  
**As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1**

1. Manufactured by Hughes-Anderson Engr. Corp. Tulsa, Oklahoma  
(Name and address of manufacturer)  
2. Manufactured for Scientific Design Co. New York, New York  
(Name and address of purchaser)  
3. Location of Installation Houston Chemical Co. Beaumont, Texas  
(Name and address)  
4. Type Vert. Vessel No. 1825 1825-01-13  
(Horiz., or vert. tank) (Mfr's Serial No.) (CRN) (Drawing)  
454 Year Built 1976  
(Nat'l Bld No.)  
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1974 and Addenda to Summer 75 and Code Case no. \_\_\_\_\_  
(Year) (Date)  
Special service per UG-120(d) \_\_\_\_\_  
Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: \_\_\_\_\_  
(Name of part, item number, mfr's name and identifying stamp)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: Material SA-516-70 Nominal Thickness 1/2 in. Corrosion Allowance 1/16 in.  
(Spec. No., Grade)  
Diam. 4 ft 5 in. Length 19 ft 6-3/4 in.

**CERTIFICATE OF COMPLIANCE**

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.  
Date 8-2-76 Signed Hughes-Anderson Engr. Corp. Bill Johnson  
(Manufacturer) (Representative)  
"U" Certificate of Authorization No. 11979 expires December 31, 1976

**CERTIFICATE OF SHOP INSPECTION**

Vessel made by Hughes-Anderson Engr. Corp. at Tulsa, Oklahoma  
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Illinois and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pressure vessel described in this Manufacturers' Data Report on 8-26-76 1976, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-26-76  
Signed C. L. Cooney Commissions NB #5745  
(Inspector) (Nat'l Board, State, Province and No.)

**CERTIFICATE OF COMPLIANCE FOR FIELD WORK**

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date \_\_\_\_\_ Signed \_\_\_\_\_ by \_\_\_\_\_  
(Manufacturer) (Representative)  
"U" Certificate of Authorization No. \_\_\_\_\_ expires \_\_\_\_\_, 19\_\_\_\_

**CERTIFICATE OF FIELD ASSEMBLY INSPECTION**

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of \_\_\_\_\_ and employed by \_\_\_\_\_ of \_\_\_\_\_ have compared the statements in this Manufacturers' Data Report with the described pressure vessel and state that parts referred to as data items \_\_\_\_\_, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1.

The described vessel was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date \_\_\_\_\_  
Signed \_\_\_\_\_ Commissions \_\_\_\_\_  
(Authorized Inspector) (Nat'l Board, State, Province and No.)

832001#

7. Seams: Longitudinal Dbl. Butt R.T. Spot Efficiency 85 %  
(Welded, Dbl., Sngl., Lap, Butt) (Spot or Full)H.T. Temp \_\_\_\_\_ F Time \_\_\_\_\_ Girth Dbl. Butt Welded  
(Welded, Dbl., Sngl., Lap, Butt)R.T. Spot No. of Courses 2  
(Spot, Partial, or Full)

8. Heads: (a) Material \_\_\_\_\_ (Spec. No., Grade) (b) Material \_\_\_\_\_ (Spec. No., Grade)

Location Minimum Corrosion Crown Knuckle Elliptical  
(Top, Bottom, Ends) Thickness Allowance Radius Radius Ratio

(a) \_\_\_\_\_

(b) \_\_\_\_\_

Conical Hemispherical Flat Side to Pressure  
Apex Angle Radius Diameter (Convex or Concave)

(a) \_\_\_\_\_

(b) \_\_\_\_\_

If removable, bolts used (describe other fastenings) \_\_\_\_\_  
(Material, Spec. No., Gr., Size, No.)

9. Type of Jacket \_\_\_\_\_ Proof Test \_\_\_\_\_

10. Jacket Closure \_\_\_\_\_ If bar, give dimensions \_\_\_\_\_  
(Describe as ogee & weld, bar, etc.)

If bolted, describe or sketch.

11. Constructed for max. allowable working pressure 75 psi at max. temp. 340° F Min. temp. (when less than -20 F) \_\_\_\_\_ F. Hydrostatic, ~~XXXXXX~~ test pressure 115 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: Stationary—Material SA-515-70 Diam. 52-1/8 in.  
(Spec. No., Gr.) (Subject to pressure)Nominal Thickness 2-5/8\* in. Corrosion Allowance 0 in. Attachment Welded  
(Welded, Bolted)

Stationary

Material SA-515-70 Diam. 52-1/8 in.  
(Spec. No., Gr.)Nominal Thickness 2-5/8\* in. Corrosion Allowance 0 in.Attachment Welded13. Tubes: Material SA-249-304 O.D. 3/4 in. Nominal Thickness 16 BWG ~~XXXX~~ gauge  
(Spec. No., Gr.) (Avg.)Number 1,409 Type Straight  
(Straight or "U")

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: Material SA-240-304 Nominal Thickness 1/2 in. Corrosion Allowance 0 in.  
(Spec. No., Gr.)Diam. 4 ft 5 in. Length 4 ft15. Seams: Longitudinal Dbl. Butt R.T. Spot Efficiency 85 %  
(Welded, Dbl., Sngl., Lap, Butt) (Spot or Full)H.T. Temp \_\_\_\_\_ F Time \_\_\_\_\_ Girth Dbl. Butt Welded  
(Welded, Dbl., Sngl., Lap, Butt)R.T. Spot No. of courses 1  
(Spot, Partial, or Full)16. Heads: (a) Material SA-515-70 (b) Material SA-240-304  
(Spec. No., Grade) (Spec. No., Grade)Location Minimum Corrosion Crown Knuckle Elliptical  
(Top, Bottom, Ends) Thickness Allowance Radius Radius Ratio(a) Top 2-1/2\*\* In Clad(b) Bottom 1373" 0Conical Hemispherical Flat  
Apex Angle Radius Diameter(a) 53-3/4" Flat(b) ConcaveIf removable, bolts used (describe other fastenings) SA-193-B7; 3/4"; 56  
(Material, Spec. No., Gr., Size, No.)17. Constructed for max. allowable working pressure 75 psi at max. temp. 290° F Min. temp. (when less than -20 F) \_\_\_\_\_ F. Hydrostatic, ~~XXXXXX~~ test pressure 115 psi.

Items below to be completed for all vessels where applicable

18. Safety Valve Outlets: Number \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_

19. Nozzles:

| Purpose<br>(Inlet, Outlet, Drain) | Number | Diam.<br>or Size | Type  | Material      | Nominal<br>Thickness | Reinforcement<br>Material | How<br>Attached |
|-----------------------------------|--------|------------------|-------|---------------|----------------------|---------------------------|-----------------|
| Chan In                           | 1      | 6"-150#          | RF-SO | SA-240-TP-304 | Sch. 80S             | None                      | Welded          |
| Chan Out                          | 1      | 24"-150#         | RF-SO | SA-240-TP-304 | X-STG.               | None                      | Welded          |
| Shell In                          | 1      | 12"-150#         | RF-WN | SA-53-B       | X-STG.               | None                      | Welded          |
| Shell Out                         | 1      | 4"-150#          | RF-WN | SA-53-B       | Sch. 80              | None                      | Welded          |

20. Inspection Openings:

Manholes No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_

Handholes No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_

Threaded No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_

21. Supports: Skirt \_\_\_\_\_ Lugs Two \_\_\_\_\_ Legs \_\_\_\_\_ Other \_\_\_\_\_  
(Yes or no) (No.) (Describe)Attached Welded To Shell  
(Where and how)22. Remarks: Stripper Reboiler\* = Thk. Includes 3/8" Thk. 308L Overlay  
\*\* = Thk. Includes 1/8" Thk. 304 S.S. Liner

FOREIGN PRINT FILE

HOUSTON CHEMICAL COMPANY

DIVISION OF

PPG INDUSTRIES, INC.

BEAUMONT, TEXAS 77704

JOB. NO. 2677 P.O. 607009EQUIP. NO. 21-08-025VENDOR W. H. AndersonEQUIP. USED FOR 2-1 Stripper ReboilerSide to Pressure E-1407  
(Convex or Concave)

# HUGHES ANDERSON ENGINEERING CORP.

## STRIPPER REBOILER



W  
RT3



ITEM NO. 454 DRAWING NO. E-1407

ITEM NO. 1607-009 DRAWING NO. 1825

SIZE 52" X 20" TYPE BEL COMPRESS 7135

SPOT CHANNELS & SHELL

ITEM NO. 8176 WEIGHT 115 POUNDS 115

ITEM NO. 75 WEIGHT 340 POUNDS 115

ITEM NO. 75 WEIGHT 290 POUNDS 115

1409-20D.X16BWG.AVG.X20-0LG. SA-249-304


**FOREIGN PRINT FILE**  
HOUSTON CHEMICAL COMPANY,  
DIVISION OF  
PPG INDUSTRIES, INC.  
BEAUMONT, TEXAS 77704

JOB. NO. \_\_\_\_\_  
DEPT. Allyrd DATE 3/26/77 P.O. 1602-009  
VENDOR \_\_\_\_\_ EQPT. NO. 21-08-025  
MFR. Angela Anderson  
EQPT. USED FOR Stripper Refiner  
E-1407

FOREIGN PRINT FILE  
HOUSTON CHEMICAL COMPANY  
DIVISION OF  
PPG INDUSTRIES, INC.  
BEAUMONT, TEXAS 77704

JOB. NO. DATE 2/18/77 P.O. 1607-009  
DEPT. Physical EQPT. NO. 21-08-025  
VENDOR Hughes-Anderson  
MFR.  
EQPT. USED FOR Stripper Reboiler

100288



HUGHES-ANDERSON ENGINEERING CORP.  
STRIPPER REBOILER

NATL BOARD NO. 454 ITEM NO. E-1407  
PO NO. 1607-009 SERIAL NO. 1825  
SIZE 52"x20" TYPE BEL SURFACE 7/135 SOFT  
RT. (GPD) CHANNELS SHELL  
HT.  
DATE SHOP TEST SHELL 115 PSI. TUBES 115 PSI.  
SHELL MAWP 75 PSI. AT 340 F FIELD TEST 115 PSI.  
TUBES MAWP 75 PSI. AT 290 F FIELD TEST 115 PSI.  
TUBES 1409-3/4" OD X 16 BWG (A16) X 20'-0" LG. SA-287-304

HOUSTON  
CHEMICAL COMPANY  
DIVISION OF  
PPG INDUSTRIES, INC.  
BEAUMONT, TEXAS

E.C.C. EQUIPMENT NO. 21-08-025  
INSTRUMENT NO.  
NATIONAL BOARD NO. 454  
NATL. BOARD 21-08-025 P.O. 1607-009  
DESIGNER PSI. 25 1 75  
DESIGN TEMP. 380 1 290  
DESIGN PRESS. 115  
DESIGN TEMP. 340  
SHELL THK. 1/2" WELD THK. 1/2" HEAD 1703  
MANUFACTURER H. ANDERSON CORP.  
SAFETY FACTOR 1.0  
ASME CODE UG-25  
YEAR 1976

NAME R DETAIL

FINAL DESIGN

MECHANICAL DESIGN  
CHECKED  
3-22-76

HUGHES-ANDERSON ENGINEERING CORP.  
TULSA, OKLAHOMA

DRAWING TITLE NAME R DETAILS  
WORK ORDER 1825 NUMBER REQ'D ONE  
DR. 10/11 DATE 3/11/76 SIZE 52"x20" DRAWING NUMBER  
SCALE 1"=1'-0" TYPE BEL 1825-11

FORM R-1, REPORT OF WELDED ☒ REPAIR OR ☐ ALTERATION  
as required by the provisions of the National Board Inspection Code

100288

1. Work performed by Exell, Inc. 10573  
(name of repair or alteration organization) (P.O. no., job no., etc.)  
690 Franklin Street, Beaumont, TX 77701  
(address)

2. Owner P.D.Glycol  
(name)  
P. O. Box 3785, Beaumont, TX 77704  
(address)

3. Location of installation P.D.Glycol  
(name)  
Gulf States Utilities Rd., Beaumont, TX 77701  
(address)

4. Unit identification: Exchanger Name of original manufacturer Hughes Anderson Eng. Corp.  
(boiler, pressure vessel)

5. Identifying nos.: 1825 454 - Item #E-1407 1976  
(mfr's. serial no.) (original National Board no.) (jurisdiction no.) (other) (year built)

6. Description of work: Installed (1) 10"-150# RFSO Flange (SA-182-F304L) and 10" nozzle  
(use back, separate sheet, or sketch if necessary)  
pipe (SA-312-TP304L) in channel.  
Dye Penetrant examination was satisfactory.  
Shop hydrotest was satisfactory.

Pressure test, if applied \_\_\_\_\_ psi

7. Replacement Parts. Attached are Manufacturers' Partial Data Reports properly identified and signed by Authorized Inspectors for the following items of this report:

(name of part, item number, mfr's. name and identifying stamp)

8. Remarks: