

COOKS R. B. C. #132

as required by the provisions of the ASME Code rules, Section VIII, Division 1

101105

- Manufactured and certified by REFUEGER ENGINEERING & MFG. COMPANY, INC. 12091 HIRSCH ROAD HOUSTON, TX 77050
(name and address of manufacturer)
- Manufactured for REFRIGERATION ENGINEERING HOUSTON, TEXAS
(name and address of purchaser)
- Location of installation REFRIGERATION ENGINEERING SAN ANTONIO, TEXAS
(name and address)
- Type: HORIZ HT-EX 89-128-B - 89-128 2029 1990
(nom. or vert., tank) (mat'l. serial no.) (CRN) (drawing no.) (mat'l. Id. no.) (year built)
- The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction and workmanship conform to ASME Code, Section VIII, Division 1: 1989
(year)

(addenda (Date)) (Code Case no.) (special service per UG-120(d))

Items 6-11 inclusive to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

- Shell: SA-516-70 .875" .125" 2'-8" 27'-4 1/2"
(mat'l. (spec. no., grade)) (nom. thickness (in.)) (corr. allow. (in.)) (dia. ID (ft. & in.)) (length overall) (ft. & in.)
- Seams: DBL. SPOT 85 N/A - DBL. SPOT 4
(long (dbl., singl.)) (RT (spot or full)) (eff. (%)) (HT temp. (°F)) (time) (girth (dbl., singl.)) (RT (spot, partial, or full)) (no. of courses)
- Heads: (a) SEE LINE 12 (b) SEE LINE 12
(mat'l. (spec. no., grade)) (mat'l. (spec. no., grade))

	Location (top, bottom, ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (convex or concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings): (mat'l. spec. no., gr., size, no.)

- Type of jacket: Proof test:
- Jacket closure: If bar, give dimensions: If bolted, describe or sketch.
- MAWP: 600 at max. temp. 300 Min design metal temp.: -6 at 600 Hydro. XXXXXXX test pressure 900
(psi) (°F) (°F) (psi)

Items 12 and 13 to be completed for tube sections.

- Tubesheets: SA-516-70 32.000" 3.625" .250" WELDED & BOLTED
(stationary mat'l. (spec. no., gr.)) (dia. (in.) (subject to pressure)) (nom. thickness (in.)) (corr. allow. (in.)) (attachment (welded, bolted))
- Tubes: SA-214 .750" .065" 886 STRAIGHT
(mat'l. (spec. no., gr.)) (OD (in.)) (nom. thickness (in. or gauge)) (no.) (type (straight or U))

Items 14-17 inclusive to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

- Shell: SA-516-70 .750" .125" 2'-9" 1'-8 1/2"
(mat'l. (spec. no., gr.)) (nom. thickness (in.)) (corr. allow. (in.)) (dia. ID (ft. & in.)) (length overall) (ft. & in.)
- Seams: DBL. SPOT 85 N/A - DBL. SPOT 1
(long (dbl., singl.)) (RT (spot or full)) (eff. (%)) (HT temp. (°F)) (time) (girth (dbl., singl.)) (RT (spot, partial, or full)) (no. of courses)
- Heads: (a) SA-516-70 (b) SA-516-70
(mat'l. (spec. no., grade)) (mat'l. (spec. no., grade))

	Location (top, bottom, ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (convex or concave)
(a)	END	.875"	.125"	-	-	2:1	-	-	-	CONCAVE
(b)	END	.875"	.125"	-	-	2:1	-	-	-	CONCAVE

Purpose (inlet, outlet, drain, etc.)	Number	Dist. or Size	Type	Mat'l.	Wall Thickness	Reinforcement Material	How Attached	Location
TUBE IN	ONE	4"-300#	RF-WH	SA-106-B	.438"	SA-S16-70	WELDED	CHAM
TUBE OUT	ONE	10"-300#	RF-WH	SA-106-B	.500"	SA-S16-70	WELDED	CHAM
SHELL IN	ONE	8"-300#	RF-WH	SA-106-B	.500"	SA-S16-70	WELDED	SHE.
SHELL OUT	ONE	8"-300#	RF-WH	SA-106-B	.500"	SA-S16-70	WELDED	SHELL
	EIGHT	3/4"	CPLG.	SA-105	.6000#	-	WELDED	CHAM/SHELL
	TWO	3/4"	CPLG.	SA-105	.6000#	-	WELDED	SHELL
	TWO	1"	CPLG.	SA-105	.6000#	-	WELDED	SHELL

19. Supports: Skirt NO Lugs -- Legs -- Other SADDLES Attached WELD TO SHELL
 (yes or no) (no.) (no.) (describe) (where and how)

20. Remarks: Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____

(name of part, item number, mfr's. name and identifying stamp)

VAPORIZER 32 X 336 BEM ITEM NO. _____

MIN. TEMP. UC-20 (f) _____

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization no. 20962 expires JAN. 10, 19 92

Date 1-26-90 Name KRUEGER ENGINEERING & MFG. COMPANY, INC.
 (manufacturer)

Signed _____

(representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by KRUEGER ENGINEERING & MFG. COMPANY, INC. at HOUSTON, TEXAS

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the state or province of TEXAS and employed by H.S.B.I. & I. CO.

_____ of CONN. have inspected the pressure vessel described in this Manufacturers' Data Report on 1-31, 19 90, and state that, to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1-31-90 Signed Bill Pann
 (Authorized Inspector)

Commissions NB 4579 NSI
 (Nat'l. Bd. (incl. endorsements) state, prov. and no.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME BOILER AND PRESSURE VESSEL CODE.

"U" Certificate of Authorization no. _____ expires _____, 19 _____

Date _____ Name _____
 (assembler that certified and constructed field assembly)

Signed _____

(representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of _____ and employed by _____

_____ of _____ have compared the statements in this Manufacturers' Data Report with the described pressure vessel and state that parts referred to as data items _____



_____ have been inspected by me and that to the best of my knowledge and belief, the manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The pressure vessel _____

KRUEGER ENGINEERING & MFG. CO.
P.O. BOX 11308
12001 HIRSH RD.
HOUSTON, TEXAS 77293

101105

CUSTOMER SW REFRIGERATION - AMOCO		REF NO 19029	
ADDRESS HOUSTON, TEXAS		PROP NO 89- 496	
PLANT LOC		DATE 6-02-89 REV 00	
SERVICE OF UNIT VAPORIZER		ITEM E- 4	
SIZE 32.00X336.00 TYPE BEM HORIZONTAL CONNECTED IN 1 PARALLEL 1 SERIES			
SURF/UNIT(G/E) 4871/ 4760FT2 SHELLS/UNIT 1 SURF/SHELL(G/E) 4871/ 4760FT2			
PERFORMANCE OF ONE UNIT			
TYPE OF PROCESS		SENSIBLE	
FLUID ALLOCATION		SHELL SIDE	
FLUID NAME		LUBE OIL	
FLOW LB/HR		258135.	
LIQUID LB/HR		258135.	
VAPOR LB/HR		0.	
NON-COND LB/HR		0.	
STEAM LB/HR		0.	
EVAP/COND LB/HR		0.	
DENSITY LB/FT3		61.9700	
CONDUCTIV BTU/(HR*FT2*OF)/FT		.0960	
SPECIFIC HEAT BTU/LB*OF		.5000	
VISCOSITY AT AVERAGE TEMP CP		27.4016	
ENTHALPY BTU/LB		.00	
TEMPERATURE(IN/OUT) OF		228.000 / 135.000	
OPERATION PRESSURE PSIG		500.00	
FOULING FACTOR HR*FT2*OF/BTU		.00200	
VELOCITY FT/SEC		1.35	
PRES DROP ALLOW/CALC PSIG		16.00 / 16.24	
HEAT EXCHANGED		11892100. BTU/HR	
SERVICE COEFF		BTU/HR*FT2*OF 65.21	
		DIRTY 68.55	
CONSTRUCTION DATA/SHELL			SKETCH
DESIGN/TEST PRESS PSIG		SHELL SIDE	TUBE SIDE
DESIGN TEMPERATURE OF		600/CODE	400/CODE
NO. PASSES PER SHELL		300.	300.
CORROSION ALLOWANCE IN		1	4
CONNECTIONS		.1250	.1250
SIZE & RATING		IN 8 300#	4 300#
		OUT 8 300#	10 300#
		INTERMEDIATE	
TUBES: 886 DIA .750 IN THK(MIN).060 IN LENGTH 28.00 FT PIT .9375 IN TR160			
TUBE TYPE BARE		MATERIAL A214	
SHELL A106B ID 32.00 OD		IN SHELL COVER	
CHANNEL OR BONNET A106B		CHANNEL COVER C.S.	
TUBESHEET STATIONARY 516-70		TUBESHEET FLOATING	
FLOATING HEAD COVER		IMPINGEMENT PROTECTION NO	
BAFFLES CROSS C.S.		TYPE SEG H % CUT(D) 25.0 SPACING C/C 9.0 IN	
BAFFLES LONG		SEAL TYPE INLET 16.0 IN	
SUPPORTS TUBE C.S.		U-BEND TYPE	
BYPASS SEAL ARRANGEMENT		TUBE-TUBESHEET JOINT EXPANDED	
EXPANSION JOINT NO		TYPE	
RHO-V2-INLET NOZZLE 681.		BUNDLE ENTRANCE 839. BUNDLE EXIT 839.	
GASKETS SHELL SIDE		TUBE SIDE	
FLOATING HEAD			
CODE REQUIREMENTS ASME-TEMA		TEMA CLASS R	
WEIGHT/SHELL		FILLED WITH WATER	
REMARKS		BUNDLE LB	

101105



MARK	NO.	REQ'D.	SIZE	SERIES	TYPE	SERVICE
C-3	TWO		1"	6000#	CPLG.	
C-2	TWO		3/4"	6000#	CPLG.	
C-1	EIGHT		3/4"	6000#	CPLG.	
D	ONE		8"	300#	RF-WIN	SHELL OUT
C	ONE		8"	300#	RF-WIN	SHELL IN
B	ONE		10"	300#	RF-WIN	TUBE OUT
A	ONE		4"	300#	RF-WIN	TUBE IN

SCHEDULE OF OPENINGS

KRUEGER ENGINEERING & MFG. CO.
HOUSTON, TEXAS

32 X 336 BEM ITEM NO.
TWO-REQ'D.

VAPORIZER

GENERAL NOTES

ALL BOLT HOLES TO BE EQUALLY SPACED AND STRADDLE VESSEL CENTERLINES.
ALL MACHINED SURFACES TO BE PROTECTED DURING SHIPMENT AND ALL THREADED CONNECTIONS TO BE PROTECTED.
VESSEL TO BE DRAINED AND CLEANED BEFORE SHIPMENT.
WT. EMPTY - 28,200 #
WT. FLOODED - 37,800 #

REFRIGERATION ENGINEER	DATE
300000	10/10/5
10/10/5	10/10/5

Handwritten: 10/10/5

NAT L BD NO 2029	
CERTIFIED BY KEMCO	
KRUEGER ENGINEERING & MFG CO INC	
HOUSTON TEXAS	
RT-3	MAX ALLOWABLE WORK PRESSURE
SHELL SIDE	600 PSI AT 300 °F
TUBE SIDE	400 PSI AT 300 °F
TRANSFER SURFACE	4871
KEMCO SERIAL NO	89-1288
USERS ORDER NO	36663
ITEM NO	
MIN DESIGN METAL TEMPERATURE	-6 °F AT 600 PSI
HYDROSTATIC TEST	900 PSI
	600 PSI
MIN THK SHELL	.875"
MIN THK CHANNEL	.750"
TUBES	886-.750" X .065"
YEAR BUILT	1990

EF
B1FC

#1+2 FC Lube Oil Coders @ BCF