

Page 1 of 2

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1, "U" Certificate of Authorization No. 2847 expires Dec. 21, 1989

Date 9/28/88 Co. name THE BOARDMAN COMPANY (Manufacturer) Signed Roger Grommet (Representative) ROGER GROMMET

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by THE BOARDMAN COMPANY at Oklahoma City, OK

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Oklahoma and employed by C.U. MASS.

have inspected the component described in this Manufacturer's Data Report on 9-30, 19 88, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 9-30-88 Signed [Signature] (Authorized Inspector) Commissions NB-7936; OK-263

(Not Boarded and reinspected, State, PWS and/or)

FORM U-4 MANUFACTURERS' DATA REPORT SUPPLEMENTARY SHEET

as required by the provisions of the ASME Code rules, Section VIII, Division 1

Page 2 of 2

1. Manufactured and certified by THE BOARDMAN COMPANY; 1401 SW 11TH ST.; OKLAHOMA CITY, OK 73108
(name and address of manufacturer)
2. Manufactured for BARNARD & BURK ENGINEERS; 10252 MAYFAIR DR.; BATON ROUGE, LA 70895
(name and address of purchaser)
3. Location of Installation TEXACO REFINING & MARKETING; 1401 SO. DOUGLASS RD.; ELDORADO, KS 67042
(name and address)
4. Type: VERTICAL N-3423 ----- 19556 2297 1988
(horiz., vert., tank, etc.) (mfr's. serial no.) (CRN) (drawing no.) (Nat'l. Bd. no.) (year built)

Data Report Item Number	Remarks
* 10 NOZZLES (CONT'D.)	
TERMOWELL	2 1½" CL 150 RF WN SA312-316L STD WT ----- WELDED SHELL
MANWAY	1 24" " " " " SA240-316L .375" SA240-316L " "
MANWAY	1 18" " " " " " " " " TOP HD.
CATALYST DUMP	1 6" " " " " SA312-316L STD WT " " BOT. HD.
INLET	1 3" " " " " " " " " " "
DRAIN OUTLET	1 3" " " " " " " " " " "

SAFETY VALVE OPENING: CUSTOMER SHALL PROVIDE THIS VESSEL WITH AN OVERPRESSURE PROTECTIVE
DEVICE, PER UG-125 THROUGH UG-136, PRIOR TO PLACING VESSEL IN SERVICE.

Date 7/26/88 Name THE BOARDMAN COMPANY Signed Roger Grommet
(manufacturer) (representative) GROMMET

Date 9-30-88 Signed [Signature] Commissions NB-7936; OK-263
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) state, prov. and no.)

Note: Each additional sheet shall be signed and dated by the certificate holder and the AI.

This form may be obtained from The National Board of Boiler and Pressure Vessel Inspectors, 1055 Crupper Ave., Col's., OH 43229