



Title:

Thermatrix Inc.
SYSTEM DESIGN CRITERIA
DOCUMENT

Lyondell Equistar
Flameless Thermal Oxidizer System
Newtown Square, Pennsylvania

Document No.: 4172-DCD-E-PM-4, Rev. A
Date: January 24, 2003
Approved: ^{TMX} *Gloria M. Castiglione* LYONDELL

Page: 1
Of: 11

Thermatrix Inc. System Design Criteria Document

Flameless Thermal Oxidizer System

For

Lyondell Equistar Newtown Square, Pennsylvania

January 24, 2003

RELEASE FOR CUSTOMER APPROVAL
YOUR P. O. # 4400380679LY
OUR O. O. # 02E-4172
DATE 1/24/03 PER

Thermatrix Inc.
Five Sentry Parkway East, Suite 204
Blue Bell, PA 19422
(610) 834-0300 / (610) 834-0473



Title:

Thermatrix Inc.
**SYSTEM DESIGN CRITERIA
DOCUMENT**

Lyondell Equistar
Flameless Thermal Oxidizer System
Newtown Square, Pennsylvania

Document No.: 4172-DCD-E-PM-4, Rev. A
Date: January 24, 2003
Approved: TMX LYONDELL

Page: 2
Of: 11

TABLE OF CONTENTS

1 **PURPOSE** 2

2 **REFERENCES** 3

3 **PROJECT BACKGROUND** 3

4 **PROJECT SCOPE** 3

5 **EQUIPMENT SUPPLY SCOPE** 4

6 **PROCESS DESCRIPTION** 4

7 **DESIGN BASIS AND PERFORMANCE CRITERIA** 5

 7.1 **PROCESS STREAM DESIGN BASIS** 5

 7.1.1 **Performance Criteria** 6

 7.1.2 **Other** 6

Appendix A

Thermatrix (TMX) Process Flow Diagram:
Dwgs. 4172-P30-01, Rev. A
TMX Piping and Instrumentation Diagrams:
Dwgs. 4172-P40-01, 02, Rev. A

REVISION SUMMARY

| Doc. No. | Revision | Date | Description |
|----------|----------|------|-------------|
|----------|----------|------|-------------|

1 Purpose

This document formally establishes the design and performance requirements for the supply of a Thermatrix flameless thermal oxidizer system (FTO) consisting of one (1) ES-100 oxidizer to the Lyondell Equistar, Newtown Square, PA to treat volatile organic compound (VOC) emissions.

This document contains proprietary information which is to be held confidential and may not be disclosed to others in whole or in part without the prior written consent of an officer of Thermatrix Inc.



Lyondell Equistar

Flameless Thermal Oxidizer System

Newtown Square, Pennsylvania

Title:

Thermatrix Inc.
**SYSTEM DESIGN CRITERIA
DOCUMENT**

Document No.: 4172-DCD-E-PM-4, Rev. A

Date: January 24, 2003

Approved:

TMX

LYONDELL

Page: 3

Of: 11

2 References

Process Specification Form, dated April 23, 2002

Thermatrix Proposal 02302, dated May 6, 2002

Thermatrix Proposal 02302FB, Rev. 1, dated October 7, 2002

Lyondell Purchase Order No. 4400380679LY dated December 11, 2002

3 Project Background

The purpose of this project is to design and build an ES-100 FTO system. The system will thermally treat volatile organic compound (VOCs) emissions generated from a pilot plant in the Lyondell Equistar Newtown Square, PA site. VOCs include propane, propylene, methanol, propylene oxide, and others. The system will be located indoors in a Class I, Division 2, Group D electrical area classification.

4 Project Scope

Thermatrix will be responsible for the following project activities:

- Project management including site meetings.
- Crating and preparation for shipment.
- Pre-assembly and mounting of fume and air trains.
- Pre-wiring of control panel and pre-ship functional check.
- Programmable logic controller programming.
- Wiring of mounted instruments, valves and motors to control panel.

Lyondell will be responsible for the following project activities:

- Shipping to jobsite (arranged by Thermatrix and reimbursed by Buyer).
- Unloading and temporary storage.
- Site preparation including civil and foundation preparation.
- Installation of oxidizer system skid on foundation.
- Installation of oxidizer vessel on skid.
- Emissions or performance testing.



Lyondell Equistar

Flameless Thermal Oxidizer System

Newtown Square, Pennsylvania

Title:

Thermatrix Inc.
**SYSTEM DESIGN CRITERIA
DOCUMENT**

Document No.: 4172-DCD-E-PM-4, Rev. A

Date: January 24, 2003

Approved:

TMX

LYONDELL

Page: 4

Of: 11

5 Equipment Supply Scope

Thermatrix is to design and provide all the components for a thermal oxidation system to be installed at the Lyondell Equistar Newtown Square, PA. Site. The scope is depicted on the Thermatrix piping and instrumentation diagrams (P&ID) 4172-P40-01, Rev. A. The Thermatrix FTO will consist of the following equipment:

- ES Oxidizer with preheaters, refractory, thermowells, thermocouples, and ceramic media;
- Dilution Air Blower with Inlet Filter, a spare second blower is to be provided;
- Control Panel with PLC controls, pre-wiring of panels with pre-ship wiring functional check;
- Power Panel with motor starter and heater power controllers, pre-wiring of panels with pre-ship wiring functional check;
- Stack extending 35 feet from the skid base;
- Piping, Valving, Instrumentation;
- Deflagration Arrester with thermocouple;
- Spare oxidizer thermowell with thermocouple;
- Structural Skid mounted system.

Lyondell will supply the following equipment:

- Ladder and platform for access to stack sampling ports.

6 Process Description

VOC fumes, nitrogen, carbon dioxide, and water vapor are emitted from a pilot plant. The "Hydrocarbon Vent Stream" is piped to the FTO system. The fume stream is combined with dilution air and is sent to the oxidizer under positive pressure.

The Thermatrix flameless oxidation process is based on a patented matrix that enhances the oxidation process. The matrix is a carefully designed volume of inert ceramic media selected for its thermal properties. Equipment and instrument tag numbers may be found on Piping and Instrumentation Drawing 4172-P40-01. The design flow rates for the thermal oxidation system are shown on Process Flow Diagram 4172-P30-01.

The tie point for the fume collection system is at the edge of the Thermatrix system skid. The fume enters the ES-100 skid through an air operated block valve and the flow is indicated with a rotameter. The fume is directed to the bottom of the oxidizer. Dilution air is required to maintain the proper operating temperature of the oxidization zone as well as to keep the operating limit of the system below the LFL. This is automatically accomplished by maintaining a constant volume dilution airflow through the system.

This document contains proprietary information which is to be held confidential and may not be disclosed to others in whole or in part without the prior written consent of an officer of Thermatrix Inc.



Lyondell Equistar
 Flameless Thermal Oxidizer System
 Newtown Square, Pennsylvania

Title:

Thermatrix Inc.
SYSTEM DESIGN CRITERIA
DOCUMENT

Document No.: 4172-DCD-E-PM-4, Rev. A
 Date: January 24, 2003
 Approved: TMX LYONDELL

Page: 5
 Of: 11

A blower is used to supply this dilution air. The flow rate of air to the oxidizer is measured to provide local indication. An air-actuated block valve is opened when the blower is energized.

The oxidizer shell is fabricated of carbon steel and lined with a refractory blanket that reduces the external skin temperature suitable for the electrical area classification. The oxidizer has three internal vertical protection tubes that house the heating elements. A single vertical thermowell in the bed is also provided. The oxidizer contains randomly packed ceramic saddles that fill the oxidizer from the bottom to 12 inches above the top of the protection tubes. During startup, the cold ceramic media is heated using the electrically controlled heaters. The heaters operate during the run mode to enhance low BTU fume streams. For the "Normal Case" basis the heaters are expected to operate at partial capacity as needed. For the "Maximum Case" basis the heaters will be idling.

The gas mixture enters a nozzle on the bottom of the oxidizer and flows upward through the media. The oxidation reaction takes place at the heated region of the ceramic bed. The oxidation occurs in an 8 to 12 inch zone and the temperature rises from the inlet temperature to the full operating temperature. Hydrocarbons are oxidized to carbon dioxide gas and water vapor. Nitrogen and excess oxygen are also present in the reaction products. The oxidation reaction generates heat, which is transferred and stored in the media. The hot media then radiates heat back to the incoming gas mixture and sustains the oxidation reaction. Above the reaction zone, the temperature of the media is at the operating temperature. The upward flowing gas emerges from the media and into the oxidizer headspace, which is lined with refractory blanket. A 12-inch nozzle exhausts the reaction products into a refractory lined stack that vents to atmosphere.

7 Design Basis and Performance Criteria

7.1 Process Stream Design Basis

Lyondell supplied stream flow and composition data (Process Specification Form dated April 23, 2002) provides the following instantaneous maximum design basis for the Newtown Square, PA site thermal oxidizer system:

| Flow rate | Units | Normal Fume | Maximum Fume |
|-------------------------|-------|-------------|--------------|
| Flow | SCFM | 1.6 | 2.0 |
| Temperature | °C | 10 - 30 | 10 - 30 |
| Relative Humidity | % | 1.5 | 0 |
| Pressure (tie-point) | IWG | 24 | 30 |
| Major components | | | |
| Oxygen | lb/hr | 0.48 | 0.42 |
| Nitrogen | lb/hr | 3.74 | 2.33 |
| Carbon dioxide | lb/hr | 0.02 | 0.004 |
| Propane | lb/hr | 4.5 | 10.0 |
| Propylene | lb/hr | 1.14 | 1.3 |
| Methanol | lb/hr | 0.004 | 0.03 |
| Propylene oxide | lb/hr | 0.0001 | 0.0001 |
| Hydrogen | lb/hr | 0.01 | 0.00 |



Lyondell Equistar
Flameless Thermal Oxidizer System
Newtown Square, Pennsylvania

Title:

Thermatrix Inc.
SYSTEM DESIGN CRITERIA
DOCUMENT

Document No.: 4172-DCD-E-PM-4, Rev. A

Date:

January 24, 2003

Page: 6

Approved:

TMX

LYONDELL

Of: 11

The "Maximum Fume" listed above is the highest permissible safe fume loading for the thermal oxidizer. Total oxidizer capacity to safely treat other chemical mixtures is dependent on the composite physical and chemical properties of the mixtures. Thermatrix does not authorize the processing of other fume mixtures or of mixtures which exceed the loading of the "Maximum Fume" case without thorough Thermatrix review and written approval.

7.1.1 Performance Criteria

The oxidation system is guaranteed to destroy 99.99% of the Volatile Organic Compounds (VOC) in the incoming fume stream or 1 ppmv per VOC in the oxidizer exhaust, whichever is less restrictive.

7.1.2 Other

Equipment provided by Thermatrix is warranted to be free of defects in materials or workmanship, under normal and proper use, for a period of 12 months from initial operation of the product, or 18 months after shipment, or 18 months from notice of readiness to ship, whichever first occurs.

Lyondell Equistar will be responsible for stack sampling to verify the system performance meets the specifications.

The stack will be provided with two sampling ports (6-inch min.) with no access platforms to the ports. Lyondell Equistar will be responsible for the regulatory mandated operational stack sampling and analysis.



Title:

Thermatrix Inc.
SYSTEM DESIGN CRITERIA DOCUMENT

Lyondell Equistar
Flameless Thermal Oxidizer System
Newtown Square, Pennsylvania

Document No.:
Date:
Approved:

4172-P101, Rev. A
January 24, 2003
TMX LYONDELL
Page: 7
Of: 11

| Client Name/Location: Lyondell Equistar, Newtown Square, PA. Project No: 4172 | Description (use attachments if necessary) |
|--|--|
| 1. Scope of Project | |
| 1.1 Equipment Configuration Associated with P.O. | Process Stream Table Rev. A, Project 4172 |
| 1.1.1 PFD (Process Flow Diagram) | Dwgs. 4172-P40-01, Rev. A |
| 1.1.2 P&ID (Piping and Instrumentation Diagram) | PLC |
| 1.2 Type of controls: PLC, DCS, or I/O only | TMX |
| 1.3 Responsibility for Controls Programming: TMX or Client | TMX |
| 1.4 Responsibility for Electrical motor control: TMX or Client | Lyondell |
| 1.5 Responsibility for Lighting: TMX or Client | Not Provided by TMX |
| 1.6 Communications (Phones, Radios, Intercoms, etc.) | Designed, supplied and installed by Lyondell |
| 1.7 Safety Showers | By Lyondell |
| 1.8 Fire Protection Plan | TBD by Lyondell |
| 1.9 Emission Monitoring Requirements | TMX will supply load diagrams including stack support load. Lyondell will provide foundation engineering, design, installation, and stack support engineering, design, and installation. |
| 1.10 Civil – foundations and curbing | Not Provided by TMX |
| 1.11 Type Of Heat Tracing: Steam Or Electric | Not Provided by TMX |
| 1.12 Responsibility For Heat Tracing And Insulation | Not Provided by TMX |
| 1.13 Engineering Documentation | |
| 1.13.1 Definition of approval documents | SDCD, P&ID, PFD, General Arrangement |
| 1.13.2 Number of document iteration cycles | 1 |
| 1.13.3 Electrical design requirements | Electrical one-line drawing |
| 1.14 HAZOP | Not included by Lyondell Request |
| 1.15 Overall Project Schedule | TMX will provide and maintain project schedule |
| 2.0 Fume Data | |
| 2.1 General Fume Characteristics | |
| 2.1.1 Source description | See Process Specification Form dated April 23, 2002. Supplied by Lyondell. |
| 2.1.2 Capability to treat Explosive Group B gases | No. The system is not designed for a Group B composite mixture. The Normal Case contains a maximum of 0.01 lbs/hr hydrogen but this does not result in a composite group B gas feed to the FTO. There is no hydrogen in the Maximum Design case. |

This document contains proprietary information which is to be held confidential and may not be disclosed to others in whole or in part without the prior written consent of an officer of Thermatrix Inc.



Title:

Thermatrix Inc.
SYSTEM DESIGN CRITERIA DOCUMENT

Lyondell Equistar
Flameless Thermal Oxidizer System
Newtown Square, Pennsylvania

Document No.:
Date:
Approved:

4172-P101, Rev. A
January 24, 2003
TMX LYONDELL
Page: 8
Of: 11

| Client Name/Location: Lyondell Equistar, Newtown Square, PA. Project No: 4172 | Description (use attachments if necessary) |
|--|--|
| 2.1.3 Halogenated gases present | No |
| 2.1.4 Sulfonated gases present | No |
| 2.1.5 Nitrogenated gases present | Nitrogen |
| 2.1.6 Free acids present | No |
| 2.1.7 Carrier gas | Nitrogen |
| 2.1.8 Oxygen concentration | 6% mole fraction, per Process Stream Design Basis |
| 2.1.9 Relative humidity | 0 - 2% |
| 2.2 Flow Rate & Composition vs. Time | Detailed in Process Stream Design Basis |
| 2.3 Supply Pressure and Motive Force | Detailed in Process Stream Design Basis |
| 2.4 Tie Point Location, Line Size, Connection Type | Per TMX P&IDs and General Arrangement drawing. |
| 3.0 Tie Point Definition & Criteria <i>Quantity available is stipulated where there are limitations; if not stipulated, design requirement will be stipulated.</i> | |
| 3.1 Electric Power | |
| 3.1.1 Control Voltage | 120 vac, 1 phase, 60 Hz, 20amp |
| 3.1.2 Lighting Voltage | Not applicable |
| 3.1.3 Voltage Available for Large Power Loads (e.g., motors) | 480 volts, 3 phase, 60 Hz, 100amp |
| 3.1.4 Electrical Area Classification | Class I, Division 2, Group D |
| 3.1.5 Tie Point Location | Lyondell to provide power wiring to TMX control panels. TMX to provide single line drawing and wiring diagram. |
| 3.2 Fuel Gas | Not applicable |
| 3.3 Water | Not applicable |
| 3.4 Instrument/Plant air | |
| 3.4.1 Quantity Available | 5 SCFM continuous required |
| 3.4.2 Dew Point | (-30°F) |
| 3.4.3 Pressure | 80 psig |
| 3.4.4 Tie Point Location, Line Size, Connection Type | Lyondell to field route and connect to TMX Tie Point #3 per TMX P&IDs and General Arrangement drawing. |
| 3.5 Controls | |
| 3.5.1 Location of Man-Machine Interface (panel at FTO or at remote location) | Panel on FTO control panel. PLC shall be Allen Bradley |
| 3.5.2 Location of Controllers (panel at FTO or at remote location) | Control panel – Locate HOA switches in front of control panel in skid |

This document contains proprietary information which is to be held confidential and may not be disclosed to others in whole or in part without the prior written consent of an officer of Thermatrix Inc.



Title:

Thermatrix Inc.
SYSTEM DESIGN CRITERIA DOCUMENT

Lyondell Equistar
Flameless Thermal Oxidizer System
Newtown Square, Pennsylvania

Document No.:
Date:
Approved:

4172-P101, Rev. A
 January 24, 2003
 TMX LYONDELL
 Page: 9
 Of: 11

| Client Name/Location: Lyondell Equistar, Newtown Square, PA. Project No: 4172 | Description (use attachments if necessary) |
|---|--|
| 3.5.3 Shared Signals (remote indication) | Not applicable |
| 3.5.4 Client Control Interface | Not applicable |
| 3.5.5 Tie Point Location | Not applicable |
| 3.5.6 Remote Communications | Not applicable |
| 3.6 Caustic Supply | Not applicable |
| 3.7 Steam Supply | Not applicable |
| 3.8 Liquid Blowdown | Not applicable |
| 3.9 Vent Stack | |
| 3.9.1 Stack Discharge Elevation | Extends 35 feet from the skid base |
| 3.9.2 Minimum Stack Discharge Velocity | TMX standard |
| 3.9.3 Maximum Stack Surface Temperature | 392 ° F Maximum |
| 3.9.4 Required Sample Port Connections (no., size, orientation, location on stack) | 2 @ 90° apart, 1" NPT 3000# Couplings, location selected by TMX |
| 3.9.5 Tie Point Location, Line Size, Connection Type | Vent Stack is within TMX scope. Lyondell to support stack. |
| 3.10 Other Customer Supplied Interfaces | Not applicable |
| 4.0 Performance Data | |
| 4.1 Emissions Performance Data | |
| 4.1.1 DRE | |
| 4.1.1.1 High VOC destruction required (99.99%) | 99.99% VOC destruction or 1 ppm _v per VOC in the oxidizer exhaust, whichever is less restrictive. |
| 4.2 Operating Performance Data | |
| 4.2.1 Desired Turn-up and turn-down | None |
| 5.0 Materials Requirements | |
| 5.1 Equipment/Instrumentation Component Grade | |
| 5.1.1 Chemical/Refinery Grade | TMX standard |
| 5.2 Materials of Construction Preferences <i>These may be defined in Design Specs section; but should be summarized here</i> | |
| 5.2.1 Furnace Piping, Valves, Instruments, Specialties | TMX standard |
| 5.2.2 Oxidizer Components | TMX standard |
| 5.2.3 Dilution Air Piping, Valves, Instruments, Specialties | TMX standard |
| 5.2.4 Dilution Air Blower | TMX standard |
| 5.2.5 Vent Stack | TMX standard |



Lyondell Equistar

Flameless Thermal Oxidizer System
Newtown Square, Pennsylvania

Title:

Thermatrix Inc.
SYSTEM DESIGN CRITERIA DOCUMENT

Document No.:
Date:
Approved:

4172-P101, Rev. A
January 24, 2003
TMX LYONDELL

Page: 10
Of: 11

| Client Name/Location: Lyondell Equistar, Newtown Square, PA. Project No: 4172 | Description (use attachments if necessary) |
|--|---|
| 5.2.6 Flame arrester | TMX standard |
| 5.2.7 Dilution Air Heater | TMX standard |
| 6.0 Project Specifications | |
| 6.1 Meteorology & Site Conditions | |
| 6.1.1 Wind Speed | Lyondell to supply |
| 6.1.2 Prevailing Wind Direction | Lyondell to supply |
| 6.1.3 Average Temperature | Lyondell to supply |
| 6.1.4 Extreme Low Temperature | Lyondell to supply |
| 6.1.5 Winter Dry Bulb (minimum 99%) | Lyondell to supply |
| 6.1.6 Summer Dry Bulb (maximum 99%) | Lyondell to supply |
| 6.1.7 Average Rainfall | Lyondell to supply |
| 6.1.8 Design Snow Loading | Lyondell to supply |
| 6.2 Seismic | Seismic Zone Factor Design 0 |
| 6.3 Elevation Above Sea Level | Lyondell to supply |
| 6.4 Design Specs (client vs. TMX; attach client's if applicable) | |
| 6.4.1 Piping | TMX standard |
| 6.4.2 Mechanical | TMX standard |
| 6.4.3 Electrical | TMX standard |
| 6.4.4 Instrumentation | TMX standard |
| 6.4.5 Layout | TMX standard |
| 6.4.6 Structural | TMX standard |
| 6.4.7 Painting and Coatings | TMX standard |
| 6.4.8 Noise | TMX standard |
| 7.0 Client Preferences and Special Requirements | |
| 7.1 Space Requirements | See General Arrangement Drawings |
| 7.2 Preferred Suppliers | |
| 7.2.1 Equipment | None |
| 7.2.2 Instrumentation | None |
| 7.2.3 Controls | None |
| 7.2.4 Electrical | None |
| 7.2.5 Valves | None |



Lyondell Equistar

Flameless Thermal Oxidizer System
Newtown Square, Pennsylvania

Title:

Thermatrix Inc.
SYSTEM DESIGN CRITERIA DOCUMENT

Document No.:

4172-P101, Rev. A

Date:

January 24, 2003

Approved:

TMX LYONDELL

Page: 11

Of: 11

| Client Name/Location: Lyondell Equistar, Newtown Square, PA. Project No: 4172 | Description (use attachments if necessary) |
|--|--|
| 7.3 System Assembly & Testing | |
| 7.3.1 Pre-Assembly(air blower; piping; oxidizer) | Pre-assembly and mounting of fume and air trains by TMX |
| 7.3.2 On-site assembly | Installation of Oxidizer vessel on skid and stack by Lyondell |
| 7.3.3 Testing Location and Scope | Pre-wiring of control panel and pre-ship functional check by TMX. Emissions or performance testing by Lyondell. |
| 7.3.4 Transportation Size Limitations | All components can be shipped per DOT regulations. |
| 7.4 Drawing Conventions | |
| 7.4.1 Drawing Numbers | TMX numbering system |
| 7.4.2 Equipment & Instrument Tag Numbering | TMX numbering system |
| 7.4.3 Drawing Symbols | TMX numbering system |
| 7.4.4 Dimensions (English, metric, mixed metric) | English, °F |
| 8.0 Level of Redundancy | |
| 8.1 Major Equipment | Non-installed spare Blower and FTO Thermowell /Thermocouple |
| 8.2 Instrumentation & Control | Per TMX P&ID |
| 9.0 Process Control Methodology | |
| 9.1 System Interlocks/Switches | Per TMX P&ID |
| | |
| | |
| | |
| | |
| | |
| | |
| | |