

FORM U-1 MANUFACTURERS' DATA REPORT FOR UNFIRED PRESSURE VESSELS

As required by the Provisions of the ASME Code Rules and the National Board

1. Manufactured by SOUTHERN HEAT EXCHANGER CORPORATION, TUSCALOOSA, ALABAMA
(Name and address of Manufacturer)
2. Manufactured for Hercules Inc. Wilmington, North Carolina
(Name and address of Purchaser)

3. Type Horiz Kind HT EXCHR. Vessel No. (673) () Nat'l Bd. No. 673 Yr. Built 1967
(Horiz. or Vert.) (Tank, Jacketed, Heat Exch.) (Mfr's Serial) (State & State No.)

Items 4-9 incl. to be completed for single wall vessels (such as air tanks), jackets of jacketed vessels, or shells of Heat Exchangers

4. SHELL: Material A-53-B T.S. 60,000 Nominal Thickness 5/16 in. Corrosion Allowance 1/16 in. Diam. 2ft. 2in. Length 18 ft. 0 in.
(Kind and Spec. No.) (Fig. or F.B. & lowest T.S.)

5. SEAMS: Long Seamless S.R. No X.R. No Sectioned No Efficiency 100%
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

Girth Dbl Butt S.R. No X.R. Spot Sectioned No No. of Courses 1

6. HEADS: (a) Material A-212-B T.S. 70,000 (b) Material SA-240 TP 316 T.S. 70,000

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	<u>5/16"</u>			<u>2:1</u>				<u>concave</u>
(b)								

If removable, bolts used Other fastening
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)

7. STAYBOLTS: If hollow Attach. ent. Threaded, Welded Pitch X (Vert.) Diam. (Nominal)
(Material) (Size of Hole) (Threaded, Welded) (Horiz.) (Vert.)

8. JACKET CLOSURE: (Describe as oval & weld, bar, etc. If bar give dimensions, if bolted, describe or sketch)

9. Constructed for maximum allowable working pressure 150 psi. at Max. temp. 375 °F Min. temp. (when less than -20°) °F Test Pressure 225 psi.
(Pneumatic, Hydraulic or Combination)

Items 10 and 11 to be completed for tube sections.

10. TUBE SHEETS: Stationary. Material SA240 TP 316 Diam. 26 in. Thickness 1 1/4 Attachment Welded
(Kind & Spec. No.) (Subject to Pressure) (Welded, Bolted)

Floating. Material SA249 TP 316 Diam. in. Thickness in. Attachment in.
(Kind & Spec. No.)

11. TUBES: Material SA249 TP 316 O.D. 3/4 in. Thickness 16 ~~XXXX~~ Number 628 Type Straight
(Kind & Spec. No.) (or gage) (Straight or U)

Items 12-15 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

12. SHELL: Material A240 TP 316 T.S. 75,000 Nominal Thickness 1/4 in. Corrosion Allowance 0 in. Diam. 2ft. 2in. Length 2ft. 18 in.
(Kind and Spec. No.) (Fig. or F.B. & Spec. Min. T.S.)

13. SEAMS: Long Dbl Butt S.R. No X.R. Spot Sectioned No Efficiency 85 %
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

Girth Dbl Butt S.R. No X.R. Spot Sectioned No No. of courses 1

14. Heads (a) Material A-212-B T.S. 70,000 (b) Material SA-240 TP 316 T.S. 70,000 (c) Material SA-240 TP 316 T.S. 70,000

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a) <u>XXXXXX</u> ends	<u>1 3/4"</u>						<u>26"</u>	
(b) Channel								
(c) Floating								

If removable, bolts used (a) 28 - 5/8" Dia (b) Other fastening
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)

15. Constructed for maximum allowable working pressure 150 psi. at Max. temp. 375 °F Min. temp. (when less than -20°) °F Test Pressure 225 psi.
(Pneumatic, Hydraulic or Combination)

16. SAFETY VALVE OUTLETS: Number STUDS SA193 GRADE B7 Size NUTS SA194 CLASS 2H Location (Describe or Attach Sketch)

Items below to be completed for all Vessels where applicable.

17. NOZZLES: Purpose (Inlet, Outlet, Drain) In Number 1 Diam. or Size 24" Type Flg'd Material SA-240-316 Thickness 3/16 Reinforcement Material - How Attached Welded

Out Number 1 Diam. or Size 4" Type Flg'd Material SA-240-316 Thickness Sch 10 Reinforcement Material - How Attached Welded

In-out Number 2 Diam. or Size 6"/3" Type Flg'd Material A53-B Thickness Sch 40/80 Reinforcement Material - How Attached Welded

18. INSPECTION Manholes, No. Handholes, No. Threaded, No. Supports: Skirt Lugs Legs 2 Other Attached weld to she

20. REMARKS: * SA240-316 S/S X 1/4 thick liner on heads

(Brief description of purpose of the vessel, as Air Tank, After Cooler, Jacketed Cooker, etc. State contents of each part.) (Over)

We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this unfired pressure vessel conform to the ASME Code for Unfired Pressure Vessels.

Date May 10 1967 Signed SOUTHERN HEAT EXCHANGER CORP.
(Manufacturer)

Bonar L. Ingram
Bonar L. Ingram

Certificate of Authorization Expires

DECEMBER 31, 1967

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY SOUTHERN HEAT EXCHANGER CORP. at TUSCALOOSA, ALABAMA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Louisiana and employed by HARTFORD STEAM BOILER INSP. & INS. CO. of HARTFORD, CONN. have inspected the pressure vessel described in this manufacturer's data report on MAY 11 1967 19 , and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 5-11-67 19

Edward A. Benefiel
Inspector's Signature Edward A. Benefiel Commissions NAT'L BOARD 6046
Nat'l Board or State and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of and employed by of have compared the statements in this manufacturer's data report with the described pressure vessel and state that parts referred to as data items , not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has manufactured and assembled this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code. The described vessel was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Inspector's Signature Commissions
Nat'l Board or State and No.