

71-167

As required by the provisions of the ASME Code Rules, Sec. VIII, Division I **ITEM E-422-S**

2. Manufactured for HERCULES INC. WILMINGTON DEL. DEST: WILMINGTON, NORTH CAROLINA.
(Name and address of Purchaser)

3. Type Horiz. Kind HEAT EXCH. Vessel No. (1462) () Natl. Bd. No. 1462 Yr. Built 1971
(Horiz. or Vert.) (Tank, Jacketed, Heat Exch.) (Mfrs. Serial) (State & State No.)

Items 4-9 incl. to be completed for single wall vessels (such as air tanks), jackets of jacketed vessels, or shells of heat exchangers.

4. SHELL: Material SA-240 TP 304 T.S. 75000 Nominal Thickness 1/4 In. Corrosion Allowance 0 In. Diam. 2 Ft. 11 1/2 In. Length 21 Ft. 6 In.
(Kind and Spec. No.) (Fig. or F.B. & Spec. Min. T.S.)

5. SEAMS: Long DOUBLE BUTT H.T. No R.T. No Sectioned No Efficiency 70%
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

If riveted describe seams fully on reverse side of form.

Girth DOUBLE BUTT H.T. NO R.T. NO Sectioned NO No. of Courses 3 form.

6. HEADS (a) Material				(b) Material				T.S.
Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a) END	.25"			2:1				CONCAVE

(b) [REDACTED]

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)

7. STAYBOLTS: NONE If hollow Attachment Pitch X Diam.
 (Material) (Size of Hole) (Threaded, Welded) (Horiz.) (Vert.) (Nominal)

8. JACKET CLOSURE: None (Describe as open & weld, bar, etc. If bar, give dimensions. If bolted, describe or sketch)

9. Constructed for max. allowable working press ¹ 75 psi at max. temp. 300° F. Min. temp. (when less than -20°) °F. ² ~~Hydrostatic~~ ~~Pressure~~ ~~Test~~ Press 115 psi.

Items 10 and 11 to be completed for tube sections.

10. TUBE SHEETS: Stationary. Material SA-240 TYPE 304 Diam. 35 1/2 In. Thickness 1 1/2 In. Attachment WELDED
 (Kind & Spec. No.) (Subject to Pressure) (Welded, Bolted)

Floating. Material _____ (Kind & Spec. No.) _____ Diam. _____ In. Thickness _____ In. Attachment _____

11. TUBES: Material SA-249 TP 304 O.D. 3/4 In. Thickness 16 or Gage Number 538 Type "U"
(Kind & Spec. No.) (Straight or U)

Items 12-15 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

12. SHELL Material SA-285 Gr C T.S. 55000 Nominal Thickness 1/2 In. Allowance 1/2 In. Diam. 3 Ft. 0 In. Length 1 Ft. 4 1/2 In.
(Kind and Spec. No.) (Fig. or F.B. & Spec. Min. T.S.)

13. SEAMS: Long DOUBLE BUTT H.T. NO R.T. NO Sectioned NO Efficiency 70 %
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

If riveted describe seams fully on reverse side of form.

Girth UW-13.2(d) H.T. NO R.T. NO Sectioned NO No. of courses 1

14. HEADS (a) Material SA-515 Gr 70 T.S. 70000 (b) Material _____ T.S. _____ (c) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a) Top beam ends	2.125"						40.125	FLAT

(b) Change: _____

(c) Floaring

If removable, bolts used (a) (36) 5/8" SA-193 Gr B7/SA-194-2H (b) _____
(Material Spec. No. T.S. Size Number)

(continued)

(c) _____ Other fastening _____ (Describe or Attach Sketch)

Hydrostatic)

15. Constructed for max. 100 300°F Min. temp. (when less than 20°) 0°F Gas turbine Test 150 psi

allowable working press: 100 psi at max. temp. 300 F., less than -20 () F. 100 psi.

Items below to be completed for all vessels where applicable.

16. SAFETY VALVE OUTLETS: Number NONE, Size _____, Location _____

Purpose (Inlet,	Reinforcement	How
	Material	Attached

Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Material	Attached
1	1	1/2"	Flange	Cast Iron	1/4"	Steel	Welded

<u>IN/OUT</u>	<u>2</u>	<u>12</u>	<u>FLANGED</u>	<u>SA-53 GR B SHS.</u>	<u>SCH. 30</u>	<u>WELDED</u>

IN	2	12	"	SA-40P 304	716	"
				SA-40P 304	SA-40P	

OUT	1	6	"	SA-312 TP 304	SEA-40	"
IN	2	21	"	SA-312 TP 304	SEA-40	"

VENT/RAIN 3 2" " " SCH. 40 "

[illegible]

.....

² If postweld heat-treated. ³ List under remarks other internal or external pressures with coincident temperature when applicable.

DA 126-19527-FCD 026019 E-422-3

F.O. 026 77-1-1-1-1-1

18. INSPECTION Manholes, No. NONE Size _____ Location _____
 OPENINGS: Handholes, No. 11 Size _____ Location _____
 Threaded, No. 11 Size _____ Location _____ SHELL
 19. SUPPORTS: Skirt YES Lugs _____ Legs 2 Other _____ Attached WELDED
 (Yes or No) (Number) (Number) (Describe) (Where & How)
 20. REMARKS: HEAT EXCHANGER. CONTENTS CONFIDENTIAL. NOT LETHAL.

(Brief description of purpose of the vessel, as Air Tank, After Cooler, Jacketed Cooker, etc. State contents of each part.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division I.

Date Nov. 29, 1971 Signed SOUTHERN HEAT EXCHANGER CORP. By J. W. Pyle
 (Manufacturer)

Certificate of Authorization Expires DECEMBER 31, 1972

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY SOUTHERN HEAT EXCHANGER CORP. at TUSCALOOSA, ALABAMA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province OHIO and employed by HARTFORD STEAM BOILER INSP. AND INS. CO. of HARTFORD, CONN. have inspected the pressure vessel described in this manufacturer's data report on 12/22 1971, and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12/22 1971

James Dennis Watkins
 Inspector's Signature

Commissions

6795

Nat'l Board, State, or Province and No.

JAMES DENNIS WATKINS

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province _____ and employed by _____ of _____

_____ have compared the statements in this manufacturer's data report with the described pressure vessel and state that parts referred to as data items _____ not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code. The described vessel was inspected and subjected to a hydrostatic test of _____ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ 19 _____



Inspector's Signature

Commissions

Nat'l Board, State, or Province and No.

IV

III



FOR SUPPORT DETAILS SEE SHEET 1A.

B.P.F. NO. 42196

DATE 12-28-71

SHEET 2 APPARATUS NO.

E-422-5

PROJECT & ACCOUNT 026019

2003

ORDER NO. 336-026-19527

PLANT Hanover
APPROVED

J. R. Lee 3/10/72

CUSTOMER: HERCULES INCORPORATED

CUST. P.O. NO. 336-026-19527-DB-000-F

ITEM NO. E-422-5 PROJ. NO.

PLANT WILMINGTON, NORTH CAROLINA
TEMA SIZE AND TYPE35-240 CHU MICH. DIAP. EVAP. CONDENSER
SOUTHERN HEAT EXCHANGER CORP.

P. O. BOX 2400

TUSCALOOSA, ALABAMA 35401



DATE 9-28-71 ORD. NO. DWG. SE-12

BY: D. NOLAND 71-167 SHEET 1 C

GEN. REV.

CHANGED NOZZLE TO R.F.W.N.F. 90° L.R. ELL

ADDED DYE CHECK - SHEET 3



TUBE HOLE

304 S.S.

B.P.F. NO. 42196 DATE 1

SHEET 3 APPARATUS NO. 2

PROJECT & ACCOUNT 026019 2

ORDER NO. 336-026-19527

SC PLANT APPROVED Hanover
TE *Kevin Ree* 3/10

DATE:	9-24-71	ORD. NO.	DW
BY:	D. NOLAND	71-167	SHE

VIEW X-X

BAFFLE CUT ALTERNATES A-A, B-B - LAST BAFFLE IS FULL CIRCLE.
BAFFLE DIA. = 34.825"
T.L. = 34.37164"
TUBE HOLE DIA. IN BAFFLES = 25/32"

[illegible]