

FORM U-1 (1) MANUFACTURERS' DATA REPORT OF PRESSURE VESSELS  
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured by Waner Mfg. Corp. 8200 W. 16th St. Tulsa, Oklahoma  
(Name and address of manufacturer)  
2. Manufactured for Hercofina Wilmington, N. C.  
(Name and address of purchaser)  
3. Location of Installation Hercofina Wilmington, N. C.  
(Name and address)  
4. Type Vert. Ht. Exch. Vessel No. 79-1515 79-1515 1455 Year Built 1979  
(Horiz. or vert. tank) (Mfr's Serial No.) (CRN) (Drawing) (Nat'l Bld No.)  
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1977  
and Addenda to 12-31-78 and Code Case no. \_\_\_\_\_  
(Date) (Year)  
Special service per UG-120(d) None  
Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: None  
(Name of part, item number, mfr's name and identifying stamp)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: Material SA240-316L Nominal Thickness 3/8 in. Corrosion Allowance 0 in. Diam. 3 ft. 6 in. Length 29 ft. 11 3/8 in.  
(Spec No., Grade) (Overall)  
7. Seams: Longitudinal Db1 R.T. Spot Efficiency 85 % H.T. Temp --- F Time --- Girth \* R.T. \*\* No. of Courses 3  
(Dbl., Sngl.) (Spot or Full) (Dbl., Sngl.) (Spot, Partial, or Full)  
8. Heads: (a) Material \_\_\_\_\_ (b) Material \_\_\_\_\_  
(Spec No., Grade) (Spec No., Grade) \*Corner Jt. & Db1  
\*\*Exempt & Spot

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) \_\_\_\_\_

(Material, Spec. No., Gr., Size, No.)

9. Type of Jacket \_\_\_\_\_ Proof Test \_\_\_\_\_  
10. Jacket Closure \_\_\_\_\_ If bar, give dimensions \_\_\_\_\_ If bolted, describe or sketch.  
(Describe as ogee & weld, bar, etc.)  
11. Constructed for max. allowable working pressure 150 psi at max. temp. 400 F Min. temp. (when less than -20 F) \_\_\_\_\_ F.  
Hydrostatic, pneu. or comb. test pressure 225 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: Stationary Material SA182 F316 Diam. 43 in. Nominal Thick. 3 1/8 in. Corrosion Allow. 0 in. Attachment Welded (Two)  
(Spec. No., Gr.) (Subject to pressure) (Welded, Bolted)

Floating Material \_\_\_\_\_ Diam. \_\_\_\_\_ in. Nominal Thick. \_\_\_\_\_ in. Corrosion Allow. \_\_\_\_\_ in. Attachment \_\_\_\_\_  
(Spec. No., Gr.)

13. Tubes: Material SA249-316 O.D. 75 in. Min. Thickness 0.65 in. or gauge Number 1197 Type Straight  
(Spec. No., Gr.) (Straight or "U")

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: Material SA240-316 Nominal Thickness 3/8 in. Corrosion Allowance 0 in. Diam. 15 ft. 0 in. Length 4 ft. 15 1/16 in. FRT  
(Spec. No., Gr.)  
15. Seams: Longitudinal Db1 R.T. Spot Efficiency 85 % H.T. Temp --- F Time --- Girth Db1 R.T. Spot \_\_\_\_\_ No. of courses 1  
(Dbl., Sngl.) (Spot or Full) (Dbl., Sngl.) (Spot, Partial or Full) BACK

16. Heads: (a) Material SA182 F316 (b) Material \_\_\_\_\_  
(Spec No., Grade) (Spec No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	Ends	Hub Type Flanges								
(b)										

If removable, bolts used (describe other fastenings) Channels: SA193-B7, 5/8, 76

(Material, Spec. No., Gr., Size, No.)

17. Max. allowable working pressure 150 psi at max temp. 400 F. Min. temp. (when less than -20F) \_\_\_\_\_ F.  
Hydro. pneu. or comb. test pressure 225 psi.

Items below to be completed for all vessels where applicable

18. Safety Valve Outlets: Number \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_



19. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Non Thickness	Reinforcement Material	How Attached
Channel In-Out	1-1	20"150	WN	SA240-316L	3/8"	Weld	Welded
Shell In-Out	1-1	20"150	WN	SA240-316L	3/8"	SA240-316L	Welded
Aux.	4	4"150	WN	SA312-316L	Std.	Weld	Welded

20. Inspection Openings:

Manholes No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_

Handholes No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_

Threaded No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_

21. Supports: Skirt Yes Lugs \_\_\_\_\_ Lugs \_\_\_\_\_ Other \_\_\_\_\_ Attached Shell Welded  
(Yes or no) (No) (No) (Describe) (Where and how)

22. Remarks: Service: Expander Preheater

Size: 42-360

Type: BEM Item: E-4100-3

OTE: SA240-316L - 60"ID x 1/2" Nom. Flanged and Flued Heads in shell w/SA240-316L 1/2" x 2'10" cyl. between heads.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date 8-28-79 Signed Waner Mfg. Corp. by R.J. Smith  
(Manufacturer) (Representative)

"U" Certificate of Authorization No. 8979 expires March 30, 19 82

CERTIFICATE OF SHOP INSPECTION

Vessel made by Waner Mfg. Corp. at Tulsa, Oklahoma

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Arkansas and employed by Commercial Union Ins. Co.

of Boston, Mass. have inspected the pressure vessel described in this Manufacturers' Data Report on 8-23, 1979, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-24-79  
Signed Thomas Payne Commissions N.B. #8940  
(Inspector) (Nat'l Board, State, Province and No.)

CERTIFICATE OF COMPLIANCE FOR FIELD WORK

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date \_\_\_\_\_ Signed \_\_\_\_\_ by \_\_\_\_\_  
(Manufacturer) (Representative)

"U" Certificate of Authorization No. \_\_\_\_\_ expires \_\_\_\_\_, 19 \_\_\_\_\_

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of \_\_\_\_\_ and employed by \_\_\_\_\_

of \_\_\_\_\_ have compared the statements in this Manufacturers' Data Report with the described pressure vessel and state that parts referred to as data items \_\_\_\_\_, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1.

The described vessel was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date \_\_\_\_\_  
Signed \_\_\_\_\_ Commissions \_\_\_\_\_  
(Authorized Inspector) (Nat'l Board, State, Province and No.)

#104120

8-23-79

NAT·L BD. NO. 1455	
U	150
W	400
RT 3	150
	400
	1979
	X1300013
	79-1515
	E-4100-3
CU	