

1. Manufactured by Joseph Oat & Sons, Inc. Camden, New Jersey  
(Name and address of Manufacturer)

2. Manufactured for Hercules, Inc. Wilmington, North Carolina **104389**  
(Name and address of Purchaser)

3. Type Horiz. Kind Heat Exch. Vessel No. (2080-1) ( ) Natl. Bd. No. 583 Yr. Built 1972  
(Horiz. or Vert.) (Tank, Jacketed, Heat Exch.) (Mfrs. Serial) (State & State No.)

Items 4-9 incl. to be completed for single wall vessels (such as air tanks); jackets of jacketed vessels; or shells of heat exchangers.

4. SHELL: Material SA285GRC T.S. 55000 Nominal Thickness 3/8 In. Allowance 1/16 In. Diam. 2 Ft. 6 In. Length 12 Ft. 0 In.  
(Kind and Spec. No.) (Fig. or F.B. & Spec. Min. T.S.)

5. SEAMS: Long DBW H.T. No R.T. Spot Sectioned No Efficiency 85 %  
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

Girth DBW H.T. No R.T. Spot Sectioned No No. of Courses 2

6. HEADS (a) Material SA285GRC T.S. 55000 (b) Material SA285GRC T.S. 55000  
Location (Top, bottom, ends) Thickness 1-1/8 Crown Radius 0 Knuckle Radius 0 Elliptical Ratio 0 Conical Apex Angle 0 Hemispherical Radius 0 Flat Diameter 34-3/8 Side to Pressure (Convex or Concave) 0

(a) 0 (b) 0

If removable, bolts used SA193 B7 32 3/4 10 UNC Other fastening Same  
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)

7. STAYBOLTS: 0 If hollow 0 Attachment 0 Pitch 0 X 0 Diam. 0  
(Material) (Size of Hole) (Threaded, Welded) (Horiz.) (Vert.) (Nominal)

8. JACKET CLOSURE: 0  
(Describe as ogee & weld, bar, etc. If bar, give dimensions, if bolted, describe or sketch)

9. Constructed for max. allowable working press. 100 psi at max. temp. 650 °F. less than -20° Min. temp. (when 0 °F. less than -20°) Hydrostatic Test Press 150 psi.  
(Describe or Attach Sketch)

Items 10 and 11 to be completed for tube sections.

10. TUBE SHEETS: Stationary. Material SA240 T304 Diam. 30 In. Thickness 1-1/16 In. Attachment Welded  
(Kind & Spec. No.) (Subject to Pressure) (Welded, Bolted)

Floating. Material SA249 Diam. 30 In. Thickness 1-1/16 In. Attachment 0  
(Kind & Spec. No.)

11. TUBES: Material T304 O.D. 3/4 In. Thickness 16 Gauge Number 799 Type Straight  
(Kind & Spec. No.) (Straight or U)

Items 12-15 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

12. SHELL Material SA240T304 T.S. 75000 Nominal Thickness 1/4 In. Allowance 0 In. Diam. 2 Ft. 6 In. Length 2 Ft. 0 In.  
(Kind and Spec. No.) (Fig. or F.B. & Spec. Min. T.S.)

13. SEAMS: Long DBW H.T. No R.T. Spot Sectioned No Efficiency 85 %  
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

Girth Single H.T. No R.T. None Sectioned No No. of courses 2

14. HEADS (a) Material SA285GRC T.S. 55000 (b) Material Same T.S. 55000 (c) Material SA285GRC T.S. 55000  
Location (Top, bottom, ends) Thickness 1-1/8 Crown Radius 0 Knuckle Radius 0 Elliptical Ratio 0 Conical Apex Angle 0 Hemispherical Radius 0 Flat Diameter 34-3/8 Side to Pressure (Convex or Concave) 0

(a) 0 (b) 0 (c) 0

If removable, bolts used (a) SA193 B7 32 3/4 10 UNC (b) Same  
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)

(c) 0 Other fastening Same

15. Constructed for max. allowable working press. 50 psi at max. temp. 300 °F. less than -20° Min. temp. (when 0 °F. less than -20°) Hydrostatic Test Press 90.6 psi.  
(Describe or Attach Sketch)

Items below to be completed for all vessels where applicable.

16. SAFETY VALVE OUTLETS: Number 0 Size 0 Location In Piping

17. NOZZLES

Purpose (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
A	1	24"	Plt.	SA240T304	3/8"	None	Welded
B-C	2	6"	Pipe	SA312T304	SCH40	"	"
E-D	2	14"	"	SA53GRB	STD.	"	"

P.O. 026-35067-FCD Equ. No. E-4057-3 Proj. 026035



18. INSPECTION Manholes, No. \_\_\_\_\_ Size \_\_\_\_\_ Location #104389  
 OPENINGS: Handholes, No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_  
 Threaded, No. 4 & 2 Size 3/4" & 1/2" Location Exp. Joint & Nozzles D&E  
 19. SUPPORTS: Skirt No Lugs \_\_\_\_\_ Legs \_\_\_\_\_ Other \_\_\_\_\_ Support \_\_\_\_\_ Attached Shell Welded \_\_\_\_\_  
 (Yes or No) (Number) (Number) (Describe) (Where & How)

20. REMARKS: Vessel is a Slurry Tank Flash Condenser constructed to Oat Dwg.  
5218-2 and the 1971 ASME Code Section VIII.  
Equipment No. E-4051-3

(Brief description of purpose of the vessel, as Air Tank, After Cooler, Jacketed Cooker, etc. State contents of each part.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division I.

Date 9/1 1972 Signed Joseph Oat & Sons, Inc. By James Christman  
 (Manufacturer)

Certificate of Authorization Expires #184 12/31/73

### CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Joseph Oat & Sons, Inc. at Camden, New Jersey

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province N. J. and employed by Royal Globe Indemnity Company of New York, N. Y. have inspected the pressure vessel described in this manufacturer's

data report on 1972, and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Sept 1 1972

James R. Hansen Commissions N.B. 6900  
 Inspector's Signature Nat'l Board, State, or Province and No.

### CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province \_\_\_\_\_ and employed by \_\_\_\_\_ of \_\_\_\_\_


have compared the statements in this manufacturer's data report with the described pressure vessel and state that parts referred to as data items \_\_\_\_\_, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure vessel Code. The described vessel was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date \_\_\_\_\_ 19 \_\_\_\_\_

\_\_\_\_\_  
 Inspector's Signature Commissions Nat'l Board, State, or Province and No.






NOTE: ALL COUPLINGS ARE HALF-COUPPLINGS-3000#-THD.

N	3/4"	3000#	CPLG.	DRAIN	NPT W/PLUG	1
M	3/4"	3000#	CPLG.	VENT	NPT W/PLUG	1
L2 & 5	(2) 3/4"	3000#	CPLG.	THERMOMETER	NPT W/PLUG	1 2
K2 & 5	(2) 1/2"	3000#	CPLG.	PRESS. GAGE	NPT W/PLUG	1 2
						1 2
						1 2
						1 2
E	14"	STD WT.	SORF	WATER OUT	150#	1
D	14"	STD WT.	SORF	WATER IN	150#	1
C	6"	40	L.J.	VENT	150#	1
B	6"	40	L.J.	COND. OUT	150#	1
A	24"	3/8" WALL	L.J.	STEAM IN	150#	1
MARK	SIZE	SCH.	FLANGE	PURPOSE	REMARKS	DATE
						2-16-72

6/1/72	REVISOR	REVISION
5/22/72	1	REVISED PER HERCULES MARKED PRINT DATED 5-25-72. DELETED NOZS. J, H, G, F, L, 1, 3, 4, E, K, 3, 4
	1	REVISED PER HERCULES MARKED PRINT DATED 3/21/72 & TO SUIT FAB. DWG.
		ISSUED FOR APPROVAL
		REVISIONS



#104389

B.P.F. NO. 42360 DATE 6-14-72

SHEET 1 APPARATUS NO. E-4051-3

PROJECT & ACCOUNT 026035

ORDER NO. 336-026-35067

PLANT APPROVED HANOVER

HERCULES P.O. 026-35067 OAT JOB NO. J-2080-1

PROJ. NO. 026035 EQUIP. NO. E-4051-3

OUTLINE DRAWING

SLURRY TANK FLASH CONDENSER

HERCULES INCORPORATED

HANOVER PLANT

WILMINGTON, N. C.

JOS. OAT & SONS, INC. CAMDEN, N. J.

DRAWN-RO DATE-2-16-72 DWG. 5212

SCALE - NONE

REV. 2