

FORM U-1 MANUFACTURERS' DATA REPORT FOR UNFIRED PRESSURE VESSELS

As required by the Provisions of the ASME Code Rules

M & L JOB # 17357-1

- Manufactured by MANNING & LEWIS ENG. CO., 675 RAHWAY AVE., UNION, N. J. 07083
(Name and address of manufacturer)
- Manufactured for CLARK OIL & REFINING CORP BLUE ISLAND ILL.
(Name and address of Purchaser)
- Type HORIZ Kind HEAT EXCH Vessel No. (5490) (Mfrs. Serial) (State & State No.)
(Horiz. or Vert.) (Tank, Jacketed, Heat Exch) Natl. Bd. No. 2926 Yr. Built 1969

Items 4-9 incl. to be completed for single wall vessels (such as air tanks), jackets of jacketed vessels, or shells of heat exchangers.

- SHELL: Material SA-240-304 T.S. 75000 Nom. Tks. 1875 in. Allow. 062 in. Dia. 2 Ft. 5 in. Lgth. 9 Ft. 9 3/4 in.
(Kind and Spec. No.) (Fig. or P.B. & Spec. Min. T.S.)
- SEAMS: Long DBL BUTT H.T. NO R.T. SPOT Sectioned NO Efficiency 85 %
(Welded, Dbl. Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)
Girth GROOVE H.T. NO R.T. SPOT Sectioned NO No. of Courses 1
(Yes or No) (Spot or Complete) (Yes or No)
- HEADS: (a) Material SA-240-304 T.S. 75000 (b) Material SA-240-304 T.S. 75000
(Top, bottom, ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)
(a) 5/16 24 2 1/2 30.25 CONCAVE
(b) 1.812 24 2 1/2 30.25 FLAT
(c) Floating
- If removable, bolts used SA-193-B7-125000 3/4-10 28 (Material, Spec. No., T.S., Size, Number) Other fastening None (Describe or Attach Sketch)
- STAYBOLTS: None If hollow None Attachment None Pitch X Diam. None
(Material) (Size of Hole) (Threaded, Welded) (Horiz.) (Vert.) (Nominal)
- JACKET CLOSURE: None
(DESCRIBE AS GAGE & WELD, BAR, ETC. IF BAR, GIVE DIMENSIONS. IF BOLTED, DESCRIBE OR SKETCH).
- Constructed for max. allowable working press. 75 psi. at max. temp. 275 °F. Min. temp. (when less than -20°) None °F. Hydrostatic } Test Press. 134 psi.
Pneumatic or }
Combination }

Items 10 and 11 to be completed for tube sections.

- TUBE SHEETS: Stationary. Material SA-240-304 Dia. 30.25 in. Tks. 1.1875 in. Attachment Welded
(Kind & Spec. No.) (Subject to Pressure) (Welded, Bolted) (CLAMPED)
Floating. Material SA-240-304 Dia. 30.25 in. Tks. 1.1875 in. Attachment Welded
(Kind & Spec. No.)
- TUBES: Material SA-240-304 O.D. 3/4 in. Thickness 16 or Gage Number 662 Type STRAIGHT
(Kind & Spec. No.) (Straight or U)

Items 12-15 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

- SHELL: Material SA-285-C T.S. 55000 Nom. Tks. 312 in. Allow. 064 in. Dia. 2 Ft. 5 in. Lgth. 1 Ft. 5 3/4 in.
(Kind and Spec. No.) (Fig. or P.B. & Spec. Min. T.S.)
- SEAMS: Long DBL BUTT H.T. NO R.T. NO Sectioned NO Efficiency 85 %
(Welded, Dbl. Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)
Girth DBL BUTT H.T. NO R.T. NO Sectioned NO No. of Courses 1
(Yes or No) (Spot or Complete) (Yes or No)
- HEADS: (a) Material SA-285-C T.S. 55000 (b) Material SA-515-70 T.S. 70000 (c) Material SA-515-70 T.S. 70000
(Top, bottom, ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)
(a) 5/16 24 2 1/2 30.25 CONCAVE
(b) 1.812 24 2 1/2 30.25 FLAT
(c) Floating
- If removable, bolts used (a) SA-193-B7-125000 3/4-10 28 (Material, Spec. No., T.S., Size, Number) (b) None Other fastening None (Describe or Attach Sketch)
- Constructed for max. allowable working press. 75 psi. at max. temp. 275 °F. Min. temp. (when less than -20°) None °F. Hydrostatic } Test Press. 113 psi.
Pneumatic or }
Combination }

Items below to be completed for all vessels where applicable.

- SAFETY VALVE OUTLETS: Number None Size None Location None
- NOZZLES:

Purpose (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
IN-OUT	2	6" 150°	FLANGED	SA-53-B	5/16		Welded
INLET	1	10" 150°	"	SA-240-304	3/16		"
OUTLET	1	4" 150°	"	SA-312-304	5/16		"
VENT	1	2" 150°	"	"	5/16		"
DRAIN	1	3/4" 3000°	SCREWED	SA-182-F304	3000°		"
THERMO	6	3/4" 3000°	"	"	3000°		"
THERMO VENT DRAIN	6	3/4" 6000°	"	SA-105-11	6000°		"

18. INSPECTION Manholes, No. _____ Size _____ Location _____
 OPENINGS: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____

19. SUPPORTS: Skirt _____ Lugs _____ Logs 2 Other _____ Attached WELDED TO SHELL
 (Yes or No) (Number) (Number) (Describe) (Where & How)

20. REMARKS: 29-120 CONDENSER WITH ACETONE IN THE SHELL AND WATER IN THE TUBES

(Brief description of purpose of the vessel, as Air Tank, After Cooler, Jacketed Cooker, etc. State contents of each part.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for unfired Pressure Vessels.

Date 1/18 19 69 Signed MANNING & LEWIS ENG. CO. By A. L. Gale
 MANUFACTURER
 Certificate of Authorization Expires DEC. 31 1970

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY MANNING & LEWIS ENG. CO. at UNION, N. J.

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province Nat'l Bd. and employed by COMMERCIAL UNION INSURANCE CO. of NEW YORK, N.Y. have inspected the pressure vessel described in this manufacturer's data report on _____ 19____, and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1-18-69 19____ Commissions NAT'L BD. 3872
Joe E. Egan Inspector's Signature Nat'l Board or State and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province _____ and employed by _____ of _____ have compared the statements in this manufacturer's data report

with the described pressure vessel and state that parts referred to as data items _____ not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code. The described vessel was inspected and subjected to a hydrostatic test of _____ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ 19____ Commissions _____
 _____ Inspector's Signature Nat'l Board or State and No.