

FORM N-1 CERTIFICATE HOLDER'S DATA REPORT FOR NUCLEAR VESSELS*
As Required by the Provisions of the ASME Code, Section III, Division 1

Pg. 1 of 2

1. Manufactured and certified by Joseph Oat Corporation / 2500 Broadway, Camden, New Jersey 08104
(name and address of N Certificate Holder)
2. Manufactured for TVA / 1270 Nuclear Plant Road, HWY 68, Spring City, TN 37381
(name and address of Purchaser)
3. Location of installation Watts Bar Unit 1 / 1270 Nuclear Plant Road, HWY 68, Spring City, TN 37381
(name and address)
4. Type Horizontal Heat Exchanger 2692-B --- D-12609.01/4 3607 2012
(horizontal or vertical) (tank, jacketed, heat ex.) (Certificate Holder's serial no.) (CRN) (drawing no.) (National Bd. no.) (year built)
5. ASME Code, Section III, Division 1 1974 None 3 -----
(edition) [Addenda (if applicable) (date)] (class) (Code Case no.)

Items 6-10 inclusive to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

6. Shell SA516-70 70 ksi .625" .402" 54.312" 13'-7.250"
(material spec. no.) (tensile strength) (nominal thickness) (minimum design thickness) (diameter ID) (length overall)
7. Seams Double V No Spot 85 Double V No Spot 2
(long.) (HT¹) (RT) (eff. %) (girth) (HT¹) (RT) (no. of courses)
8. Heads SA516-70 70 ksi ----- -----
[(a) material spec. no.] (tensile strength) [(b) material spec. no.] (tensile strength)

	Location (top, bottom, ends)	Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (convex or concave)
(a)	End	.547"	.125'	---	---	---	---	---	---	Concave
(b)	-----	---	---	---	---	---	---	---	---	-----

If removable, bolts used ----- Other fastening -----
(material spec. no., size, quantity) (describe or attach sketch)

9. Jacket closure -----
(Describe as ogee & weld, bar, etc. If bar, give dimensions, describe, or sketch)
10. Design pressure² 150 psi at max. temp. 200 F. Min. pressure-test temp. 40 F. Pneu., hydro., or comb. test pressure 225 psi

Items 11 and 12 to be completed for tube sections.

11. Tubesheets SA240-304/304L 54.312" 3.812" Welded
(stationary, material spec. no.) [diameter (subject to press.)] (thickness) [attachment (welded, bolted)]
- ----- ----- -----
(floating, material spec. no.) (diameter) (thickness) (attachment)
12. Tubes SA249-304/304L .750" .049" 1194 U
(material spec. no.) (OD) [thickness (inches or gage)] (no.) [type (straight or U)]

Items 13 to 16 inclusive to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

13. Shell SA240-304/304L 75 ksi .500" .271" 55.312 1'-8"
(material spec. no.) (tensile strength) (nominal thickness) (minimum design thickness) (diameter ID) (length overall)
14. Seams Double V No Spot 85 Double V No Spot 1
[long. (welded, dbl., single)] [HT¹ (yes or no)] (RT) (eff. %) (girth) (HT¹) (RT) (no. of courses)
15. Heads ----- ----- SA240-304/304L 75 ksi ----- -----
[(a) material spec. no.] (tensile strength) [(b) material spec. no.] (tensile strength) [(c) material spec. no.] (tensile strength)

	Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (convex or concave)
(a)	Top, bottom, ends	-----	---	---	---	-----	-----	---	-----
(b)	Channel	.430"	---	---	---	-----	-----	---	Concave
(c)	Floating	-----	---	---	---	-----	-----	---	-----

If removable, bolts used ----- Other fastening -----
(material spec. no., size, quantity) (describe or attach sketch)

16. Design pressure² 150 psi at 200 F. Min. pressure-test temp. 40 F. Pneu., hydro., or comb. test pressure 225 psi

¹If postweld heat treated. ²List other internal or external pressure with coincident temperature when applicable.

* Supplemental information in the form of lists, sketches, or drawings may be used provided: (1) size is 8 1/2 x 11; (2) information in items 1 through 4 on this Data Report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Certificate Holder's Serial No. 2692-B

17. Nozzles, inspection and safety valve openings

Purpose (inlet, outlet, drain, etc.)	Quantity	Diameter or Size	Type	How Attached	Material	Thickness	Reinforcement Material	Location
Inlet/Outlet	2	10"	WNRF	Welded	304/304L	150#	SA240-304/304L	-----
Inlet/Outlet	2	14"	Pipe	Welded	106-B	.500"	SA516-70	-----
Vent/Drain	4	3/4"	H Cplg.	Welded	304/304L	6000#	None	-----
Vent/Drain	2	3/4"	H. Cplg.	Welded	234/105	6000#	None	-----
Flush/Inspection	5	4"	Stud Pad	Welded	304/304L	150#	None	Chan. Cover
Flush/Inspection	4	4"	Stud Pad	Welded	105	150#	None	Shell

18. Supports: Skirt No Lugs 0 Legs 0 Other Saddles (2) Attached Shell, Welded
(yes or no) (quantity) (quantity) (describe) (where and how)

19. Remarks:

CERTIFICATION OF DESIGN

Design specification certified by James C. Nygaard P.E. State KS Reg. no. 11287
Design report certified by Yingzong Bu P.E. State MD Reg. no. 36775

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N-1488 Expires 08/04/2012
Date 7/20/12 Name Joseph Oat Corporation Signed [Signature]
(N Certificate Holder) (authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by OneBeacon America Insurance Company

of Lynn, MA have inspected the component described in this Data Report on 07/20/2012, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this component in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 07/20/2012 Signed [Signature] Commission NR9541 N, NT786
(Authorized Nuclear Inspector) (National Board Number and Endorsement)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the statements on this report are correct and that the field assembly construction of all parts of this nuclear vessel conforms to the rules of construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. _____ Expires _____
Date _____ Name _____ Signed _____
(N Certificate Holder) (authorized representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by _____

of _____ have compared the statements in this Data Report with the described component and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me on _____ and that to the best of my knowledge and belief, the Certificate Holder has constructed and assembled this component in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commission _____
(Authorized Nuclear Inspector) (National Board Number and Endorsement)