

FORM U-1 MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured by ROCKAWAY TANK, INCORPORATED DOVER, N. J.
(Name and address of manufacturer)
2. Manufactured for HOFFMANN-La ROCHE, INCORPORATED NUTLEY, N. J.
(Name and address of purchaser)
3. Location of installation HOFFMANN-La ROCHE, INCORPORATED BELVIDERE, N. J.
(Name and address)
4. Type Vertical Vessel No. R-4559-512 RT-4-621B 512 Year Built 1980
(Horizontal, or vertical tank) (Manufacturer's Serial No.) (CRN) (Drawing) (NAT'l Brd No.)
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1977 and Addenda to S-79 and Code Case no. N/A
(Date) (Year)
- Special service per UG-120(d) N/A
- Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: N/A
(Name of part, item number, minor's name and identifying stamp)

Items 6-11 incl. to be completed for single wall vessel, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: Material SA-240 3/16 In. Corrosion Allowance 0 In. Diam. 1 ft. 6 In. Length 15 ft. 11-3/4 In.
(Spec. No., Grade) (Overall)
7. Seams: D.B. & S.B. & Backup
Longitudinal D.B.R.T. No Efficiency 70 % H.T. Temp F Time Girth Weld R.T. No No. of Courses 7
(Dbl., Sngl.) (Spot or Full) (Dbl., Sngl.) (Spot, Partial, or Full)

8. Heads: (a) Material (Spec. No., Grade) (b) Material (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings)

(Material, Spec. No., Gr., Size, No.)

9. Type of Jacket Proof Test
10. Jacket Closure Full Vac If bar, give dimensions If bolted, describe or sketch.
(Describe as open & weld, bar, etc.)
11. Constructed for max. allowable working pressure 6 30 psi at max. temp. 300 F Min. temp. (when less than -20 F) F.
Hydrostatic, ~~maximum allowable~~ test pressure 50 psi.

Items 12 and 13 to be completed for tube sections T-316

12. Tubesheets: Stationary Material SA-240 Diam. 18 In. Nominal Thick. 1-3/16 In. Corrosion Allow. 0 In. Attachment Welded
(Spec. No., Gr.) (Subject to pressure) (Welded, Rilled)

Floating Material SA-249 Diam. In. Nominal Thick. In. Corrosion Allow. In. Attachment
(Spec. No., Gr.)

13. Tubes: Material T-316 O.D. 3/4 In. Nominal Thickness 16 In. ~~XXXX~~ Number 268 Type Straight
(Spec. No., Gr.) (Straight or "U")

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: Material SA-240 3/16 In. Corrosion Allowance 0 In. Diam. 1 ft. 6 In. Length 1 ft. 9 1/4 In.
(Spec. No., Gr.)
15. Seams: Weld
Longitudinal D.B.R.T. No Efficiency 70 % H.T. Temp F Time Girth D.B.R.T. No No. of courses 1 Each
(Dbl., Sngl.) (Spot or Full) (Dbl., Sngl.) (Spot, Partial or Full)

16. Heads: (a) Material SA-240, T-316 (b) Material SA-515 Gr. 70
(Spec. No., Grade) (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	<u>Top</u>	<u>1/8"</u>	<u>0</u>	<u>18"</u>	<u>1-1/2"</u>				<u>18"</u>	<u>Concave</u>
(b)	<u>Bottom</u>	<u>1-1/8"</u>	<u>0</u>							<u>Flat</u>

If removable, bolts used (describe other fastenings) a & b SA-193 Gr. B-7, (16) 5/8" Dia. Bolts
(Material, Spec. No., Gr., Size, No.)

17. Max. allowable working pressure 100 psi at max temp. 300 F. Min. temp. F. Hydro. test pressure 155 psi.

Items below to be completed for all vessels where applicable

18. Safety Valve Outlets: Number Size Location

10. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Nominal Thickness	Reinforcement Material	How Attached
Shell Inlet	1	16"	Flgd./	SA-105	150#	Weld	Welded
			Nozz.	SA-240, T-316	3/8"		
Channel Inlet	1	10"	"	"	150#	3/16"	"
Channel Outlet	1	10"	"	"	150#	3/16"	"
Shell Outlet	1	3"	Flgd./	SA-105	150#		
			Nozz.	SA-312TP-316	.216"	"	"
Instrument	13	3/4"	Thread.	SA-182F-316	3000#	"	"

Coupl.

20. Inspection Openings:

Manholes No. _____ Size _____ Location _____

Handholes No. _____ Size _____ Location _____

Threaded No. _____ Size _____ Location _____

21. Supports: Skirt _____ Lugs 4 _____ Other _____ Attached Welded to Shell
(Yes or no) (No) (No) (Describe) (Where and how)

22. Remarks: 848 Sq. Ft. Surface Fixed Tubesheet Shell & Tube Heat Exchanger, TEMA Type AEM. Shell Contains Combination Vapor Chest & Expansion Joint
25 1/2" I.D. X 20" Long With 1/4" Nom. Tk. Flanged Only & Flued Heads on Each
End Reducing to 17-5/8" I.D. at Shell Junction. All Material SA-240, T-316.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.
 Date Feb. 14, 1980 Signed ROCKAWAY TANK, INC. by Eric A. Waller, Pres.
 (Manufacturer) (Representative)

"U" Certificate of Authorization No. 7712 expires February 28, 19 82

CERTIFICATE OF SHOP INSPECTION

Vessel made by ROCKAWAY TANK, INC. at DOVER, N. J.

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of N. J. and employed by STATE OF NEW JERSEY

of _____, have inspected the pressure vessel described in this Manufacturers' Data Report on Feb. 14, 1980, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date February 27, 1980

Signed E. J. Merna Commissions N.B. 6575
 (Inspector) (Nat'l Board, State, Province and No.)

CERTIFICATE OF COMPLIANCE FOR FIELD WORK

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date _____ Signed _____ by _____
 (Manufacturer) (Representative)

"U" Certificate of Authorization No. _____ expires _____, 19 _____

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board and Pressure Vessel Inspectors and the State or Province of _____ and employed by _____

of _____, have compared the statements in this Manufacturers' Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed

and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1.

The described vessel was inspected and subjected to a hydrostatic test of _____ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____

Signed _____ Commissions _____
 (Authorized Inspector) (Nat'l Board, State, Province and No.)