

112945

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

HX-0040

- 1. Manufactured and certified by ENERGY EXCHANGER COMPANY, 1844 NORTH GARNETT ROAD, TULSA, OK 74116
2. Manufactured for SOUTHERN COMPANY SERVICES, INC. 42 INVERNESS CENTER PARKWAY BIRMINGHAM, AL 35242
3. Location of installation MISSISSIPPI POWER CO., DEKALB, MS.
4. Type: HORIZ. HEAT EXCHANGER X-7931
5. ASME Code, Section VIII, Div. 1 2007 EDITION (2009 ADDENDA)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multichamber vessels.

- 6. Shell (a) No. of course(s): 3 / 1 (b) Overall length (ft & in.): 23'-10 5/8" / 4'-2" (1)

Table with columns: Course(s), Material, Thickness, Long. Joint (Cat. A), Circum. Joint (Cat. A, B, & C), Heat Treatment. Rows include vessel courses with diameters, lengths, materials, and joint specifications.

- 7. Heads: (a) SA-516-70 (b) SA-516-70

Table for head specifications with columns: Location, Thickness, Radius, Elliptical Ratio, Conical Apex Angle, Hemispherical Radius, Flat Diameter, Side to Pressure, Category A.

- If removable, bolts used (describe other fastening) SHELL TO CHANNEL; SA-193-B7, 7/8" DIA, 28

- 8. Type of jacket Jacket closure

- 9. MAWP 158 15 psi at max. temp. 500 500 °F Min. design metal temp. 10 °F at 158 psi

- 10. Impact test NO, EXEMPT PER UG-20(f) at test temperature of --- °F.

- 11. Hydro., pneu., or comb.-Test press. 210 P.S.I.G. Proof test

Items 12 and 13 to be completed for tube sections.

- 12. Tubesheet: SA-516-70N 29 1/4" 3" 5/16" Bolted

- 13. Tubes: SA-214 3/4" 0.083" THK (MIN) 125 "U"

Items 14-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

- 14. Shell (a) No. of course(s): 1 (b) Overall length (ft & in.): 0'-9 5/8"

Table for inner chamber shell with columns: Course(s), Material, Thickness, Long. Joint (Cat. A), Circum. Joint (Cat. A, B, & C), Heat Treatment.

- 15. Heads: (a) SA-516-70N (b) SA-516-70N

Table for inner chamber head specifications with columns: Location, Thickness, Radius, Elliptical Ratio, Conical Apex Angle, Hemispherical Radius, Flat Diameter, Side to Pressure, Category A.

- If removable, bolts used (describe other fastening) a) SA-193B7, 7/8" DIA, 28

FORM U-1 (Back)

16. MAWP 185 --- psi at max. temp. 145 --- °F Min. design metal temp. 10 °F at 185 psi.
(internal) (external) (internal) (external)

17. Impact test NO, EXEMPT PER UG-20(f) at test temperature of --- °F.
(Indicate yes or no and the component(s) impact tested)

18. Hydro., pneu., or comb. Test press. 245 P.S.I.G. Proof test _____

19. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	How Attached		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
INLET/OUTLET	1/1	14"-150#	RF-WN	SA-106B	SA-105	.500"	1/8"	WELD	WELDED	WELDED	SHELL
INLET	1	3"-150#	FF-WN	SA-106B	SA-105	.438"	1/8"	WELD	WELDED	WELDED	CHANNEL
OUTLET	1	3"-150#	FF-WN	SA-106B	SA-105	.438"	1/8"	WELD	WELDED	WELDED	CHANNEL
VENT/DRAIN	1/1	1"-150#	RF-WN	SA-105	---	.500"	1/8"	WELD	WELDED	---	CHANNEL COVER

20. Supports: Skirt NO Lugs --- Legs --- Others (2) Saddles Attached WELDED TO SHELL
(Yes or no) (No.) (No.) (Describe) (Where and how)

21. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:
 (List the name of part, item number, mfg's. name and identifying number)

22. Remarks: SERVICE: LP VENT GAS COMPRESSOR PRE COOLER; P.O. NO: 17497-0001; ITEM NO.: HX0040; SIZE: 28-288; TYPE: AGU
TUBES DESIGNED W/ 0" C.A., SAFETY RELIEF DEVICES BY OTHERS; LINES 6-11 INCLUDES (1) 33 3/8" OD x 28" ID x 4" THK. SA-266-4N RING
LINES 14-18 INCLUDES (1) 33 3/8" O.D. X 28" I.D. X 3 15/16" THK. RING & (1) 33 3/8" OD x 28" ID x 4" THK. RING, BOTH SA-266-4N
(1) Annular distributor contains (2) 35 3/4" OD x 28 7/8" ID x 3/4" thk. SA-516-70 Closure Rings & (2) 3 1/4" x 3/8" thk. x 49 7/8" SA-516-70 Divider Plates

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1.

U Certificate Authorization No. 12370 Expires SEPTEMBER 27, 20 13
 Date 10-6-11 Name ENERGY EXCHANGER COMPANY Signed Egan O'Dover
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of OKLAHOMA and employed by ONEBEACON AMERICA INSURANCE COMPANY of LYNN, MA have inspected the pressure vessel described in this Manufacturer's Data Report on 10-6-2011, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10-6-11 Signed [Signature] Commissions N.B.# 12064 A OKLA.# 7
(Authorized Inspector) (Nat'l Board incl. endorsements, State, Province, and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the statements on this report are correct and that field assembly construction of all parts of this vessel conforms with the requirements of ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. U Certificate of Authorization No. _____

U Certificate of Authorization No. _____ Expires _____, 20 _____
 Date _____ Name _____ Signed _____
(Assembler) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____, have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. The described vessel was inspected and _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Nat'l Board incl. endorsements, State, Province, and No.)