

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS

As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. **Manufactured and certified by** SPX HEAT TRANSFER, INC. 2121 N. 161ST EAST AVENUE Tulsa, OK 74116
(Name and address of Manufacturer)
2. **Manufactured for** SPX Flow Technology USA, Inc. Ocala, FL 34474
(Name and address of Purchaser)
3. **Location of installation** Mississippi Power Company, Kemper County IGCC, Unit 1, Project Kemper County, MS
(Name and address)
4. **Type:** Vertical HP Assembly Chamber (Tank) LH WUH/790.110100-3A N/A 7405265 R-A 8716 2012
(Horiz., vert., or sphere) (Tank, separator, jkt. Vessel, heat exch., etc.) (Mfg's serial number) (CRN) (Drawing No.) (Nat'l Bd. No.) (Year Built)
5. **ASME Code, Section VIII, Div. 1** 2010 Edition N/A N/A
[Edition and Addenda, if applicable (date)] (Code Case number) [Special service per UG-120(d)]
- Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multichamber vessels.
6. **Shell:** (a) **Number of course(s)** 1 (b) **Overall length** 96"

Course(s)			Material	Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A,B, &C)			Heat Treatment	
No.	Diameter	Length	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
1	132" OD	96"	SA-516-70N	1.500"	.0625"	1	Full	100%	1	Full	100%	N/A	N/A

7. **Heads:** (a) SA-516-70N HT-N/A (b) SA-516-70N HT-N/A
(Material spec. number, grade or type (H.T. - Time and temp.)) (Material spec. number, grade or type (H.T. - Time and temp.))
- | | Location (Top, Bottom, Ends) | Thickness | | Radius | | Elliptical Ratio | Conical Apex Angle | Hemis. Radius | Flat Diameter | Side to Pressure | | Category A | | |
|-----|------------------------------|-----------|--------|--------|---------|------------------|--------------------|---------------|---------------|------------------|---------|------------|------------------|------|
| | | Min. | Corr. | Crown | Knuckle | | | | | Convex | Concave | Type | Full, Spot, None | Eff. |
| (a) | TOP | 1.375" | .0625" | | | 2:1 | | | | | X | N/A | N/A | N/A |
| (b) | BOTTOM | 1.375" | .0625" | | | 2:1 | | | | | X | N/A | N/A | N/A |

If removable, bolts used (describe other fastening)

N/A

8. **Type of jacket** N/A **Jacket closure** N/A
(Mat'l Spec. No., Grade, size, No.) (Describe as ogee and weld, bar, etc.)
- If bar, give dimensions N/A If bolted, describe or sketch
9. **MAWP** 350 N/A **psi at max. temp.** 450 N/A **F Min. design metal temp.** 10 **F at** 350 **psi**
(Internal) (External) (Internal) (External)

10. **Impact Test** No-exempt per UCS 66 **at test temperature of** N/A **F**
(Indicate yes or no and the component(s) impact tested)

11. **Hydro., pneu., or comb. test pressure** 455 psi **Proof test** N/A

Items 12 and 13 to be completed for tube sections.

12. **Tubesheet**
(Stationary (material spec. no.)) (Diameter (subject to press.)) (Nominal thickness) (Corr. Allow.) (Attachment (welded or bolted))
(Floating (material spec. no.)) (Diameter) (Nominal thickness) (Corr. Allow.) (Attachment)

13. **Tubes**
(Material spec.no, grade or type) (O.D.) (Nominal thickness) (Number) (Type (straight or U))

Items 14-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

14. **Shell:** (a) **Number of course(s)** (b) **Overall length**

Course(s)			Material	Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A,B, &C)			Heat Treatment	
No.	Diameter	Length	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time

15. **Heads:** (a) (b)
(Material spec. number, grade or type (H.T. - Time and temp.)) (Material spec. number, grade or type (H.T. - Time and temp.))

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemis. Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full, Spot, None	Eff.
(a)														
(b)														

If removable, bolts used (describe other fastening)

(Mat'l Spec. No., Grade, size, No.)

16. MAWP _____ psi at max. temp. _____ F Min. design metal temp. _____ F at _____ psi
 (Internal) (External) (Internal) (External)
17. Impact Test _____ at test temperature of _____ F
 (Indicate yes or no and the component(s) impact tested)
18. Hydro., pneu., or comb. test pressure _____ Proof test _____
19. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
Manway	1	20"	RFLWN	SA-105		300#	.0625'		Weld	-	Shell
Drain	2	8"	RFLWN	SA-105		300#	.0625'	-	Weld	-	Shell
Connection	1	1.500'	RFLWN	SA-105		300#	.0625'	-	Weld	-	Shell
Inlet	1	20"	RFLWN	SA-105		300#	.0625"	-	Weld	-	Top-Head
Inlet	1	8"	RFLWN	SA-105		300#	.0625'	-	Weld	-	Top-Head
Relief	1	2.000'	RFLWN	SA-105		300#	.0625'	-	Weld	-	Top-Head
Outlet	1	20"	RFLWN	SA-105		300#	.0625"	-	Weld	-	Bottom-Head

20. Supports: Skirt YES _____ Lugs N/A _____ Legs N/A _____ Other N/A _____ Attached _____ Bottom-Weld _____
 (Yes or no) (Number) (Number) (Describe) (Where and how)
21. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report (list the name of part, item number, Manufacturer's name and identifying number):
 Shell Head-Top and Bottom, Uni-Form Components, Inc., Top-S/N 6292 (No NB assigned) Bottom-S/N 6298 (No NB assigned)
22. Remarks: Outlet Nozzle(N10) Bottom-Head Assembly cont'd- (1) 20" LR 90 Elbow-Sch STD, SA-234-B, CA-.0625", Weld (1) PIPE SMLS 20'-SCH 20, SA-53B-ERW, CA-.0625', Weld (1) FORGING 24.25" OD-19.25ID, SA-105, CA-.0625', Weld
 Manway cont'd (N02)-(1) 20" RF Blind Flange CLS300, SA-105, CA-.0625", Bolt (36) Stud-Thread 1.250"-8X 11.500 GALVANIZED, A153, SA193B7
 (72) Nut Hexagon 1.250"-8 GALVANIZED A153, SA194-2H Relief Valve supplied by other

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1.

U Certificate of Authorization Number 11,178

Expires 06/04/13

Date 04/26/2016

Name SPX Heat Transfer, Inc.

Signed

(Manufacturer)

(Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of OK and employed by OneBeacon Contract Inspection Services of Lynn, MA have inspected the pressure vessel described in this Manufacturer's Data Report on 04/06/12, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 04/26/2016

Signed

John Ash
 (Authorized Inspector)

Commissions

15649 Ar
 [National Board (incl. endorsements)]

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the statements in this report are correct and that the field assembly construction of all parts of this vessel conforms with the requirements of ASME CODE, Section VIII, Division 1.

U Certificate of Authorization Number

Expires

Date

Name

Signed

(Assembler)

(Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by _____ of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME CODE, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date

Signed

(Authorized Inspector)

Commissions

[National Board (incl. endorsements), State, Province, and Number]

#8716 2/3

FORM U-2A MANUFACTURER'S PARTIAL DATA REPORT (ALTERNATIVE FORM)
A Part of a Pressure Vessel Fabricated by One Manufacturer for Another Manufacturer
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by UNI FORM COMPONENTS CO. 10703 SHELDON ROAD HOUSTON TEXAS 77044
(Name and address of Manufacturer)

2. Manufactured for YUBA HEAT TRANSFER 2121 N 161ST EAST AVE. TULSA, OK 74116
(Name and address of Purchaser)

3. Location of installation UNKNOWN
(Name and address)

4. Type: TWO-PIECE HEAD S/N 6292 N/A
(Description of vessel part (shell, two-piece head, tube bundle)) (Manufacturer's serial number) (CRN)

5. ASME Code Section VIII Div 1 NO DRAWING BY UCC 2012
(National Board number) (Drawing number) (Drawing prepared by) (Year built)

6. Shell (a) No. of course (s): 2010E/2011A N/A N/A
(Edition and Addenda (date)) (Code Case number) [Special Service per UG-120(d)]

Course(s)			Material	Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A, B, & C)			Heat Treatment	
No.	Diameter	Length	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
3	London (4)	SA 516 70 48000											

7. Heads: (a) SA 516-70 (NORMALIZED 1650° @ 100 MIN.) (b) N/A														
(Material spec. number, grade or type) (H.T. – time & temp) (Material spec. number, grade or type) (H.T. – time & temp)														
	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Gown	Knuckle					Convex	Concave	Type	Full, Spot, None	Eff
(a)	N/A	1.375				2:1						1	FULL	
(b)														

If removable, bolts used (describe other fastenings) _____

8. MAWP _____ at max temp. _____
(Internal) (External) (Material spec. number, grade, size, number) Min. design metal temp. _____ at _____

9. Impact Test _____ at test temperature of _____
Indicate yes or no and the component(s) Impact tested (Internal) (External)

10. Hydro., pneu., or comb. test press. _____ Proof Test _____

11. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc)	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	How Attached		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	

12. Identification of parts

Name of Part	Quantity	Line No.	Mfr's Identification No.	Mfr's Drawing no.	CRN	National Board No.	Year Built

13. Supports: Skirt _____ Lugs _____ Legs _____ Others _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where and how)

14. Remarks 1 HEAD: 129" I.D. X 1.625" NOM.

UCC JOB NUMBER 100468

DESIGN BY OTHERS HYDRO BY OTHERS PWHT BY OTHERS

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of material, construction and workmanship of this pressure vessel part conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1.

U Certificate of Authorization No. 18.206 Expires 11/03/2013

Date 1/31/12 Name UNI FORM COMPONENTS CO. Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of TEXAS and employed by ONE BEACON AMERICA INSURANCE of LYNN, MA. have inspected the pressure vessel part described in this Manufacturer's Data Report on 1/31/12 and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel part in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel part described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1/31/12 Signed [Signature] Commissions NB9604A
(Authorized Inspector) (National Board (incl endorsements) State, Province and number)

#8716 3/3

FORM U-2A MANUFACTURER'S PARTIAL DATA REPORT (ALTERNATIVE FORM)
A Part of a Pressure Vessel Fabricated by One Manufacturer for Another Manufacturer
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by UNI FORM COMPONENTS CO. 10703 SHELDON ROAD HOUSTON TEXAS 77044
(Name and address of Manufacturer)

2. Manufactured for YUBA HEAT TRANSFER 2121 N 161ST EAST AVE. TULSA, OK 74116
(Name and address of Purchaser)

3. Location of installation UNKNOWN
(Name and address)

4. Type: TWO-PIECE HEADS S/N 6298-S/N 6299 N/A
(Description of vessel part (shell, two-piece head, tube bundle)) (Manufacturer's serial number) (CRN)
NO DRAWING BY UCC 2012
(National Board number) (Drawing number) (Drawing prepared by) (Year built)

5. ASME Code Section VIII Div 1 2010E/2011A N/A N/A
(Edition and Addenda (date)) (Code Case number) [Special Service per UG-120(d)]

6. Shell (a) No. of course (s): N/A (b) Overall Length: N/A

No.	Course(s)		Material		Thickness		Long. Joint (Cat. A)		Circum. Joint (Cat. A, B, & C)		Heat Treatment	
	Diameter	Length	Spec./Grade or Type		Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Temp. Time

7. Heads: (a) SA 516-70 (NORMALIZED 1650° @ 100 MIN.) (b) N/A
(Material spec. number, grade or type) (H.T. - time & temp) (Material spec. number, grade or type) (H.T. - time & temp)

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Down	Knuckle					Convex	Concave	Type	Full, Spot, None	Eff.
(a)	N/A	1.375				2:1						1	FULL	
(b)														

If removable, bolts used (describe other fastenings)
(Material spec. number, grade, size, number) Min. design metal temp. at

8. MAWP at max temp.
(Internal) (External) (Internal) (External)

9. Impact Test at test temperature of
Indicate yes or no and the component(s) impact tested

10. Hydro., pneu., or comb. test press. Proof Test

11. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc)	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	How Attached		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	

12. Identification of parts

Name of Part	Quantity	Line No.	Mfr's Identification No.	Mfr's Drawing no.	CRN	National Board No.	Year Built

13. Supports: Skirt Lugs Legs Others Attached
(Yes or No) (Number) (Number) (Describe) (Where and how)

14. Remarks 2 HEADS: 129" I.D. X 1.625" NOM.
UCC JOB NUMBER 100468
DESIGN BY OTHERS HYDRO BY OTHERS

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of material, construction and workmanship of this pressure vessel part conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1.

U Certificate of Authorization No. 18.206 Expires 11/03/2013


Date 2/13/12 Name UNI FORM COMPONENTS CO. Signed 
(Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of TEXAS and employed by ONE BEACON AMERICA INSURANCE of LYNN, MA.

have inspected the pressure vessel part described in this Manufacturer's Data Report on 2/13/12

and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel part in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel part described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2/13/12 Signed  Commissions NB9604A
(Authorized Inspector) [National Board (incl endorsements) State, Province and number]