



DOCUMENT PACKAGE

78" ID ACA After Reactor

Item No: R-2210

PO No: 4700984380

Serial No: 293-03

National Board: 2

Evonik Corporation

Mobile, Alabama Plant

ACA Project

CONTENTS

U-1A Data Report

Copy of Nameplate

QC Checklist

QC Documents

Drawings

Bill of Materials

Mill Test Reports

Carolina Integrated Solutions

157 Derrick Road

Spartanburg, South Carolina 29303

864-308-8281

National Board Number: 2
Mfg. Representative: Rm Date: 2-17-16
Authorized Inspector: NA Date: 2-17-16

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
(Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by Carolina Integrated Solutions, 157 Derrick Road, Spartanburg, South Carolina 29303, USA
(Name and address of Manufacturer)

2. Manufactured for Dominion Tank and Vessel, 1501 Valley Road, Richmond, VA 23222, USA
(Name and address of Purchaser)

3. Location of installation Evonik, 4201 Degussa Rd, Mobile County, AL 36582, USA
(Name and address)

4. Type Vertical 293-03 N/A 15515-03-1 R1 2 2015
(Horizontal or vertical, tank) (Manufacturer's serial number) (CRN) (Drawing number) (National Board number) (Year built)

5. ASME Code, Section VIII, Division 1 2013 Edition N/A Lethal Service
(Edition and Addenda, if applicable (date)) (Code Case numbers) (Special service per UG-120(d))

6. Shell SA-240 316L 0.3125" 0" 6'-6" 13'-9"
(Material spec. number, grade) (Nominal thickness) (Corr. allow.) (Inner diameter) (Length (overall))

Body Flanges on Shells												
No.	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Location	Bolting			
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

7. Seams Type 1 Full 100% N/A N/A Type 1 Full 100% 2
(Long. (welded, dbl., singl., lap, butt)) (R.T. (spot or full)) (Eff., %) (H.T. temp.) (Time, hr) (Girth (welded, dbl., singl., lap, butt)) (R.T. (Spot or Full)) (Eff., %) (No. of courses)

8. Heads: (a) Material SA-240 316L (b) Material SA-240 316L
(Spec. no., grade) (Spec. no., grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	TOP	0.4"	0"	78" IR	4.75" IR	N/A	N/A	N/A	N/A	Concave
(b)	BOTTOM	0.4"	0"	78" IR	4.75" IR	N/A	N/A	N/A	N/A	Concave

Body Flanges on Heads												
	Location	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Bolting			
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material
(a)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(b)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

9. MAWP 45 psi -14.7 psi at max. temp. 338.00 °F 338.00 °F
(Internal) (External) (Internal) (External)

Min. design metal temp. -20.00 °F at 45 psi. Hydro., pneu., or comb. test pressure Hydro. at 60 psi
Proof test N/A

10. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Type	Material		Nozzle Thickness		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
A2,S1	2	NPS 2	Cl. 150 WN	SA-312 TP316L	SA-182 F316L	0.154"	0"	N/A	UW-16.1(e)	APP 2-4(6)	Top Head
A4,A6,T1,V1	4	NPS 1.5	Cl. 150 WN	SA-312 TP316L	SA-182 F316L	0.145"	0"	N/A	UW-16.1(e)	APP 2-4(6)	Top Head/Shell
Sight Glass (G1)	1	6" ID	N/A	SA-182 F316L	N/A	2.5"	0"	N/A	UW-16.1(e)	N/A	Top Head
L2,R1	2	NPS 4	Cl. 150 WN	SA-312 TP316L	SA-182 F316L	0.237"	0"	N/A	UW-16.1(e)	APP 2-4(6)	Top Head
Level Switch - High (L4)	1	NPS 3	Cl. 150 WN	SA-312 TP316L	SA-182 F316L	0.216"	0"	N/A	UW-16.1(e)	APP 2-4(6)	Top Head
Manway w/Davit (M1)	1	23.25" ID	Cl. 150 WN	SA-240 316L	SA-182 F316L	0.375"	0"	SA-240 316L	UW-16.1(h)	APP 2-4(6)	Top Head

11. Supports: Skirt No Lugs 4 Legs N/A Other N/A Attached Shell -02 - Welded
(Yes or no) (Number) (Number) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: NONE
(Name of part, item number, Manufacturer's name and identifying stamp)

Shop test performed in the horizontal position.
Safety Relief by others.
See attached U-4 form.

National Board Number: 2
Mfg. Representative: Rm Date: 2-17-16
Authorized Inspector: JA Date: 2-17-16

Form U-1A (Back)

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. "U" Certificate of Authorization Number 51.098 expires July 1, 2018.

Date 2-17-16 Co. name Carolina Integrated Solutions Signed Billy McRobie
(Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by Carolina Integrated Solutions at 157 Derrick Road Spartanburg, South Carolina 29303
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by OneCIS Insurance Company

have inspected the component described in this Manufacturer's Data Report on 12-22-15, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-17-16 Signed [Signature] Commissions NB-14016A
(Authorized Inspector) [National Board (incl. endorsements)]

(04/14)

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by Carolina Integrated Solutions 157 Derrick Road Spartanburg, South Carolina 29303 USA
(Name and address of Manufacturer)

2. Manufactured for Dominion Tank and Vessel 1501 Valley Road Richmond, VA 23222 USA
(Name and address of Purchaser)

3. Location of installation Evonik 4201 Degussa Rd Mobile County, AL 36582 USA
(Name and address)

4. Type Vertical Reactor 293-03
(Horizontal, vertical, or sphere) (Tank, separator, heat exch., etc.) (Manufacturer's serial number)

N/A 15515-03-1 R1 2 2015
(CRN) (Drawing Number) (National Board number) (Year built)

Additional Nozzles:

Purpose (Inlet, Outlet, Drain, etc)	No.	Diameter or Size	Type	Material		Nozzle Thickness		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
Off Gas Vent (V2)	1	NPS 1	Cl. 150 WN	SA-312 TP316L	SA-182 F316L	0.133"	0"	N/A	UW-16.1(e)	APP 2-4(6)	Top Head
A7,S2	2	NPS 3	Cl. 150 WN	SA-312 TP316L	SA-182 F316L	0.216"	0"	SA-240 316L	UW-16.1(h)	APP 2-4(6)	Top Head,Shell
Liquid Outlet (B1)	1	NPS 4	Cl. 150 WN	SA-312 TP316L	SA-182 F316L	0.237"	0"	SA-240 316L	UW-16.1(h)	APP 2-4(6)	BTM Head

Certificate of Authorization: Type U No. 51.098 Expires July 1, 2018

Date 2-17-16 Name Carolina Integrated Solutions Signed Ruby mc Raluis
(Manufacturer) (Representative)

Date 2-17-16 Name [Signature] Commissions NB-14016A
(Authorized Inspector) (National Board (incl. endorsements))

CERTIFIED BY

18 2



CAROLINA
INTEGRATED SOLUTIONS

U-V-L
RT

SERIAL NO. 293-03 YR. BLT. 2015

SHELL

MAWP 45 psi @ 338 °F

MDMT -20 °F @ 45 psi

MAEWP -14.7 psi @ 338 °F

JACKET

MAWP [] psi @ [] °F

MDMT [] °F @ [] psi

TANK 3

MAINT	3.1 BARG	PSIG @	170 °C	°F
MDMT	-29 °C	°F @	3.1 BARG	PSIG
MAINT	-1.013 BARG	PSIG @	170 °C	°F
TKT MAINT		PSIG @		°F
TKT MDMT		°F @		PSIG
INSPECTOR				
PLANT - MOBILE ALABAMA				
WEIGHT	7600 LBS			
MATERIAL	SA-240 316 / 316L			
P.O. No.	4750984380			
EQUIP No.	R-2210			
PROC No.	4142-00940			

CUSTOMER: _____

Job# 293-03


DATE: 8/5/2015

DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210

DRAWING NO. 15515-03-1,2,3 REV. 01

QC MANAGER APPROVED: Rick McRobie

DATE: 08/05/15

AI REVIEWED: 

DATE: _____

DATE: 8-19-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
1	Verify WPS				
2	Review Calculations and Drawings				NA 8-19-15
3	Review Material Test Reports				
	GS=Girth Seam LS= Long Seam				
	Fit-Up Bottom Head to Shell Course 1 (GS 1)	1	11-17-15 RM		
	Weld Inside		12-1-15 RM	CI3	
	Pt Backgrind		PT GOOD 12-4-15 RM		NA 12-4-15
	Weld Outside			CI3	
	Fit-Up Shell Course 1 Long Seam (LS 1)	1	11-17-15 RM		
	Weld Inside		12-1-15 RM	CI3	
	PT Backgrind		PT GOOD 12-4-15 RM		NA 12-4-15
	Weld Outside			CI3	
	Fit-Up Shell Course 1 to Shell Course 2 (GS 2)	1	11-17-15 RM		
	Weld Inside		12-1-15 RM	CI3	
	PT Backgrind		PT GOOD 12-4-15 RM		NA 12-4-15
	Weld Outside			CI3	
	Fit-Up Shell Course 2 Long Seam (LS 2)	1	11-17-15 RM		
	Weld Inside		12-1-15 RM	CI3	
	PT Backgrind		PT GOOD 12-4-15 RM		NA 12-4-15

CUSTOMER: _____

Job# 293-03

DATE: 8/5/2015

DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210

DRAWING NO. 15515-03-1,2,3 REV. 01

QC MANAGER APPROVED: Rick McRobie

DATE: 08/05/15

DATE: _____

AI REVIEWED: NA

DATE: 8-19-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	Weld Outside				
	Fit-Up Shell Course 2 to Top Head (GS 3)	1	12-3-15 RM		
	Weld Inside		12-3-15 RM	CI3	
	PT Backgrind		PT GOOD 12-4-15 RM		NA 12-4-15
	Weld Outside			CI3	
	Schedule Of Openings				
	A1				
	W1	5	11-9-15 RM	CI12	
	W2	5	11-9-15 RM	CI12	
	W3	5	12-16-15 RM	CI16	
	Completed Nozzle		12-22-15 RM		
	A2				
	W1	5	10-22-15 RM	CI12	
	W2	5	10-30-15 RM	CI12	10-30-15 NA
	Completed Nozzle		12-22-15 RM		
	A3				
	W1	2	11-10-15 RM	CI12	
	W2	2	11-10-15 RM	CI12	
	W3	2	12-16-15 RM	CI16	

CUSTOMER: _____ Job# 293-03 DATE: 8/5/2015
 DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210 DRAWING NO. 15515-03-1,2,3 REV. 01
 QC MANAGER APPROVED: Rick McRobie DATE: 08/05/15
 _____ DATE: _____
 AI REVIEWED: N.A. DATE: 8-15-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	Completed Nozzle		12-22-15 Rm		
	A4				
	W1	2	10-22-15 Rm	CI12	
	W2	2	10-30-15 Rm	CI12	10-30-15 N.A.
	W3	2	11-17-15 Rm	CI12	
	W4	2	11-17-15 Rm	CI12	
	Completed Nozzle		12-22-15 Rm		
	A5 /				
	W1	3	11-9-15 Rm	CI2	
	W2	3	11-9-15 Rm	CI2	
	W3	3	12-16-15 Rm	CI16	
	Completed Nozzle		12-22-15 Rm		
	A6				
	W1	3	10-22-15 Rm	CI12	
	W2	3	10-30-15 Rm	CI12	10-30-15 N.A.
	W3	3	11-17-15 Rm	CI12	
	W4	3	11-17-15 Rm	CI12	
	Completed Nozzle		12-22-15 Rm		
	A7				
	W1	6	11-10-15 Rm	CI12	
	W2	6	12-14-15 Rm	CI16	

CUSTOMER: _____

Job# 293-03

DATE: 8/5/2015

DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210

DRAWING NO. 15515-03-1,2,3 REV. 01

QC MANAGER APPROVED: Rick McRobie

DATE: 08/05/15

DATE: _____

AI REVIEWED: N/A

DATE: 8-19-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	W3	6	12-14-15 Rm	CI16	
	W4	6	12-14-15 Rm	CI16	
	W5	6	11-10-15 Rm	CI12	
	W6	6	11-10-15 Rm	CI12	
	Completed Nozzle		12-22-15 Rm		
	B1				
	W1	7	10-26-15 Rm	CI12	
	W2	7	10-30-15 Rm	CI12	10-30-15 N/A
	W3	7	10-30-15 Rm	CI12	
	W4	7	10-30-15 Rm	CI12	
	W5	7	11-13-15 Rm	CI12	
	W6	7	11-13-15 Rm	CI12	
	W7	7	11-13-15 Rm	CI12	
	Completed Nozzle		12-22-15 Rm		
	G1				
	W1	8	11-18-15 Rm	CI1	
	W2	X			
	Completed Nozzle		12-22-15 Rm		
	L1				
	W1	4	11-10-15 Rm	CI1	
	W2	4	11-10-15 Rm	CI1	
	Completed Nozzle		12-22-15 Rm		

CUSTOMER: _____

Job# 293-03

DATE: 8/5/2015

DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210

DRAWING NO. 15515-03-1,2,3 REV. 01

QC MANAGER APPROVED: Rick McRobie

DATE: 08/05/15

DATE: _____

AI REVIEWED: N/A

DATE: 8-19-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	L2				
	W1	4	10-26-15 Rm	CI12	
	W2	4	10-30-15 Rm	CI12	10-30-15 N/A
	Completed Nozzle		12-22-15 Rm		
	L4				
	W1	9	10-26-15 Rm	CI12	
	W2	9	10-30-15 Rm	CI12	10-30-15 N/A
	Completed Nozzle		12-22-15 Rm		
	M1				
	W1	10A	10-27-15 Rm	CI12 R+H CI3 F+C	
	W2	10A	10-27-15 Rm	CI12 R+H CI3 F+C	
	W3	10A	10-30-15 Rm	CI12 R+C CI3 F+C	10-30-15 N/A
	W4	10A	10-30-15 Rm	CI3	
	W5	10A	10-30-15 Rm	CI3	
	W6	10B	12-18-15 Rm	CI16	
	W7	10B	12-18-15 Rm	CI16	
	W8	10B	12-18-15 Rm	CI16	
	W9	10B	12-22-15 Rm	CI3	
	W10	10B	12-22-15 Rm	CI3	
	W11	10B	12-22-15 Rm	CI3	
	Completed Manway		12-22-15 Rm		

CUSTOMER: _____ Job# 293-03 DATE: 8/5/2015
 DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210 DRAWING NO. 15515-03-1,2,3 REV. 01
 QC MANAGER APPROVED: Rick McRobie DATE: 08/05/15
 _____ DATE: _____
 AI REVIEWED: N.A. DATE: 8-19-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	R1				
	W1	11	10-26-15 Rm	CI12	
	W2	11	10-30-15 Rm	CI12	10-30-15 N.A.
	Completed Nozzle		12-22-15 Rm		
	S1 /				
	W1	12	10-26-15 Rm	CI12	
	W2	12	10-30-15 Rm	CI12	10-30-15 N.A.
	Completed Nozzle		12-22-15 Rm		
	S2				
	W1	13	10-26-15 Rm	CI12	
	W2	13	10-30-15 Rm	CI12	10-30-15 N.A.
	W3	13	10-30-15 Rm	CI12	
	W4	13	10-30-15 Rm	CI12	
	Completed Nozzle		12-22-15 Rm		
	T1				
	W1	14	11-13-15 Rm	CI1	
	W2	14	12-14-15 Rm	CI16	
	W3	14	12-14-15 Rm	CI16	
	W4	14	12-14-15 Rm	CI16	
	Completed Nozzle		12-22-15 Rm		
	V1				

CUSTOMER: _____

Job# 293-03

DATE: 8/5/2015

DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210

DRAWING NO. 15515-03-1,2,3 REV. 01

QC MANAGER APPROVED: Rick McRobie

DATE: 08/05/15

DATE: _____

AI REVIEWED: J.A.

DATE: 8-19-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	W1	15	10-26-15 Rm	CI12	
	W2	15	10-30-15 Rm	CI12	10-30-15 N.A
	W3	15	11-17-15 Rm	CI12	
	W4	15	11-17-15 Rm	CI12	
	Completed Nozzle		12-22-15 Rm		
	V2				
	W1	16	10-26-15 Rm	CI12	
	W2	16	10-30-15 Rm	CI12	10-30-15 N.A
	W3	16	11-17-15 Rm	CI12	
	W4	16	11-17-15 Rm	CI12	
	Completed Nozzle		12-22-15 Rm		
	Attachments				
	Lifting Lug A				
	W1	17	12-18-15 Rm	CI3	
	W2	17	12-18-15 Rm	CI3	
	W3	17	12-18-15 Rm	CI3	
	W4	17	12-18-15 Rm	CI3	
	Completed Weld		12-22-15 Rm		
	Lifting Lug B				
	W1	17	12-18-15 Rm	CI3	
	W2	17	12-18-15 Rm	CI3	

CUSTOMER: _____

Job# 293-03

DATE: 8/5/2015

DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210

DRAWING NO. 15515-03-1,2,3 REV. 01

QC MANAGER APPROVED: Rick McRobie

DATE: 08/05/15

DATE: _____

AI REVIEWED: N.A

DATE: 8-15-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	W3	17	12-18-15 Rm	CI3	
	W4	17	12-18-15 Rm	CI3	
	Completed Weld		12-22-15 Rm		
	Trailing Lug				
	W1	18	12-18-15 Rm	CI3	
	W2	18	12-18-15 Rm	CI3	
	Completed Weld		12-22-15 Rm		
	Dip Pipe Support Bracket A3				
	W1	19	12-16-15 Rm	CI16	
	W2	19	12-16-15 Rm	CI16	
	W3	19	12-16-15 Rm	CI16	
	W4	19	12-16-15 Rm	CI16	
	Completed Weld		12-22-15 Rm		
	Dip Pipe Support Bracket A5				
	W1	19	12-16-15 Rm	CI16	
	W2	19	12-16-15 Rm	CI16	
	W3	19	12-16-15 Rm	CI16	
	W4	19	12-16-15 Rm	CI16	
	Completed Weld		12-22-15 Rm		
	Dip Pipe Support Bracket A1				

CUSTOMER: _____

Job# 293-03

DATE: 8/5/2015

DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210

DRAWING NO. 15515-03-1,2,3 REV. 01

QC MANAGER APPROVED: Rick McRobie

DATE: 08/05/15

DATE: _____

AI REVIEWED: NA

DATE: 8-19-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	W1	19	12-16-15 Rm	CI16	
	W2	19	12-16-15 Rm	CI16	
	W3	19	12-16-15 Rm	CI16	
	W4	19	12-16-15 Rm	CI16	
	Completed Weld		12-22-15 Rm		
	Dip Pipe Support Bracket L1				
	W1	19	12-16-15 Rm	CI16	
	W2	19	12-16-15 Rm	CI16	
	W3	19	12-16-15 Rm	CI16	
	W4	19	12-16-15 Rm	CI16	
	Completed Weld		12-22-15 Rm		
	Support Lug A				
	W1	20	12-18-15 Rm	CI3	
	W2	20	11-30-15 Rm	CIS	
	W3	20	11-30-15 Rm	CIS	
	W4	20	11-30-15 Rm	CIS	
	W5	20	12-18-15 Rm	CI12	
	W6	20	11-30-15 Rm	CIS	
	Completed Weld		12-22-15 Rm		
	Support Lug B				
	W1	20	12-18-15 Rm	CI3	

CUSTOMER: _____

Job# 293-03

DATE: 8/5/2015

DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210

DRAWING NO. 15515-03-1,2,3 REV. 01

QC MANAGER APPROVED: Rick McRobie

DATE: 08/05/15

DATE: _____

AI REVIEWED: N.A

DATE: 8-19-15

OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	W2	20	11-30-15 Rm	CI5	
	W3	20	11-30-15 Rm	CI5	
	W4	20	11-30-15 Rm	CI5	
	W5	20	12-18-15 Rm	CI12	
	Completed Weld		12-22-15 Rm		
	Support Lug C				
	W1	20	12-18-15 Rm	CI3	
	W2	20	11-30-15 Rm	CI5	
	W3	20	11-30-15 Rm	CI5	
	W4	20	11-30-15 Rm	CI5	
	W5	20	12-18-15 Rm	CI12	
	W6	20	11-30-15 Rm	CI5	
	Completed Weld		12-22-15 Rm		
	Support Lug D				
	W1	20	12-18-15 Rm	CI3	
	W2	20	11-30-15 Rm	CI5	
	W3	20	11-30-15 Rm	CI5	
	W4	20	11-30-15 Rm	CI5	
	W5	20	12-18-15 Rm	CI12	
	Completed Weld		12-22-15 Rm		
	Top Ring W1				

CUSTOMER: _____ **Job#** 293-03 **DATE:** 8/5/2015
DESCRIPTION: 78" ID ACA AFTER REACTOR R-2210 **DRAWING NO.** 15515-03-1,2,3 REV. 01
QC MANAGER APPROVED: Rick McRobie **DATE:** 08/05/15
AI REVIEWED: NA **DATE:** 8-15-15



OPERATION NUMBERS	DESCRIPTION ITEMS BELOW HAVE TO FOLLOW IN NUMERICAL ORDER GIVEN. A = ACTUAL R = REVIEW W = WITNESS H = HOLD	DATE AND SIGNATURE			
		Weld Map	CIS INSPECTOR	Welder I.D.	AUTHORIZED INSPECTOR
	0-90	21	12-18-15 Rm	CI3	
	90-180	21	12-18-15 Rm	CI3	
	180-270	21	12-18-15 Rm	CI3	
	270-0	21	12-18-15 Rm	CI3	
	Completed Weld		12-22-15 Rm		
	Shell Clips 1-8				
	W1	22	12-18-15 Rm	CI16	
	Completed Weld		12-22-15 Rm		
	Head Clips 1-4				
	W1	22	11-13-15 Rm	CI2	
	Completed Weld		12-22-15 Rm		
	Stiffener Ring W1				
	0-90	1	12-18-15 Rm	CI3	
	90-180	1	12-18-15 Rm	CI3	
	180-270	1	12-18-15 Rm	CI3	
	270-0	1	12-18-15 Rm	CI3	
	FINAL INTERNAL INSPECTION		12-22-15 Rm		12-22-15 H
	FINAL EXTERNAL INSPECTION		12-22-15 Rm		12-22-15 H
	REVIEW RT FILM		12-28-15 Rm		NA 12-28-15 H
	REVIEW NAMEPLATE / ATTACHMENT		12-28-15 Rm		NA 12-28-15 H
	HYDRO AT 60 PSIG		H4020 C100 0 12-22-15 Rm		NA 12-22-15 H


CERTIFICATION OF DYE-PENETRANT TEST INSPECTION

IAF JOB NO 293-03 CUSTOMER Evonik
 CUSTOMER REFERENCE PO. _____ LAF DRAWING NO. _____
 PROCEDURE NO. 124, REV. 3 METHOD: VISIBLE
 ACCEPTANCE CRITERIA: SECTION V, ARTICLE 6 & SECTION VIII, DIV. 1, APPENDIX 8
 MATERIALS: MAGNAFLUX SPOTCHEK SKL-SPI BATCH # 15G01K
MAGNAFLUX SPOTCHECK SKC-S BATCH # 15F15K
MAGNAFLUX SPOTCHECK SKD-S2 BATCH # 15F11K
 LIGHTING: MINIMUM 100 fc

TYPE AND LOCATION OF WELD							
ROOT	BACKCHIP	COVER	FILLET	MATL	THKNSS	ACCEPT REJECT	WELD LOCATION
X			X	316 ss	Sch 40	ACC	A6 1-1/2" W2
X			X	316 ss	Sch 40	ACC	V1 1-1/2" W2
X			X	316 ss	Sch 40	ACC	S1 2" W2
X			X	316 ss	Sch 40	ACC	R1 4" W2
X			X	316 ss	Sch 40	ACC	A2 2" W2
X			X	316 ss	Sch 40	ACC	L2 4" W2
X			X	316 ss	Sch 40	ACC	A4 1-1/2" W2
X			X	316 ss	Sch 40	ACC	V2 1" W2
X			X	316 ss	Sch 40	ACC	L4 3" W2
X			X	316 ss	Sch 40	ACC	S2 3" W2
X			X	316 ss	3/8" PL	ACC	M1 24" W3

I HAVE WITNESSED THIS TEST AND CERTIFY THAT THE WELDS ARE FREE OF ANY SURFACE DEFECTS

 INSPECTOR
 QUALIFICATION LEVEL

 QUALITY CONTROL MANAGER
 _____ CUSTOMER REPRESENTATIVE

DATE 11-10-15 _____ DATE _____



CERTIFICATION OF DYE-PENETRANT TEST INSPECTION

IAF JOB NO 293-03 CUSTOMER Evonik
 CUSTOMER REFERENCE PO. _____ IAF DRAWING NO. _____
 PROCEDURE NO. 124, REV. 3 METHOD: VISIBLE
 ACCEPTANCE CRITERIA: SECTION V, ARTICLE 6 & SECTION VIII, DIV. 1, APPENDIX 8
 MATERIALS: MAGNAFLUX SPOTCHEK SKL-SPI BATCH # 15G01K
MAGNAFLUX SPOTCHECK SKC-S BATCH # 15F15K
MAGNAFLUX SPOTCHECK SKD-S2 BATCH # 15F11K
 LIGHTING: MINIMUM 100 fc

TYPE AND LOCATION OF WELD							
ROOT	BACKCHIP	COVER	FILLET	MATL	THKNESS	ACCEPT REJECT	WELD LOCATION
X			X	316 ss	Sch 40	ACC	B1 4" W2
			X	316 ss	5/16 PL	ACC	B1 4" W3
			X	316 ss	5/16 PL	ACC	B1 4" W4
			X	316 ss	3/16 PL	ACC	B1 4" W5
			X	316 ss	3/16 PL	ACC	B1 4" W6
			X	316 ss	3/16 PL	ACC	B1 4" W7

I HAVE WITNESSED THIS TEST AND CERTIFY THAT THE WELDS ARE FREE OF ANY SURFACE DEFECTS

Ricky McRobie INSPECTOR Level II QUALIFICATION LEVEL

Ricky McRobie QUALITY CONTROL MANAGER _____ CUSTOMER REPRESENTATIVE

DATE 11-10-15 _____ DATE _____

CERTIFICATION OF DYE-PENETRANT TEST INSPECTION

IAF JOB NO 293-03 CUSTOMER Evonik
 CUSTOMER REFERENCE PO. _____ IAF DRAWING NO. _____
 PROCEDURE NO. 124, REV. 3 METHOD: VISIBLE
 ACCEPTANCE CRITERIA: SECTION V, ARTICLE 6 & SECTION VIII, DIV. 1, APPENDIX 8
 MATERIALS: MAGNAFLUX SPOTCHEK SKL-SPI BATCH # 15G01K
MAGNAFLUX SPOTCHECK SKC-S BATCH # 15F15K
MAGNAFLUX SPOTCHECK SKD-S2 BATCH # 15F11K
 LIGHTING: MINIMUM 100 fc

TYPE AND LOCATION OF WELD

ROOT	BACKCHIP	COVER	FILLET	MTRL	THKNESS	ACCEPT REJECT	WELD LOCATION
	X			316 ss	5/16 ss	ACC	GS1
	X			316 ss	5/16 ss	ACC	LS1
	X			316 ss	5/16 ss	ACC	GS2
	X			316 ss	5/16 ss	ACC	LS2
	X			316 ss	5/16 ss	ACC	GS3

I HAVE WITNESSED THIS TEST AND CERTIFY THAT THE WELDS ARE FREE OF ANY SURFACE DEFECTS

Rick McPolnie
INSPECTOR

Kevin H
QUALIFICATION LEVEL

Rick McPolnie
QUALITY CONTROL MANAGER

CUSTOMER REPRESENTATIVE

DATE 12-7-15

DATE _____

CERTIFICATION OF DYE-PENETRANT TEST INSPECTION

IAF JOB NO 293-03 CUSTOMER Evonik
 CUSTOMER REFERENCE PO. _____ IAF DRAWING NO. _____
 PROCEDURE NO. 124, REV. 3 METHOD: VISIBLE
 ACCEPTANCE CRITERIA: SECTION V, ARTICLE 6 & SECTION VIII, DIV. 1, APPENDIX 8
 MATERIALS: MAGNAFLUX SPOTCHEK SKL-SPI BATCH # 15G01K
MAGNAFLUX SPOTCHECK SKC-S BATCH # 15F15K
MAGNAFLUX SPOTCHECK SKD-S2 BATCH # 15F11K
 LIGHTING: MINIMUM 100 fc

TYPE AND LOCATION OF WELD							
ROOT	BACKCHIP	COVER	FILLET	MATL	THKNESS	ACCEPT REJECT	WELD LOCATION
			X	316 ss	sch 40	ACC	A1 1-1/2" W2,3
			X	316 ss	sch 40	ACC	A3 1" W2,3
			X	316 ss	sch 40	ACC	A5 1" W2,3
X			X	316 ss	sch 40	ACC	A7 3" W2,3,4
X			X	316 ss	sch 40	ACC	B1 4" W5,6,7
			X	316 ss	3/8 ss	ACC	M1w6,7,8,9,10,11
X			X	316 ss	sch 40	ACC	T1 1-1/2" W2,3,4
			X	316 ss	5/8 ss	ACC	Lug A W1,2,3,4
			X	316 ss	5/8 ss	ACC	Lug B W1,2,3,4
			X	316 ss	5/8 ss	ACC	T Lug W1,2
			X	316 ss	1/4 ss	ACC	dpsb A3 w1,2,3,4

I HAVE WITNESSED THIS TEST AND CERTIFY THAT THE WELDS ARE FREE
 OF ANY SURFACE DEFECTS

Ricky Mc Rolui
 INSPECTOR

Level II
 QUALIFICATION LEVEL

Ricky Mc Rolui
 QUALITY CONTROL MANAGER

 CUSTOMER REPRESENTATIVE

DATE 12-18-15

DATE _____

CERTIFICATION OF DYE-PENETRANT TEST INSPECTION

IAF JOB NO 293-03 CUSTOMER Evonik
 CUSTOMER REFERENCE PO. _____ IAF DRAWING NO. _____
 PROCEDURE NO. 124, REV. 3 METHOD: VISIBLE
 ACCEPTANCE CRITERIA: SECTION V, ARTICLE 6 & SECTION VIII, DIV. 1, APPENDIX 8
 MATERIALS: MAGNAFLUX SPOTCHEK SKL-SPI BATCH # 15G01K
MAGNAFLUX SPOTCHECK SKC-S BATCH # 15F15K
MAGNAFLUX SPOTCHECK SKD-S2 BATCH # 15F11K
 LIGHTING: MINIMUM 100 fc

TYPE AND LOCATION OF WELD							
ROOT	BACKCHIP	COVER	FILLET	MATL	THKNESS	ACCEPT REJECT	WELD LOCATION
			X	316 ss	1/4 ss	ACC	dpsb A5 w1,2,3,4
			X	316 ss	1/4 ss	ACC	dpsb A1 w1,2,3,4
			X	316 ss	1/4 ss	ACC	dpsb L1 w1,2,3,4
			X	316 ss	1/2 ss	ACC	SLA w1,2,3,4,5,6
			X	316 ss	1/2 ss	ACC	SLB w1,2,3,4,5
			X	316 ss	1/2 ss	ACC	SLC w1,2,3,4,5,6
			X	316 ss	1/2 ss	ACC	SLD w1,2,3,4,5
			X	316 ss	3/16 ss	ACC	Tring W1 0-360
			X	316 ss	3/16 ss	ACC	SClips 1-8 W1
			X	316 ss	3/16 ss	ACC	HClips 1-4 W1
			X	316 ss	3/8 ss	ACC	Sring W1 0-360

I HAVE WITNESSED THIS TEST AND CERTIFY THAT THE WELDS ARE FREE
 OF ANY SURFACE DEFECTS

Ruby McRae INSPECTOR *Level II* QUALIFICATION LEVEL
Ruby McRae QUALITY CONTROL MANAGER _____ CUSTOMER REPRESENTATIVE
 DATE 12-18-15 DATE _____



157 Derrick Road - Spartanburg, SC 29303 - 864-308-8281

HYDROSTATIC/PRESSURE TEST DATA

SOP 1.9

FORM 101 HDQC

PAGE 1 of 1

CONTRACT NO. 293	DIV. 3	PURCHASER EVONIK	LOCATION SPARTANBU RG	TYPE VESSEL PRESSURE LS
TYPE TEST WATER	TEST CONDUCTED BY RICKY MCROBIE		LEVEL CERT. 2	
DESIGN PRESSURE 45 PSIG	DESIGN VACUUM _____	TIME PERIOD TEST WAS HELD		
TEST PRESSURE 60 PSIG	TEST VACUUM _____	1 HRS ___ MINUTES		
HEIGHT OF WATER LEVEL FULL		TYPE OF LEAK CHECKING PERFORMED VISUAL		
GAUGE NO. CIS-1	GAUGE CALIBRATION DATE 12/22/2015	GAUGE MANUFACTURER dynamic fluid comp	GAUGE RANGE 0-300	
EXAMINATION TIME AM	MATERIAL TYPE 316L	TEMPERATURE SELECT GRADE	TEMPERATURE GAUGE NO.	
DESCRIBE ANY REPAIRS MADE NONE _____				
COMMENTS _____				
<p>AS A DULY AUTHORIZED REPRESENTATIVE OF <u>CAROLINA INTEGRATED SOLUTIONS</u> , I HEREBY CERTIFY THAT THE ABOVE TANK AND/OR VESSEL HAS BEEN TESTED IN ACCORDANCE WITH CIS PROCEDURE <u>1.9</u> , AND APPLICABLE CODE REQUIREMENTS. THIS CERTIFICATION DOES NOT RELIEVE CIS OF ANY WARRANTIES EXPRESSED IN THE CONTRACT.</p>				
CIS REPRESENTATIVE <i>Ricky McRobie</i>	DATE 12/22/2015	DISPOSITION ACCEPTED		
CUSTOMER REPRESENTATIVE <i>Larry Teal</i>	DATE 12/22/2015	DISPOSITION ACCEPTED		
AUTHORIZED INSPECTOR <i>[Signature]</i>	DATE 12/22/2015	DISPOSITION ACCEPTED		



157 Derrick Road - Spartanburg, SC 29303 - 864-308-8281

VISUAL INSPECTION REPORT

PAGE 1 of

REPORT NO. 1	CONTRACT 293	DIV. 3	REFERENCE 15515-03-1	DRAWING REV. 1	PIECE MARK NO. 293-03
MAT'L TYPE 316L	MAT'L THICKNESS 5/16", SCH40	PROCEDURE NO. S.O.P. 2.1	EQUIPMENT FOR WHITE LIGHT FLASH LIGHT (LED)		
SURFACE CONDITION AS WELDED		JOINT TYPE BUTT	STAGE OF MFG. FINAL		
EXAMINATION TIME AM		DURATION EXAMINATION TIME 1 HRS. MINUTES			
DESCRIPTION/IDENTIFICATION		STATUS (ACCEPTED\REJECTED)	INSPECTED BY		
GS1		ACCEPTED	RM		
LS1		ACCEPTED	RM		
GS2		ACCEPTED	RM		
LS2		ACCEPTED	RM		
GS3		ACCEPTED	RM		
NOZZLE A1		ACCEPTED	RM		
NOZZLE A2		ACCEPTED	RM		
NOZZLE A3		ACCEPTED	RM		
NOZZLE A4		ACCEPTED	RM		
NOZZLE A5		ACCEPTED	RM		
REFERENCE SKETCH (or PHOTOGRAPH) - <u>IF REQUIRED</u>					
CERTIFIED BY RICK MCROBIE		DATE 12/22/2015	CERT. LEVEL 2	DISPOSITION ACCEPTED	
CUSTOMER REP. LARRY TEAL		DATE 12/22/2015	CODE INSPECTOR REVIEW NICK AMADOR	DATE 12/22/2015	



157 Derrick Road - Spartanburg, SC 29303 - 864-308-8281

VISUAL INSPECTION REPORT

PAGE 2 of

REPORT NO. 2	CONTRACT 293	DIV. 3	REFERENCE 15515-03-1	DRAWING REV. 1	PIECE MARK NO. 293-03
MAT'L TYPE 316L	MAT'L THICKNESS 5/16", SCH40	PROCEDURE NO. S.O.P. 2.1	EQUIPMENT FOR WHITE LIGHT FLASH LIGHT (LED)		
SURFACE CONDITION AS WELDED		JOINT TYPE BUTT	STAGE OF MFG. FINAL		
EXAMINATION TIME AM		DURATION EXAMINATION TIME 1 HRS. MINUTES			
DESCRIPTION/IDENTIFICATION		STATUS (ACCEPTED\REJECTED)	INSPECTED BY		
NOZZLE A6		ACCEPTED	RM		
NOZZLE A7		ACCEPTED	RM		
NOZZLE B1		ACCEPTED	RM		
NOZZLE G1		ACCEPTED	RM		
NOZZLE L1		ACCEPTED	RM		
NOZZLE L2		ACCEPTED	RM		
NOZZLE L4		ACCEPTED	RM		
NOZZLE M1		ACCEPTED	RM		
NOZZLE R1		ACCEPTED	RM		
NOZZLE S1		ACCEPTED	RM		
REFERENCE SKETCH (or PHOTOGRAPH) - <u>IF REQUIRED</u>					
CERTIFIED BY RICK MCROBIE		DATE 12/22/2015	CERT. LEVEL 2	DISPOSITION ACCEPTED	
CUSTOMER REP. LARRY TEAL		DATE 12/22/2015	CODE INSPECTOR REVIEW NICK AMADOR	DATE 12/22/2015	



157 Derrick Road - Spartanburg, SC 29303 - 864-308-8281

VISUAL INSPECTION REPORT

PAGE 3 of

REPORT NO. 3	CONTRACT 293	DIV. 3	REFERENCE 15515-03-1	DRAWING REV. 1	PIECE MARK NO. 293-03
MAT'L TYPE 316L	MAT'L THICKNESS 5/16", SCH40	PROCEDURE NO. S.O.P. 2.1	EQUIPMENT FOR WHITE LIGHT FLASH LIGHT (LED)		
SURFACE CONDITION AS WELDED		JOINT TYPE BUTT	STAGE OF MFG. FINAL		
EXAMINATION TIME AM		DURATION EXAMINATION TIME 1 HRS. MINUTES			
DESCRIPTION/IDENTIFICATION		STATUS (ACCEPTED\REJECTED)	INSPECTED BY		
NOZZLE S2		ACCEPTED	RM		
NOZZLE T1		ACCEPTED	RM		
NOZZLE V1		ACCEPTED	RM		
NOZZLE V2		ACCEPTED	RM		
LIFTING LUG A		ACCEPTED	RM		
LIFTING LUG B		ACCEPTED	RM		
TAILING LUG		ACCEPTED	RM		
DIP PIPE SUPPORT BRACKET A3		ACCEPTED	RM		
DIP PIPE SUPPORT BRACKET A5		ACCEPTED	RM		
DIP PIPE SUPPORT BRACKET A1		ACCEPTED	RM		
REFERENCE SKETCH (or PHOTOGRAPH) - <u>IF REQUIRED</u>					
CERTIFIED BY RICK MCROBIE		DATE 12/22/2015	CERT. LEVEL 2	DISPOSITION ACCEPTED	
CUSTOMER REP. LARRY TEAL		DATE 12/22/2015	CODE INSPECTOR REVIEW NICK AMADOR	DATE 12/22/2015	



157 Derrick Road - Spartanburg, SC 29303 - 864-308-8281

VISUAL INSPECTION REPORT

PAGE 4 of

REPORT NO. 4	CONTRACT 293	DIV. 3	REFERENCE 15515-03-1	DRAWING REV. 1	PIECE MARK NO. 293-03
MAT'L TYPE 316L	MAT'L THICKNESS 5/16", SCH40	PROCEDURE NO. S.O.P. 2.1	EQUIPMENT FOR WHITE LIGHT FLASH LIGHT (LED)		
SURFACE CONDITION AS WELDED		JOINT TYPE BUTT	STAGE OF MFG. FINAL		
EXAMINATION TIME AM		DURATION EXAMINATION TIME 1 HRS. MINUTES			
DESCRIPTION/IDENTIFICATION		STATUS (ACCEPTED\REJECTED)	INSPECTED BY		
DIP PIPE SUPPORT BRACKET L1		ACCEPTED	RM		
SUPPORT LUG A		ACCEPTED	RM		
SUPPORT LUG B		ACCEPTED	RM		
SUPPORT LUG C		ACCEPTED	RM		
SUPPORT LUG D		ACCEPTED	RM		
TOP RING		ACCEPTED	RM		
SHELL CLIPS		ACCEPTED	RM		
HEAD CLIPS		ACCEPTED	RM		
STIFFENER RING		ACCEPTED	RM		
		SELECT OPTION			
REFERENCE SKETCH (or PHOTOGRAPH) - <u>IF REQUIRED</u>					
CERTIFIED BY RICK MCROBIE		DATE 12/22/2015	CERT. LEVEL 2	DISPOSITION ACCEPTED	
CUSTOMER REP. LARRY TEAL		DATE 12/22/2015	CODE INSPECTOR REVIEW NICK AMADOR	DATE 12/22/2015	



RADIOGRAPHIC INSPECTION REPORT

Job # P243513 PO # 293-2782 WO # N/A Date: 10/29/2015 Page 1 of 1


CLIENT: CAROLINA INTERGRATED SOLUTIONS
LOCATION: 100 B Southwest Dr. Spartanburg, South Carolina 29303

PART NO.: TANK 293-03
PART NAME: TANK #3 MANWAY
MATERIAL: STAINLESS STEEL
THICKNESS: .437"
TYPE WELD: Butt

RADIOGRAPHIC INSPECTION TECHNIQUE

Table with 2 columns: Specification(s) and parameters. Includes details like Isotope (Ir192), Film Size (4.5" X 17"), Film Type (Fuji 50), Sensitivity (#7 WIRE .013"), Penetrameter (1 ASTM B), and various exposure and processing parameters.

SETUP



INTERPRETATION

Table for defect interpretation with columns for Part I.D./Film View, various defect types (Crack, Slag Inclusion, etc.), and Density. Includes rows for Horizontal Seam and Vertical Seam.

RADIOGRAPHER(S): Brett Powell Level II R.T.
INTERPRETER: Brett Powell Level II R.T.
CLIENT APPROVAL: Lab work

This report may not be reproduced except in full without the written approval of ATS. If the method used is a customer provided, non-standard test method, ATS does not assume responsibility for validation of the method.



APPLIED TECHNICAL SERVICES, INCORPORATED

Q1214 Pelham Davis Circle, Greenville, South Carolina 29615 • (864) 675-6060 Fax (864) 675-6040 • www.atslab.com

RADIOGRAPHIC INSPECTION REPORT

Job # P245625 PO # 293-2828 WO # N/A Date: 12/12/2015 Page 1 of 1


CLIENT: **CAROLINA INTERGRATED SOLUTIONS**
 LOCATION: **157 DERRICK RD**
SPARTANBURG, SC. 29303

PART NO.: **TANK 293-03**
 PART NAME: **SEE BELOW**
 MATERIAL: **STAINLESS STEEL**
 THICKNESS: **.312" ROLLED STEEL**
 TYPE WELD: **SAW**

RADIOGRAPHIC INSPECTION TECHNIQUE

Specification(s)	ATS 120.1 REV 25	IAW	ASME SECTION VIII	
Isotope	IR 192	D1240	Film Size	4.5" X 17"
Curies	94		Film Type	Fuji 80
KV	N/A		Sensitivity	#6 WIRE .0100"
MA	N/A		Penetrameter	1 ASTM B
Time	320 SECONDS		Shim(s)	N/A
SFD	39.1 INCHES		Develop: Temp:	70° F
SOD	39 INCHES		Time:	4.5 MIN
OFD	.312 INCHES		Screen(s)	.002 PB F&B
Source Size (Physical)	.1"x.1"		Source Size (Effective)	.143
Geometric Unsharpness	.001"		Films Per Cassette	1
			Weld Reinforcement	.090"

SETUP



INTERPRETATION

PART I.D./ FILM VIEW	Accept	Reject	Crack	Slag Inclusion	Tungsten Inclusion	Porosity	Undercut	Incomplete Fusion	Incomplete	Root Concavity	Root Convexity	DENSITY		REMARKS
												Penetrameter	Area of Interest	
WGS1												3.2	3.2	WELDER ID C13
0 TO 1	✓											3.2	3.2	
1 TO 2	✓											3.2	3.2	
2 TO 3	✓											3.3	3.3	
3 TO 4	✓						/					3.3	3.3	
4 TO 5	✓						/					3.3	3.3	
5 TO 6	✓											3.3	3.3	
6 TO 7	✓			/								3.2	3.2	
7 TO 8	✓											3.2	3.2	
8 TO 9	✓											3.3	3.3	
9 TO 10	✓											3.3	3.3	
10 TO 11	✓											3.3	3.3	
11 TO 12	✓											3.3	3.3	
12 TO 13	✓											3.3	3.3	
13 TO 14	✓											3.3	3.3	
14 TO 15	✓											3.3	3.3	
15 TO 16	✓											3.3	3.3	CRIMP
16 TO 17	✓											3.8	3.8	
17 TO 18	✓						/					3.5	3.5	
18 TO 19	✓						/					3.6	3.6	
19 TO 20	✓											3.3	3.3	
20 TO 0	✓											3.3	3.3	

RADIOGRAPHER(S): Jerry L Dillard Jerry L Dillard Level II R.T.
 INTERPRETER: Jerry L Dillard Jerry L Dillard Level II R.T.
 CLIENT APPROVAL: Ruby McRae

This report may not be reproduced except in full without the written approval of ATS. If the method used is a customer provided, non-standard test method, ATS does not assume responsibility for validation of the method.



APPLIED TECHNICAL SERVICES, INCORPORATED

214 Pelham Davis Circle, Greenville, South Carolina 29615 • (864) 675-6060 Fax (864) 675-6040 • www.atslab.com


RADIOGRAPHIC INSPECTION REPORT

Job # P245625 PO # 293-2828 WO # N/A Date: 12/12/2015 Page 1 of 1

CLIENT: CAROLINA INTERGRATED SOLUTIONS
LOCATION: 157 DERRICK RD
SPARTANBURG, SC. 29303

PART NO.: TANK 293-03
PART NAME: SEE BELOW
MATERIAL: STAINLESS STEEL
THICKNESS: .312" ROLLED STEEL
TYPE WELD: SAW

RADIOGRAPHIC INSPECTION TECHNIQUE			
Specification(s)	ATS 120.1 REV 25	IAW	ASME SECTION VIII
Isotope	IR 192	D1240	Film Size 4.5" X 17"
Curies	94		Film Type Fuji 80
KV	N/A		Sensitivity #6 WIRE .0100"
MA	N/A		Penetrameter 1 ASTM B
Time	320	SECONDS	Shim(s) N/A
SFD	39.1	INCHES	Develop: Temp: 70° F Time: 4.5 MIN
SOD	39	INCHES	Screen(s) .002 PB F&B
OFD	.312	INCHES	Source Size (Effective) .143
Source Size (Physical)	.1"x.1"		Films Per Cassette 1
Geometric Unsharpness	.001"		Weld Reinforcement .090"



PART I.D./ FILM VIEW	Accept	Reject	Crack	Slag Inclusion	Tungsten Inclusion	Porosity	Undercut	Incomplete Fusion	Incomplete	Root Concavity	Root Convexity	DENSITY		REMARKS
												Penetrameter	Area of Interest	
W GS2														WELDER ID C13
0 TO 1	✓											2.7	2.7	
1 TO 2	✓											2.8	2.8	CRIMP
2 TO 3	✓											2.6	2.6	
3 TO 4	✓											2.8	2.8	
4 TO 5	✓			/	/							2.7	2.7	
5 TO 6	✓											2.8	2.8	EDGE OF CAP
6 TO 7	✓			/	/							2.7	2.7	ROOT EDGE
7 TO 8	✓											2.8	2.8	
8 TO 9	✓											2.6	2.6	
9 TO 10	✓											2.8	2.8	
10 TO 11	✓											2.7	2.7	
11 TO 12	✓											3.0	3.0	
12 TO 13	✓											3.1	3.1	
13 TO 14	✓											3.0	3.0	
14 TO 15	✓					/						3.2	3.2	
15 TO 16	✓					/						3.2	3.2	
16 TO 17	✓					/						3.0	3.0	
17 TO 18	✓											3.3	3.3	
18 TO 19	✓											3.2	3.2	
19 TO 20	✓											3.1	3.1	
20 TO 0	✓											3.3	3.3	

RADIOGRAPHER(S): Jerry L Dillard Jerry L Dillard Level II R.T.
 INTERPRETER: Jerry L Dillard Jerry L Dillard Level II R.T.
 CLIENT APPROVAL: Bruce M. Robert

This report may not be reproduced except in full without the written approval of ATS. If the method used is a customer provided, non-standard test method, ATS does not assume responsibility for validation of the method.



APPLIED TECHNICAL SERVICES, INCORPORATED

214 Pelham Davis Circle, Greenville, South Carolina 29615 • (864) 675-6060 Fax (864) 675-6040 • www.atslab.com

RADIOGRAPHIC INSPECTION REPORT

Job # P245625 PO # 293-2828 WO # N/A Date: 12/12/2015 Page 1 of 1


CLIENT: **CAROLINA INTERGRATED SOLUTIONS**
 LOCATION: **157 DERRICK RD**
SPARTANBURG, SC. 29303

PART NO.: TANK 293-03
 PART NAME: SEE BELOW
 MATERIAL: STAINLESS STEEL
 THICKNESS: .312" ROLLED STEEL
 TYPE WELD: SAW

RADIOGRAPHIC INSPECTION TECHNIQUE

Specification(s)	ATS 120.1 REV 25	IAW	ASME SECTION VIII			
Isotope	IR 192	D1240	Film Size	4.5" X 17"		
Curies	94		Film Type	Fuji 80		
KV	N/A		Sensitivity	#6 WIRE .0100"		
MA	N/A		Penetrameter	1 ASTM B		
Time	320	SECONDS	Shim(s)	N/A		
SFD	39.1	INCHES	Develop: Temp:	70° F	Time:	4.5 MIN
SOD	39	INCHES	Screen(s)	.002 PB F&B		
OFD	.312	INCHES	Source Size (Effective)	.143		
Source Size (Physical)	.1"x.1"		Films Per Cassette	1		
Geometric Unsharpness	.001"		Weld Reinforcement	.090"		

SETUP



INTERPRETATION

PART I.D./ FILM VIEW	Accept	Reject	Crack	Slag Inclusion	Tungsten Inclusion	Porosity	Undercut	Incomplete Fusion	Incomplete	Root Concavity	Root Convexity	DENSITY		REMARKS
												Penetrameter	Area of Interest	
WGS3														WELDER ID C13
0 TO 1	✓				/							3.5	3.5	
1 TO 2	✓											3.6	3.6	
2 TO 3	✓											3.5	3.5	
3 TO 4	✓											3.4	3.4	
4 TO 5	✓											3.8	3.8	
5 TO 6	✓						/					3.7	3.7	
6 TO 7	✓											3.6	3.6	
7 TO 8	✓					/	/					3.5	3.5	
8 TO 9	✓					/						3.6	3.6	
9 TO 10	✓											3.5	3.5	
10 TO 11	✓											3.4	3.4	
11 TO 12	✓											3.5	3.5	
12 TO 13	✓											3.6	3.6	
13 TO 14	✓					/						3.6	3.6	
14 TO 15	✓											3.7	3.7	
15 TO 16	✓											3.5	3.5	
16 TO 17	✓											3.4	3.4	
17 TO 18	✓											3.5	3.5	
18 TO 19	✓											3.7	3.7	
19 TO 20	✓											3.8	3.8	
20 TO 0	✓											3.3	3.3	

RADIOGRAPHER(S): _____

Jerry L Dillard
Jerry L Dillard

Jerry L Dillard Level II R.T.

INTERPRETER: _____

Jerry L Dillard Level II R.T.

CLIENT APPROVAL: _____

Railey McRobert

This report may not be reproduced except in full without the written approval of ATS. If the method used is a customer provided, non-standard test method, ATS does not assume responsibility for validation of the method.



APPLIED TECHNICAL SERVICES, INCORPORATED

214 Pelham Davis Circle, Greenville, South Carolina 29615 • (864) 675-6060 Fax (864) 675-6040 • www.atslab.com

RADIOGRAPHIC INSPECTION REPORT

Job # P245625 PO # 293-2828 WO # N/A Date: 12/12/2015 Page 1 of 1


CLIENT: CAROLINA INTERGRATED SOLUTIONS
LOCATION: 157 DERRICK RD
SPARTANBURG, SC. 29303

PART NO.: TANK 293-03
PART NAME: SEE BELOW
MATERIAL: STAINLESS STEEL
THICKNESS: .312" ROLLED STEEL
TYPE WELD: SAW

RADIOGRAPHIC INSPECTION TECHNIQUE

Specification(s)	ATS 120.1 REV 25	IAW	ASME SECTION VIII	
Isotope	IR 192	D1240	Film Size	4.5" X 17"
Curies	94		Film Type	Fuji 80
KV	N/A		Sensitivity	#6 WIRE .0100"
MA	N/A		Penetrameter	1 ASTM B
Time	320 SECONDS		Shim(s)	N/A
SFD	39.1 INCHES		Develop: Temp:	70° F
SOD	39 INCHES		Time:	4.5 MIN
OFD	.312 INCHES		Screen(s)	.002 PB F&B
Source Size (Physical)	.1"x.1"		Source Size (Effective)	.143
Geometric Unsharpness	.001"		Films Per Cassette	1
			Weld Reinforcement	.090"

SETUP



INTERPRETATION

PART I.D./ FILM VIEW	Accept	Reject	Crack	Slag Inclusion	Tungsten Inclusion	Porosity	Undercut	Incomplete Fusion	Incomplete	Root Concavity	Root Convexity	DENSITY		REMARKS
												Penetrameter	Area of Interest	
WLS1														WELDER ID C13
0 TO 1	✓											2.1	2.1	
1 TO 2	✓											2.3	2.3	
2 TO 3	✓											2.6	2.6	
3 TO 4	✓											2.8	2.8	
4 TO 5	✓											2.4	2.4	
5 TO 6	✓											2.3	2.3	
6 TO 7	✓											2.1	2.1	
WLS2														WELDER ID C13
0 TO 1	✓											2.1	2.1	
1 TO 2	✓											2.3	2.3	
2 TO 3	✓											2.6	2.6	
3 TO 4	✓											2.8	2.8	
4 TO 5	✓	X		X								2.4	2.4	
5 TO 6	✓											2.3	2.3	
6 TO 7	✓	X		X								2.3	2.1	
7 TO 8	✓											2.1	2.1	

RADIOGRAPHER(S): Jerry L Dillard Jerry L Dillard Level II R.T.
 INTERPRETER: Jerry L Dillard Jerry L Dillard Level II R.T.
 CLIENT APPROVAL: Bruce M. Zolner

This report may not be reproduced except in full without the written approval of ATS. If the method used is a customer provided, non-standard test method, ATS does not assume responsibility for validation of the method.



APPLIED TECHNICAL SERVICES, INCORPORATED

214 Pelham Davis Circle, Greenville, South Carolina 29615 • (864) 675-6060 Fax (864) 675-6040 • www.atslab.com

RADIOGRAPHIC INSPECTION REPORT

Job # P245625 PO # 293-2828 WO # N/A Date: 12/12/2015 Page 1 of 1


CLIENT: CAROLINA INTERGRATED SOLUTIONS
LOCATION: 157 DERRICK RD
SPARTANBURG, SC. 29303

PART NO.: TANK 293-03
PART NAME: SEE BELOW
MATERIAL: STAINLESS STEEL
THICKNESS: .312" ROLLED STEEL
TYPE WELD: SAW

RADIOGRAPHIC INSPECTION TECHNIQUE

Specification(s)	ATS 120.1 REV 25 IAW ASME SECTION VIII	
Isotope	IR 192 D1240	Film Size 4.5" X 17"
Curies	94	Film Type Fuji 80
KV	N/A	Sensitivity #6 WIRE .0100"
MA	N/A	Penetrameter 1 ASTM B
Time	320 SECONDS	Shim(s) N/A
SFD	39.1 INCHES	Develop: Temp: 70° F Time: 4.5 MIN
SOD	39 INCHES	Screen(s) .002 PB F&B
OFD	.312 INCHES	Source Size (Effective) .143
Source Size (Physical)	.1"x.1"	Films Per Cassette 1
Geometric Unsharpness	.001"	Weld Reinforcement .090"

SETUP



INTERPRETATION

PART I.D./ FILM VIEW	Accept	Reject	Crack	Slag Inclusion	Tungsten Inclusion	Porosity	Undercut	Incomplete Fusion	Incomplete	Root Concavity	Root Convexity	DENSITY		REMARKS
												Penetrameter	Area of Interest	
												W1		
0 TO 1	✓											3.5	3.5	
1 TO 2	✓											3.6	3.6	
2 TO 3	✓											3.6	3.5	
3 TO 0	✓											3.8	3.6	
W2														
0 TO 1		X				X						3.0	3.3	
1 TO 2	✓											3.1	3.1	
2 TO 3	✓											3.2	3.2	
3 TO 0		X				X						3.3	3.3	

RADIOGRAPHER(S): _____ Jerry L Dillard Level II R.T.
 INTERPRETER: _____ Jerry L Dillard Level II R.T.
 CLIENT APPROVAL: *Ruby McRobie*

This report may not be reproduced except in full without the written approval of ATS. If the method used is a customer provided, non-standard test method, ATS does not assume responsibility for validation of the method.



RADIOGRAPHIC INSPECTION REPORT

Job # P245625 PO # 293-2828 WO # N/A Date: 12/14/2015 Page 1 of 1


CLIENT: CAROLINA INTERGRATED SOLUTIONS
LOCATION: 157 DERRICK RD SPARTANBURG, SC. 29303

PART NO.: TANK 293-03
PART NAME: SEE BELOW
MATERIAL: STAINLESS STEEL
THICKNESS: .312" ROLLED STEEL
TYPE WELD: SAW

RADIOGRAPHIC INSPECTION TECHNIQUE

Table with 2 columns: Specification(s) and values. Includes details like Isotope (IR 192), Film Size (4.5" X 17"), Sensitivity (#6 WIRE .0100"), and Source Size (.1"x.1").

SETUP




INTERPRETATION



Table for interpretation with columns for Part ID/Film View, various defect types (Accept, Reject, Crack, etc.), and Density (Penetrator, Area of Interest). Includes a row for W2R1 with density values.

RADIOGRAPHER(S): Jerry L Dillard Level II R.T.
INTERPRETER: Jerry L Dillard Level II R.T.
CLIENT APPROVAL: Riley McRobbie

This report may not be reproduced except in full without the written approval of ATS. If the method used is a customer provided, non-standard test method, ATS does not assume responsibility for validation of the method.



- PAINT, DISCOLORATION & GENERAL SHOP SOIL TO PROVIDE A MUTUALLY ACCEPTABLE WORKMANLIKE PRODUCT.
- GASKET DIMENSIONS FOR CLASS 150# FLGS TO BE PER ANSI B16.5 TABLE E3. DTV TO SUPPLY (3) SPARE GASKET FOR MANWAY & ALL BLIND CONNECTIONS.
 - TEST GASKETS TO BE SAME DIMENSIONS & COMPRESSIBILITY AS SERVICE.
 - PRESSURE BOLTING SUPPLIED W/VESEL TO BE USED FOR TESTING.
 - VESSEL EXT: PICKLE & PASSIVATE WELDS PER NOTE 8; ACID WASH REMAINDER.
 - VES INTERIOR: PICKLE & PASSIVATE PER STD TS 25-0205-2. ANY WATER LEFT AFTER HYDROTEST TO BE REMOVED BY BLOWING AIR OR SWABBING.
 - ALL NOZZLE REPADS TO HAVE 1/8" NPT WEEP HOLES @ LOW POINT; AIR-SOAP BUBBLE TEST @15 PSI. ALL OTHER EXT. PADS TO HAVE 1/4" VENT HOLES.
 - LUBRICATE ALL BOLT THREADS W/ANTI-SEIZE.
 - PAINT 45° 135°, 225° & 315° ABOVE SUPPORT LUGS USING 4" TALL LETTERING.
 - SPREADER BAR REQUIRED WHEN LIFTING VESSEL; SHACKLE SIZE= 9 1/2 TON
 - 2" INSULATION REQ'D (BY OTHERS).
 - VESSEL WEIGHTS: EMPTY= 7,600 lbs; FLOODED (WATER)= 39,000 lbs; OPERATING= 32,200 lbs.
 - CAPACITY: 3,810 gals; HEADS= 209 gals; SHELL= 3,403 gal.
 - (1) VESSEL REQ'D.



NOZZLE LOAD TABLE

NOZ MARK	lbf			lbf ft		
	P	V ₁	V ₂	M ₁	M ₂	M _T
A7	787	922	674	1032	664	1328
B1	967	1079	787	1549	1033	1918
S1	517	697	517	369	295	590
S2	787	922	674	1032	664	1328

FRACTION TO MILLIMETER CONVERSION

FRACTION	MM	FRACTION	MM
1/8"	[3]	9/16"	[14]
3/16"	[5]	5/8"	[16]
1/4"	[6]	11/16"	[17]
5/16"	[8]	3/4"	[19]
3/8"	[10]	13/16"	[21]
7/16"	[11]	7/8"	[22]
1/2"	[13]	15/16"	[24]

CERTIFIED BY **NE** LATER

CAROLINA INTEGRATED SOLUTIONS
157 Derrick Rd, Spartanburg, SC 29303

SERIAL NO. 293-03 YR BUILT 2015

SHELL	
MAWP	45 psi @ 338 °F
MDMT	-20 °F @ 45 psi
MAEWP	-14.7 psi @ 338 °F

JACKET	
MAWP	psi @ °F
MDMT	°F @ psi

MAWP	3.1 BARG	PSIG @	170°C	°F @
MDMT	-29°C	°F @	3.1 BARG	PSIG
MAEWP	-1.013 BARG	PSIG @	170°C	°F
JKT MAWP	PSIG @	°F		
JKT MDMT	°F @	PSIG		
INSPECTOR				
PLANT	MOBILE, ALABAMA			
WEIGHT	7,600 LBS			
MATERIAL	SA-240 316/316L			
P.O. No.	4700984380			
EQUIP No.	R-2210			
PROJ No.	4142-00940			

AS-BUILT

CERTIFIED

NOZZLE SCHEDULE

REPADS	MARK	SIZE	SCH	NO.	DESCRIPTION	SERVICE	DETAIL
	A1	1 1/2"	40S	1	150# ANSI RFWN FLG	CRUDE ACA INLET DIP-PIPE	13
	A2	2"	40S	1	150# ANSI RFWN W/RED. RFSO FLG	MOUNT FOR A1	13
	A3	1"	40S	1	150# ANSI RFWN FLG	ACETIC ACID INLET DIP-PIPE	6
	A4	1 1/2"	40S	1	150# ANSI RFWN W/RED. SO & GUSSETS	MOUNT FOR A3	2,6
	A5	1"	40S	1	150# ANSI RFWN FLG	LIQUID INLET DIP-PIPE	6
	A6	1 1/2"	40S	1	150# ANSI RFWN W/RED. SO & GUSSETS	MOUNT FOR A5	2,6
	A7	3"	40S	1	150# ANSI RFWN FLG	IN TANK EDUCTOR INLET	16
	B1	4"	40S	1	150# ANSI RFWN FLG	PRODUCT OUTLET	12
	G1	6"	-	1	150# ANSI RF STUD PAD	SIGHT GLASS	8
	L1	3"	40S	1	150# ANSI RFWN FLG	LEVEL INDICATION STILLING WELL	7
	L2	4"	40S	1	150# ANSI RFWN FLG W/RED. SO FLG	MOUNT FOR L1	7
	L4	3"	40S	1	150# ANSI RFWN FLG	LEVEL SWITCH- HIGH	14
	M1	24"	3/8"	1	150# ANSI RFWN FLG W/BF	MANWAY W/DAVIT	4,5
	R1	4"	40S	1	150# ANSI RFWN FLG	EMERGENCY PRESSURE RELIEF	3
	S1	2"	40S	1	150# ANSI RFWN FLG W/BF	SPARE	3
	S2	3"	40S	1	150# ANSI RFWN FLG W/BF	SPARE	3
	T1	1 1/2"	40S	1	150# ANSI RFWN FLG W/GUSSETS	TEMPERATURE INDICATION	15
	V1	1 1/2"	40S	1	150# ANSI RFWN FLG W/GUSSETS	VAPOR EQUALIZATION	2
	V2	1"	40S	1	150# ANSI RFWN FLG W/GUSSETS	OFF GAS VENT	2

DESIGN DATA

- DESIGN PRESS & TEMP: VESSEL- (-14.7) +45 PSIG @338°F [(-1.013) +3.1 BARG @170°C]
- OPERATING PRESS & TEMP: VESSEL- 1 PSIG @158°F [0.6 BARG @-70°C]
- CORROSION ALLOWANCE- NONE
- SPECIFIC GRAVITY OF CONTENTS- 0.993 (61.98 lb/cf)
- HYDROTEST- 60 PSIG [4.1 BARG] (USE WATER W/A CHLORIDE CONTENT <50 ppm).
- FULL RADIOGRAPH REQ'D.
- WIND LOAD- PER IBC 2009; 140 MPH, I=1.15, EXP C, 62 FT ELEVATION.
- SEISMIC LOAD- PER IBC 2009; Ss=11%, S1=5.1%, I=1.5, CLASS D
- VESSEL TO BE DESIGNED FOR LETHAL SERVICE.

MATERIAL

- HEADS & SHELL- SA-240 316/316L
 NOZ NECKS- SA-312 TP 316/316L (SMLS)
 FLANGES- SA-182 F 316/316L
 MANWAY NECK- SA-240 316/316L
 SUPPORT LUGS- SA-240 304/304L
 SIGHT GLASS- SA-240 316/316L
 FITTINGS- SA-403 WP 316/316L
 REINF PADS- SA-240 316/316L
- INTERNAL ATTACH- SA-240 316/316L
 LIFT & TAIL LUGS- SA-240 304/304L
 EXTERNAL ATTACH- SA-240 304/304L
 SUPPORT LUGS- SA-240 304/304L
 BOLTING- SA-193 B7/SA-194 2H (GALV)
 GASKETS: VES- SP WD CGI 316/GRAPHITE
 SIGHT GLASS- 1/8" GRAPHITE

WELDING PROCEDURES

No.	PROCESS	ROD	NOTES	No.	PROCESS	ROD	NOTES
8-8-2	(GTAW)	ER308L	304 to 304	8-8-4	(GMAW)	ER316L	316 ROOT ONLY
8-8-3	(FCAW)	ER308LT-1	304 to 304	8-8-5	(SAW)	ER316L	316 to 316
8-8-4	(GMAW)	ER308L	304 ROOT ONLY	8-8-2	(GTAW)	ER316L	304 to 316
8-8-5	(SAW)	ER308L	304 to 304	8-8-3	(FCAW)	ER316LT-1	304 to 316
8-8-2	(GTAW)	ER316L	316 to 316	8-8-4	(GMAW)	ER316L	304/316 ROOT ONLY
8-8-3	(FCAW)	ER316LT-1	316 to 316	8-8-5	(SAW)	ER316L	304 to 316

CONSTRUCTION NOTES

- VESSEL TO BE DESIGNED & CONSTRUCTED PER ASME CODE, SEC VIII, DIV 1, 2013 EDITION; ALSO PER SPECS LISTED BELOW.
- ASME CODE STAMP & NATIONAL BOARD REGISTRATION REQ'D.
- FLANGE FACE FINISH= 125AA
- NOZZLE BOLT HOLES TO STRADDLE 0-180° CENTERLINE OR ITS PARALLEL.
- INSIDE NOZZLE PROJECTION= 0, UNLESS NOTED OTHERWISE.
- NOZZLE "B1" TO BE GROUND FLUSH.
- SHELL & HEAD JOINTS TO BE FULL PENETRATION BUTT JOINTS; NOZZLE NECK TO SHELL OR HEAD JOINTS TO BE FULL PENETRATION.
- ALL WELDS TO BE PASTED PER EC PT&E SPEC 25-0205, PARAGRAPH 5.2. PICKLING PASTE MATERIAL TO BE METINOX 71E OR EQUIVALENT.
- HOLD FOR AUTH ASME & CUSTOMER INSPECTORS AT: a) FIT-UP & COMPLETION OF BACKGOUGING; b) FIT-UP OF MANWAY; c) HYDROTEST.
- INTERNAL WELDS TO BE REASONABLY SMOOTH, BUT NOT NECESSARILY RIPPLE FREE OR GROUND SMOOTH.
- INSIDE SURFACE OF COMPLETED VESSEL TO BE FREE OF RUST, SCALE, SLAG, GREASE, WELD FLUX, SPATTER, ARC BURNS, GOUGES, TOOL MARKS, OIL, INK, MILL MARKINGS.

LETHAL SERVICE

REFERENCE:

- CUST PO No: 4700984380
 ITEM No: R-2210
 PROJ No: 4142-00940
 SPEC Nos: R-2210, REV 2; 20.230.013, REV 2;
 20.230.030, REV 2; 20.230.036, R2; 20.230.032
 CUST STDS: 25-0101-3; 25-0205-2; 25-0801-2; 25-0807;
 25-0901; 25-0902; 25-0903; 25-0108; 25-0303

DTV REF DWGS: 15515-03-2, 15515-03-3

DESTINATION: THEODORE, AL

MARK	REVISION DESCRIPTION	BY	CHK'D	DATE	CERTIFIED
2	ADD DIP-PIPE GUIDE ELEVS	RTC	BT	12-7-15	
1	ADD CONSTRUCTION NOTE 17	RTC	BT	11-3-15	
0	REV PER CUSTOMER APPROVAL	RTC	BT	7-7-15	
A	REV PER CUSTOMER COMMENTS	RTC	BT	5-5-15	

DRAWN RTC 2-10-15
 CHECKED BT 2-18-15
 SCALE 1"=12"
 JOB NO. 293-03
15515-03-1 2

DOMINION
Tank & Vessel Company, Inc.
1501 Valley Road, Richmond, VA 23222

78"ID ACA AFTER REACTOR R-2210
 EVONIK CORPORATION
 MOBILE ALABAMA PLANT
 ACA PROJECT



ASME Pressure Vessel Design Calculations

Item: ACA After Reactor

Vessel No: R-2210

Customer: Evonik Corporation (Theodore, AL)

Contract: 293-03 (DTV #15515-03)

Designer: bturner

Rev - Date: 2 - 07/20/2015

Table of Contents

Revision History	1/132
Pressure Summary	2/132
Vacuum Summary	4/132
Thickness Summary	5/132
Weight Summary	6/132
Nozzle Schedule	7/132
Nozzle Summary	8/132
Radiography Summary	9/132
Hydrostatic Test	11/132
Wind Code	12/132
Seismic Code	18/132
Liquid Level	23/132
Support Lugs	24/132
Vacuum Ring	37/132
F&D Head (top)	40/132
Straight Flange on F&D Head (top)	44/132
Shell -02	48/132
Shell -01	53/132
Straight Flange on F&D Head (btm)	57/132
F&D Head (btm)	61/132
Mount for A1 (A2)	65/132
Mount for A3 (A4)	69/132
Mount for A5 (A6)	73/132
InTank Eductor Inlet (A7)	77/132
Liquid Outlet (B1)	82/132
Sight Glass (G1)	87/132
Mount for L1 (L2)	91/132

Table of Contents

<u>Level Switch - High (L4)</u>	95/132
<u>Manway w/Davit (M1)</u>	99/132
<u>Off Gas Vent (V2)</u>	104/132
<u>Emergency Pressure Relief (R1)</u>	108/132
<u>Spare (S1)</u>	112/132
<u>Spare (S2)</u>	116/132
<u>Temperature Indicator (T1)</u>	121/132
<u>Vent (V1)</u>	125/132
<u>Lifting Lugs (Evonik Type 2)</u>	129/132
<u>Tailing Lug (Evonik Type 2)</u>	131/132

Revision History

Revisions			
No.	Date	Operator	Notes
0	2/11/2015	bturner	Customer Approval
1	5/ 5/2015	bturner	Revised per customer comments
2	7/20/2015	bturner	Revised per customer comments. Released for fabrication.

Pressure Summary

Component Summary										
Identifier	P Design (psi)	T Design (°F)	MAWP (psi)	MAP (psi)	MAEP (psi)	T _e external (°F)	MDMT (°F)	MDMT Exemption		Impact Tested
F&D Head (top)	45	338	94.77	97.09	32.18	338	-320	Note 1		No
Straight Flange on F&D Head (top)	45	338	207.38	212.47	52.69	338	-320	Note 2		No
Shell -02	45	338	128.62	133.17	20.36	338	-320	Note 3		No
Shell -01	45	338	125.18	133.17	20.36	338	-320	Note 4		No
Straight Flange on F&D Head (btm)	45	338	202.52	212.47	52.81	338	-320	Note 6		No
F&D Head (btm)	45	338	89.44	97.09	32.18	338	-320	Note 5		No
Support Lugs	45	338	45	N/A	N/A	N/A	N/A	N/A		N/A
Vacuum Ring	N/A	N/A	N/A	N/A	17.92	338	N/A	N/A		No
Mount for A1 (A2)	45	338	167.01	171.11	32.18	338	-55	Note 7		No
Mount for A3 (A4)	45	338	167.01	171.11	32.18	338	-55	Note 7		No
Mount for A5 (A6)	45	338	167.01	171.11	32.18	338	-55	Note 7		No
InTank Educator Inlet (A7)	45	338	125.29	133.17	20.36	338	-55	Nozzle	Note 7	No
								Pad	Note 4	No
Liquid Outlet (B1)	45	338	159.06	168.66	32.18	338	-55	Nozzle	Note 7	No
								Pad	Note 8	No
Sight Glass (G1)	45	338	138.31	171.11	32.18	338	-55	Note 9		No
Mount for L1 (L2)	45	338	99.53	101.97	24.29	338	-55	Note 7		No
Level Switch - High (L4)	45	338	120.97	123.93	30.62	338	-55	Note 7		No
Manway w/Davit (M1)	45	338	45.4	46.51	20.16	338	-55	Nozzle	Note 7	No
								Pad	Note 4	No
Emergency Pressure Relief (R1)	45	338	99.53	101.97	24.29	338	-55	Note 7		No
Spare (S1)	45	338	167.01	171.11	32.18	338	-55	Note 7		No
Spare (S2)	45	338	165.69	169.75	32.18	338	-55	Nozzle	Note 7	No
								Pad	Note 1	No
Temperature Indicator (T1)	45	338	125.31	133.17	20.36	338	-55	Note 7		No
Vent (V1)	45	338	167.01	171.11	32.18	338	-55	Note 7		No
Off Gas Vent (V2)	45	338	167.01	171.11	32.18	338	-55	Note 7		No

Chamber Summary	
Design MDMT	-20 °F
Rated MDMT	-55 °F @ 45 psi
MAWP hot & corroded	45 psi @ 338 °F
MAP cold & new	46.51 psi @ 70 °F
MAEP	17.92 psi @ 338 °F
(1) The MAWP is limited due to the MAWP limit set in the Calculations tab of the Set Mode dialog.	

Notes for MDMT Rating		
Note #	Exemption	Details
1.	Impact test exempt per UHA-51(g) (coincident ratio = 0.2628)	
2.	Impact test exempt per UHA-51(g) (coincident ratio = 0.2105)	
3.	Impact test exempt per UHA-51(g) (coincident ratio = 0.347)	
4.	Rated MDMT per UHA-51(d)(1)(a), (carbon content does not exceed 0.10%) = -320 °F	
5.	Impact test exempt per UHA-51(g) (coincident ratio = 0.2939)	
6.	Impact test exempt per UHA-51(g) (coincident ratio = 0.2333)	
7.	Flange rating governs: Flange rated MDMT per UHA-51(d)(1)(a) = -320 °F Bolts rated MDMT per Fig UCS-66 note (c) = -55 °F	
8.	Impact test exempt per UHA-51(g) (coincident ratio = 0.2953)	
9.	Impact test exempt per UHA-51(g) (coincident ratio = 0.2628)	Bolts rated MDMT per Fig UCS-66 note (c) = -55 °F

Vacuum Summary

Largest Unsupported Length Le			
Component	Line of Support	Elevation above Datum (in)	Length Le (in)
F&D Head (top)	-	181.6505	N/A
-	1/3 depth of F&D Head (top)	172.4168	N/A
Straight Flange on F&D Head (top) Top	-	168	88.9168
Straight Flange on F&D Head (top) Bottom	-	166.5	88.9168
Shell -02 Top	-	166.5	88.9168
Shell -02 Bottom	-	97.5	88.9168
Shell -01 Top	-	97.5	88.9168
-	Vacuum Ring	83.5	88.4168
Shell -01 Bottom	-	1.5	88.9168
Straight Flange on F&D Head (btm) Top	-	1.5	87.9168
Straight Flange on F&D Head (btm) Bottom	-	0	87.9168
-	1/3 depth of F&D Head (btm)	-4.4168	N/A
F&D Head (btm)	-	-13.6505	N/A
For Rings, the listed value of 'Le' is Ls per UG-29.			

Thickness Summary

Component Data								
Component Identifier	Material	Diameter (in)	Length (in)	Nominal t (in)	Design t (in)	Total Corrosion (in)	Joint E	Load
F&D Head (top)	SA-240 316L	78 ID	13.6505	0.4*	0.2346	0	1.00	External
Straight Flange on F&D Head (top)	SA-240 316L	78 ID	1.5	0.5	0.2743	0	1.00	External
Shell -02	SA-240 316L	78 ID	69	0.3125	0.2735	0	1.00	External
Shell -01	SA-240 316L	78 ID	96	0.3125	0.2735	0	1.00	External
Straight Flange on F&D Head (btm)	SA-240 316L	78 ID	1.5	0.5	0.2731	0	1.00	External
F&D Head (btm)	SA-240 316L	78 ID	13.6505	0.4*	0.2346	0	1.00	External
*Head minimum thickness after forming								

Definitions	
Nominal t	Vessel wall nominal thickness
Design t	Required vessel thickness due to governing loading + corrosion
Joint E	Longitudinal seam joint efficiency
Load	
Internal	Circumferential stress due to internal pressure governs
External	External pressure governs
Wind	Combined longitudinal stress of pressure + weight + wind governs
Seismic	Combined longitudinal stress of pressure + weight + seismic governs

Weight Summary

Weight (lb) Contributed by Vessel Elements											
Component	Metal New*	Metal Corroded	Insulation	Insulation Supports	Lining	Piping + Liquid	Operating Liquid		Test Liquid		Surface Area ft ²
							New	Corroded	New	Corroded	
F&D Head (top)	649.1	649.1	92	0	0	0	0	0	1,747.3	1,747.3	40
Shell -02	1,538.4	1,538.4	242.7	0	0	0	6,508.5	6,508.5	11,901.5	11,901.5	118
Shell -01	2,139.3	2,139.3	337.7	0	0	0	16,443.9	16,443.9	16,559.8	16,559.8	165
F&D Head (btm)	718.8	718.8	92	0	0	0	1,643.1	1,643.1	1,654.7	1,654.7	44
Support Lugs	493.3	493.3	0	0	0	0	0	0	0	0	27
TOTAL:	5,538.9	5,538.9	764.5	0	0	0	24,595.5	24,595.5	31,863.2	31,863.2	394

*Shells with attached nozzles have weight reduced by material cut out for opening.

Weight (lb) Contributed by Attachments											
Component	Body Flanges		Nozzles & Flanges		Packed Beds	Ladders & Platforms	Trays	Tray Supports	Rings & Clips	Vertical Loads	Surface Area ft ²
	New	Corroded	New	Corroded							
F&D Head (top)	0	0	1,065.5	1,065.5	0	0	0	0	0	0	28
Shell -02	0	0	0	0	0	0	0	0	49.8	0	2
Shell -01	0	0	24.6	24.6	0	0	0	0	110.5	0	15
F&D Head (btm)	0	0	22.2	22.2	0	0	0	0	0	0	1
TOTAL:	0	0	1,112.3	1,112.3	0	0	0	0	160.3	0	46

Vessel Totals		
	New	Corroded
Operating Weight (lb)	32,172	32,172
Empty Weight (lb)	7,576	7,576
Test Weight (lb)	38,675	38,675
Surface Area (ft ²)	440	-
Capacity** (US gal)	3,810	3,810

**The vessel capacity does not include volume of nozzle, piping or other attachments.

Vessel Lift Condition	
Vessel Lift Weight, New (lb)	7,576
Center of Gravity from Datum (in)	100.9732

Nozzle Schedule

Specifications									
Nozzle mark	Identifier	Size	Materials		Impact Tested	Normalized	Fine Grain	Flange	Blind
A2	Mount for A1	NPS 2 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 2 Class 150 WN A182 F316L	NPS 2 Class 150 A182 F316L
A4	Mount for A3	NPS 1.5 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 1 1/2 Class 150 WN A182 F316L	NPS 1 1/2 Class 150 A182 F316L
A6	Mount for A5	NPS 1.5 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 1 1/2 Class 150 WN A182 F316L	NPS 1 1/2 Class 150 A182 F316L
A7	InTank Eductor Inlet	NPS 3 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 3 Class 150 WN A182 F316L	No
			Pad	SA-240 316L	No	No	No		
B1	Liquid Outlet	NPS 4 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 4 Class 150 WN A182 F316L	No
			Pad	SA-240 316L	No	No	No		
G1	Sight Glass	11 OD x 2.5	Nozzle	SA-182 F316L <= 5 (low stress)	No	No	No	N/A	NPS 6 Class 150 A182 F316L
L2	Mount for L1	NPS 4 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 4 Class 150 WN A182 F316L	NPS 4 Class 150 A182 F316L
L4	Level Switch - High	NPS 3 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 3 Class 150 WN A182 F316L	No
M1	Manway w/Davit	24 OD x 0.375	Nozzle	SA-240 316L	No	No	No	NPS 24 Class 150 WN A182 F316L	NPS 24 Class 150 A182 F316L
			Pad	SA-240 316L	No	No	No		
R1	Emergency Pressure Relief	NPS 4 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 4 Class 150 WN A182 F316L	No
S1	Spare	NPS 2 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 2 Class 150 WN A182 F316L	NPS 2 Class 150 A182 F316L
S2	Spare	NPS 3 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 3 Class 150 WN A182 F316L	NPS 3 Class 150 A182 F316L
			Pad	SA-240 316L	No	No	No		
T1	Temperature Indicator	NPS 1.5 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 1 1/2 Class 150 WN A182 F316L	No
V1	Vent	NPS 1.5 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 1 1/2 Class 150 WN A182 F316L	No
V2	Off Gas Vent	NPS 1 Sch 40S (Std)	Nozzle	SA-312 TP316L Wld & smls pipe	No	No	No	NPS 1 Class 150 WN A182 F316L	No

Nozzle Summary

Dimensions												
Nozzle mark	OD (in)	t _n (in)	Req t _n (in)	A ₁ ?	A ₂ ?	Shell			Reinforcement Pad		Corr (in)	A _a /A _r (%)
						Nom t (in)	Design t (in)	User t (in)	Width (in)	t _{pad} (in)		
A2	2.375	0.154	0.154	Yes	Yes	0.4*	N/A		N/A	N/A	0	Exempt
A4	1.9	0.145	0.145	Yes	Yes	0.4*	N/A		N/A	N/A	0	Exempt
A6	1.9	0.145	0.145	Yes	Yes	0.4*	N/A		N/A	N/A	0	Exempt
A7	3.5	0.216	0.216	Yes	Yes	0.3125	N/A		2	0.3125	0	Exempt
B1	4.5	0.237	0.237	Yes	Yes	0.4*	0.3943		2	0.3125	0	100.0
G1	11	2.5	0.3281	Yes	Yes	0.4*	0.1077		N/A	N/A	0	100.0
L2	4.5	0.237	0.237	Yes	Yes	0.4*	0.3158		N/A	N/A	0	100.0
L4	3.5	0.216	0.216	Yes	Yes	0.4*	0.2897		N/A	N/A	0	100.0
M1	24	0.375	0.076	Yes	Yes	0.4*	0.278		2	0.3125	0	100.0
R1	4.5	0.237	0.237	Yes	Yes	0.4*	0.3158		N/A	N/A	0	100.0
S1	2.375	0.154	0.154	Yes	Yes	0.4*	N/A		N/A	N/A	0	Exempt
S2	3.5	0.216	0.216	Yes	Yes	0.4*	0.3968		2	0.3125	0	100.0
T1	1.9	0.145	0.145	Yes	Yes	0.3125	N/A		N/A	N/A	0	Exempt
V1	1.9	0.145	0.145	Yes	Yes	0.4*	N/A		N/A	N/A	0	Exempt
V2	1.315	0.133	0.133	Yes	Yes	0.4*	N/A		N/A	N/A	0	Exempt

*Head minimum thickness after forming

Definitions	
t _n	Nozzle thickness
Req t _n	Nozzle thickness required per UG-45/UG-16
Nom t	Vessel wall thickness
Design t	Required vessel wall thickness due to pressure + corrosion allowance per UG-37
User t	Local vessel wall thickness (near opening)
A _a	Area available per UG-37, governing condition
A _r	Area required per UG-37, governing condition
Corr	Corrosion allowance on nozzle wall

Radiography Summary

UG-116 Radiography							
Component	Longitudinal Seam		Top Circumferential Seam		Bottom Circumferential Seam		Mark
	Category (Fig UW-3)	Radiography / Joint Type	Category (Fig UW-3)	Radiography / Joint Type	Category (Fig UW-3)	Radiography / Joint Type	
F&D Head (top)	A	Full UW-11(a) / Type 1	N/A	N/A	B	Full UW-11(a) / Type 1	RT1
Shell -02	A	Full UW-11(a) / Type 1	B	Full UW-11(a) / Type 1	B	Full UW-11(a) / Type 1	RT1
Shell -01	A	Full UW-11(a) / Type 1	B	Full UW-11(a) / Type 1	B	Full UW-11(a) / Type 1	RT1
F&D Head (btm)	A	Full UW-11(a) / Type 1	B	Full UW-11(a) / Type 1	N/A	N/A	RT1
Nozzle	Longitudinal Seam		Nozzle to Vessel Circumferential Seam		Nozzle free end Circumferential Seam		
Mount for A1 (A2)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Mount for A3 (A4)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Mount for A5 (A6)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Sight Glass (G1)	N/A	Seamless No RT	D	N/A / Type 7	N/A	N/A	N/A
Mount for L1 (L2)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Level Switch - High (L4)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Manway w/Davit (M1)	A	User Defined (E = 1.00)	D	N/A / Type 7	C	Full UW-11(a) / Type 1	RT1
Off Gas Vent (V2)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Emergency Pressure Relief (R1)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Spare (S1)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Spare (S2)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Vent (V1)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
InTank Educator Inlet (A7)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Temperature Indicator (T1)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Liquid Outlet (B1)	N/A	Seamless No RT	D	N/A / Type 7	C	UW-11(a)(4) exempt / Type 1	N/A
Nozzle Flange	Longitudinal Seam		Flange Face		Nozzle to Flange Circumferential Seam		
ASME B16.5/16.47 flange attached to Mount for A1 (A2)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Mount for A3 (A4)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Mount for A5 (A6)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Mount for L1 (L2)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Level Switch - High (L4)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A

ASME B16.5/16.47 flange attached to Manway w/Davit (M1)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	Full UW-11(a) / Type 1	RT1
ASME B16.5/16.47 flange attached to Off Gas Vent (V2)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Emergency Pressure Relief (R1)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Spare (S1)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Spare (S2)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Vent (V1)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to InTank Eductor Inlet (A7)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Temperature Indicator (T1)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
ASME B16.5/16.47 flange attached to Liquid Outlet (B1)	N/A	Seamless No RT	N/A	N/A / Gasketed	C	UW-11(a)(4) exempt / Type 1	N/A
UG-116(e) Required Marking: RT1							

Hydrostatic Test

Horizontal shop hydrostatic test based on MAWP per UG-99(b)

$$\begin{aligned}
 \text{Gauge pressure at } 70^{\circ}\text{F} &= \\
 &= 1.3 \cdot \text{MAWP} \cdot \text{LSR} \\
 &= 1.3 \cdot 45 \cdot 1.0245 \\
 &= 59.93 \text{ psi}
 \end{aligned}$$

Horizontal shop hydrostatic test							
Identifier	Local test pressure (psi)	Test liquid static head (psi)	UG-99(b) stress ratio	UG-99(b) pressure factor	Stress during test (psi)	Allowable test stress (psi)	Stress excessive?
F&D Head (top) (1)	62.749	2.816	1.0245	1.30	6,118	22,500	No
Straight Flange on F&D Head (top)	62.749	2.816	1.0245	1.30	4,926	22,500	No
Shell -02	62.749	2.816	1.0245	1.30	7,862	22,500	No
Shell -01	62.749	2.816	1.0245	1.30	7,862	22,500	No
Straight Flange on F&D Head (btm)	62.749	2.816	1.0245	1.30	4,926	22,500	No
F&D Head (btm)	62.749	2.816	1.0245	1.30	6,118	22,500	No
Emergency Pressure Relief (R1)	60.53	0.597	1.0245	1.30	10,777	33,750	No
InTank Eductor Inlet (A7)	61.396	1.463	1.0245	1.30	6,798	33,750	No
Level Switch - High (L4)	61.396	1.463	1.0245	1.30	8,487	33,750	No
Liquid Outlet (B1)	61.414	1.481	1.0245	1.30	7,280	33,750	No
Manway w/Davit (M1)	61.761	1.827	1.0245	1.30	21,324	33,750	No
Mount for A1 (A2)	60.891	0.958	1.0245	1.30	10,834	33,750	No
Mount for A3 (A4)	61.857	1.924	1.0245	1.30	10,785	33,750	No
Mount for A5 (A6)	60.526	0.593	1.0245	1.30	10,552	33,750	No
Mount for L1 (L2)	61.414	1.481	1.0245	1.30	10,934	33,750	No
Off Gas Vent (V2)	62.204	2.271	1.0245	1.30	10,397	33,750	No
Sight Glass (G1)	62.33	2.397	1.3577	1.30	8,520	33,750	No
Spare (S1)	60.909	0.976	1.0245	1.30	10,344	33,750	No
Spare (S2)	61.866	1.932	1.0245	1.30	6,834	33,750	No
Temperature Indicator (T1)	60.358	0.425	1.0245	1.30	12,852	33,750	No
Vent (V1)	60.395	0.462	1.0245	1.30	10,530	33,750	No

- (1) F&D Head (top) limits the UG-99(b) stress ratio.
 (2) P_L stresses at nozzle openings have been estimated using the method described in Division 2 Part 4.5.
 (3) $1.5 \cdot 0.9 \cdot S_y$ used as the basis for the maximum local primary membrane stress at the nozzle intersection P_L .
 (4) The zero degree angular position is assumed to be up, and the test liquid height is assumed to the top-most flange.

The field test condition has not been investigated.

Wind Code

Building Code: IBC 2009 (Wind loads determined in accordance with ASCE 7-05)		
Elevation of base above grade	62.0000 ft	
Increase effective outer diameter by	1.0000 ft	
Wind Force Coefficient, Cf	0.7000	
Occupancy Category (Table 1-1)	III	
Basic Wind Speed, V	140.0000 mph	
Importance Factor, I	1.1500	
Exposure category	C	
Wind Directionality Factor, Kd	0.9500	
Topographic Factor, Kzt	1.0000	
Enforce min. loading of 10 psf	Yes	
Vessel Characteristics		
Height, h	3.0594 ft	
Minimum Diameter, b	Operating, Corroded	6.8854 ft
	Empty, Corroded	6.8854 ft
	Hydrotest, Corroded, Field	6.5521 ft
Fundamental Frequency, n₁	Operating, Corroded	40.5263 Hz
	Empty, Corroded	94.3023 Hz
	Hydrotest, Corroded, Field	41.8902 Hz
	Vacuum, Corroded	40.5263 Hz
Damping coefficient, β	Operating, Corroded	0.0255
	Empty, Corroded	0.0210
	Hydrotest, Corroded, Field	0.0260
	Vacuum, Corroded	0.0255

[Table Lookup Values](#)

2.4.1 Basic Load Combinations for Allowable Stress Design

Load combinations considered in accordance with ASCE section 2.4.1:

5.	$D + P + P_s + W$
7.	$0.6D + P + P_s + W$
Parameter Description	
D	= Dead load
P	= Internal or external pressure load
P_s	= Static head load
W	= Wind load

Wind Deflection Reports:

[Operating, Corroded](#)

[Empty, Corroded](#)

[Vacuum, Corroded](#)

[Hydrotest, Corroded, field](#)

[Wind Pressure Calculations](#)

Wind Deflection Report: Operating, Corroded

Component	Elevation of Bottom above Base (in)	Effective OD (ft)	Elastic Modulus E (10 ⁶ psi)	Inertia I (ft ⁴)	Platform Wind Shear at Bottom (lb _f)	Total Wind Shear at Bottom (lb _f)	Bending Moment at Bottom (lb _f -ft)	Deflection at Top (in)
F&D Head (top)	21.5625	7.91	26.8	*	0	331	1,576	0
Shell -02 (top)	0	7.89	26.8	2.842	0	912	2,693	0
Shell -02 (bottom)	0	7.89	26.8	2.842	0	4,070	26,328	0.0002
Shell -01	-47.4375	7.89	26.8	2.842	0	2,813	12,744	0.0011
F&D Head (btm)	-143.4375	7.91	26.8	*	0	309	168	0.0012
*Moment of Inertia I varies over the length of the component								

Wind Deflection Report: Empty, Corroded								
Component	Elevation of Bottom above Base (in)	Effective OD (ft)	Elastic Modulus E (10 ⁶ psi)	Inertia I (ft ⁴)	Platform Wind Shear at Bottom (lb _f)	Total Wind Shear at Bottom (lb _f)	Bending Moment at Bottom (lb _f -ft)	Deflection at Top (in)
F&D Head (top)	21.5625	7.91	28.3	*	0	331	1,576	0
Shell -02 (top)	0	7.89	28.3	2.842	0	912	2,693	0
Shell -02 (bottom)	0	7.89	28.3	2.842	0	4,070	26,328	0.0002
Shell -01	-47.4375	7.89	28.3	2.842	0	2,813	12,744	0.001
F&D Head (btm)	-143.4375	7.91	28.3	*	0	309	168	0.0012
*Moment of Inertia I varies over the length of the component								

Wind Deflection Report: Vacuum, Corroded								
Component	Elevation of Bottom above Base (in)	Effective OD (ft)	Elastic Modulus E (10 ⁶ psi)	Inertia I (ft ⁴)	Platform Wind Shear at Bottom (lb _f)	Total Wind Shear at Bottom (lb _f)	Bending Moment at Bottom (lb _f -ft)	Deflection at Top (in)
F&D Head (top)	21.5625	7.91	26.8	*	0	331	1,576	0
Shell -02 (top)	0	7.89	26.8	2.842	0	912	2,693	0
Shell -02 (bottom)	0	7.89	26.8	2.842	0	4,070	26,328	0.0002
Shell -01	-47.4375	7.89	26.8	2.842	0	2,813	12,744	0.0011
F&D Head (btm)	-143.4375	7.91	26.8	*	0	309	168	0.0012
*Moment of Inertia I varies over the length of the component								

Wind Deflection Report: Field Hydrotest, Corroded								
Component	Elevation of Bottom above Base (in)	Effective OD (ft)	Elastic Modulus E (10 ⁶ psi)	Inertia I (ft ⁴)	Platform Wind Shear at Bottom (lb _f)	Total Wind Shear at Bottom (lb _f)	Bending Moment at Bottom (lb _f -ft)	Deflection at Top (in)
F&D Head (top)	21.5625	7.91	28.3	*	0	104	1,452	0
Shell -02 (top)	0	7.89	28.3	2.842	0	287	1,803	0
Shell -02 (bottom)	0	7.89	28.3	2.842	0	1,286	8,371	0.0001
Shell -01	-47.4375	7.89	28.3	2.842	0	888	4,080	0.0003
F&D Head (btm)	-143.4375	7.91	28.3	*	0	97	52	0.0004
*Moment of Inertia I varies over the length of the component								

Wind Pressure (WP) Calculations

Gust Factor (G_f) Calculations

$$K_z = 2.01 * (Z/Z_g)^{2/\alpha}$$

$$= 2.01 * (Z/900.0000)^{0.2105}$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V^2 * I$$

$$= 0.00256 * K_z * 1.0000 * 0.9500 * 140.0000^2 * 1.1500$$

$$= 54.8173 * K_z$$

$$WP = q_z * G * C_f \text{ (Minimum 10 lb/ft}^2\text{)}$$

$$= q_z * G * 0.7000 \text{ (Minimum 10 lb/ft}^2\text{)}$$

Design Wind Pressures							
Height Z (')	Kz	qz (psf)	WP (psf)				
			Operating	Empty	Hydrotest New	Hydrotest Corroded	Vacuum
15.0	0.8489	46.53	29.65	29.65	N.A.	10.00	29.65
20.0	0.9019	49.44	31.50	31.50	N.A.	10.40	31.50
25.0	0.9453	51.82	33.01	33.01	N.A.	10.90	33.01
30.0	0.9823	53.84	34.30	34.30	N.A.	11.32	34.30
40.0	1.0436	57.21	36.45	36.45	N.A.	12.03	36.45
50.0	1.0938	59.96	38.20	38.20	N.A.	12.61	38.20
60.0	1.1366	62.30	39.69	39.69	N.A.	13.10	39.69
70.0	1.1741	64.36	41.00	41.00	N.A.	13.54	41.00

Design Wind Force determined from: $F = \text{Pressure} * A_f$, where A_f is the projected area.

Gust Factor Calculations

[Operating, Corroded](#)
[Empty, Corroded](#)
[Vacuum, Corroded](#)
[Hydrotest, Corroded, field](#)

Gust Factor Calculations: Operating, Corroded

Vessel is considered a rigid structure as $n_1 = 40.5263 \text{ Hz} \geq 1 \text{ Hz}$.

$$\begin{aligned}
 z^- &= \max(0.60 * h, z_{\min}) \\
 &= \max(0.60 * 3.0594, 15.0000) \\
 &= 15.0000
 \end{aligned}$$

$$\begin{aligned}
 I_{z^-} &= c * (33 / z^-)^{1/6} \\
 &= 0.2000 * (33 / 15.0000)^{1/6} \\
 &= 0.2281
 \end{aligned}$$

$$\begin{aligned}
 L_{z^-} &= l * (z^- / 33)^{ep} \\
 &= 500.0000 * (15.0000 / 33)^{0.2000} \\
 &= 427.0566
 \end{aligned}$$

$$\begin{aligned}
 Q &= \text{Sqr}(1 / (1 + 0.63 * ((b + h) / L_{z^-})^{0.63})) \\
 &= \text{Sqr}(1 / (1 + 0.63 * ((6.8854 + 3.0594) / 427.0566)^{0.63})) \\
 &= 0.9718
 \end{aligned}$$

$$\begin{aligned}
 G &= 0.925 * (1 + 1.7 * g_e * I_{z^-} * Q) / (1 + 1.7 * g_v * I_{z^-}) \\
 &= 0.925 * (1 + 1.7 * 3.40 * 0.2281 * 0.9718) / (1 + 1.7 * 3.40 * 0.2281) \\
 &= 0.9101
 \end{aligned}$$

Gust Factor Calculations: Empty, Corroded

Vessel is considered a rigid structure as $n_1 = 94.3023 \text{ Hz} \geq 1 \text{ Hz}$.

$$\begin{aligned}
z^- &= \max (0.60 * h , z_{\min}) \\
&= \max (0.60 * 3.0594 , 15.0000) \\
&= 15.0000 \\
I_{z^-} &= c * (33 / z^-)^{1/6} \\
&= 0.2000 * (33 / 15.0000)^{1/6} \\
&= 0.2281 \\
L_{z^-} &= l * (z^- / 33)^{ep} \\
&= 500.0000 * (15.0000 / 33)^{0.2000} \\
&= 427.0566 \\
Q &= \text{Sqr}(1 / (1 + 0.63 * ((b + h) / L_{z^-})^{0.63})) \\
&= \text{Sqr}(1 / (1 + 0.63 * ((6.8854 + 3.0594) / 427.0566)^{0.63})) \\
&= 0.9718 \\
G &= 0.925 * (1 + 1.7 * g_e * I_{z^-} * Q) / (1 + 1.7 * g_v * I_{z^-}) \\
&= 0.925 * (1 + 1.7 * 3.40 * 0.2281 * 0.9718) / (1 + 1.7 * 3.40 * 0.2281) \\
&= 0.9101
\end{aligned}$$

Gust Factor Calculations: Vacuum, Corroded

Vessel is considered a rigid structure as $n_1 = 40.5263 \text{ Hz} \geq 1 \text{ Hz}$.

$$\begin{aligned}
z^- &= \max (0.60 * h , z_{\min}) \\
&= \max (0.60 * 3.0594 , 15.0000) \\
&= 15.0000 \\
I_{z^-} &= c * (33 / z^-)^{1/6} \\
&= 0.2000 * (33 / 15.0000)^{1/6} \\
&= 0.2281 \\
L_{z^-} &= l * (z^- / 33)^{ep} \\
&= 500.0000 * (15.0000 / 33)^{0.2000} \\
&= 427.0566 \\
Q &= \text{Sqr}(1 / (1 + 0.63 * ((b + h) / L_{z^-})^{0.63})) \\
&= \text{Sqr}(1 / (1 + 0.63 * ((6.8854 + 3.0594) / 427.0566)^{0.63})) \\
&= 0.9718 \\
G &= 0.925 * (1 + 1.7 * g_e * I_{z^-} * Q) / (1 + 1.7 * g_v * I_{z^-}) \\
&= 0.925 * (1 + 1.7 * 3.40 * 0.2281 * 0.9718) / (1 + 1.7 * 3.40 * 0.2281) \\
&= 0.9101
\end{aligned}$$

Gust Factor Calculations: Hydrottest, Corroded, field

Vessel is considered a rigid structure as $n_1 = 41.8902 \text{ Hz} \geq 1 \text{ Hz}$.

$$\begin{aligned}
z^- &= \max (0.60 * h , z_{\min}) \\
&= \max (0.60 * 3.0594 , 15.0000) \\
&= 15.0000 \\
I_{z^-} &= c * (33 / z^-)^{1/6} \\
&= 0.2000 * (33 / 15.0000)^{1/6} \\
&= 0.2281 \\
L_{z^-} &= l * (z^- / 33)^{ep}
\end{aligned}$$

$$= 500.0000 * (15.0000 / 33)^{0.2000}$$

$$= 427.0566$$

$$Q = \text{Sqr}(1 / (1 + 0.63 * ((b + h) / L_z)^{0.63}))$$

$$= \text{Sqr}(1 / (1 + 0.63 * ((6.8854 + 3.0594) / 427.0566)^{0.63}))$$

$$= 0.9723$$

$$G = 0.925 * (1 + 1.7 * g_e * I_z * Q) / (1 + 1.7 * g_v * I_z)$$

$$= 0.925 * (1 + 1.7 * 3.40 * 0.2281 * 0.9723) / (1 + 1.7 * 3.40 * 0.2281)$$

$$= 0.9104$$

Table Lookup Values	
$\alpha = 9.5000, z_g = 900.0000 \text{ ft}$	[Table 6-2, page 78]
$c = 0.2000, l = 500.0000, ep = 0.2000$	[Table 6-2, page 78]
$a^- = 0.1538, b^- = 0.6500$	[Table 6-2, page 78]
$z_{\min} = 15.0000 \text{ ft}$	[Table 6-2, page 78]
$g_Q = 3.40$	[6.5.8.1 page 26]
$g_v = 3.40$	[6.5.8.1 page 26]

Seismic Code

Building Code: IBC 2009 building mounted (Seismic loads determined in accordance with ASCE 7-05)		
Site Class	D	
Spectral Response Acceleration at short period (% g), S_s	11.00%	
Spectral Response Acceleration at period of 1 sec (% g), S_1	5.10%	
Response Modification Factor from Table 13.6-1, R_p	3.0000	
Importance Factor, I_p	1.5000	
Amplification factor from Table 13.6-1, a_p	1.0000	
z/h Ratio	0.8600	
Acceleration-based Site Coefficient, F_a	1.6000	
Velocity-based Site Coefficient, F_v	2.4000	
Redundancy factor, ρ	1.0000	
Occupancy Category (Table 1-1)	III	
User Defined Vertical Accelerations Considered	No	
Vessel Characteristics		
Height	3.0594 ft	
Weight	Operating, Corroded	32,172 lb
	Empty, Corroded	7,576 lb
	Vacuum, Corroded	32,172 lb
Period of Vibration Calculation		
Fundamental Period, T	Operating, Corroded	0.025 sec (f = 40.5 Hz)
	Empty, Corroded	0.011 sec (f = 94.3 Hz)
	Vacuum, Corroded	0.025 sec (f = 40.5 Hz)

The fundamental period of vibration T (above) is calculated using the Rayleigh method of approximation

$$T = 2 * \text{PI} * \text{Sqr}(\{\text{Sum}(W_i * y_i^2)\} / \{g * \text{Sum}(W_i * y_i)\}), \text{ where}$$

W_i is the weight of the i^{th} lumped mass, and y_i is its deflection when the system is treated as a cantilever beam.

12.4.2.3 Basic Load Combinations for Allowable Stress Design

Load combinations considered in accordance with ASCE section 2.4.1:

5.	$D + P + P_s + 0.7E$	$= (1.0 + 0.14S_{DS})D + P + P_s + 0.7\rho Q_E$	
8.	$0.6D + P + P_s + 0.7E$	$= (0.6 - 0.14S_{DS})D + P + P_s + 0.7\rho Q_E$	
Parameter description			
D	= Dead load		
P	= Internal or external pressure load		
P_s	= Static head load		
E	= Seismic load	$= E_h +/- E_v$	$= \rho Q_E +/- 0.2S_{DS}D$

Seismic Shear Reports:

[Operating, Corroded](#)

[Empty, Corroded](#)

[Vacuum, Corroded](#)

[Base Shear Calculations](#)

Seismic Shear Report: Operating, Corroded

Component	Elevation of Bottom above Base (in)	Elastic Modulus E (10 ⁶ psi)	Inertia I (ft ⁴)	Seismic Shear at Bottom (lb _f)	Bending Moment at Bottom (lb _f -ft)
F&D Head (top)	21.5625	26.8	*	35	1,432
Shell -02 (top)	0	26.8	2.8424	39	1,500
Shell -02 (bottom)	0	26.8	2.8424	1,397	12,221
Shell -01	-47.4375	26.8	2.8424	1,272	6,855
F&D Head (btm)	-143.4375	26.8	*	215	112
*Moment of Inertia I varies over the length of the component					

Seismic Shear Report: Empty, Corroded

Component	Elevation of Bottom above Base (in)	Elastic Modulus E (10 ⁶ psi)	Inertia I (ft ⁴)	Seismic Shear at Bottom (lb _f)	Bending Moment at Bottom (lb _f -ft)
F&D Head (top)	21.5625	28.3	*	44	1,440
Shell -02 (top)	0	28.3	2.8424	48	1,524
Shell -02 (bottom)	0	28.3	2.8424	288	2,804
Shell -01	-47.4375	28.3	2.8424	267	1,692
F&D Head (btm)	-143.4375	28.3	*	90	59
*Moment of Inertia I varies over the length of the component					

Seismic Shear Report: Vacuum, Corroded					
Component	Elevation of Bottom above Base (in)	Elastic Modulus E (10 ⁶ psi)	Inertia I (ft ⁴)	Seismic Shear at Bottom (lb _f)	Bending Moment at Bottom (lb _f -ft)
F&D Head (top)	21.5625	26.8	*	35	1,432
Shell -02 (top)	0	26.8	2.8424	39	1,500
Shell -02 (bottom)	0	26.8	2.8424	1,397	12,221
Shell -01	-47.4375	26.8	2.8424	1,272	6,855
F&D Head (btm)	-143.4375	26.8	*	215	112
*Moment of Inertia I varies over the length of the component					

11.4.3: Maximum considered earthquake spectral response acceleration

The maximum considered earthquake spectral response acceleration at short period, S_{MS}

$$S_{MS} = F_a * S_g = 1.6000 * 11.00 / 100 = 0.1760$$

The maximum considered earthquake spectral response acceleration at 1 s period, S_{M1}

$$S_{M1} = F_v * S_1 = 2.4000 * 5.10 / 100 = 0.1224$$

11.4.4: Design spectral response acceleration parameters

Design earthquake spectral response acceleration at short period, S_{DS}

$$S_{DS} = 2 / 3 * S_{MS} = 2 / 3 * 0.1760 = 0.1173$$

Design earthquake spectral response acceleration at 1 s period, S_{D1}

$$S_{D1} = 2 / 3 * S_{M1} = 2 / 3 * 0.1224 = 0.0816$$

11.6 Seismic Design Category

The Occupancy Category is III.

From Table 11.6-1, the Seismic Design Category based on $S_{DS} = 0.1173$ is A.

From Table 11.6-2, the Seismic Design Category based on $S_{D1} = 0.0816$ is B.

This vessel is assigned to Seismic Design Category B.

12.4.2.3: Seismic Load Combinations: Vertical Term

Factor is applied to dead load.

$$\begin{aligned} \text{Compressive Side:} &= 1.0 + 0.14 * S_{DS} \\ &= 1.0 + 0.14 * 0.1173 \\ &= 1.0164 \end{aligned}$$

$$\begin{aligned} \text{Tensile Side:} &= 0.6 - 0.14 * S_{DS} \\ &= 0.6 - 0.14 * 0.1173 \\ &= 0.5836 \end{aligned}$$

Base Shear Calculations

[Operating, Corroded](#)

[Empty, Corroded](#)

[Vacuum, Corroded](#)

Base Shear Calculations: Operating, Corroded

The base shear F_p is as per Equation 13.3-1 below, provided its value is between F_{pMin} and F_{pMax}

$$\begin{aligned}F_p &= 0.40 * a_p * S_{DS} * W_p / (R_p / I_p) * (1 + 2 * z/h) \\ &= 0.40 * 1.0000 * 0.1173 * 32,171.5586 / (3.0000 / 1.5000) * (1 + 2 * 0.8600) \\ &= 2,053.4890 \text{ lb}\end{aligned}$$

$$\begin{aligned}F_{pMin} &= 0.30 * S_{DS} * I_p * W_p \\ &= 0.30 * 0.1173 * 1.5000 * 32,171.5586 \\ &= 1,698.66 \text{ lb}\end{aligned}$$

$$\begin{aligned}F_{pMax} &= 1.60 * S_{DS} * I_p * W_p \\ &= 1.60 * 0.1173 * 1.5000 * 32,171.5586 \\ &= 9,059.51 \text{ lb}\end{aligned}$$

$$F_p = 2,053.49 \text{ lb}$$

12.4.2.1 Seismic Load Combinations: Horizontal Seismic Load Effect, E_h

$$\begin{aligned}Q_E &= F_p \\ E_h &= 0.7 * \rho * Q_E \text{ (Only 70% of seismic load considered as per Section 2.4.1)} \\ &= 0.70 * 1.0000 * 2,053.49 \\ &= 1,437.44 \text{ lb}\end{aligned}$$

Base Shear Calculations: Empty, Corroded

The base shear F_p is as per Equation 13.3-1 below, provided its value is between F_{pMin} and F_{pMax}

$$\begin{aligned}F_p &= 0.40 * a_p * S_{DS} * W_p / (R_p / I_p) * (1 + 2 * z/h) \\ &= 0.40 * 1.0000 * 0.1173 * 7,576.0244 / (3.0000 / 1.5000) * (1 + 2 * 0.8600) \\ &= 483.5726 \text{ lb}\end{aligned}$$

$$\begin{aligned}F_{pMin} &= 0.30 * S_{DS} * I_p * W_p \\ &= 0.30 * 0.1173 * 1.5000 * 7,576.0244 \\ &= 400.01 \text{ lb}\end{aligned}$$

$$\begin{aligned}F_{pMax} &= 1.60 * S_{DS} * I_p * W_p \\ &= 1.60 * 0.1173 * 1.5000 * 7,576.0244 \\ &= 2,133.41 \text{ lb}\end{aligned}$$

$$F_p = 483.57 \text{ lb}$$

12.4.2.1 Seismic Load Combinations: Horizontal Seismic Load Effect, E_h

$$\begin{aligned}Q_E &= F_p \\ E_h &= 0.7 * \rho * Q_E \text{ (Only 70% of seismic load considered as per Section 2.4.1)} \\ &= 0.70 * 1.0000 * 483.57 \\ &= 338.50 \text{ lb}\end{aligned}$$

Base Shear Calculations: Vacuum, Corroded

The base shear F_p is as per Equation 13.3-1 below, provided its value is between F_{pMin} and F_{pMax}

$$\begin{aligned} F_p &= 0.40 * a_p * S_{DS} * W_p / (R_p / I_p) * (1 + 2 * z/h) \\ &= 0.40 * 1.0000 * 0.1173 * 32,171.5586 / (3.0000 / 1.5000) * (1 + 2 * 0.8600) \\ &= 2,053.4890 \text{ lb} \end{aligned}$$

$$\begin{aligned} F_{pMin} &= 0.30 * S_{DS} * I_p * W_p \\ &= 0.30 * 0.1173 * 1.5000 * 32,171.5586 \\ &= 1,698.66 \text{ lb} \end{aligned}$$

$$\begin{aligned} F_{pMax} &= 1.60 * S_{DS} * I_p * W_p \\ &= 1.60 * 0.1173 * 1.5000 * 32,171.5586 \\ &= 9,059.5107 \text{ lb} \end{aligned}$$

$$F_p = 2,053.49 \text{ lb}$$

12.4.2.1 Seismic Load Combinations: Horizontal Seismic Load Effect, E_h

$$\begin{aligned} Q_E &= F_p \\ E_h &= 0.7 * \rho * Q_E \text{ (Only 70% of seismic load considered as per Section 2.4.1)} \\ &= 0.70 * 1.0000 * 2,053.49 \\ &= 1,437.44 \text{ lb} \end{aligned}$$

Liquid Level

ASME Section VIII Division 1, 2013 Edition	
Location from Datum (in)	135.5
Operating Liquid Specific Gravity	0.993

Support Lugs

Inputs	
Support material	SA-240 304L
This support is attached to	Shell -02
Distance from baseplate to datum	144.9375"
Lug allowable stress, S_b	16,700 psi
Shell to center of load bearing area, d	10.3125"
Lug length, circumferential direction, L	12.375"
Lug attachment fillet weld size	0.25"
Radial/bending lug stiffness ratio	2
Number of support lugs	4
Local Shell	
Outer Diameter	78.625"
Thickness	0.3125"
Inner Corrosion	0"
Outer Corrosion	0"
Base Plate	
Width, b	16.375"
Thickness, t_b	0.75"
Load Bearing Width, L_b	8.0625"
Gusset	
Height, h	15.125"
Thickness, t_g	0.5"
Separation, L_g	9"
Reinforcing Pad	
Width, Circumferential Direction	16"
Length, Longitudinal Direction	20"
Thickness, t_e	0.5"
Attachment Fillet Weld Size	0.25"

Stresses in Shell at Lug Supports

Condition	Total Weight (lb)	Shear V (lbf)	Moment M (lbf-ft)	Lug orient	Lug Loading						Stress in Shell (psi)		
					W (lb)	P _r (lbf)	V _L (lbf)	M _L (lbf-ft)	V _c (lbf)	M _c (lbf-ft)	Primary Circ (P _L)	Primary Long (P _L)	Combined P _L +P _b +Q
Wind, operating Attack angle = 0°	32,172	4,982	23,635	0°	4,826	-1,661	1,968	1,691.36	0	0.00	8,191	4,212	13,220
				90°	8,043	0	8,043	6,911.86	830	713.59	10,032	5,292	29,414
				180°	8,043	1,661	10,901	9,367.61	0	0.00	10,107	5,628	38,846
				270°	8,043	0	8,043	6,911.86	-830	-713.59	10,032	5,292	29,414
Wind, operating Attack angle = 45°	32,172	4,982	23,635	0°	4,826	-881	2,805	2,410.63	-881	-756.88	7,948	4,370	14,730
				90°	4,826	-881	2,805	2,410.63	881	756.88	7,948	4,370	14,730
				180°	8,043	881	10,064	8,648.34	881	756.88	10,349	5,627	35,523
				270°	8,043	881	10,064	8,648.34	-881	-756.88	10,349	5,627	35,523
Wind, operating, new Attack angle = 0°	32,172	4,982	23,635	0°	4,826	-1,661	1,968	1,691.36	0	0.00	8,191	4,212	13,220
				90°	8,043	0	8,043	6,911.86	830	713.59	10,032	5,292	29,414
				180°	8,043	1,661	10,901	9,367.61	0	0.00	10,107	5,628	38,846
				270°	8,043	0	8,043	6,911.86	-830	-713.59	10,032	5,292	29,414
Wind, operating, new Attack angle = 45°	32,172	4,982	23,635	0°	4,826	-881	2,805	2,410.63	-881	-756.88	7,948	4,370	14,730
				90°	4,826	-881	2,805	2,410.63	881	756.88	7,948	4,370	14,730
				180°	8,043	881	10,064	8,648.34	881	756.88	10,349	5,627	35,523
				270°	8,043	881	10,064	8,648.34	-881	-756.88	10,349	5,627	35,523
Wind, empty, new Attack angle = 0°	7,576	4,982	23,635	0°	1,136	-1,661	-1,721	-1,479.16	0	0.00	2,439	1,404	7,646
				90°	1,894	0	1,894	1,627.66	830	713.59	-1,040	-770	6,319
				180°	1,894	1,661	4,752	4,083.42	0	0.00	-4,103	-2,013	-17,639
				270°	1,894	0	1,894	1,627.66	-830	-713.59	-1,040	770	6,319
Wind, empty, new Attack angle = 45°	7,576	4,982	23,635	0°	1,136	-881	-884	-759.88	-881	-756.88	1,277	1,562	7,018
				90°	1,136	-881	-884	-759.88	881	756.88	1,277	1,562	7,018
				180°	1,894	881	3,915	3,364.14	881	756.88	-2,941	-1,562	-13,997
				270°	1,894	881	3,915	3,364.14	-881	-756.88	-2,941	-1,562	-13,997
Wind, vacuum Attack angle = 0°	32,172	4,982	23,635	0°	4,826	-1,661	1,968	1,691.36	0	0.00	-1,849	-980	-8,635
				90°	8,043	0	8,043	6,911.86	830	713.59	-6,251	-3,402	-27,468
				180°	8,043	1,661	10,901	9,367.61	0	0.00	-9,314	-4,830	-38,836
				270°	8,043	0	8,043	6,911.86	-830	-713.59	-6,251	-3,402	-27,468
Wind, vacuum Attack angle = 45°	32,172	4,982	23,635	0°	4,826	-881	2,805	2,410.63	-881	-756.88	-2,583	-1,495	-10,687
				90°	4,826	-881	2,805	2,410.63	881	756.88	-2,583	-1,495	-10,687
				180°	8,043	881	10,064	8,648.34	881	756.88	-8,152	-4,315	-35,172
				270°	8,043	881	10,064	8,648.34	-881	-756.88	-8,152	-4,315	-35,172
Seismic, operating, new Attack angle = 0°	32,172	1,437	10,721	0°	4,694	-479	3,397	2,919.58	0	0.00	7,912	4,014	15,899
				90°	8,175	0	8,175	7,025.40	240	205.88	10,104	5,333	29,775
				180°	8,175	479	9,471	8,139.39	0	0.00	10,385	5,576	33,475
				270°	8,175	0	8,175	7,025.40	-240	-205.88	10,104	5,333	29,775
Seismic, operating, new Attack angle = 45°	32,172	1,437	10,721	0°	4,694	-254	3,777	3,245.86	-254	-218.37	7,919	4,058	16,723
				90°	4,694	-254	3,777	3,245.86	254	218.37	7,919	4,058	16,723

				180°	8,175	254	9,092	7,813.11	254	218.37	10,379	5,532	32,494
				270°	8,175	254	9,092	7,813.11	-254	-218.37	10,379	5,532	32,494
Seismic, empty, new Attack angle = 0°	7,576	339	1,280	0°	1,105	-113	951	816.86	0	0.00	623	331	3,268
				90°	1,925	0	1,925	1,654.40	56	48.48	-1,057	-595	6,349
				180°	1,925	113	2,080	1,787.40	0	0.00	-1,243	-679	-6,993
				270°	1,925	0	1,925	1,654.40	-56	-48.48	-1,057	-595	6,349
Seismic, empty, new Attack angle = 45°	7,576	339	1,280	0°	1,105	-60	996	855.82	-60	-51.42	601	328	3,356
				90°	1,105	-60	996	855.82	60	51.42	601	328	3,356
				180°	1,925	60	2,035	1,748.44	60	51.42	-1,171	-648	-6,780
				270°	1,925	60	2,035	1,748.44	-60	-51.42	-1,171	-648	-6,780
Seismic, vacuum Attack angle = 0°	32,172	1,437	10,721	0°	4,694	-479	3,397	2,919.58	0	0.00	-3,269	-1,810	-12,116
				90°	8,175	0	8,175	7,025.40	240	205.88	-6,323	-3,443	-27,880
				180°	8,175	479	9,471	8,139.39	0	0.00	-7,466	-4,000	-32,721
				270°	8,175	0	8,175	7,025.40	-240	-205.88	-6,323	-3,443	-27,880
Seismic, vacuum Attack angle = 45°	32,172	1,437	10,721	0°	4,694	-254	3,777	3,245.86	-254	-218.37	-3,680	-2,000	-13,125
				90°	4,694	-254	3,777	3,245.86	254	218.37	-3,680	-2,000	-13,125
				180°	8,175	254	9,092	7,813.11	254	218.37	-7,056	-3,810	-31,205
				270°	8,175	254	9,092	7,813.11	-254	-218.37	-7,056	-3,810	-31,205

Applied Loads (Seismic, operating, new, Attack angle = 0°, lug orientation = 180°)	
Radial load, P_r	479.15 lb _f
Circumferential moment, M_c	0 lb _f -in
Circumferential shear, V_c	0 lb _f
Longitudinal moment, M_L	97,672.7 lb _f -in
Longitudinal shear, V_L	9,471.29 lb _f
Torsion moment, M_t	0 lb _f -in
Internal pressure, P	45 psi
Mean shell radius, R_m	39.1563"
Local shell thickness, T	0.3125"
Design factor	3

Maximum stresses due to the applied loads at the pad edge (includes pressure)

$$\gamma = R_m / T = 39.1563 / 0.3125 = 125.3$$

$$C_1 = 8, C_2 = 10 \text{ in}$$

$$\text{Local circumferential pressure stress} = P \cdot R_i / T = 5,616 \text{ psi}$$

$$\text{Local longitudinal pressure stress} = P \cdot R_i / (2 \cdot T) = 2,808 \text{ psi}$$

$$\text{Maximum combined stress } (P_L + P_b + Q) = 17,154 \text{ psi}$$

$$\text{Allowable combined stress } (P_L + P_b + Q) = \pm 3 \cdot S = \pm 48,900 \text{ psi}$$

The maximum combined stress ($P_L + P_b + Q$) is within allowable limits.

Maximum local primary membrane stress (P_L) = 10,385 psi

Allowable local primary membrane stress (P_L) = $\pm 1.5 \cdot S = \pm 24,450$ psi

The maximum local primary membrane stress (P_L) is within allowable limits.

Stresses at the pad edge per WRC Bulletin 107										
Figure	value	β	A_u	A_l	B_u	B_l	C_u	C_l	D_u	D_l
3C*	3.5638	0.2577	0	0	0	0	-140	-140	-140	-140
4C*	11.0052	0.2406	-431	-431	-431	-431	0	0	0	0
1C	0.06	0.2211	0	0	0	0	-1,766	1,766	-1,766	1,766
2C-1	0.0131	0.2211	-386	386	-386	386	0	0	0	0
3A*	3.5533	0.2201	0	0	0	0	0	0	0	0
1A	0.0532	0.2314	0	0	0	0	0	0	0	0
3B*	6.9564	0.2371	-5,200	-5,200	5,200	5,200	0	0	0	0
1B-1	0.0105	0.2249	-7,155	7,155	7,155	-7,155	0	0	0	0
Pressure stress*			5,616	5,616	5,616	5,616	5,616	5,616	5,616	5,616
Total circumferential stress			-7,556	7,526	17,154	3,616	3,710	7,242	3,710	7,242
Primary membrane circumferential stress*			-15	-15	10,385	10,385	5,476	5,476	5,476	5,476
3C*	4.021	0.2406	-157	-157	-157	-157	0	0	0	0
4C*	10.3463	0.2577	0	0	0	0	-405	-405	-405	-405
1C-1	0.0285	0.2437	-839	839	-839	839	0	0	0	0
2C	0.0323	0.2437	0	0	0	0	-951	951	-951	951
4A*	10.9824	0.2201	0	0	0	0	0	0	0	0
2A	0.0212	0.2535	0	0	0	0	0	0	0	0
4B*	3.3944	0.2371	-2,925	-2,925	2,925	2,925	0	0	0	0
2B-1	0.0138	0.2471	-8,558	8,558	8,558	-8,558	0	0	0	0
Pressure stress*			2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808
Total longitudinal stress			-9,671	9,123	13,295	-2,143	1,452	3,354	1,452	3,354
Primary membrane longitudinal stress*			-274	-274	5,576	5,576	2,403	2,403	2,403	2,403
Shear from M_t			0	0	0	0	0	0	0	0
Circ shear from V_c			0	0	0	0	0	0	0	0
Long shear from V_L			0	0	0	0	-758	-758	758	758
Total Shear stress			0	0	0	0	-758	-758	758	758
Combined stress (P_L+P_B+Q)			-9,671	9,123	17,154	-5,759	3,941	7,385	3,941	7,385

* denotes primary stress.

Applied Loads (Seismic, operating, new, Attack angle = 0°, lug orientation = 180°)	
Radial load, P_r	239.57 lb _f
Circumferential moment, M_c	0 lb _f -in
Circumferential shear, V_c	0 lb _f
Longitudinal moment, M_L	48,836.4 lb _f -in
Longitudinal shear, V_L	4,735.65 lb _f
Torsion moment, M_t	0 lb _f -in
Internal pressure, P	45 psi
Mean shell radius, R_m	39.1563"
Local shell thickness, T	0.8125"
Design factor	3

Maximum stresses due to the applied loads at the lug edge (includes pressure)

$$\gamma = R_m / T = 39.1563 / 0.8125 = 48.1923$$

$$C_1 = 0.5, C_2 = 2 \text{ in}$$

Note: Actual lug $C_1 / C_2 < 1 / 4$, $C_1 / C_2 = 1 / 4$ used as this is the minimum ratio covered by WRC 107.

$$\text{Local circumferential pressure stress} = P \cdot R_i / T = 5,616 \text{ psi}$$

$$\text{Local longitudinal pressure stress} = P \cdot R_i / (2 \cdot T) = 2,808 \text{ psi}$$

$$\text{Maximum combined stress } (P_L + P_b + Q) = 33,475 \text{ psi}$$

$$\text{Allowable combined stress } (P_L + P_b + Q) = \pm 3 \cdot S = \pm 48,900 \text{ psi}$$

The maximum combined stress $(P_L + P_b + Q)$ is within allowable limits.

$$\text{Maximum local primary membrane stress } (P_L) = 6,798 \text{ psi}$$

$$\text{Allowable local primary membrane stress } (P_L) = \pm 1.5 \cdot S = \pm 24,450 \text{ psi}$$

The maximum local primary membrane stress (P_L) is within allowable limits.

Stresses at the lug edge per WRC Bulletin 107

Figure	value	β	A_u	A_l	B_u	B_l	C_u	C_l	D_u	D_l
3C*	9.2315	0.0378	0	0	0	0	-70	-70	-70	-70
4C*	9.4401	0.0306	-71	-71	-71	-71	0	0	0	0
1C	0.2688	0.0225	0	0	0	0	-585	585	-585	585
2C-1	0.2293	0.0225	-499	499	-499	499	0	0	0	0
3A*	0.236	0.0203	0	0	0	0	0	0	0	0
1A	0.1052	0.0252	0	0	0	0	0	0	0	0
3B*	1.6759	0.0322	-1,253	-1,253	1,253	1,253	0	0	0	0
1B-1	0.0632	0.0277	-25,827	25,827	25,827	-25,827	0	0	0	0
Pressure stress*			5,616	5,616	5,616	5,616	5,616	5,616	5,616	5,616
Total circumferential stress			-22,034	30,618	32,126	-18,530	4,961	6,131	4,961	6,131
Primary membrane circumferential stress*			4,292	4,292	6,798	6,798	5,546	5,546	5,546	5,546
3C*	9.4365	0.0306	-71	-71	-71	-71	0	0	0	0
4C*	9.3382	0.0378	0	0	0	0	-70	-70	-70	-70
1C-1	0.2283	0.0319	-497	497	-497	497	0	0	0	0
2C	0.179	0.0319	0	0	0	0	-390	390	-390	390
4A*	0.2807	0.0203	0	0	0	0	0	0	0	0
2A	0.0633	0.0331	0	0	0	0	0	0	0	0
4B*	0.4364	0.0322	-603	-603	603	603	0	0	0	0
2B-1	0.1037	0.0384	-30,632	30,632	30,632	-30,632	0	0	0	0
Pressure stress*			2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808
Total longitudinal stress			-28,995	33,263	33,475	-26,795	2,348	3,128	2,348	3,128
Primary membrane longitudinal stress*			2,134	2,134	3,340	3,340	2,738	2,738	2,738	2,738
Shear from M_t			0	0	0	0	0	0	0	0
Circ shear from V_c			0	0	0	0	0	0	0	0
Long shear from V_L			0	0	0	0	-729	-729	729	729
Total Shear stress			0	0	0	0	-729	-729	729	729
Combined stress (P_L+P_B+Q)			-28,995	33,263	33,475	-26,795	5,151	6,299	5,151	6,299
* denotes primary stress.										

Applied Loads (Wind, operating, Attack angle = 0°, lug orientation = 180°)	
Radial load, P_r	1,660.73 lb _f
Circumferential moment, M_c	0 lb _f -in
Circumferential shear, V_c	0 lb _f
Longitudinal moment, M_L	112,411.4 lb _f -in
Longitudinal shear, V_L	10,900.5 lb _f
Torsion moment, M_t	0 lb _f -in
Internal pressure, P	45 psi
Mean shell radius, R_m	39.1563"
Local shell thickness, T	0.3125"
Design factor	3

Maximum stresses due to the applied loads at the pad edge (includes pressure)

$$\gamma = R_m / T = 39.1563 / 0.3125 = 125.3$$

$$C_1 = 8, C_2 = 10 \text{ in}$$

$$\text{Local circumferential pressure stress} = P \cdot R_i / T = 5,616 \text{ psi}$$

$$\text{Local longitudinal pressure stress} = P \cdot R_i / (2 \cdot T) = 2,808 \text{ psi}$$

$$\text{Maximum combined stress } (P_L + P_b + Q) = 17,005 \text{ psi}$$

$$\text{Allowable combined stress } (P_L + P_b + Q) = \pm 3 \cdot S = \pm 48,900 \text{ psi}$$

The maximum combined stress ($P_L + P_b + Q$) is within allowable limits.

$$\text{Maximum local primary membrane stress } (P_L) = 10,107 \text{ psi}$$

$$\text{Allowable local primary membrane stress } (P_L) = \pm 1.5 \cdot S = \pm 24,450 \text{ psi}$$

The maximum local primary membrane stress (P_L) is within allowable limits.

Stresses at the pad edge per WRC Bulletin 107

Figure	value	β	A_u	A_l	B_u	B_l	C_u	C_l	D_u	D_l
3C*	3.5638	0.2577	0	0	0	0	-484	-484	-484	-484
4C*	11.0052	0.2406	-1,494	-1,494	-1,494	-1,494	0	0	0	0
1C	0.06	0.2211	0	0	0	0	-6,122	6,122	-6,122	6,122
2C-1	0.0131	0.2211	-1,337	1,337	-1,337	1,337	0	0	0	0
3A*	3.5533	0.2201	0	0	0	0	0	0	0	0
1A	0.0532	0.2314	0	0	0	0	0	0	0	0
3B*	6.9564	0.2371	-5,985	-5,985	5,985	5,985	0	0	0	0
1B-1	0.0105	0.2249	-8,235	8,235	8,235	-8,235	0	0	0	0
Pressure stress*			5,616	5,616	5,616	5,616	5,616	5,616	5,616	5,616
Total circumferential stress			-11,435	7,709	17,005	3,209	-990	11,254	-990	11,254
Primary membrane circumferential stress*			-1,863	-1,863	10,107	10,107	5,132	5,132	5,132	5,132
3C*	4.021	0.2406	-546	-546	-546	-546	0	0	0	0
4C*	10.3463	0.2577	0	0	0	0	-1,404	-1,404	-1,404	-1,404
1C-1	0.0285	0.2437	-2,908	2,908	-2,908	2,908	0	0	0	0
2C	0.0323	0.2437	0	0	0	0	-3,296	3,296	-3,296	3,296
4A*	10.9824	0.2201	0	0	0	0	0	0	0	0
2A	0.0212	0.2535	0	0	0	0	0	0	0	0
4B*	3.3944	0.2371	-3,366	-3,366	3,366	3,366	0	0	0	0
2B-1	0.0138	0.2471	-9,850	9,850	9,850	-9,850	0	0	0	0
Pressure stress*			2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808
Total longitudinal stress			-13,862	11,654	12,570	-1,314	-1,892	4,700	-1,892	4,700
Primary membrane longitudinal stress*			-1,104	-1,104	5,628	5,628	1,404	1,404	1,404	1,404
Shear from M_t			0	0	0	0	0	0	0	0
Circ shear from V_c			0	0	0	0	0	0	0	0
Long shear from V_L			0	0	0	0	-872	-872	872	872
Total Shear stress			0	0	0	0	-872	-872	872	872
Combined stress (P_L+P_D+Q)			-13,862	11,654	17,005	-4,523	-2,423	11,368	-2,423	11,368

* denotes primary stress.

Applied Loads (Wind, operating, Attack angle = 0°, lug orientation = 180°)

Radial load, P_r	830.37 lb _f
Circumferential moment, M_c	0 lb _f -in
Circumferential shear, V_c	0 lb _f
Longitudinal moment, M_L	56,205.7 lb _f -in
Longitudinal shear, V_L	5,450.25 lb _f
Torsion moment, M_t	0 lb _f -in
Internal pressure, P	45 psi
Mean shell radius, R_m	39.1563"
Local shell thickness, T	0.8125"
Design factor	3

Maximum stresses due to the applied loads at the lug edge (includes pressure)

$$\gamma = R_m / T = 39.1563 / 0.8125 = 48.1923$$

$$C_1 = 0.5, C_2 = 2 \text{ in}$$

Note: Actual lug $C_1 / C_2 < 1 / 4$, $C_1 / C_2 = 1 / 4$ used as this is the minimum ratio covered by WRC 107.

$$\text{Local circumferential pressure stress} = P \cdot R_i / T = 5,616 \text{ psi}$$

$$\text{Local longitudinal pressure stress} = P \cdot R_i / (2 \cdot T) = 2,808 \text{ psi}$$

$$\text{Maximum combined stress } (P_L + P_b + Q) = 38,846 \text{ psi}$$

$$\text{Allowable combined stress } (P_L + P_b + Q) = \pm 3 \cdot S = \pm 48,900 \text{ psi}$$

The maximum combined stress $(P_L + P_b + Q)$ is within allowable limits.

$$\text{Maximum local primary membrane stress } (P_L) = 6,812 \text{ psi}$$

$$\text{Allowable local primary membrane stress } (P_L) = \pm 1.5 \cdot S = \pm 24,450 \text{ psi}$$

The maximum local primary membrane stress (P_L) is within allowable limits.

Stresses at the lug edge per WRC Bulletin 107

Figure	value	β	A_u	A_l	B_u	B_l	C_u	C_l	D_u	D_l
3C*	9.2315	0.0378	0	0	0	0	-241	-241	-241	-241
4C*	9.4401	0.0306	-246	-246	-246	-246	0	0	0	0
1C	0.2688	0.0225	0	0	0	0	-2,029	2,029	-2,029	2,029
2C-1	0.2293	0.0225	-1,731	1,731	-1,731	1,731	0	0	0	0
3A*	0.236	0.0203	0	0	0	0	0	0	0	0
1A	0.1052	0.0252	0	0	0	0	0	0	0	0
3B*	1.6759	0.0322	-1,442	-1,442	1,442	1,442	0	0	0	0
1B-1	0.0632	0.0277	-29,724	29,724	29,724	-29,724	0	0	0	0
Pressure stress*			5,616	5,616	5,616	5,616	5,616	5,616	5,616	5,616
Total circumferential stress			-27,527	35,383	34,805	-21,181	3,346	7,404	3,346	7,404
Primary membrane circumferential stress*			3,928	3,928	6,812	6,812	5,375	5,375	5,375	5,375
3C*	9.4365	0.0306	-246	-246	-246	-246	0	0	0	0
4C*	9.3382	0.0378	0	0	0	0	-244	-244	-244	-244
1C-1	0.2283	0.0319	-1,723	1,723	-1,723	1,723	0	0	0	0
2C	0.179	0.0319	0	0	0	0	-1,351	1,351	-1,351	1,351
4A*	0.2807	0.0203	0	0	0	0	0	0	0	0
2A	0.0633	0.0331	0	0	0	0	0	0	0	0
4B*	0.4364	0.0322	-694	-694	694	694	0	0	0	0
2B-1	0.1037	0.0384	-35,255	35,255	35,255	-35,255	0	0	0	0
Pressure stress*			2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808
Total longitudinal stress			-35,110	38,846	36,788	-30,276	1,213	3,915	1,213	3,915
Primary membrane longitudinal stress*			1,868	1,868	3,256	3,256	2,564	2,564	2,564	2,564
Shear from M_t			0	0	0	0	0	0	0	0
Circ shear from V_c			0	0	0	0	0	0	0	0
Long shear from V_L			0	0	0	0	-838	-838	838	838
Total Shear stress			0	0	0	0	-838	-838	838	838
Combined stress (P_L+P_B+Q)			-35,110	38,846	36,788	-30,276	3,636	7,595	3,636	7,595
* denotes primary stress.										

Gusset plate required thickness, Bednar 5.2

$$\begin{aligned} S_c &= 12,525 / (1 + (1/12,525) * (h / (0.289 * t_g))^2) \\ &= 12,525 / (1 + (1/12,525) * (15.125 / (0.289 * 0.5))^2) \\ &= 6,681 \text{ psi} \end{aligned}$$

$$\begin{aligned} t_g &= V_L * (3 * d - b) / (S_c * b^2 * \sin(\alpha)^2) \\ &= 10,900.5 * (3 * 10.3125 - 16.375) / (6,681 * 16.375^2 * \sin(42.728)^2) \\ &= 0.1925 \text{ in} \end{aligned}$$

The gusset thickness of 0.5 in is adequate.

Lug base plate required thickness

From Escoe table 4-8 ($l/b = 1.8194$)

$$C_x = 0.12811, C_y = -0.12464$$

$$\begin{aligned} f_c &= V_L / (L_b * L) \\ &= 10,900.5 / (8.0625 * 12.375) \\ &= 109 \text{ psi} \end{aligned}$$

$$\begin{aligned} M_x &= C_x * f_c * L_g^2 \\ &= 0.12811 * 109 * 9^2 \\ &= 1,133.7 \text{ in-lb/in} \end{aligned}$$

$$\begin{aligned} M_y &= C_y * f_c * L_b^2 \\ &= -0.12464 * 109 * 8.0625^2 \\ &= -885.17 \text{ in-lb/in} \end{aligned}$$

$$\begin{aligned} M &= \text{Max}[\text{Abs}(M_x), \text{Abs}(M_y)] \\ &= \text{Max}[\text{Abs}(1,133.7), \text{Abs}(-885.17)] \\ &= 1,133.7 \text{ in-lb/in} \end{aligned}$$

$$\begin{aligned} t_b &= \text{Sqr}(6 * M / S_b) \\ &= \text{Sqr}(6 * 1,133.7 / 16,700) \\ &= 0.6382 \text{ in} \end{aligned}$$

The base plate thickness of 0.75 in is adequate.

Support Lug to Pad Fillet Weld Sizing - Bednar chapters 5.2 and 10.3

Note: continuous welding on both sides of the gusset is assumed for all support lug fillet welds.

$$d_h = t_a + h + t_b$$

$$\begin{aligned} L_w &= b + 2 * d_h = 12.375 + 2 * 15.875 = 44.125 \text{ in} \\ Z_w &= (2 * b * d_h + d_h^2) / 3 = (2 * 12.375 * 15.875 + 15.875^2) / 3 = 214.97 \text{ in}^2 \\ Z_z &= (2 * d_h * b + b^2) / 3 = (2 * 15.875 * 12.375 + 12.375^2) / 3 = 182.02 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Shear } f_1 &= V_L / L_w = 10,900.5 / 44.125 = 247 \text{ lb/in} \\ \text{Shear } f_2 &= V_c / L_w = 0 / 44.125 = 0 \text{ lb/in} \\ \text{Bending } f_3 &= \text{larger absolute value of } M_L / Z_w \text{ or } M_c / Z_z \\ &= M_L / Z_w \\ &= 112,411.4 / 214.97 \\ &= 522.91 \text{ lb/in} \end{aligned}$$

$$\text{Resultant load } f = (f_1^2 + f_2^2 + f_3^2)^{1/2}$$

$$= (247.04^2 + 0^2 + 522.91^2)^{1/2}$$
$$= 578.32 \text{ lb}_f/\text{in}$$

$$\text{Required weld size } w = F/(0.707 \cdot 0.55 \cdot S_a)$$

$$= 578.32/(0.707 \cdot 0.55 \cdot 16,300)$$
$$= 0.0912 \text{ in}$$

The support lug fillet weld size of 0.25 in is adequate.

Support Lug Pad to Shell Fillet Weld Sizing - Bednar chapters 5.2 and 10.3

$$L_w = 2 \cdot (b + d_h) = 2 \cdot (16 + 20) = 72 \text{ in}$$

$$Z_w = b \cdot d_h + d_h^2/3 = 16 \cdot 16 + 20^2/3 = 453.33 \text{ in}^2$$

$$Z_z = d_h \cdot b + b^2/3 = 20 \cdot 16 + 16^2/3 = 405.33 \text{ in}^2$$

$$\text{Shear } f_1 = V_L/L_w = 10,900.5/72 = 151 \text{ lb}_f/\text{in}$$

$$\text{Shear } f_2 = V_c/L_w = 0/72 = 0 \text{ lb}_f/\text{in}$$

$$\text{Bending } f_3 = \text{larger absolute value of } M_L/Z_w \text{ or } M_c/Z_z$$

$$= M_L/Z_w$$

$$= 112,411.4/453.33$$

$$= 247.97 \text{ lb}_f/\text{in}$$

$$\text{Resultant load } f = (f_1^2 + f_2^2 + f_3^2)^{1/2}$$

$$= (151.4^2 + 0^2 + 247.97^2)^{1/2}$$
$$= 290.53 \text{ lb}_f/\text{in}$$

$$\text{Required weld size } w = F/(0.707 \cdot 0.55 \cdot S_a)$$

$$= 290.53/(0.707 \cdot 0.55 \cdot 16,300)$$
$$= 0.0458 \text{ in}$$

The support lug pad fillet weld size of 0.25 in is adequate.

Vacuum Ring

ASME Section VIII Division 1, 2013 Edition	
Attached to	Shell -01
Ring type	Flat bar
Description	3/8x3.5 Flat Bar
Material	SA-240 304L (II-D p. 86, ln. 43)
External design pressure	14.7 psi
External design temperature	338 °F
Corrosion allowance	0"
Distance from ring neutral axis to datum	83.5"
Distance to previous support	88.9168"
Distance to next support	87.9168"
Internal ring	No
Welds	
Weld configuration	Continuous both sides
Fillet weld leg size	0.25"
Vessel thickness at weld location, new	0.3125"
Vessel corrosion allowance at weld location	0"
Stiffener thickness at weld location	0.375"
Ring Properties	
Max depth to thickness ratio	12
Ring distance to centroid	1.75"
Ring area	1.3125 in ²
Ring inertia	1.3398 in ⁴

External Pressure, (Corroded & at 338 °F) UG-29(a)

$$L / D_o = 88.9168 / 78.625 = 1.1309$$

$$D_o / t = 78.625 / 0.2736 = 287.3773$$

$$\text{From Table G: } A = 2.4161\text{E-}04$$

$$\text{From Table HA-4: } B = 3,171.23 \text{ psi}$$

$$\begin{aligned} P_a &= 4*B / (3*(D_o / t)) \\ &= 4*3,171.23 / (3*(78.625 / 0.273595)) \\ &= 14.71 \text{ psi} \end{aligned}$$

$$\begin{aligned} B &= 0.75*P*D_o / (t + A_s / L_s) \\ &= 0.75*14.7*78.625 / (0.2736 + 1.3125 / 88.4168) \\ &= 3,005 \text{ psi} \end{aligned}$$

$$\text{From Table HA-3: } A = 0.00022966 \text{ (ring, 338 °F)}$$

From Table HA-4: $A = 0.00022899$ (shell, 338°F)

$$\begin{aligned} I'_s &= [D_o^2 * L_s * (t + A_s / L_s) * A] / 10.9 \\ &= [78.625^2 * 88.4168 * (0.2736 + 1.3125 / 88.4168) * 0.00022966] / 10.9 \\ &= 3.3219 \text{ in}^4 \end{aligned}$$

I' for the composite corroded shell-ring cross section is 4.0478 in⁴

As $I' \geq I'_s$ a 3/8x3.5 Flat Bar stiffener is adequate for an external pressure of 14.7 psi.

Check the stiffener ring attachment welds per UG-30

Per UG-30(f)(1) the minimum attachment weld size is 0.25 in

The fillet weld size of 0.25 in is adequate per UG-30(f)(1).

Radial pressure load, $P * L_s = 14.7 * 88.4168 = 1,299.73 \text{ lb}_f/\text{in}$

Radial shear load, $V = 0.01 * P * L_s * D_o = 0.01 * 14.7 * 88.4168 * 78.625 = 1,021.91 \text{ lb}_f$

First moment of area, $Q = 1.7 * 0.8294 = 1.4133 \text{ in}^3$

Weld shear flow, $q = V * Q / I' = 356.8059 \text{ lb}_f/\text{in}$

Combined weld load, $f_w = \text{Sqr}(1,299.7274^2 + 356.8059^2) = 1,347.81 \text{ lb}_f/\text{in}$

Allowable weld stress per UW-18(d) $S_w = 0.55 * S = 0.55 * 16,300 = 8,965 \text{ psi}$

Fillet weld size required to resist radial pressure and shear

$$\begin{aligned} t_w &= f_w * (d_{\text{weld segment}} + d_{\text{toe}}) / (S_w * d_{\text{weld total}}) + \text{corrosion} \\ &= 1,347.81 * (1 + 0) / (8,965 * 2) + 0 \\ &= 0.0752 \text{ in} \end{aligned}$$

The fillet weld size of 0.25 in is adequate to resist radial pressure and shear.

Maximum Allowable External Pressure, (Corroded & at 338°F) UG-29(a)

$$L / D_o = 88.9168 / 78.625 = 1.1309$$

$$D_o / t = 78.625 / 0.2958 = 265.8082$$

From Table G: $A = 2.723E-04$

From Table HA-4: $B = 3,575.1 \text{ psi}$

$$\begin{aligned} P_a &= 4 * B / (3 * (D_o / t)) \\ &= 4 * 3,575.1 / (3 * (78.625 / 0.295796)) \\ &= 17.93 \text{ psi} \end{aligned}$$

$$\begin{aligned} B &= 0.75 * P * D_o / (t + A_s / L_s) \\ &= 0.75 * 17.92 * 78.625 / (0.2958 + 1.3125 / 88.4168) \\ &= 3,401 \text{ psi} \end{aligned}$$

From Table HA-3: $A = 0.00025985$ (ring, 338°F)

From Table HA-4: $A = 0.00025908$ (shell, 338°F)

$$\begin{aligned} I'_s &= [D_o^2 * L_s * (t + A_s / L_s) * A] / 10.9 \\ &= [78.625^2 * 88.4168 * (0.2958 + 1.3125 / 88.4168) * 0.00025985] / 10.9 \\ &= 4.0478 \text{ in}^4 \end{aligned}$$

I' for the composite corroded shell-ring cross section is 4.0478 in⁴

As $I' \geq I'_s$ a 3/8x3.5 Flat Bar stiffener is adequate for an external pressure of 17.92 psi.

Check the stiffener ring attachment welds per UG-30

Per UG-30(f)(1) the minimum attachment weld size is 0.25 in

The fillet weld size of 0.25 in is adequate per UG-30(f)(1).

Radial pressure load, $P \cdot L_s = 17.92 \cdot 88.4168 = 1,584.14 \text{ lb}_f/\text{in}$

Radial shear load, $V = 0.01 \cdot P \cdot L_s \cdot D_o = 0.01 \cdot 17.92 \cdot 88.4168 \cdot 78.625 = 1,245.53 \text{ lb}_f$

First moment of area, $Q = 1.7 \cdot 0.8294 = 1.4133 \text{ in}^3$

Weld shear flow, $q = V \cdot Q / I' = 434.8852 \text{ lb}_f/\text{in}$

Combined weld load, $f_w = \text{Sqr}(1,584.1447^2 + 434.8852^2) = 1,642.75 \text{ lb}_f/\text{in}$

Allowable weld stress per UW-18(d) $S_w = 0.55 \cdot S = 0.55 \cdot 16,300 = 8,965 \text{ psi}$

Fillet weld size required to resist radial pressure and shear

$$\begin{aligned} t_w &= f_w \cdot (d_{\text{weld segment}} + d_{\text{toe}}) / (S_w \cdot d_{\text{weld total}}) + \text{corrosion} \\ &= 1,642.75 \cdot (1 + 0) / (8,965 \cdot 2) + 0 \\ &= 0.0916 \text{ in} \end{aligned}$$

The fillet weld size of 0.25 in is adequate to resist radial pressure and shear.

F&D Head (top)

ASME Section VIII Division 1, 2013 Edition				
Component		F&D Head		
Material		SA-240 316L (II-D p. 74, ln. 9)		
Attached To		Shell -02		
Impact Tested	Normalized	Fine Grain Practice	PWHT	Optimize MDMT/ Find MAWP
No	No	No	No	No
		Design Pressure (psi)	Design Temperature (°F)	Design MDMT (°F)
Internal		45	338	-20
External		14.7	338	
Static Liquid Head				
Condition		P_s (psi)	H_s (in)	SG
Test horizontal		2.82	78	1
Dimensions				
Inner Diameter		78"		
Crown Radius L		78"		
Knuckle Radius r		4.75"		
Minimum Thickness		0.4"		
Corrosion	Inner	0"		
	Outer	0"		
Length L_{sf}		1.5"		
Nominal Thickness t_{sf}		0.5"		
Weight and Capacity				
		Weight (lb)¹		Capacity (US gal)¹
New		649.05		198.26
Corroded		649.05		198.26
Insulation				
		Thickness (in)	Density (lb/ft³)	Weight (lb)
Insulation		2	12	92.01
		Spacing(in)	Individual Weight (lb)	Total Weight (lb)
Insulation Supports		0	0	0
Radiography				
Category A joints		Full UW-11(a) Type 1		

Head to shell seam	Full UW-11(a) Type 1
---------------------------	----------------------

¹includes straight flange

Results Summary	
Governing condition	external pressure
Minimum thickness per UG-16	0.0625" + 0" = 0.0625"
Design thickness due to internal pressure (t)	0.1899"
Design thickness due to external pressure (t _e)	0.2346"
Maximum allowable working pressure (MAWP)	94.77 psi
Maximum allowable pressure (MAP)	97.09 psi
Maximum allowable external pressure (MAEP)	32.18 psi
Rated MDMT	-320 °F

UHA-51 Material Toughness Requirements	
$t_r = 45 \cdot 78 \cdot 1 / (2 \cdot 16,700 \cdot 1 - 0.2 \cdot 45) =$	0.1051"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.1051 \cdot 1 / (0.4 - 0) =$	0.2628
Impact test exempt per UHA-51(g) (coincident ratio = 0.2628)	
Rated MDMT =	-320 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.	

Factor M		
$M = 1/4 \cdot [3 + (L / r)^{1/2}]$		
Corroded	$M = 1/4 \cdot [3 + (78 / 4.75)^{1/2}]$	1.7631
New	$M = 1/4 \cdot [3 + (78 / 4.75)^{1/2}]$	1.7631

Design thickness for internal pressure, (Corroded at 338 °F) Appendix 1-4(d)

$$\begin{aligned}
 t &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) + \text{Corrosion} \\
 &= 45 \cdot 78 \cdot 1.7631 / (2 \cdot 16,300 \cdot 1 - 0.2 \cdot 45) + 0 \\
 &= \a href="#">0.1899"
 \end{aligned}$$

Maximum allowable working pressure, (Corroded at 338 °F) Appendix 1-4(d)

$$\begin{aligned}
 P &= 2 \cdot S \cdot E \cdot t / (L \cdot M + 0.2 \cdot t) - P_s \\
 &= 2 \cdot 16,300 \cdot 1 \cdot 0.4 / (78 \cdot 1.7631 + 0.2 \cdot 0.4) - 0 \\
 &= \a href="#">94.77 \text{ psi}
 \end{aligned}$$

Maximum allowable pressure, (New at 70 °F) Appendix 1-4(d)

$$\begin{aligned}
 P &= 2 \cdot S \cdot E \cdot t / (L \cdot M + 0.2 \cdot t) - P_s \\
 &= 2 \cdot 16,700 \cdot 1 \cdot 0.4 / (78 \cdot 1.7631 + 0.2 \cdot 0.4) - 0 \\
 &= \a href="#">97.09 \text{ psi}
 \end{aligned}$$

Design thickness for external pressure, (Corroded at 338 °F) UG-33(e)

Equivalent outside spherical radius (R_o)

$$\begin{aligned} &= \text{Outside crown radius} \\ &= 78.4 \text{ in} \end{aligned}$$

$$\begin{aligned} A &= 0.125 / (R_o / t) \\ &= 0.125 / (78.4 / 0.234551) \\ &= 0.000374 \end{aligned}$$

From Table HA-4: $B = 4,913.5547$ psi

$$\begin{aligned} P_a &= B / (R_o / t) \\ &= 4,913.5547 / (78.4 / 0.2346) \\ &= 14.7 \text{ psi} \end{aligned}$$

$$t = 0.2346" + \text{Corrosion} = 0.2346" + 0" = 0.2346"$$

Check the external pressure per UG-33(a)(1) Appendix 1-4(d)

$$\begin{aligned} t &= 1.67 * P_e * L * M / (2 * S * E - 0.2 * 1.67 * P_e) + \text{Corrosion} \\ &= 1.67 * 14.7 * 78 * 1.7631 / (2 * 16,300 * 1 - 0.2 * 1.67 * 14.7) + 0 \\ &= 0.1036" \end{aligned}$$

The head external pressure design thickness (t_e) is [0.2346"](#).

Maximum Allowable External Pressure, (Corroded at 338 °F) UG-33(e)

Equivalent outside spherical radius (R_o)

$$\begin{aligned} &= \text{Outside crown radius} \\ &= 78.4 \text{ in} \end{aligned}$$

$$\begin{aligned} A &= 0.125 / (R_o / t) \\ &= 0.125 / (78.4 / 0.4) \\ &= 0.000638 \end{aligned}$$

From Table HA-4: $B = 6,308.0192$ psi

$$\begin{aligned} P_a &= B / (R_o / t) \\ &= 6,308.0192 / (78.4 / 0.4) \\ &= 32.1838 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure, UG-33(a)(1) Appendix 1-4(d)

$$\begin{aligned} P &= 2 * S * E * t / ((L * M + 0.2 * t) * 1.67) \\ &= 2 * 16,300 * 1 * 0.4 / ((78 * 1.7631 + 0.2 * 0.4) * 1.67) \\ &= 56.75 \text{ psi} \end{aligned}$$

The maximum allowable external pressure (MAEP) is [32.18](#) psi.

% Forming strain - UHA-44(a)(2)

$$\begin{aligned} \text{EFE} &= (75 \cdot t / R_i) \cdot (1 - R_f / R_o) \\ &= (75 \cdot 0.5 / 5) \cdot (1 - 5 / \infty) \\ &= 7.5\% \end{aligned}$$

Straight Flange on F&D Head (top)

ASME Section VIII Division 1, 2013 Edition				
Component		Cylinder		
Material		SA-240 316L (II-D p. 74, In. 9)		
Impact Tested	Normalized	Fine Grain Practice	PWHT	Optimize MDMT/ Find MAWP
No	No	No	No	No
		Design Pressure (psi)	Design Temperature (°F)	Design MDMT (°F)
Internal		45	338	-20
External		14.7	338	
Static Liquid Head				
Condition		P_s (psi)	H_s (in)	SG
Test horizontal		2.82	78	1
Dimensions				
Inner Diameter		78"		
Length		1.5"		
Nominal Thickness		0.5"		
Corrosion	Inner	0"		
	Outer	0"		
Weight and Capacity				
		Weight (lb)		Capacity (US gal)
New		53.64		31.03
Corroded		53.64		31.03
Insulation				
		Thickness (in)	Density (lb/ft³)	Weight (lb)
Insulation		2	12	0
		Spacing(in)	Individual Weight (lb)	Total Weight (lb)
Insulation Supports		0	0	0
Radiography				
Longitudinal seam		Full UW-11(a) Type 1		
Bottom Circumferential seam		Full UW-11(a) Type 1		

Results Summary	
Governing condition	External pressure
Minimum thickness per UG-16	0.0625" + 0" = 0.0625"
Design thickness due to internal pressure (t)	0.1079"
Design thickness due to external pressure (t _e)	0.2743"
Design thickness due to combined loadings + corrosion	0.0448"
Maximum allowable working pressure (MAWP)	207.38 psi
Maximum allowable pressure (MAP)	212.47 psi
Maximum allowable external pressure (MAEP)	52.69 psi
Rated MDMT	-320 °F

UHA-51 Material Toughness Requirements	
$t_r = 45 \cdot 39 / (16,700 \cdot 1 - 0.6 \cdot 45) =$	0.1053"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.1053 \cdot 1 / (0.5 - 0) =$	0.2105
Impact test exempt per UHA-51(g) (coincident ratio = 0.2105)	
Rated MDMT =	-320 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.	

Design thickness, (at 338 °F) UG-27(c)(1)

$$\begin{aligned}
 t &= P \cdot R / (S \cdot E - 0.60 \cdot P) + \text{Corrosion} \\
 &= 45 \cdot 39 / (16,300 \cdot 1.00 - 0.60 \cdot 45) + 0 \\
 &= \a href="#">0.1079"
 \end{aligned}$$

Maximum allowable working pressure, (at 338 °F) UG-27(c)(1)

$$\begin{aligned}
 P &= S \cdot E \cdot t / (R + 0.60 \cdot t) - P_s \\
 &= 16,300 \cdot 1.00 \cdot 0.5 / (39 + 0.60 \cdot 0.5) - 0 \\
 &= \a href="#">207.38 \text{ psi}
 \end{aligned}$$

Maximum allowable pressure, (at 70 °F) UG-27(c)(1)

$$\begin{aligned}
 P &= S \cdot E \cdot t / (R + 0.60 \cdot t) \\
 &= 16,700 \cdot 1.00 \cdot 0.5 / (39 + 0.60 \cdot 0.5) \\
 &= \a href="#">212.47 \text{ psi}
 \end{aligned}$$

External Pressure, (Corroded & at 338 °F) UG-28(c)

$$\begin{aligned}
 L / D_o &= 88.9168 / 79 = 1.1255 \\
 D_o / t &= 79 / 0.2743 = 288.0010 \\
 \text{From table G: } A &= 0.000242 \\
 \text{From table HA-4: } B &= 3,175.2138 \text{ psi}
 \end{aligned}$$

$$\begin{aligned}
 P_a &= 4 \cdot B / (3 \cdot (D_o / t)) \\
 &= 4 \cdot 3,175.21 / (3 \cdot (79 / 0.2743)) \\
 &= 14.7 \text{ psi}
 \end{aligned}$$

Design thickness for external pressure $P_a = 14.7$ psi

$$t_a = t + \text{Corrosion} = 0.2743 + 0 = \underline{0.2743"}$$

Maximum Allowable External Pressure, (Corroded & at 338 °F) UG-28(c)

$$L / D_o = 88.9168 / 79 = 1.1255$$

$$D_o / t = 79 / 0.5 = 158.0000$$

From table G: $A = 0.000605$

From table
HA-4: $B = 6,243.9546$ psi

$$\begin{aligned} P_a &= 4*B / (3*(D_o / t)) \\ &= 4*6,243.95 / (3*(79 / 0.5)) \\ &= \underline{52.69} \text{ psi} \end{aligned}$$

% Forming strain - UHA-44(a)(2)

$$\begin{aligned} EFE &= (50*t / R_f) * (1 - R_f / R_o) \\ &= (50*0.5 / 39.25) * (1 - 39.25 / \infty) \\ &= 0.6369\% \end{aligned}$$

Thickness Required Due to Pressure + External Loads								
Condition	Pressure P (psi)	Allowable Stress Before UG-23 Stress Increase (psi)		Temperature (°F)	Corrosion C (in)	Load	Req'd Thk Due to Tension (in)	Req'd Thk Due to Compression (in)
		S _t	S _c					
Operating, Hot & Corroded	45	16,300	7,501	338	0	Wind	0.0448	0.0443
						Seismic	0.0448	0.0443
Operating, Hot & New	45	16,300	7,501	338	0	Wind	0.0448	0.0443
						Seismic	0.0448	0.0443
Hot Shut Down, Corroded	0	16,300	7,501	338	0	Wind	0.0001	0.0012
						Seismic	0.0001	0.0012
Hot Shut Down, New	0	16,300	7,501	338	0	Wind	0.0001	0.0012
						Seismic	0.0001	0.0012
Empty, Corroded	0	16,700	10,071	70	0	Wind	0	0.0009
						Seismic	0.0001	0.0009
Empty, New	0	16,700	10,071	70	0	Wind	0	0.0009
						Seismic	0.0001	0.0009
Vacuum	-14.7	16,300	7,501	338	0	Wind	0.0319	0.0331
						Seismic	0.0319	0.0331
Hot Shut Down, Corroded, Weight & Eccentric Moments Only	0	16,300	7,501	338	0	Weight	0.0005	0.0014

Shell -02

ASME Section VIII Division 1, 2013 Edition				
Component		Cylinder		
Material		SA-240 316L (II-D p. 74, ln. 9)		
Impact Tested	Normalized	Fine Grain Practice	PWHT	Optimize MDMT/ Find MAWP
No	No	No	No	No
		Design Pressure (psi)	Design Temperature (°F)	Design MDMT (°F)
Internal		45	338	-20
External		14.7	338	
Static Liquid Head				
Condition		P_s (psi)	H_s (in)	SG
Operating		1.36	38	0.993
Test horizontal		2.82	78	1
Dimensions				
Inner Diameter		78"		
Length		69"		
Nominal Thickness		0.3125"		
Corrosion	Inner	0"		
	Outer	0"		
Weight and Capacity				
		Weight (lb)		Capacity (US gal)
New		1,538.43		1,427.3
Corroded		1,538.43		1,427.3
Insulation				
		Thickness (in)	Density (lb/ft³)	Weight (lb)
Insulation		2	12	242.74
		Spacing(in)	Individual Weight (lb)	Total Weight (lb)
Insulation Supports		0	0	0
Radiography				
Longitudinal seam		Full UW-11(a) Type 1		
Top Circumferential seam		Full UW-11(a) Type 1		
		Full UW-11(a) Type 1		

Bottom Circumferential seam

Results Summary	
Governing condition	External pressure
Minimum thickness per UG-16	0.0625" + 0" = 0.0625"
Design thickness due to internal pressure (t)	0.1112"
Design thickness due to external pressure (t _e)	0.2735"
Design thickness due to combined loadings + corrosion	0.0542"
Maximum allowable working pressure (MAWP)	128.62 psi
Maximum allowable pressure (MAP)	133.17 psi
Maximum allowable external pressure (MAEP)	20.36 psi
Rated MDMT	-320 °F

UHA-51 Material Toughness Requirements	
$t_r = 46.36 \cdot 39 / (16,700 \cdot 1 - 0.6 \cdot 46.36) =$	0.1085"
Stress ratio = $t_r \cdot E' / (t_n - c) = 0.1085 \cdot 1 / (0.3125 - 0) =$	0.347
Impact test exempt per UHA-51(g) (coincident ratio = 0.347)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Design thickness, (at 338 °F) UG-27(c)(1)

$$\begin{aligned}
 t &= P \cdot R / (S \cdot E - 0.60 \cdot P) + \text{Corrosion} \\
 &= 46.36 \cdot 39 / (16,300 \cdot 1.00 - 0.60 \cdot 46.36) + 0 \\
 &= \a href="#">0.1112"
 \end{aligned}$$

Maximum allowable working pressure, (at 338 °F) UG-27(c)(1)

$$\begin{aligned}
 P &= S \cdot E \cdot t / (R + 0.60 \cdot t) - P_s \\
 &= 16,300 \cdot 1.00 \cdot 0.3125 / (39 + 0.60 \cdot 0.3125) - 1.36 \\
 &= \a href="#">128.62 \text{ psi}
 \end{aligned}$$

Maximum allowable pressure, (at 70 °F) UG-27(c)(1)

$$\begin{aligned}
 P &= S \cdot E \cdot t / (R + 0.60 \cdot t) \\
 &= 16,700 \cdot 1.00 \cdot 0.3125 / (39 + 0.60 \cdot 0.3125) \\
 &= \a href="#">133.17 \text{ psi}
 \end{aligned}$$

External Pressure, (Corroded & at 338 °F) UG-28(c)

$$\begin{aligned}
 L / D_o &= 88.9168 / 78.625 = 1.1309 \\
 D_o / t &= 78.625 / 0.2735 = 287.4751 \\
 \text{From table G: } A &= 0.000241 \\
 \text{From table HA-4: } B &= 3,169.4091 \text{ psi}
 \end{aligned}$$

$$\begin{aligned}
 P_a &= 4*B / (3*(D_o / t)) \\
 &= 4*3,169.41 / (3*(78.625 / 0.2735)) \\
 &= 14.7 \text{ psi}
 \end{aligned}$$

Design thickness for external pressure $P_a = 14.7$ psi

$$t_a = t + \text{Corrosion} = 0.2735 + 0 = \underline{0.2735"}$$

Maximum Allowable External Pressure, (Corroded & at 338 °F) UG-28(c)

$$\begin{aligned}
 L / D_o &= 88.9168 / 78.625 = 1.1309 \\
 D_o / t &= 78.625 / 0.3125 = 251.6000 \\
 \text{From table G: } A &= 0.000293 \\
 \text{From table HA-4: } B &= 3,841.19 \text{ psi}
 \end{aligned}$$

$$\begin{aligned}
 P_a &= 4*B / (3*(D_o / t)) \\
 &= 4*3,841.19 / (3*(78.625 / 0.3125)) \\
 &= \underline{20.36} \text{ psi}
 \end{aligned}$$

% Forming strain - UHA-44(a)(2)

$$\begin{aligned}
 EFE &= (50*t / R_f) * (1 - R_f / R_o) \\
 &= (50*0.3125 / 39.1563) * (1 - 39.1563 / \infty) \\
 &= 0.399\%
 \end{aligned}$$

External Pressure + Weight + Wind Loading Check (Bergman, ASME paper 54-A-104)

$$\begin{aligned}
 P_v &= W / (2*\pi*R_m) + M / (\pi*R_m^2) \\
 &= 2,337.1 / (2*\pi*39.1563) + 32,316 / (\pi*39.1563^2) \\
 &= 16.2087 \text{ lb/in} \\
 \alpha &= P_v / (P_e*D_o) \\
 &= 16.2087 / (14.7*78.625) \\
 &= 0.014 \\
 n &= 6 \\
 m &= 1.23 / (L / D_o)^2 \\
 &= 1.23 / (88.9168 / 78.625)^2 \\
 &= 0.9617 \\
 \text{Ratio } P_e &= (n^2 - 1 + m + m*\alpha) / (n^2 - 1 + m) \\
 &= (6^2 - 1 + 0.9617 + 0.9617*0.014) / (6^2 - 1 + 0.9617) \\
 &= 1.0004 \\
 \text{Ratio } P_e * P_e &\leq \text{MAEP} \\
 (1.0004 * 14.7 = 14.71) &\leq 20.36
 \end{aligned}$$

Cylinder design thickness is satisfactory.

External Pressure + Weight + Wind Loading Check at Bottom Seam (Bergman, ASME paper 54-A-104)

$$\begin{aligned}
 P_v &= 0.6*W / (2*\pi*R_m) + M / (\pi*R_m^2) \\
 &= 0.60*-29,096.8 / (2*\pi*39.1563) + 315,939 / (\pi*39.1563^2) \\
 &= -5.3682 \text{ lb/in} \\
 \alpha &= P_v / (P_e*D_o) \\
 &= -5.3682 / (14.7*78.625) \\
 &= -0.0046 \\
 n &= 6
 \end{aligned}$$

$$\begin{aligned}
m &= 1.23 / (L / D_o)^2 \\
&= 1.23 / (88.9168 / 78.625)^2 \\
&= 0.9617 \\
\text{Ratio } P_e &= (n^2 - 1 + m + m*\alpha) / (n^2 - 1 + m) \\
&= (6^2 - 1 + 0.9617 + 0.9617*-0.0046) / (6^2 - 1 + 0.9617) \\
&= 1
\end{aligned}$$

$$\text{Ratio } P_e * P_e \leq \text{MAEP}$$

$$(1 * 14.7 = 14.7) \leq 20.36$$

Cylinder design thickness is satisfactory.

External Pressure + Weight + Seismic Loading Check (Bergman, ASME paper 54-A-104)

$$\begin{aligned}
P_v &= (1 + 0.14*S_{DS})*W / (2*\pi*R_m) + M / (\pi*R_m^2) \\
&= 1.02*2,337.1 / (2*\pi*39.1563) + 17,998 / (\pi*39.1563^2) \\
&= 13.3921 \text{ lb/in}
\end{aligned}$$

$$\begin{aligned}
\alpha &= P_v / (P_e * D_o) \\
&= 13.3921 / (14.7*78.625) \\
&= 0.0116
\end{aligned}$$

$$n = 6$$

$$\begin{aligned}
m &= 1.23 / (L / D_o)^2 \\
&= 1.23 / (88.9168 / 78.625)^2 \\
&= 0.9617
\end{aligned}$$

$$\begin{aligned}
\text{Ratio } P_e &= (n^2 - 1 + m + m*\alpha) / (n^2 - 1 + m) \\
&= (6^2 - 1 + 0.9617 + 0.9617*0.0116) / (6^2 - 1 + 0.9617) \\
&= 1.0003
\end{aligned}$$

$$\text{Ratio } P_e * P_e \leq \text{MAEP}$$

$$(1.0003 * 14.7 = 14.7) \leq 20.36$$

Cylinder design thickness is satisfactory.

External Pressure + Weight + Seismic Loading Check at Bottom Seam(Bergman, ASME paper 54-A-104)

$$\begin{aligned}
P_v &= (0.6 - 0.14*S_{DS})*W / (2*\pi*R_m) + M / (\pi*R_m^2) \\
&= 0.58*-29,096.8 / (2*\pi*39.1563) + 146,654 / (\pi*39.1563^2) \\
&= -38.5707 \text{ lb/in}
\end{aligned}$$

$$\begin{aligned}
\alpha &= P_v / (P_e * D_o) \\
&= -38.5707 / (14.7*78.625) \\
&= -0.0334
\end{aligned}$$

$$n = 6$$

$$\begin{aligned}
m &= 1.23 / (L / D_o)^2 \\
&= 1.23 / (88.9168 / 78.625)^2 \\
&= 0.9617
\end{aligned}$$

$$\begin{aligned}
\text{Ratio } P_e &= (n^2 - 1 + m + m*\alpha) / (n^2 - 1 + m) \\
&= (6^2 - 1 + 0.9617 + 0.9617*-0.0334) / (6^2 - 1 + 0.9617) \\
&= 1
\end{aligned}$$

$$\text{Ratio } P_e * P_e \leq \text{MAEP}$$

$$(1 * 14.7 = 14.7) \leq 20.36$$

Cylinder design thickness is satisfactory.

Thickness Required Due to Pressure + External Loads									
Condition	Pressure P (psi)	Allowable Stress Before UG-23 Stress Increase (psi)		Temperature (°F)	Corrosion C (in)	Location	Load	Req'd Thk Due to Tension (in)	Req'd Thk Due to Compression (in)
		S _t	S _c						
Operating, Hot & Corroded	45	16,300	6,864	338	0	Top	Wind	0.0449	0.044
							Seismic	0.0447	0.0442
						Bottom	Wind	0.0542	0.0451
							Seismic	0.0525	0.0468
Operating, Hot & New	45	16,300	6,864	338	0	Top	Wind	0.0449	0.044
							Seismic	0.0447	0.0442
						Bottom	Wind	0.0542	0.0451
							Seismic	0.0525	0.0468
Hot Shut Down, Corroded	0	16,300	6,864	338	0	Top	Wind	0.0001	0.002
							Seismic	0.0002	0.0016
						Bottom	Wind	0.0094	0.0003
							Seismic	0.0077	0.002
Hot Shut Down, New	0	16,300	6,864	338	0	Top	Wind	0.0001	0.002
							Seismic	0.0002	0.0016
						Bottom	Wind	0.0094	0.0003
							Seismic	0.0077	0.002
Empty, Corroded	0	16,700	9,231	70	0	Top	Wind	0.0001	0.0015
							Seismic	0.0002	0.0012
						Bottom	Wind	0.0042	0.0049
							Seismic	0.0013	0.0002
Empty, New	0	16,700	9,231	70	0	Top	Wind	0.0001	0.0015
							Seismic	0.0002	0.0012
						Bottom	Wind	0.0042	0.0049
							Seismic	0.0013	0.0002
Vacuum	-14.7	16,300	6,864	338	0	Top	Wind	0.0347	0.0368
							Seismic	0.035	0.0364
						Bottom	Wind	0.0125	0.0341
							Seismic	0.0165	0.0301
Hot Shut Down, Corroded, Weight & Eccentric Moments Only	0	16,300	6,864	338	0	Top	Weight	0.0009	0.0019
						Bottom	Weight	0.0073	0.0072

Shell -01

ASME Section VIII Division 1, 2013 Edition				
Component		Cylinder		
Material		SA-240 316L (II-D p. 74, In. 9)		
Impact Tested	Normalized	Fine Grain Practice	PWHT	Optimize MDMT/ Find MAWP
No	No	No	No	No
		Design Pressure (psi)	Design Temperature (°F)	Design MDMT (°F)
Internal		45	338	-20
External		14.7	338	
Static Liquid Head				
Condition		P_s (psi)	H_s (in)	SG
Operating		4.8	134	0.993
Test horizontal		2.82	78	1
Dimensions				
Inner Diameter		78"		
Length		96"		
Nominal Thickness		0.3125"		
Corrosion	Inner	0"		
	Outer	0"		
Weight and Capacity				
		Weight (lb)		Capacity (US gal)
New		2,139.3		1,985.81
Corroded		2,139.3		1,985.81
Insulation				
		Thickness (in)	Density (lb/ft³)	Weight (lb)
Insulation		2	12	337.72
		Spacing(in)	Individual Weight (lb)	Total Weight (lb)
Insulation Supports		0	0	0
Radiography				
Longitudinal seam		Full UW-11(a) Type 1		
Top Circumferential seam		Full UW-11(a) Type 1		
		Full UW-11(a) Type 1		

Bottom Circumferential seam
--

Results Summary	
Governing condition	External pressure
Minimum thickness per UG-16	0.0625" + 0" = 0.0625"
Design thickness due to internal pressure (t)	0.1194"
Design thickness due to external pressure (t _e)	0.2735"
Design thickness due to combined loadings + corrosion	0.0523"
Maximum allowable working pressure (MAWP)	125.18 psi
Maximum allowable pressure (MAP)	133.17 psi
Maximum allowable external pressure (MAEP)	20.36 psi
Rated MDMT	-320 °F

UHA-51 Material Toughness Requirements
Rated MDMT per UHA-51(d)(1)(a), (carbon content does not exceed 0.10%) = -320 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.

Design thickness, (at 338 °F) UG-27(c)(1)

$$\begin{aligned}
 t &= P \cdot R / (S \cdot E - 0.60 \cdot P) + \text{Corrosion} \\
 &= 49.8 \cdot 39 / (16,300 \cdot 1.00 - 0.60 \cdot 49.8) + 0 \\
 &= \a href="#">0.1194"
 \end{aligned}$$

Maximum allowable working pressure, (at 338 °F) UG-27(c)(1)

$$\begin{aligned}
 P &= S \cdot E \cdot t / (R + 0.60 \cdot t) - P_s \\
 &= 16,300 \cdot 1.00 \cdot 0.3125 / (39 + 0.60 \cdot 0.3125) - 4.8 \\
 &= \a href="#">125.18 \text{ psi}
 \end{aligned}$$

Maximum allowable pressure, (at 70 °F) UG-27(c)(1)

$$\begin{aligned}
 P &= S \cdot E \cdot t / (R + 0.60 \cdot t) \\
 &= 16,700 \cdot 1.00 \cdot 0.3125 / (39 + 0.60 \cdot 0.3125) \\
 &= \a href="#">133.17 \text{ psi}
 \end{aligned}$$

External Pressure, (Corroded & at 338 °F) UG-28(c)

$$\begin{aligned}
 L / D_o &= 88.9168 / 78.625 = 1.1309 \\
 D_o / t &= 78.625 / 0.2735 = 287.4751 \\
 \text{From table G: } A &= 0.000241 \\
 \text{From table HA-4: } B &= 3,169.4091 \text{ psi}
 \end{aligned}$$

$$\begin{aligned}
 P_a &= 4 \cdot B / (3 \cdot (D_o / t)) \\
 &= 4 \cdot 3,169.41 / (3 \cdot (78.625 / 0.2735)) \\
 &= 14.7 \text{ psi}
 \end{aligned}$$

Design thickness for external pressure $P_a = 14.7$ psi

$$t_a = t + \text{Corrosion} = 0.2735 + 0 = \underline{0.2735"}$$

Maximum Allowable External Pressure, (Corroded & at 338 °F) UG-28(c)

$$L / D_o = 88.9168 / 78.625 = 1.1309$$

$$D_o / t = 78.625 / 0.3125 = 251.6000$$

From table G: $A = 0.000293$

From table
HA-4: $B = 3,841.19$ psi

$$\begin{aligned} P_a &= 4*B / (3*(D_o / t)) \\ &= 4*3,841.19 / (3*(78.625 / 0.3125)) \\ &= \underline{20.36} \text{ psi} \end{aligned}$$

% Forming strain - UHA-44(a)(2)

$$\begin{aligned} EFE &= (50*t / R_f) * (1 - R_f / R_o) \\ &= (50*0.3125 / 39.1563) * (1 - 39.1563 / \infty) \\ &= 0.399\% \end{aligned}$$

External Pressure + Weight + Wind Loading Check (Bergman, ASME paper 54-A-104)

$$\begin{aligned} P_v &= 0.6*W / (2*\pi*R_m) + M / (\pi*R_m^2) \\ &= 0.60*-28,037.9 / (2*\pi*39.1563) + 152,923 / (\pi*39.1563^2) \\ &= -36.6297 \text{ lb/in} \end{aligned}$$

$$\begin{aligned} \alpha &= P_v / (P_e*D_o) \\ &= -36.6297 / (14.7*78.625) \\ &= -0.0317 \end{aligned}$$

$$n = 6$$

$$\begin{aligned} m &= 1.23 / (L / D_o)^2 \\ &= 1.23 / (88.9168 / 78.625)^2 \\ &= 0.9617 \end{aligned}$$

$$\begin{aligned} \text{Ratio } P_e &= (n^2 - 1 + m + m*\alpha) / (n^2 - 1 + m) \\ &= (6^2 - 1 + 0.9617 + 0.9617*-0.0317) / (6^2 - 1 + 0.9617) \\ &= 1 \end{aligned}$$

$$\text{Ratio } P_e * P_e \leq \text{MAEP}$$

$$(1 * 14.7 = 14.7) \leq 20.36$$

Cylinder design thickness is satisfactory.

External Pressure + Weight + Seismic Loading Check (Bergman, ASME paper 54-A-104)

$$\begin{aligned} P_v &= (0.6 - 0.14*S_{DS}) * W / (2*\pi*R_m) + M / (\pi*R_m^2) \\ &= 0.58*-28,037.9 / (2*\pi*39.1563) + 82,261 / (\pi*39.1563^2) \\ &= -49.4277 \text{ lb/in} \end{aligned}$$

$$\begin{aligned} \alpha &= P_v / (P_e*D_o) \\ &= -49.4277 / (14.7*78.625) \\ &= -0.0428 \end{aligned}$$

$$n = 6$$

$$\begin{aligned} m &= 1.23 / (L / D_o)^2 \\ &= 1.23 / (88.9168 / 78.625)^2 \\ &= 0.9617 \end{aligned}$$

$$\begin{aligned} \text{Ratio } P_e &= (n^2 - 1 + m + m*\alpha) / (n^2 - 1 + m) \\ &= (6^2 - 1 + 0.9617 + 0.9617*0.0428) / (6^2 - 1 + 0.9617) \\ &= 1 \end{aligned}$$

$$\text{Ratio } P_e * P_e \leq \text{MAEP}$$

$$(1 * 14.7 = 14.7) \leq 20.36$$

Cylinder design thickness is satisfactory.

Thickness Required Due to Pressure + External Loads								
Condition	Pressure P (psi)	Allowable Stress Before UG-23 Stress Increase (psi)		Temperature (°F)	Corrosion C (in)	Load	Req'd Thk Due to Tension (in)	Req'd Thk Due to Compression (in)
		S _t	S _c					
Operating, Hot & Corroded	45	16,300	6,864	338	0	Wind	0.0523	0.0467
						Seismic	0.0516	0.0474
Operating, Hot & New	45	16,300	6,864	338	0	Wind	0.0523	0.0467
						Seismic	0.0516	0.0474
Hot Shut Down, Corroded	0	16,300	6,864	338	0	Wind	0.0074	0.0019
						Seismic	0.0068	0.0025
Hot Shut Down, New	0	16,300	6,864	338	0	Wind	0.0074	0.0019
						Seismic	0.0068	0.0025
Empty, Corroded	0	16,700	9,231	70	0	Wind	0.0023	0.0021
						Seismic	0.0009	0.0002
Empty, New	0	16,700	9,231	70	0	Wind	0.0023	0.0021
						Seismic	0.0009	0.0002
Vacuum	-14.7	16,300	6,864	338	0	Wind	0.0171	0.0303
						Seismic	0.0187	0.0288
Hot Shut Down, Corroded, Weight & Eccentric Moments Only	0	16,300	6,864	338	0	Weight	0.007	0.007

Straight Flange on F&D Head (btm)

ASME Section VIII Division 1, 2013 Edition				
Component		Cylinder		
Material		SA-240 316L (II-D p. 74, In. 9)		
Impact Tested	Normalized	Fine Grain Practice	PWHT	Optimize MDMT/ Find MAWP
No	No	No	No	No
		Design Pressure (psi)	Design Temperature (°F)	Design MDMT (°F)
Internal		45	338	-20
External		14.7	338	
Static Liquid Head				
Condition		P_s (psi)	H_s (in)	SG
Operating		4.86	135.5	0.993
Test horizontal		2.82	78	1
Dimensions				
Inner Diameter		78"		
Length		1.5"		
Nominal Thickness		0.5"		
Corrosion	Inner	0"		
	Outer	0"		
Weight and Capacity				
		Weight (lb)		Capacity (US gal)
New		53.64		31.03
Corroded		53.64		31.03
Insulation				
		Thickness (in)	Density (lb/ft³)	Weight (lb)
Insulation		2	12	0
		Spacing(in)	Individual Weight (lb)	Total Weight (lb)
Insulation Supports		0	0	0
Radiography				
Longitudinal seam		Full UW-11(a) Type 1		
Top Circumferential seam		Full UW-11(a) Type 1		

Results Summary	
Governing condition	External pressure
Minimum thickness per UG-16	0.0625" + 0" = 0.0625"
Design thickness due to internal pressure (t)	0.1196"
Design thickness due to external pressure (t _e)	0.2731"
Design thickness due to combined loadings + corrosion	0.0502"
Maximum allowable working pressure (MAWP)	202.52 psi
Maximum allowable pressure (MAP)	212.47 psi
Maximum allowable external pressure (MAEP)	52.81 psi
Rated MDMT	-320 °F

UHA-51 Material Toughness Requirements	
$t_r = 49.86 \cdot 39 / (16,700 \cdot 1 - 0.6 \cdot 49.86) =$	0.1166"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.1166 \cdot 1 / (0.5 - 0) =$	0.2333
Impact test exempt per UHA-51(g) (coincident ratio = 0.2333)	
Rated MDMT =	-320 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.	

Design thickness, (at 338 °F) UG-27(c)(1)

$$\begin{aligned}
 t &= P \cdot R / (S \cdot E - 0.60 \cdot P) + \text{Corrosion} \\
 &= 49.86 \cdot 39 / (16,300 \cdot 1.00 - 0.60 \cdot 49.86) + 0 \\
 &= \a href="#">0.1196"
 \end{aligned}$$

Maximum allowable working pressure, (at 338 °F) UG-27(c)(1)

$$\begin{aligned}
 P &= S \cdot E \cdot t / (R + 0.60 \cdot t) - P_s \\
 &= 16,300 \cdot 1.00 \cdot 0.5 / (39 + 0.60 \cdot 0.5) - 4.86 \\
 &= \a href="#">202.52 \text{ psi}
 \end{aligned}$$

Maximum allowable pressure, (at 70 °F) UG-27(c)(1)

$$\begin{aligned}
 P &= S \cdot E \cdot t / (R + 0.60 \cdot t) \\
 &= 16,700 \cdot 1.00 \cdot 0.5 / (39 + 0.60 \cdot 0.5) \\
 &= \a href="#">212.47 \text{ psi}
 \end{aligned}$$

External Pressure, (Corroded & at 338 °F) UG-28(c)

$$\begin{aligned}
 L / D_o &= 87.9168 / 79 = 1.1129 \\
 D_o / t &= 79 / 0.2731 = 289.2485 \\
 \text{From table G: } A &= 0.000243 \\
 \text{From table HA-4: } B &= 3,188.9677 \text{ psi}
 \end{aligned}$$

$$\begin{aligned}
 P_a &= 4 \cdot B / (3 \cdot (D_o / t)) \\
 &= 4 \cdot 3,188.97 / (3 \cdot (79 / 0.2731)) \\
 &= 14.7 \text{ psi}
 \end{aligned}$$

Design thickness for external pressure $P_a = 14.7$ psi

$$t_a = t + \text{Corrosion} = 0.2731 + 0 = \underline{0.2731"}$$

Maximum Allowable External Pressure, (Corroded & at 338 °F) UG-28(c)

$$L / D_o = 87.9168 / 79 = 1.1129$$

$$D_o / t = 79 / 0.5 = 158.0000$$

From table G: $A = 0.000612$

From table
HA-4: $B = 6,258.183$ psi

$$\begin{aligned} P_a &= 4*B / (3*(D_o / t)) \\ &= 4*6,258.18 / (3*(79 / 0.5)) \\ &= \underline{52.81} \text{ psi} \end{aligned}$$

% Forming strain - UHA-44(a)(2)

$$\begin{aligned} EFE &= (50*t / R_f) * (1 - R_f / R_o) \\ &= (50*0.5 / 39.25) * (1 - 39.25 / \infty) \\ &= 0.6369\% \end{aligned}$$

Thickness Required Due to Pressure + External Loads								
Condition	Pressure P (psi)	Allowable Stress Before UG-23 Stress Increase (psi)		Temperature (°F)	Corrosion C (in)	Load	Req'd Thk Due to Tension (in)	Req'd Thk Due to Compression (in)
		S _t	S _c					
Operating, Hot & Corroded	45	16,300	7,501	338	0	Wind	0.0501	0.048
						Seismic	0.0502	0.0479
Operating, Hot & New	45	16,300	7,501	338	0	Wind	0.0501	0.048
						Seismic	0.0502	0.0479
Hot Shut Down, Corroded	0	16,300	7,501	338	0	Wind	0.0053	0.0031
						Seismic	0.0054	0.0031
Hot Shut Down, New	0	16,300	7,501	338	0	Wind	0.0053	0.0031
						Seismic	0.0054	0.0031
Empty, Corroded	0	16,700	10,071	70	0	Wind	0.0002	0.0001
						Seismic	0.0002	0.0001
Empty, New	0	16,700	10,071	70	0	Wind	0.0002	0.0001
						Seismic	0.0002	0.0001
Vacuum	-14.7	16,300	7,501	338	0	Wind	0.0203	0.025
						Seismic	0.0202	0.0252
Hot Shut Down, Corroded, Weight & Eccentric Moments Only	0	16,300	7,501	338	0	Weight	0.0063	0.0063

F&D Head (btm)

ASME Section VIII Division 1, 2013 Edition				
Component		F&D Head		
Material		SA-240 316L (II-D p. 74, ln. 9)		
Attached To		Shell -01		
Impact Tested	Normalized	Fine Grain Practice	PWHT	Optimize MDMT/ Find MAWP
No	No	No	No	No
		Design Pressure (psi)	Design Temperature (°F)	Design MDMT (°F)
Internal		45	338	-20
External		14.7	338	
Static Liquid Head				
Condition		P_s (psi)	H_s (in)	SG
Operating		5.33	148.7505	0.993
Test horizontal		2.82	78	1
Dimensions				
Inner Diameter		78"		
Crown Radius L		78"		
Knuckle Radius r		4.75"		
Minimum Thickness		0.4"		
Corrosion	Inner	0"		
	Outer	0"		
Length L_{sf}		1.5"		
Nominal Thickness t_{sf}		0.5"		
Weight and Capacity				
		Weight (lb)¹		Capacity (US gal)¹
New		718.8		198.26
Corroded		718.8		198.26
Insulation				
		Thickness (in)	Density (lb/ft³)	Weight (lb)
Insulation		2	12	92.01
		Spacing(in)	Individual Weight (lb)	Total Weight (lb)
Insulation Supports		0	0	0
Radiography				

Category A joints	Full UW-11(a) Type 1
Head to shell seam	Full UW-11(a) Type 1

¹includes straight flange

Results Summary	
Governing condition	external pressure
Minimum thickness per UG-16	0.0625" + 0" = 0.0625"
Design thickness due to internal pressure (t)	0.2124"
Design thickness due to external pressure (t _e)	0.2346"
Maximum allowable working pressure (MAWP)	89.44 psi
Maximum allowable pressure (MAP)	97.09 psi
Maximum allowable external pressure (MAEP)	32.18 psi
Rated MDMT	-320 °F

UHA-51 Material Toughness Requirements	
$t_r = 50.33 \cdot 78 \cdot 1 / (2 \cdot 16,700 \cdot 1 - 0.2 \cdot 50.33) =$	0.1176"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.1176 \cdot 1 / (0.4 - 0) =$	0.2939
Impact test exempt per UHA-51(g) (coincident ratio = 0.2939)	
Rated MDMT =	-320 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.	

Factor M		
$M = 1/4 \cdot [3 + (L / r)^{1/2}]$		
Corroded	$M = 1/4 \cdot [3 + (78 / 4.75)^{1/2}]$	1.7631
New	$M = 1/4 \cdot [3 + (78 / 4.75)^{1/2}]$	1.7631

Design thickness for internal pressure, (Corroded at 338 °F) Appendix 1-4(d)

$$\begin{aligned}
 t &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) + \text{Corrosion} \\
 &= 50.33 \cdot 78 \cdot 1.7631 / (2 \cdot 16,300 \cdot 1 - 0.2 \cdot 50.33) + 0 \\
 &= \a href="#">0.2124"
 \end{aligned}$$

Maximum allowable working pressure, (Corroded at 338 °F) Appendix 1-4(d)

$$\begin{aligned}
 P &= 2 \cdot S \cdot E \cdot t / (L \cdot M + 0.2 \cdot t) - P_s \\
 &= 2 \cdot 16,300 \cdot 1 \cdot 0.4 / (78 \cdot 1.7631 + 0.2 \cdot 0.4) - 5.33 \\
 &= \a href="#">89.44 \text{ psi}
 \end{aligned}$$

Maximum allowable pressure, (New at 70 °F) Appendix 1-4(d)

$$\begin{aligned}
 P &= 2 \cdot S \cdot E \cdot t / (L \cdot M + 0.2 \cdot t) - P_s \\
 &= 2 \cdot 16,700 \cdot 1 \cdot 0.4 / (78 \cdot 1.7631 + 0.2 \cdot 0.4) - 0 \\
 &= \a href="#">97.09 \text{ psi}
 \end{aligned}$$

Design thickness for external pressure, (Corroded at 338 °F) UG-33(e)Equivalent outside spherical radius (R_o)

$$= \text{Outside crown radius}$$

$$= 78.4 \text{ in}$$

$$A = 0.125 / (R_o / t)$$

$$= 0.125 / (78.4 / 0.234551)$$

$$= 0.000374$$

From Table HA-4: $B = 4,913.5547$
psi

$$P_a = B / (R_o / t)$$

$$= 4,913.5547 / (78.4 / 0.2346)$$

$$= 14.7 \text{ psi}$$

$$t = 0.2346" + \text{Corrosion} = 0.2346" + 0" = 0.2346"$$

Check the external pressure per UG-33(a)(1) Appendix 1-4(d)

$$t = 1.67 * P_e * L * M / (2 * S * E - 0.2 * 1.67 * P_e) + \text{Corrosion}$$

$$= 1.67 * 14.7 * 78 * 1.7631 / (2 * 16,300 * 1 - 0.2 * 1.67 * 14.7) + 0$$

$$= 0.1036"$$

The head external pressure design thickness (t_e) is [0.2346"](#).**Maximum Allowable External Pressure, (Corroded at 338 °F) UG-33(e)**Equivalent outside spherical radius (R_o)

$$= \text{Outside crown radius}$$

$$= 78.4 \text{ in}$$

$$A = 0.125 / (R_o / t)$$

$$= 0.125 / (78.4 / 0.4)$$

$$= 0.000638$$

From Table HA-4: $B = 6,308.0192$
psi

$$P_a = B / (R_o / t)$$

$$= 6,308.0192 / (78.4 / 0.4)$$

$$= 32.1838 \text{ psi}$$

Check the Maximum External Pressure, UG-33(a)(1) Appendix 1-4(d)

$$P = 2 * S * E * t / ((L * M + 0.2 * t) * 1.67)$$

$$= 2 * 16,300 * 1 * 0.4 / ((78 * 1.7631 + 0.2 * 0.4) * 1.67)$$

$$= 56.75 \text{ psi}$$


The maximum allowable external pressure (MAEP) is [32.18](#) psi.

% Forming strain - UHA-44(a)(2)

$$\begin{aligned} \text{EFE} &= (75 \cdot t / R_f) \cdot (1 - R_f / R_o) \\ &= (75 \cdot 0.5 / 5) \cdot (1 - 5 / \infty) \\ &= 7.5\% \end{aligned}$$

Mount for A1 (A2)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	60°
End of nozzle to datum line	184"
Calculated as hillside	Yes
Distance to head center, R	27"
Passes through a Category A joint	No

Nozzle

Description	NPS 2 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	2.067"
Nominal wall thickness	0.154"
Corrosion allowance	0"
Opening chord length	2.203"
Projection available outside vessel, L _{pr}	4.2206"
Projection available outside vessel to flange face, L _f	6.7206"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg ₄₁	0.1563"
---------------------------------	---------

Nozzle to vessel groove weld	0.4"
------------------------------	------

ASME B16.5-2009 Flange	
Description	NPS 2 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, ln. 31)
Blind included	Yes
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Gasket	
Description	Flexitallic Spiral Wound CGI 316L S.S.
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F	
Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 * 1.0335 / (16,700 * 1 - 0.6 * 45) =$	0.0028"
Stress ratio = $t_r * E^* / (t_n - c) = 0.0028 * 1 / (0.1348 - 0) =$	0.0207
Impact test exempt per UHA-51(g) (coincident ratio = 0.0207)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)	UG-45 Summary (in)
For P = 167.01 psi @ 338 °F	The nozzle passes UG-45

A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1348	0.1348

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1078	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 171.11 psi @ 70 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1348	0.1348

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1078	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 32.18 psi @ 338 °F								

							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1348	0.1348


UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1078	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Mount for A3 (A4)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	120°
End of nozzle to datum line	184"
Calculated as hillside	Yes
Distance to head center, R	27"
Passes through a Category A joint	No

Nozzle

Description	NPS 1.5 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	1.61"
Nominal wall thickness	0.145"
Corrosion allowance	0"
Opening chord length	1.7159"
Projection available outside vessel, L_{pr}	4.3639"
Projection available outside vessel to flange face, L_f	6.8039"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg₄₁	0.1563"
---------------------------------------	---------

Nozzle to vessel groove weld	0.4"
------------------------------	------

ASME B16.5-2009 Flange	
Description	NPS 1.5 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, ln. 31)
Blind included	Yes
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Gasket	
Description	Flexitallic Spiral Wound CGI 316L S.S.
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F	
Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 \cdot 0.805 / (16,700 \cdot 1 - 0.6 \cdot 45) =$	0.0022"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.0022 \cdot 1 / (0.1269 - 0) =$	0.0171
Impact test exempt per UHA-51(g) (coincident ratio = 0.0171)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)	UG-45 Summary (in)
--	-----------------------

For P = 167.01 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 171.11 psi @ 70 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary	UG-45
--------------------------------	-------

(in ²)							Summary (in)	
For Pe = 32.18 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269


UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Mount for A5 (A6)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	330°
End of nozzle to datum line	184"
Calculated as hillside	Yes
Distance to head center, R	27"
Passes through a Category A joint	No

Nozzle

Description	NPS 1.5 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	1.61"
Nominal wall thickness	0.145"
Corrosion allowance	0"
Opening chord length	1.7159"
Projection available outside vessel, L_{pr}	4.3639"
Projection available outside vessel to flange face, L_f	6.8039"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg₄₁	0.1563"
---------------------------------------	---------

Nozzle to vessel groove weld	0.4"
------------------------------	------

ASME B16.5-2009 Flange	
Description	NPS 1.5 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, In. 31)
Blind included	Yes
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Gasket	
Description	Flexitallic Spiral Wound CGI 316L S.S.
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F	
Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 \cdot 0.805 / (16,700 \cdot 1 - 0.6 \cdot 45) =$	0.0022"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.0022 \cdot 1 / (0.1269 - 0) =$	0.0171
Impact test exempt per UHA-51(g) (coincident ratio = 0.0171)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)	UG-45 Summary (in)
--	-----------------------

For P = 167.01 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 171.11 psi @ 70 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary	UG-45
--------------------------------	-------

(in ²)							Summary (in)	
For Pe = 32.18 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269


UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

InTank Eductor Inlet (A7)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	Shell -01
Orientation	90°
Nozzle center line offset to datum line	6"
End of nozzle to shell center	45.3125"
Passes through a Category A joint	No

Nozzle

Description	NPS 3 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, In. 14)
Inside diameter, new	3.068"
Nominal wall thickness	0.216"
Corrosion allowance	0"
Projection available outside vessel, L_{pr}	3.25"
Internal projection, h_{new}	6"
Projection available outside vessel to flange face, L_f	6"
Local vessel minimum thickness	0.3125"
Liquid static head included	4.7 psi
Longitudinal joint efficiency	1

Reinforcing Pad

Material specification	SA-240 316L (II-D p. 74, In. 9)
Diameter, D_p	7.5"

Thickness, t_e	0.3125"
Is split	No
Welds	
Inner Fillet, Leg ₄₁	0.2188"
Outer Fillet, Leg ₄₂	0.25"
Lower Fillet, Leg ₄₃	0.2188"
Nozzle to vessel groove weld	0.3125"
Pad groove weld	0.3125"

ASME B16.5-2009 Flange	
Description	NPS 3 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt $\leq 2 \frac{1}{2}$ (II-D p. 352, In. 31)
Blind included	No
Rated MDMT	-55°F
Liquid static head	4.64 psi
Consider External Loads on Flange MAWP Rating	No
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle
Rated MDMT per UHA-51(d)(1)(a), (carbon content does not exceed 0.10%) = -320°F
Material is exempt from impact testing at the Design MDMT of -20°F.

UHA-51 Material Toughness Requirements Pad
Rated MDMT per UHA-51(d)(1)(a), (carbon content does not exceed 0.10%) = -320°F
Material is exempt from impact testing at the Design MDMT of -20°F.

Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 129.99 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.189	0.189

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

WRC 107												
Load Case	P (psi)	P _r (lb _f)	M _c (lb _f -in)	V _c (lb _f)	M _L (lb _f -in)	V _L (lb _f)	M _t (lb _f -in)	Max Comb Stress (psi)	Allow Comb Stress (psi)	Max Local Primary Stress (psi)	Allow Local Primary Stress (psi)	Over stressed
Load case 1	129.99	787	7,968	674	12,384	922	15,936	31,789	48,900	19,117	24,450	No
Load case 1 (Hot Shut Down)	0	787	7,968	674	12,384	922	15,936	-19,617	48,900	-5,399	24,450	No
Load case 1 (Pr Reversed)	129.99	-787	7,968	674	12,384	922	15,936	35,611	48,900	21,621	24,450	No
Load case 1 (Pr Reversed) (Hot Shut Down)	0	-787	7,968	674	12,384	922	15,936	19,479	48,900	5,399	24,450	No

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 133.17 psi @ 70 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.189	0.189

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 20.36 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.0952	0.189


UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Liquid Outlet (B1)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (btm)
Orientation	0°
End of nozzle to datum line	-20"
Calculated as hillside	No
Distance to head center, R	0"
Passes through a Category A joint	No

Nozzle

Description	NPS 4 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	4.026"
Nominal wall thickness	0.237"
Corrosion allowance	0"
Projection available outside vessel, L_{pr}	3.3818"
Projection available outside vessel to flange face, L_f	6.3818"
Local vessel minimum thickness	0.4"
Liquid static head included	5.56 psi
Longitudinal joint efficiency	1

Reinforcing Pad

Material specification	SA-240 316L (II-D p. 74, ln. 9)
Diameter, D_p	8.5"

Thickness, t_e	0.3125"
Is split	No
Welds	
Inner Fillet, Leg ₄₁	0.25"
Outer Fillet, Leg ₄₂	0.25"
Nozzle to vessel groove weld	0.4"
Pad groove weld	0.3125"

ASME B16.5-2009 Flange	
Description	NPS 4 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt \leq 2 1/2 (II-D p. 352, ln. 31)
Blind included	No
Rated MDMT	-55° F
Liquid static head	5.57 psi
Consider External Loads on Flange MAWP Rating	No
MAWP rating	169.3 psi @ 338° F
MAP rating	230 psi @ 70° F
Hydrotest rating	350 psi @ 70° F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320° F Bolts rated MDMT per Fig UCS-66 note (c) = -55° F	

UHA-51 Material Toughness Requirements Nozzle
Rated MDMT per UHA-51(d)(1)(a), (carbon content does not exceed 0.10%) = -320° F
Material is exempt from impact testing at the Design MDMT of -20° F.

UHA-51 Material Toughness Requirements Pad	
$t_r = 50.56 \cdot 78 \cdot 1 / (2 \cdot 16,700 \cdot 1 - 0.2 \cdot 50.56) =$	0.1181"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.1181 \cdot 1 / (0.4 - 0) =$	0.2953
Impact test exempt per UHA-51(g) (coincident ratio = 0.2953)	
Rated MDMT =	-320° F
Material is exempt from impact testing at the Design MDMT of -20° F.	

Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 164.62 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
1.5873	1.5875	0.0231	0.3919	--	1.11	0.0625	0.2074	0.2074

UG-41 Weld Failure Path Analysis Summary (lb _f)						
All failure paths are stronger than the applicable weld loads						
Weld load W	Weld load W ₁₋₁	Path 1-1 strength	Weld load W ₂₋₂	Path 2-2 strength	Weld load W ₃₋₃	Path 3-3 strength
25,541.24	25,499.72	44,768.09	10,497.2	74,862.84	28,590.2	60,764.65

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

WRC 107												
Load Case	P (psi)	P _r (lb _f)	M ₁ (lb _f -in)	V ₂ (lb _f)	M ₂ (lb _f -in)	V ₁ (lb _f)	M _t (lb _f -in)	Max Comb Stress (psi)	Allow Comb Stress (psi)	Max Local Primary Stress (psi)	Allow Local Primary Stress (psi)	Over stressed
Load case 1	164.62	967	18,588	787	12,396	1,079	23,016	32,280	48,900	17,722	24,450	No
Load case 1 (Hot Shut Down)	0	967	18,588	787	12,396	1,079	23,016	-21,169	48,900	-2,798	24,450	No
Load case 1 (Pr Reversed)	164.62	-967	18,588	787	12,396	1,079	23,016	37,247	48,900	18,848	24,450	No
Load case 1 (Pr Reversed) (Hot Shut Down)	0	-967	18,588	787	12,396	1,079	23,016	21,197	48,900	2,798	24,450	No

Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 168.66 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
1.5873	1.5875	0.0231	0.3919	--	1.11	0.0625	0.2074	0.2074

UG-41 Weld Failure Path Analysis Summary (lb _f)						
All failure paths are stronger than the applicable weld loads						
Weld load W	Weld load W ₁₋₁	Path 1-1 strength	Weld load W ₂₋₂	Path 2-2 strength	Weld load W ₃₋₃	Path 3-3 strength
26,168.02	26,125.48	45,866.69	10,754.8	76,699.96	29,291.8	62,255.8

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

Reinforcement Calculations for MAEP


UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For Pe = 32.18 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
0.8052	1.5591	--	0.3866	--	1.11	0.0625	0.1358	0.2074

UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

Sight Glass (G1)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Note: Thread engagement shall comply with the requirements of UG-43(g).

Location and Orientation

Located on	F&D Head (top)
Orientation	180°
End of nozzle to datum line	177.9415"
Calculated as hillside	No
Distance to head center, R	27"
Passes through a Category A joint	No

Nozzle

Access opening	No
Material specification	SA-182 F316L ≤ 5 (low stress) (II-D p. 74, ln. 6)
Bolt material specification	SA-193 B7 Bolt $\leq 2 \frac{1}{2}$ (II-D p. 352, ln. 31)
Bolt rated MDMT	-55°F
Pad inner diameter	6"
Pad outer diameter, D_p	11"
Pad thickness	1.7509"
Figure UG-40 thickness, t_e	1.2909"
Tapped hole diameter	0.75"
Tapped hole depth	1.5"
Tapped hole bolt circle	9.5"
Raised face height	0.06"
Raised face outer diameter	8.5"

Corrosion allowance	0"
Projection available outside vessel, L _{pr}	1.2909"
Projection available outside vessel to flange face, L _f	1.3509"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1
Welds	
Inner Fillet, Leg ₄₂	0.375"
Nozzle to vessel groove weld	0.4"

ASME B16.5-2009 Blind	
Description	NPS 6 Class 150 Blind A182 F316L
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
Impact Tested	No
Notes	
Blind rated MDMT per UHA-51(d)(1)(a) = -320°F Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Pad	
$t_r = 45 \cdot 78 \cdot 1 / (2 \cdot 16,700 \cdot 1 - 0.2 \cdot 45) =$	0.1051"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.1051 \cdot 1 / (0.4 - 0) =$	0.2628
Impact test exempt per UHA-51(g) (coincident ratio = 0.2628)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)	UG-45 Summary (in)
---	--------------------------

For P = 138.31 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
4.2073	4.2074	0.3283	--	--	3.773	0.1061	0.3281	2.5

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Pad to shell fillet (Leg ₄₂)	0.25	0.2625	weld size is adequate

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 171.11 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
4.2136	5.1406	--	--	--	5	0.1406	0.3281	2.5

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Pad to shell fillet (Leg ₄₂)	0.25	0.2625	weld size is adequate

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 32.18 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
3.259	3.8791	--	--	--	3.773	0.1061	0.1358	2.5

UG-41 Weld Failure Path Analysis Summary


Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Pad to shell fillet (Leg ₄₂)	0.25	0.2625	weld size is adequate

Mount for L1 (L2)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	90°
End of nozzle to datum line	184"
Calculated as hillside	Yes
Distance to head center, R	27"
Passes through a Category A joint	No

Nozzle

Description	NPS 4 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	4.026"
Nominal wall thickness	0.237"
Corrosion allowance	0"
Opening chord length	4.2911"
Projection available outside vessel, L _{pr}	3.3587"
Projection available outside vessel to flange face, L _f	6.3587"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg ₄₁	0.25"
---------------------------------	-------

Nozzle to vessel groove weld	0.4"
------------------------------	------

ASME B16.5-2009 Flange	
Description	NPS 4 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, ln. 31)
Blind included	Yes
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Gasket	
Description	Flexitallic Spiral Wound CGI 316L S.S.
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F	
Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 \cdot 2.013 / (16,700 \cdot 1 - 0.6 \cdot 45) =$	0.0054"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.0054 \cdot 1 / (0.2074 - 0) =$	0.0262
Impact test exempt per UHA-51(g) (coincident ratio = 0.0262)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)	UG-45 Summary (in)
	The nozzle passes UG-45

For P = 99.53 psi @ 338 °F The opening is adequately reinforced								
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
1.0225	1.0227	0.6939	0.2663	--	--	0.0625	0.2074	0.2074

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate

Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 101.97 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
1.0225	1.0228	0.694	0.2663	--	--	0.0625	0.2074	0.2074

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 24.29 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
0.6774	0.6774	0.3614	0.2535	--	--	0.0625	0.1025	0.2074

UG-41 Weld Failure Path Analysis Summary


Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate

Level Switch - High (L4)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	0°
End of nozzle to datum line	190"
Calculated as hillside	No
Distance to head center, R	0"
Passes through a Category A joint	No

Nozzle

Description	NPS 3 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	3.068"
Nominal wall thickness	0.216"
Corrosion allowance	0"
Projection available outside vessel, L _{pr}	5.6191"
Internal projection, h _{new}	12"
Projection available outside vessel to flange face, L _f	8.3691"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg ₄₁	0.2188"
---------------------------------	---------

Lower Fillet, Leg ₄₃	0.2188"
Nozzle to vessel groove weld	0.4"

ASME B16.5-2009 Flange	
Description	NPS 3 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, In. 31)
Blind included	No
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F	
Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 \cdot 1.534 / (16,700 \cdot 1 - 0.6 \cdot 45) =$	0.0041"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.0041 \cdot 1 / (0.189 - 0) =$	0.0219
Impact test exempt per UHA-51(g) (coincident ratio = 0.0219)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)	UG-45 Summary (in)
For P = 120.97 psi @ 338 °F The opening is adequately reinforced	The nozzle passes UG-45

A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
0.8886	0.8887	0.3386	0.221	0.2333	--	0.0958	0.189	0.189

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate

Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 123.93 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
0.8886	0.8887	0.3386	0.221	0.2333	--	0.0958	0.189	0.189

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 30.62 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
0.5885	0.5886	0.0503	0.2092	0.2333	--	0.0958	0.1292	0.189

UG-41 Weld Failure Path Analysis Summary


Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate

Manway w/Davit (M1)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	270°
End of nozzle to datum line	190"
Calculated as hillside	Yes
Distance to head center, R	22"
Passes through a Category A joint	No

Nozzle

Access opening	Yes
Material specification	SA-240 316L (II-D p. 74, In. 9)
Inside diameter, new	23.25"
Nominal wall thickness	0.375"
Corrosion allowance	0"
Opening chord length	24.2572"
Projection available outside vessel, L_{pr}	2.9899"
Projection available outside vessel to flange face, L_f	8.9899"
Local vessel minimum thickness	0.4"
User input radial limit of reinforcement	19"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Reinforcing Pad

Material specification	SA-240 316L (II-D p. 74, In. 9)
-------------------------------	---------------------------------

Diameter, D_p	29.0327"
Thickness, t_e	0.3125"
Is split	Yes
Butt welds tested to confirm full penetration	No
Joint efficiency	0.75
Welds	
Inner Fillet, Leg ₄₁	0.3125"
Outer Fillet, Leg ₄₂	0.25"
Nozzle to vessel groove weld	0.4"
Pad groove weld	0.3125"

ASME B16.5-2009 Flange	
Description	NPS 24 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt \leq 2 1/2 (II-D p. 352, In. 31)
Blind included	Yes
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	Full UW-11(a) Type 1
Gasket	
Description	Flexitallic Spiral Wound CGI 316L S.S.
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 * 11.625 / (16,700 * 1 - 0.6 * 45) =$	0.0314"
Stress ratio = $t_r * E^* / (t_n - c) = 0.0314 * 1 / (0.375 - 0) =$	0.0837
Impact test exempt per UHA-51(g) (coincident ratio = 0.0837)	
Rated MDMT =	-320 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.	

UHA-51 Material Toughness Requirements Pad
Rated MDMT per UHA-51(d)(1)(a), (carbon content does not exceed 0.10%) = -320 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.

Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 45.4 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
4.6467	4.6474	2.8645	0.6852	--	0.9375	0.1602	0.0324	0.375

UG-41 Weld Failure Path Analysis Summary (lb _f)						
All failure paths are stronger than the applicable weld loads						
Weld load W	Weld load W ₁₋₁	Path 1-1 strength	Weld load W ₂₋₂	Path 2-2 strength	Weld load W ₃₋₃	Path 3-3 strength
31,598.19	29,061.27	249,845.23	17,651.27	418,087.39	33,951.27	272,951.23

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.2188	0.2188	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

% Forming strain - UHA-44(a)(2)

$$\begin{aligned}
 EFE &= (50 * t / R_f) * (1 - R_f / R_o) \\
 &= (50 * 0.375 / 11.8125) * (1 - 11.8125 / \infty) \\
 &= 1.5873\%
 \end{aligned}$$

Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 46.51 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
4.6465	4.6476	2.8647	0.6852	--	0.9375	0.1602	0.0324	0.375

UG-41 Weld Failure Path Analysis Summary (lb _f)						
All failure paths are stronger than the applicable weld loads						
Weld load W	Weld load W ₁₋₁	Path 1-1 strength	Weld load W ₂₋₂	Path 2-2 strength	Weld load W ₃₋₃	Path 3-3 strength
32,366.66	29,774.43	255,976.41	18,084.43	428,347.2	34,784.43	279,649.42

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.2188	0.2188	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

Reinforcement Calculations for MAEP


UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 20.16 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
3.3719	3.3722	1.6764	0.5981	--	0.9375	0.1602	0.076	0.375

UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.2188	0.2188	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

Off Gas Vent (V2)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	150°
End of nozzle to datum line	184"
Calculated as hillside	Yes
Distance to head center, R	27"
Passes through a Category A joint	No

Nozzle

Description	NPS 1 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	1.049"
Nominal wall thickness	0.133"
Corrosion allowance	0"
Opening chord length	1.118"
Projection available outside vessel, L_{pr}	4.7176"
Projection available outside vessel to flange face, L_f	6.9076"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg₄₁	0.1563"
---------------------------------------	---------

Nozzle to vessel groove weld	0.4"
------------------------------	------

ASME B16.5-2009 Flange	
Description	NPS 1 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, ln. 31)
Blind included	No
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 * 0.5245 / (16,700 * 1 - 0.6 * 45) =$	0.0014"
Stress ratio = $t_r * E^* / (t_n - c) = 0.0014 * 1 / (0.1164 - 0) =$	0.0122
Impact test exempt per UHA-51(g) (coincident ratio = 0.0122)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 167.01 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area							0.1164	0.1164

calculations per UG-36(c)(3)(a)		
---------------------------------	--	--

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.0931	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 171.11 psi @ 70 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1164	0.1164

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.0931	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 32.18 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}

This nozzle is exempt from area calculations per UG-36(c)(3)(a)	0.1164	0.1164
---	--------	--------


UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.0931	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Emergency Pressure Relief (R1)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	25°
End of nozzle to datum line	184"
Calculated as hillside	Yes
Distance to head center, R	27"
Passes through a Category A joint	No

Nozzle

Description	NPS 4 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	4.026"
Nominal wall thickness	0.237"
Corrosion allowance	0"
Opening chord length	4.2911"
Projection available outside vessel, L _{pr}	3.3587"
Projection available outside vessel to flange face, L _f	6.3587"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg ₄₁	0.25"
---------------------------------	-------

Nozzle to vessel groove weld	0.4"
------------------------------	------

ASME B16.5-2009 Flange	
Description	NPS 4 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, ln. 31)
Blind included	No
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F	
Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 * 2.013 / (16,700 * 1 - 0.6 * 45) =$	0.0054"
Stress ratio = $t_r * E^* / (t_n - c) = 0.0054 * 1 / (0.2074 - 0) =$	0.0262
Impact test exempt per UHA-51(g) (coincident ratio = 0.0262)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 99.53 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
1.0225	1.0227	0.6939	0.2663	--	--	0.0625	0.2074	0.2074

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate

Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in²)

UG-45 Summary (in)

For P = 101.97 psi @ 70 °F
The opening is adequately reinforced

The nozzle passes UG-45

A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
1.0225	1.0228	0.694	0.2663	--	--	0.0625	0.2074	0.2074

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in²)

UG-45 Summary (in)

For P_e = 24.29 psi @ 338 °F
The opening is adequately reinforced

The nozzle passes UG-45

A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
0.6774	0.6774	0.3614	0.2535	--	--	0.0625	0.1025	0.2074

UG-41 Weld Failure Path Analysis Summary


Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1659	0.175	weld size is adequate

Spare (S1)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	0°
End of nozzle to datum line	187.25"
Calculated as hillside	Yes
Distance to head center, R	13"
Passes through a Category A joint	No

Nozzle

Description	NPS 2 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	2.067"
Nominal wall thickness	0.154"
Corrosion allowance	0"
Opening chord length	2.0963"
Projection available outside vessel, L _{pr}	3.9945"
Projection available outside vessel to flange face, L _f	6.4945"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg ₄₁	0.1563"
---------------------------------	---------

Nozzle to vessel groove weld	0.4"
------------------------------	------

ASME B16.5-2009 Flange	
Description	NPS 2 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, ln. 31)
Blind included	Yes
Rated MDMT	-55°F
Liquid static head	0 psi
Consider External Loads on Flange MAWP Rating	No
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Gasket	
Description	Flexitallic Spiral Wound CGI 316L S.S.
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F	
Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle
Rated MDMT per UHA-51(d)(1)(a), (carbon content does not exceed 0.10%) = -320°F
Material is exempt from impact testing at the Design MDMT of -20°F.

Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 167.01 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1348	0.1348

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1078	0.1094	weld size is adequate

WRC 107

Load Case	P (psi)	P _r (lb _f)	M ₁ (lb _f -in)	V ₂ (lb _f)	M ₂ (lb _f -in)	V ₁ (lb _f)	M _t (lb _f -in)	Max Comb Stress (psi)	Allow Comb Stress (psi)	Max Local Primary Stress (psi)	Allow Local Primary Stress (psi)	Over stressed
Load case 1	167.01	517	4,428	697	3,540	517	7,080	39,837	48,900	16,368	24,450	No
Load case 1 (Hot Shut Down)	0	517	4,428	697	3,540	517	7,080	-26,554	48,900	-1,509	24,450	No
Load case 1 (Pr Reversed)	167.01	-517	4,428	697	3,540	517	7,080	42,981	48,900	17,792	24,450	No
Load case 1 (Pr Reversed) (Hot Shut Down)	0	-517	4,428	697	3,540	517	7,080	26,698	48,900	1,509	24,450	No

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in²)

UG-45 Summary (in)

For P = 171.11 psi @ 70 °F

The nozzle passes UG-45

A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1348	0.1348

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1078	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For Pe = 32.18 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1348	0.1348


UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1078	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Spare (S2)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	180°
End of nozzle to datum line	187.25"
Calculated as hillside	Yes
Distance to head center, R	13"
Passes through a Category A joint	No

Nozzle

Description	NPS 3 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	3.068"
Nominal wall thickness	0.216"
Corrosion allowance	0"
Opening chord length	3.1115"
Projection available outside vessel, L _{pr}	3.6609"
Projection available outside vessel to flange face, L _f	6.4109"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Reinforcing Pad

Material specification	SA-240 316L (II-D p. 74, ln. 9)
------------------------	---------------------------------

Diameter, D_p	7.5492"
Thickness, t_e	0.3125"
Is split	No
Welds	
Inner Fillet, Leg_{41}	0.2188"
Outer Fillet, Leg_{42}	0.25"
Nozzle to vessel groove weld	0.4"
Pad groove weld	0.3125"

ASME B16.5-2009 Flange	
Description	NPS 3 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt $\leq 2\ 1/2$ (II-D p. 352, ln. 31)
Blind included	Yes
Rated MDMT	-55°F
Liquid static head	0 psi
Consider External Loads on Flange MAWP Rating	No
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Gasket	
Description	Flexitallic Spiral Wound CGI 316L S.S.
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle
Rated MDMT per UHA-51(d)(1)(a), (carbon content does not exceed 0.10%) = -320°F
Material is exempt from impact testing at the Design MDMT of -20°F.

UHA-51 Material Toughness Requirements Pad	
$t_r = 45 \cdot 78 \cdot 1 / (2 \cdot 16,700 \cdot 1 - 0.2 \cdot 45) =$	0.1051"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.1051 \cdot 1 / (0.4 - 0) =$	0.2628
Impact test exempt per UHA-51(g) (coincident ratio = 0.2628)	
Rated MDMT =	-320 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.	

Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 165.69 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
1.2347	1.2349	0.0099	0.3415	--	0.8356	0.0479	0.189	0.189

UG-41 Weld Failure Path Analysis Summary (lb _f)						
All failure paths are stronger than the applicable weld loads						
Weld load W	Weld load W ₁₋₁	Path 1-1 strength	Weld load W ₂₋₂	Path 2-2 strength	Weld load W ₃₋₃	Path 3-3 strength
19,987.16	19,967.1	36,391.26	9,163.86	56,854.44	22,783.74	50,203.56

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

WRC 107												
Load Case	P (psi)	P _r (lb _f)	M ₁ (lb _f -in)	V ₂ (lb _f)	M ₂ (lb _f -in)	V ₁ (lb _f)	M _t (lb _f -in)	Max Comb Stress (psi)	Allow Comb Stress (psi)	Max Local Primary Stress (psi)	Allow Local Primary Stress (psi)	Over stressed
Load case 1	165.69	787	12,384	922	7,968	674	15,936	29,093	48,900	17,299	24,450	No
Load case 1 (Hot Shut Down)	0	787	12,384	922	7,968	674	15,936	-17,298	48,900	-2,181	24,450	No
Load case 1 (Pr Reversed)	165.69	-787	12,384	922	7,968	674	15,936	33,473	48,900	18,335	24,450	No
Load case 1 (Pr Reversed) (Hot Shut Down)	0	-787	12,384	922	7,968	674	15,936	17,319	48,900	2,181	24,450	No

Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 169.75 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
1.2347	1.2349	0.0099	0.3415	--	0.8356	0.0479	0.189	0.189

UG-41 Weld Failure Path Analysis Summary (lb _f)						
All failure paths are stronger than the applicable weld loads						
Weld load W	Weld load W ₁₋₁	Path 1-1 strength	Weld load W ₂₋₂	Path 2-2 strength	Weld load W ₃₋₃	Path 3-3 strength
20,477.19	20,457.1	37,284.3	9,388.74	58,249.64	23,342.86	51,435.55

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 32.18 psi @ 338 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
0.6223	1.216	--	0.3326	--	0.8355	0.0479	0.1358	0.189

UG-41 Weld Failure Path Analysis Summary


Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary

Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to pad fillet (Leg ₄₁)	0.1512	0.1531	weld size is adequate
Pad to shell fillet (Leg ₄₂)	0.1562	0.175	weld size is adequate

Temperature Indicator (T1)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	Shell -01
Orientation	45°
Nozzle center/shell outer surface intersection to datum	6"
End of nozzle to shell center	46.3199"
Tilted	15° from radial
Passes through a Category A joint	No

Nozzle

Description	NPS 1.5 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	1.61"
Nominal wall thickness	0.145"
Corrosion allowance	0"
Opening chord length	1.6668"
Projection available outside vessel, L_{pr}	4.56"
Projection available outside vessel to flange face, L_f	7"
Local vessel minimum thickness	0.3125"
Liquid static head included	4.67 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg₄₁	0.1563"
---------------------------------------	---------

Nozzle to vessel groove weld	0.3125"
------------------------------	---------

ASME B16.5-2009 Flange	
Description	NPS 1.5 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, ln. 31)
Blind included	No
Rated MDMT	-55°F
Liquid static head	4.57 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 49.67 * 0.805 / (16,700 * 1 - 0.6 * 49.67) =$	0.0024"
Stress ratio = $t_r * E^* / (t_n - c) = 0.0024 * 1 / (0.1269 - 0) =$	0.0189
Impact test exempt per UHA-51(g) (coincident ratio = 0.0189)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 129.98 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}

This nozzle is exempt from area calculations per UG-36(c)(3)(a)	0.1269	0.1269
---	--------	--------

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 133.17 psi @ 70 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For Pe = 20.36 psi @ 338 °F							The nozzle passes UG-45	
		A ₁	A ₂	A ₃	A ₅		t _{req}	t _{min}

A required	A available				A welds		
This nozzle is exempt from area calculations per UG-36(c)(3)(a)						0.0625	0.1269

UG-41 Weld Failure Path Analysis Summary

Weld strength calculations are not required for external pressure


UW-16 Weld Sizing Summary

Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Vent (V1)

ASME Section VIII Division 1, 2013 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	F&D Head (top)
Orientation	0°
End of nozzle to datum line	184"
Calculated as hillside	Yes
Distance to head center, R	27"
Passes through a Category A joint	No

Nozzle

Description	NPS 1.5 Sch 40S (Std)
Access opening	No
Material specification	SA-312 TP316L Wld & smls pipe (II-D p. 74, ln. 14)
Inside diameter, new	1.61"
Nominal wall thickness	0.145"
Corrosion allowance	0"
Opening chord length	1.7159"
Projection available outside vessel, L_{pr}	4.3639"
Projection available outside vessel to flange face, L_f	6.8039"
Local vessel minimum thickness	0.4"
Liquid static head included	0 psi
Longitudinal joint efficiency	1

Welds

Inner Fillet, Leg₄₁	0.1563"
---------------------------------------	---------

Nozzle to vessel groove weld	0.4"
------------------------------	------

ASME B16.5-2009 Flange	
Description	NPS 1.5 Class 150 WN A182 F316L
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 352, ln. 31)
Blind included	No
Rated MDMT	-55°F
Liquid static head	0 psi
MAWP rating	169.3 psi @ 338°F
MAP rating	230 psi @ 70°F
Hydrotest rating	350 psi @ 70°F
PWHT performed	No
Impact Tested	No
Circumferential joint radiography	None UW-11(c) Type 1
Notes	
Flange rated MDMT per UHA-51(d)(1)(a) = -320°F Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UHA-51 Material Toughness Requirements Nozzle	
$t_r = 45 * 0.805 / (16,700 * 1 - 0.6 * 45) =$	0.0022"
Stress ratio = $t_r * E^* / (t_n - c) = 0.0022 * 1 / (0.1269 - 0) =$	0.0171
Impact test exempt per UHA-51(g) (coincident ratio = 0.0171)	
Rated MDMT =	-320°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 167.01 psi @ 338 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}

This nozzle is exempt from area calculations per UG-36(c)(3)(a)	0.1269	0.1269
---	--------	--------

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P = 171.11 psi @ 70 °F							The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269

UG-41 Weld Failure Path Analysis Summary

The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Reinforcement Calculations for MAEP

UG-37 Area Calculation Summary (in ²)							UG-45 Summary (in)	
For P _e = 32.18 psi @ 338 °F							The nozzle passes UG-45	
		A ₁	A ₂	A ₃	A ₅		t _{req}	t _{min}

A required	A available					A welds		
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1269	0.1269


UG-41 Weld Failure Path Analysis Summary
Weld strength calculations are not required for external pressure

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.1015	0.1094	weld size is adequate

This opening does not require reinforcement per UG-36(c)(3)(a)

Lifting Lugs (Evonik Type 2)

Minimum report

Geometry Inputs	
	
Attached To	Shell -02
Material	SA-240 304L
Distance of Lift Point From Datum	177.1875"
Angular Position	180 deg and 0 deg
Length, L	10.6875"
Width, B	5.625"
Thickness, t	0.625"
Hole Diameter, d	1.5"
Pin Diameter, Dp	1.25"
Diameter at Pin, D	5.625"
Length to Brace Plate, L ₁	3.375"
Load Angle from Vertical, ϕ	0 deg
Has Brace Plate	Yes
Welds	
Size, t _w	0.3125"
Length, b ₁	1.8125"
Length, d ₂	4"
Reinforcement Pad	
Width, B _p	8.125"
Length, L _p	5.25"
Thickness, t _p	0.375"
Weld Size, t _{wp}	0.25"
Weld Length, L ₃	4"

Intermediate Values	
Load Factor	1.5000
Vessel Weight (new, incl. Load Factor), W	11,364 lb
Lug Weight (new), W_{lug}	49.8 lb (Qty=2)
Distance from Center of Gravity to Top Lug, l_1	76.2143"
Distance from Center of Gravity to Tail Lug, l_2	93.4732"
Distance from Vessel Center Line to Tail Lug, l_3	42.3125"
Allowable Stress, Tensile, σ_t	19,980 psi
Allowable Stress, Shear, σ_s	13,320 psi
Allowable Stress, Bearing, σ_p	29,970 psi
Allowable Stress, Bending, σ_b	22,201 psi
Allowable Stress, Weld Shear, $\tau_{allowable}$	13,320 psi
Allowable Stress set to 1/3 Sy per ASME B30.20	No

Summary Values	
Required Lift Pin Diameter, d_{reqd}	0.5211"
Required Lug Thickness, t_{reqd}	0.1517"
Estimated Brace Plate Length	4.2562"
Lug Stress Ratio, σ_{ratio}	0.48
Weld Shear Stress Ratio, τ_{ratio}	0.21
Lug Design	Acceptable
Local Stresses WRC 107	Acceptable
Maximum Out of Plane Lift Angle - Weak Axis Bending	22.98 deg

COMPRESS recommends a spreader beam be used to prevent weak axis bending of the top lugs. Ear lug brace plate should be removed before vessel is put in service.

Tailing Lug (Evonik Type 2)

Minimum report

Geometry Inputs	
Attached To	Shell -01
Material	SA-240 304L
Orientation	Longitudinal
Distance of Lift Point From Datum	7.5"
Angular Position	270 deg
Length, L	5.625"
Height, H	5.1875"
Thickness, t	0.625"
Hole Diameter, d	1.5"
Pin Diameter, Dp	1.25"
Load Eccentricity, a_1	0"
Distance from Load to Shell or Pad, a_2	2.375"
Load Angle Normal to Vessel, β	0 deg
Load Angle from Vertical, ϕ	-90 deg
Welds	
Size, t_w	0.4375"
Reinforcement Pad	
Width, B_p	4.3125"
Length, L_p	8.6875"
Thickness, t_p	0.625"
Weld Size, t_{wp}	0.25"

Intermediate Values	
Load Factor	1.5000
Vessel Weight (new, incl. Load Factor), W	11,364 lb
Lug Weight (new), W_{lug}	12.3 lb
Distance from Center of Gravity to Top Lug, l_1	76.2143"
Distance from Center of Gravity to Tail Lug, l_2	93.4732"
Distance from Vessel Center Line to Tail Lug, l_3	42.3125"
Allowable Stress, Tensile, σ_t	19,980 psi
Allowable Stress, Shear, σ_s	13,320 psi
Allowable Stress, Bearing, σ_p	29,970 psi
Allowable Stress, Bending, σ_b	22,201 psi
Allowable Stress, Weld Shear, $\tau_{allowable}$	13,320 psi
Allowable Stress set to 1/3 Sy per ASME B30.20	No

Summary Values	
Required Lift Pin Diameter, d_{reqd}	0.4939"
Required Lug Thickness, t_{reqd}	0.1362"
Lug Stress Ratio, σ_{ratio}	0.13
Weld Shear Stress Ratio, τ_{ratio}	0.18
Lug Design	Acceptable
Local Stresses WRC 107	Acceptable