





SCHEDULE OF CONNECTIONS				
ITEM NO.	SIZE	RATING	TYPE	SERVICE
A	1 1/2"	90#	RING	MANWAY W/ SIGHT GLASS
E	1 1/4"	150#	S.O.	AGITATOR
F	1 1/4"	150#	PAD	BTM. OUT
G	1 1/4"	150#	PAD	LIGHT CONN.
I	1 1/4"	150#	S.O.	TO CONDENSER
J	1 1/4"	150#	S.O.	TO CONDENSER
K	1 1/4"	150#	S.O.	TO CONDENSER
L	1 1/4"	150#	S.O.	TO CONDENSER
M	1 1/4"	150#	S.O.	TO CONDENSER
N	1 1/4"	150#	S.O.	TO CONDENSER
P	1 1/4"	150#	S.O.	TO CONDENSER
R	1 1/4"	150#	S.O.	TO CONDENSER
S	1 1/4"	150#	S.O.	TO CONDENSER

BILL OF MATERIAL				
ITEM NO.	QTY.	CON.	MAT. L.	DESCRIPTION
1	1		316L	SHELL 72\"/>



- GENERAL NOTES**
- 1) VESSEL DESIGNED & FABRICATED PER 1983 ASME CODE SECT VIII DIV. 1
 - 2) CODE STAMP REQ'D.
 - 3) NOZZLE BOLT HOLES TO STRADDLE MAIN VESSEL CTR. LINES, EXCEPT AGITATOR TO BE ON CTR.
 - 4) PARTIAL X-RAY REQ'D. ON BOTH CIRCUM. SEAMS AT LEAST ONE SHOT TAKEN AT JUNCTURE OF LONG. JEAM
 - 5) INTERNAL SURFACES TO HAVE #4 POLISH & BE PASSIVATED
 - 6) INTERNAL WELDS GROUND SMOOTH & FLUSH
 - 7) EXTERNAL WELDS WIRE BRUSHED
 - 8) ALL WELDS TO BE FREE OF SLAG, POROSITY, UNDERCUTS ETC.
 - 9) FOR SHIPPING, NOZZLES TO HAVE WOOD COVERS & PLUGS TO HAVE PLUGS
 - 10) VESSEL TO BE TAGGED 5004-B419 ON TOP HEAD

CUST-AMERICAN HOECHST
 P.O. # 507612
 ITEM # B419
 EST. WTS.
 EMPTY- 6200#
 FULL H₂O- 23600#
 REF. DWG.
 C-1708

U	RT ₄	NATIONAL BOARD NO.	1758
W		MFGRS. SERIAL NO.	2890
		YEAR BUILT	1986
		VAC.	
SHELL	FULL	P.S.I. AT 390 °F.	3125
JACKET	90	P.S.I. AT 390 °F.	3125
TUBES		P.S.I. AT	125
COILS		P.S.I. AT	120

ALLOY FAB, INC.
 CERTIFIED

AHC NO. E005-307

C	move L ₃ from 2021 to 220	6-20-86	B.P.
B	REV. JKT. C'PLGS. & AGIT. SIZE	3-13-86	B.P.
A	PER CUST DWG.	3-4-86	B.P.

REV. DESCRIPTION DATE BY

ALLOY FAB INC.
 SOUTH PLAINFIELD, N.J.
 (ONE) 72" O.D. 1500 GAL.
 316L₃ H.P.C.U. CRYSTALLIZER

WORK ORDER NO. 2890
 DR. BY B.P. DATE 2-21-86
 CH. BY B.P. D-1711-C
 SCALE

HYDRO TEST SHELL @ 137 P.S.I.G.
 HYDRO TEST JACKET @ 137 P.S.I.G.

114213