

FORM U-1 MANUFACTURERS' DATA REPORT FOR UNFIRED PRESSURE VESSELS

As Required by the Provisions of the ASME Code Rules

1. Manufactured by POTTSTOWN METAL PRODUCTS WORKS, POTTSTOWN, PA.
(Name and address of Manufacturer)

2. Manufactured for HERCULES POWDER COMPANY, WILMINGTON, DELAWARE
(Name and address of Purchaser)

3. Type Vert. Kind Jkt. Tk. Vessel No. (5801) (Mfr's. Serial) (State & State No.) Nat'l Bd. No. 3182 Yr. Built 1962
(Horizontal or Vertical) (Tank, Jacketed, Heat Exch.)

Items 4-9 incl. to be completed for single wall vessels (such as air tanks), jackets of jacketed vessels, or shells of heat exchangers.

4. SHELL: Material SA-285 Gr.C T.S. Flg. 55000 Nominal Thickness 1/4 in. Corrosion Allowance 1/16 in. Diam. 7 ft. 0 in. Length 6 ft. 6 in.
(Kind and Spec. No.) (Fig. or P.B. & lowest T.S.)

5. SEAMS: Long DBfusion weld S.R. No X.R. Spot Sectioned No Efficiency 85 %
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)
Girth DBfusion weld S.R. No X.R. Spot Sectioned No No. of Courses One
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

6. HEADS: (a) Material SA-285 Gr.C T.S. Flg. 55000 (b) Material T.S.
Location (Top, bottom, ends) Thickness 1/2 in. Crown Radius 78 in. Knuckle Radius 5 1/8 in. Elliptical Ratio Conical Apex angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave) Concave
(a) Bottom (b)

If removable, bolts used Other fastening
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)

7. STAYBOLTS: (Material) If hollow Attachment Pitch X Diam.
(Size of Hole) (Through, Welded) (Horizontal or Vertical) (Nominal)

8. JACKET CLOSURE: Jkt'd. shell welded with 1 1/8" thk. x 78" I.D. x 84" O.D. ring to shell
(Describe as edge & weld, bar, etc. If bar, give dimensions. If bolted, describe or sketch.)

9. Constructed for {Int.} pressure of 40 psi. Max. Temp. 287 °F. Subzero °F. Hydrostatic Test 60 psi.
{Ext.}

Items 10 and 11 to be completed for tube sections.

10. TUBE SHEETS: Stationary. Material Diam. in. Thickness in. Attachment
(Kind & Spec. No.) (Subject to Pressure) (Welded, Bolted)
Floating. Material Diam. in. Thickness in. Attachment

11. TUBES: Material O.D. in. Thickness inches or gage. Number Type
(Kind & Spec. No.) (Straight or U)

Items 12-15 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

12. SHELL: Material SA-240Tp304 T.S. 75000 Nominal Thickness 1/4 in. Corrosion Allowance in. Diam. 6 ft. 6 in. Length 11 ft. 4 in.
(Kind and Spec. No.) (Fig. or P.B. & lowest T.S.)

13. SEAMS: Long DBfusion weld S.R. No X.R. Spot Sectioned No Efficiency 85 %
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)
Girth DBfusion weld S.R. No X.R. Spot Sectioned No No. of Courses Two
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

14. HEADS: (a) Material SA-240Tp304 T.S. 75000 (b) Material SA-240Tp304 T.S. 75000 (c) Material T.S.
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)
(a) Top XXXXXX 1/4 in. 78 in. 4 3/4 in. Concave
(b) XXXXXX Bottom 1/2 in. 72 in. 4 3/4 in. Convex & Concave
(c) Floating

If removable, bolts used (a) (b)
(Material, Spec. No., T.S., Size, Number)

(c) Other fastening
(Describe or Attach Sketch)

15. Constructed for {Int.} pressure of 40 psi. Max. Temp. 287 °F. Subzero °F. Hydrostatic Test 53 psi.
{Ext.}

Items below to be completed for all vessels where applicable.

16. SAFETY VALVE OUTLETS: Number Four Size 1/2" 3/4" Location Th'd. SS304, SA-105 3000# Welded

17. NOZZLES: Purpose (Inlet, Outlet, Drain) Number Seven Diam. or Size 1" 2 1/2" 1 1/2" 3" Type Flg. SS304, SA-106 Sch. 40 Material SS304 Thickness 1 9/16" 2" Reinforcement Material How Attached Welded
Inlets & outlets three 12" 1 1/2" Pad SS304 1 9/16" 2" Welded
Inlets & outlets three 2 1/2" 1" Flg. Th'd. SS304 SA-106 Sch. 80 Sch. 40 Welded
drain three 2 1/2" 1" Flg. Th'd. SS304 SA-106 Sch. 80 Sch. 40 Welded

18. INSPECTION OPENINGS: Manholes, No. One Size 18" Location in top head. Handholes, No. Size Location
Threaded, No. Size Location

19. SUPPORTS: Skirt No Lugs four Legs Other Attached Wld. to shell
(Yes or No) (Number) (Number) (Number) (Where & How)

20. REMARKS: Nutrient cooker built in accordance with 1959 ASME code.
(Brief description of purpose of the vessel, as Air Tank, After Cooler, Jacketed Cooler, etc. State contents of each part.)
(Over)

U.S. G. No. 336-007-160-S-03-000-FCP Item 7-111
FORM U-1 MANUFACTURERS' DATA REPORT FOR UNFIRE
PRESSURE VESSEL

As Required by the Provisions of the ASME Code Rules

1. Manufactured by: POTTSTOWN METAL PRODUCTS WORKS, POTTSTOWN, PA.
(Name and Address of Manufacturer)
2. Manufactured for: HITCHCOCK POWDER COMPANY, WILMINGTON, DELAWARE
(Name and Address of Purchaser)
3. Type Vessel: KILN, 12" Dia. x 10' Long, 1500#
(Name or Year) (Type, Size, Weight, etc.)
4. Item 4-9 must be completed for all vessels which are subject to heat exchanger
We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this unfired pressure vessel conform to the ASME Code for Unfired Pressure Vessels.
Date April 12, 1962 Signed Pottstown Metal Products Wks. (Manufacturer)
Certificate of Authorization Expires Dec. 31, 1964

CERTIFICATE OF SHOP INSPECTION

Insurance Company's Serial Number 4034
VESSEL MADE BY Pottstown Metal Products Wks. at Pottstown, Pa.
I, the undersigned, holding a Certificate of Competency as an Inspector of Boilers and Unfired Pressure Vessels in THE STATE OF Pennsylvania and employed by HARTFORD STM. BLR. INSP. & INS. CO., HARTFORD CONN.
inspected internally and externally, the vessel described in this report on April 12, 1962
and certify that the statements made in this report are correct, corresponding with mill test reports of materials furnished by the builders, and measurements made of the vessel; and that this vessel is constructed in accordance with the ASME Code for Unfired Pressure Vessels.
Date April 12, 1962
Inspector's Signature William Barr
Commissions NB 589 Pa. 830
State or Nat'l Bd. & Number

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a Certificate of Competency as an Inspector of Boilers and Unfired Pressure Vessels in THE STATE OF Pennsylvania and employed by
of , have compared the statements in this manufacturer's data report with the completed vessel, and certify that parts referred to as data items were completed in the field in accordance with the requirements of the ASME Code for Unfired Pressure Vessels. The completed vessel was inspected and subjected to a hydrostatic test of psi.
Date April 12, 1962
Inspector's Signature
Commissions
State or Nat'l Bd. & Number

FORM R-2 REPORT OF ALTERATION

in accordance with provisions of the National Board Inspection Code

1. Work performed by ALLOY FABRICATORS, INC. 1
(name of alteration organization) (Form R No.)
102 SOUTH INDUSTRIAL DRIVE, TRENTON GA 30752
(address) *JMC-27-96*
KM 2-27-96

2. Owner SOFIX CORPORATION
(name)
2800 RIVERPORT RD., CHATTANOOGA TN 37406
(address)

3. Location of installation SOFIX CORPORATION
(name)
2800 RIVERPORT RD., CHATTANOOGA TN 37406
(address)

4. Unit identification JKT. VESSEL Name of original manufacturer POTTSTOWN METAL PRODUCT WORKS
(boiler, pressure vessel)

5. Identifying nos.: 5801 3182 1962
(mfg serial no.) (National Board No.) (jurisdiction no.) (other) (year built)

6. NBIC Edition/Addenda: 1992/1993 Original Construction Code: ASME SECT. VIII
(incl edition and addenda)

7. Description of work: ADDED (2) 4" NOZZLES 150# RFSO FLGS (SA-182F304)
(use supplemental sheet, Form R-4, if necessary)
& SCH40S PIPE (SA-312TP304), MOVED SUPPORT LUGS FROM JACKET TO
SHELL, ADDED 1/8" THK RAIN SHIELD, REPLACED FLGS ON NOZZLES F
(1 1/2") AND E (3") 150# RFSO FLG SA-182F304 AND NOZZLE K (3")
L (2 1/2") AND M (2 1/2") 150# RFSO FLG SA-105. NOZZLE M ALSO
HAD THE PIPE REPLACED SCH 40 PIPE SA-53-B

Pressure Test, if applied LINE 9 psi

8. Replacement Parts. Attached are Manufacturer's Partial Data Reports or Form R-3s properly completed for the following items of this report:

(name of part, item number, data report type, mfr's name and identifying stamp)

9. Remarks: INNER SHELL WAS HYDRO TESTED @ 50 PSI (HORIZONTAL) AND
THE JACKET WAS HYDRO TESTED @ 15 PSI (HORIZONTAL)

MM 2-27-96
RM 2-27-96

DESIGN CERTIFICATION

I, KEVIN W. MULLINS, certify that to the best of my knowledge and belief the statements in this report are correct and that the Design Change described in this report conforms to the National Board Inspection Code.

National Board "R" Certificate of Authorization No. 1476 expires on 04/28, 19 96

Date 2-27, 19 96 ALLOY FABRICATORS INC. Signed K. W. M. O.
(name of design organization) (authorized representative)

CERTIFICATE OF DESIGN CHANGE REVIEW

I, James R. Myhan, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the jurisdiction of Tennessee and employed by Kemper National Insurance Co's of Long Grove, IL have reviewed the design change as described in this report and state that to the best of my knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Date 2-27, 19 96 Signed James R. Myhan Commissions NB10B22A, TN2693
(inspector) (National Board (incl endorsements), and jurisdiction, and no.)

CONSTRUCTION CERTIFICATION

I, KEVIN W. MULLINS, certify that to the best of my knowledge and belief the statements in this report are correct and that all material, construction, and workmanship on this Alteration conforms to the National Board Inspection Code.

National Board "R" Certificate of Authorization No. 1476 expires on 04/28, 19 96

Date 2-27, 19 96 ALLOY FABRICATORS INC. Signed K. W. M. O.
(name of alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

I, James R. Myhan, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the jurisdiction of Tennessee and employed by Kemper National Insurance Co's of Long Grove, IL have inspected the work described in this report on Dec. 2, 19 95 and state that to the best of my knowledge and belief this work complies with the applicable requirements of the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Date 2-27, 19 96 Signed James R. Myhan Commissions NB10B22A, TN 2693
(inspector) (National Board (incl endorsements), and jurisdiction, and no.)