

Table of Contents

Cover Sheet.....	3
Vessel Design Summary:.....	4
Nozzle Summary:.....	8
Nozzle Schedule:.....	10
Bill of Material:	12
MDMT Summary:.....	13
Warnings and Errors:	15
Input Echo:.....	16
XY Coordinate Calculations:.....	26
Flg Calc [Int P]: FLANGE.....	27
Flg Calc [Int P]: BLIND FLANGE.....	31
Internal Pressure Calculations:.....	34
External Pressure Calculations:.....	38
Element and Detail Weights:.....	41
Nozzle Flange MAWP:.....	44
Natural Frequency Calculation:.....	45
Wind Load Calculation:.....	46
Earthquake Load Calculation:.....	51
Wind/Earthquake Shear, Bending:.....	54
Wind/Earthquake Deflection:.....	55
Longitudinal Stress Constants:.....	57
Longitudinal Allowable Stresses:.....	58
Longitudinal Stresses due to:.....	59
Stress due to Combined Loads:.....	62
Skirt Opening Stress Calcs:.....	67
Skirt Opening Stress Calcs:.....	70
Center of Gravity Calculation:.....	73
Lifting Lug Calcs:.....	75
Basering Calculations:.....	83
WRC Clip Analysis: Type-1.....	89
Nozzle Calcs.: Nozzle B2 2 in.....	94
Nozzle Calcs.: Nozzle LT2 2 in.....	102
Nozzle Calcs.: Nozzle L2 2 in.....	113
Nozzle Calcs.: Nozzle S 2 in.....	124
Nozzle Calcs.: Nozzle LT1 2 in.....	135
Nozzle Calcs.: Nozzle L1 2 in.....	146
Nozzle Calcs.: Nozzle B4 2 in.....	157
Nozzle Calcs.: Nozzle B3 2 in.....	168
Nozzle Calcs.: Nozzle LT3.....	177
Nozzle Calcs.: Nozzle LT4.....	190
Nozzle Calcs.: Nozzle A 3 in.....	201
Nozzle Calcs.: Nozzle B1 6in.....	212
Nozzle Calcs.: Nozzle V 2 in.....	217
Tailing Lug Calcs.:.....	223
Hydro Test Calcs. (UG-99C) :.....	225
Manway Davit Calcs.....	226
Nozzle D 2" Calcs.:.....	227
FEA A 3" Calcs.:.....	231
FEA B1 6" Calcs.:.....	256

FEA B2 2" Calcs.:	280
FEA B3-B4 & S 2" Calcs.:	305
Nozzle Derating B1 and D Calcs.:	330
FEA Of Type1, Type-2 and Ladder Cleat.:	332

18-D-272
R06
V-1264

DESIGN CALCULATION

In Accordance with ASME Section VIII Division 1

ASME Code Version : 2021

Analysis Performed by : THE ANUP ENGINEERING LIMITED.

Job File : ...\\V-1264_R06.pvdb

Date of Analysis : Dec 21,2022 4:21pm

PV Elite 24, January 2022

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Vessel Design Summary: Step: 119 4:21pm Dec 21, 2022

Vessel Design Summary:**ASME Code, Section VIII Division 1, 2021**

Diameter Spec : 29.250 in ID
Vessel Design Length, Tangent to Tangent 10.25 ft

Distance of Bottom Tangent above Grade 16.75 ft
Distance of Base above Grade 0.00 ft
Specified Datum Line Distance 16.91 ft

Internal Design Temperature 500 °F
Internal Design Pressure 105.000 psig

External Design Temperature 300 °F
External Design Pressure 15.000 psig

Maximum Allowable Working Pressure 150 psig
External Max. Allowable Working Pressure 82 psig
Shop Test Pressure 312.913 psig

Required Minimum Design Metal Temperature 32.0 °F
Warmest Computed Minimum Design Metal Temperature -55.0 °F

Wind Design Code ASCE/SEI 7-16
Earthquake Design Code ASCE/SEI 7-16

Materials of Construction:

Component Type	Material	Class	Thickness	UNS #	Normal ized	Impact Tested
Shell	SA-240 316L	...	...	S31603	No	No
Head	SA-240 316L	...	...	S31603	No	No
Flange	SA-182 F316L	...	> 5	S31603	No	No
Skirt	SA-516 70	...	...	K02700	No	No
Skirt	SA-240 316L	...	...	S31603	No	No
Nozzle	SA-312 TP316L	...	...	S31603	No	No
Nozzle	SA-182 F316L	...	<= 5	S31603	No	No
Nozzle Flg	SA-182 F316L	...	<= 5	S31603	No	No
Basering	SA-516 70	...	...	K02700	No	No
Flg Bolting	SA-193 B7M	...	<= 2 1/2	G41400	No	No
Base Bolting	SA-193 B7M	...	<= 2 1/2	G41400	No	No

Normalized is determined based on the UCS-66 material curve selection and Figure UCS-66.

Impact Tested is based on material selection and material data properties.

Element Pressures and MAWP (psig & in):

Element Description or Type	Design Pressure + Stat. head	Ext. Press.	Element M.A.W.P	Total Corrosion Allowance	Str. Flg. Gov.	In Creep Range
BTM D-END	106.619	15.00	285.000	0.0315	No	N/S
SHELL-1	106.288	15.00	359.000	0.0315	N/A	N/S
SHELL-2	105.000	15.00	360.000	0.0315	N/A	N/S
NOZZLE M FLANGE	105.000	15.00	150.000	0.0315	N/A	N/S
NOZZLE M BLIND	105.000	15.00	230.000	0.0315	N/A	N/S

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Vessel Design Summary: Step: 119 4:21pm Dec 21,2022

N/S in the Creep Range column specifies that the Creep Range Temperature was not specified in the ASME Code Section II Part D for this material.

Liquid Level: 3.77 ft Dens.: 61.776 lb/ft^3 Sp. Gr.: 0.990

Element Types and Properties:

Element Type	"To" Elev ft	Element Length ft	Nominal Thickness in	Finished Thickness in	Reqd Thk Internal in	Reqd Thk External in	Long Eff	Circ Eff
Skirt	-8.71	8.202	0.394	0.394	...	...	0.60	0.60
Skirt	-3.28	5.430	0.394	0.394	...	...	0.60	0.60
Skirt	-0.16	3.117	0.394	0.394	...	...	0.60	0.60
Ellipse	0.00	0.164	0.394	0.315	0.137	0.113	1.00	1.00
Cylinder	4.92	4.921	0.394	0.394	0.137	0.208	1.00	1.00
Cylinder	9.51	4.587	0.394	0.394	0.136	0.208	1.00	1.00
Body Flg	9.83	0.318	...	1.690	...	...	1.00	1.00
Body Flg	10.09	0.230	2.756	2.756	1.873	1.071	1.00	1.00

Wind/Earthquake Shear, Bending:

From	To	Distance to Support ft	Cumulative Wind Shear lbf	Earthquake Shear lbf	Wind Bending ft-lbf	Earthquake Bending ft-lbf
10	20	4.10105	1533.32	3575.17	26863.9	71804.7
20	30	10.917	1360.34	3456.15	14996.9	42968.9
30	40	15.1903	1041.42	2949.35	8476.37	25578.7
40	50	16.8307	975.514	2826.24	5333.18	16578
50	60	19.3733	971.986	2716.04	5173.49	16123.5
60	80	24.1273	577.65	1663.97	1360.41	5345.92
80	90	26.5797	13.7538	565.396	4.13497	233.283
90	100	26.885	6.3746	469.429	0.732	53.9045

Abs Max of the all of the Stress Ratio's : 0.2973


Basing Data : Basing W/Gussets & Chair Cap

Thickness of Basing	1.2598	in
Inside Diameter of Basing	25.2362	in
Outside Diameter of Basing	40.2756	in
Nominal Diameter of Bolts	1.7500	in
Diameter of Bolt Circle	35.5000	in
Number of Bolts	4	
Thickness of Gusset Plates	0.7874	in
Average Width of Gusset Plates	5.2360	in
Height of Gussets	8.1880	in
Distance between Gussets	4.0157	in
Thickness of Top Plate or Ring	1.5748	in
Circumferential Width of the Top Plate	7.0079	in
Radial Width of the Top Plate	5.2362	in

Basing Sketch for Cylindrical Skirts:

-----> | <----- 0.3937 in
30.00 in -----> |

Vessel Design Summary: Step: 119 4:21pm Dec 21, 2022

**Loads for Foundation/Support Design:**

Total Wind Shear on Support	1533.	lbf
Total Earthquake Shear on Support	3575.	lbf
Wind Moment on Support	26864.	ft-lbf
Earthquake Moment on Support	71805.	ft-lbf
Maximum Initial Bolt Load	22090.	lbf

Wind Shear on Support	2556.	lbf
Earthquake Shear on Support	5107.	lbf
Wind Moment on Support	44773.	ft-lbf
Earthquake Moment on Support	102578.	ft-lbf
Maximum Initial Bolt Load	36817.	lbf

Wind and Earthquake moments include the effects of user defined forces and moments if any exist in the job and were specified to act (compute loads and stresses) during these cases. Also included are moment effects due to eccentric weights if any are present in the input.

Description	Analysis	Max Stress	High Stress	Pass
	Type	Ratio	Location	Fail
Lift Lug	WRC-107/537	0.956	n/a	Passed
Local Skirt	Jawad & Farr	0.274	n/a	Passed
Type-1	WRC-107/537	0.563	n/a	Passed
Nozzle B2 2"	WRC-107/537	0.700	n/a	Passed
Nozzle LT2 2"	WRC-297	0.541	Shell	Passed
Nozzle L2 2"	WRC-297	0.541	Shell	Passed
Nozzle S 2"	WRC-297	0.541	Shell	Passed
Nozzle LT1 2"	WRC-297	0.540	Shell	Passed
Nozzle L1 2"	WRC-297	0.540	Shell	Passed
Nozzle B4 2"	WRC-297	0.538	Shell	Passed
Nozzle B3 2"	WRC-297	0.538	Shell	Passed
Nozzle LT3	WRC-297	0.540	Shell	Passed
Nozzle LT4	WRC-297	0.541	Shell	Passed
Nozzle A 3"	WRC-297	0.760	Shell	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Vessel Design Summary: Step: 119 4:21pm Dec 21,2022

Weights:

Fabricated - Bare W/O Removable Internals	5976.4	lbm
Shop Test - Fabricated + Water (Full)	9031.8	lbm
Shipping - Fab. + Rem. Intls.+ Shipping App.	5976.4	lbm
Erected - Fab. + Rem. Intls.+ Insul. (etc)	10351.6	lbm
Empty - Fab. + Intls. + Details + Wghts.	10351.6	lbm
Operating - Empty + Operating Liquid (No CA)	11381.3	lbm
Field Test - Empty Weight + Water (Full)	13180.6	lbm

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Summary: Step: 117 4:21pm Dec 21, 2022

Nozzle Calculation Summary (psig & in):

Description	MAWP	Ext	MAPNC	UG-45	[tr]	Weld Path	Areas or Stresses
Nozzle B2 2"	183	OK	...	OK	0.166	OK	Passed
Nozzle LT2 2"	359	OK	...	OK	0.182	OK	Passed
Nozzle L2 2"	359	OK	...	OK	0.182	OK	Passed
Nozzle S 2"	359	OK	...	OK	0.182	OK	Passed
Nozzle LT1 2"	359	OK	...	OK	0.181	OK	Passed
Nozzle L1 2"	359	OK	...	OK	0.181	OK	Passed
Nozzle B4 2"	359	OK	...	OK	0.181	OK	Passed
Nozzle B3 2"	359	OK	...	OK	0.181	OK	Passed
Nozzle LT3	359	OK	...	OK	0.181	OK	Passed
Nozzle LT4	359	OK	...	OK	0.182	OK	Passed
Nozzle A 3"	298	OK	...	OK	0.181	OK	Passed
Nozzle B1 6in.	157	OK	...	OK	0.276	OK	Passed
Nozzle V 2"	213	OK	...	OK	0.220	OK	Passed

Nozzle MAWP Summary:

Minimum MAWP Nozzles : 157 Nozzle : Nozzle B1 6in.
 Minimum MAWP Shells/Flanges : 150 Element : NOZZLE M FLANGE
 Minimum MAPnc Shells/Flanges : 0 Element : NOZZLE M FLANGE

Computed Vessel M.A.W.P. : 150 psig

Multiple output lines for the same nozzle indicates required Code calculations in both the longitudinal and circumferential planes of reinforcement where applicable.

Check the Spatial Relationship between the Nozzles:

From Node	Nozzle Description	Y Coordinate in	Layout Angle deg	Dia. Limit in
40	Nozzle B2 2"	0.000	0.000	4.113
50	Nozzle LT2 2"	7.968	330.000	4.037
50	Nozzle L2 2"	7.968	225.000	4.037
50	Nozzle S 2"	7.968	270.000	4.037
50	Nozzle LT1 2"	49.968	330.000	4.037
50	Nozzle L1 2"	49.968	225.000	4.037
50	Nozzle B4 2"	43.968	300.000	4.126
50	Nozzle B3 2"	37.968	225.000	4.126
50	Nozzle LT3	49.968	0.000	4.037
50	Nozzle LT4	7.968	0.000	4.037
60	Nozzle A 3"	70.968	270.000	5.026
90	Nozzle B1 6in.	0.000	180.000	12.074
90	Nozzle V 2"	0.000	305.000	8.761

The nozzle spacing is computed by the following:

= $\sqrt{l_l^2 + l_c^2}$ where

l_l - Arc length along the inside vessel surface in the long. direction.

l_c - Arc length along the inside vessel surface in the circ. direction

If any interferences/violations are found, they will be noted below.

No interference violations have been detected!

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Summary: Step: 117 4:21pm Dec 21, 2022

Checking Multiple Nozzles on Flat Head per ASME Sec. VIII Div. 1 UG-39

Comparing Nozzles on Element: NOZZLE M BLIND

UG-39 Average Nozzle Diameter and Ligament Checks:

Nozzle	Avg.	Head Dia.	Ligament	Min. dn
Pair Description	dia.	/4	Width	/4
	in	in	in	in

Nozzle B1 6in. & Nozz	3.6195	7.75	12.771	0.5157

UG-39 Nozzle Spacing and Average Area Checks:

Nozzle	Center	Avg. dia.	Avg. Area	Avg. Area
Pair Description	Spacing	* 1.25	Available	Reqd.
	in	in	in^2	in^2

Nozzle B1 6in. & Nozz	17.74	4.5244	No Calc	No Calc

UG-39 Nozzle Diameter and Distance to Edge Checks:

Nozzle	Nozzle	Head Dia.	Distance	Nozzle
Description	dia.	/2	from Edge	dia./4
	in	in	in	in

Nozzle B1 6in.	5.176	15.5	4.1575	1.294
Nozzle V 2"	2.063	15.5	5.8137	0.5157

No Multiple Nozzle spacing violations detected!

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Schedule: Step: 116 4:21pm Dec 21,2022

Nozzle Schedule:

Description	Nominal or Actual Size	Schd or FVC Type	Flg Type	Nozzle O/Dia in	Wall Thk in	Reinforcing Diameter	Pad Thk in	Cut Length in	Flg Class
Nozzle B2 2"	2.000 in	80S	WNF	2.375	0.218	...	...	6.3	600
Nozzle LT2 2"	2.000 in	Actual	LWN	3.313	0.656	...	...	7.5	300
Nozzle L2 2"	2.000 in	Actual	LWN	3.313	0.656	...	...	7.5	600
Nozzle S 2"	2.000 in	Actual	LWN	3.313	0.656	...	...	7.6	600
Nozzle LT1 2"	2.000 in	Actual	LWN	3.313	0.656	...	...	7.5	300
Nozzle L1 2"	2.000 in	Actual	LWN	3.313	0.656	...	...	7.5	600
Nozzle B4 2"	2.000 in	Actual	LWN	3.313	0.656	...	...	7.6	600
Nozzle B3 2"	2.000 in	Actual	LWN	3.313	0.656	...	...	7.6	600
Nozzle LT3	2.000 in	Actual	LWN	3.313	0.656	...	...	7.5	300
Nozzle LT4	2.000 in	Actual	LWN	3.313	0.656	...	...	7.5	300
Nozzle V 2"	2.000 in	Actual	LWN	3.313	0.656	...	...	9.6	300
Nozzle A 3"	3.000 in	XXS	WNF	3.500	0.600	...	...	5.3	600
Nozzle B1 6in.	6.000 in	XXS	WNF	6.625	0.864	...	...	6.2	300

General Notes for the above table:

The Cut Length is the Outside Projection + Inside Projection + Drop + In Plane Shell Thickness. This value does not include weld gaps, nor does it account for shrinkage.

In the case of Oblique Nozzles, the Outside Diameter must be increased. The Re-Pad WIDTH around the nozzle is calculated as follows:
Width of Pad = (Pad Outside Dia. (per above) - Nozzle Outside Dia.)/2

For hub nozzles, the thickness and diameter shown are those of the smaller and thinner section.

Nozzle Material and Weld Fillet Leg Size Details (in):

Description	Material	Shl Grve Weld	Noz Shl/Pad Weld	Pad OD Weld	Pad Grve Weld	Inside Weld
Nozzle B2 2	SA-312 TP316L	0.314	0.196	...	...	...
Nozzle LT2	SA-182 F316L	0.390	0.354	...	...	...
Nozzle L2 2	SA-182 F316L	0.390	0.354	...	...	...
Nozzle S 2"	SA-182 F316L	0.390	0.354	...	...	...
Nozzle LT1	SA-182 F316L	0.390	0.354	...	...	...
Nozzle L1 2	SA-182 F316L	0.390	0.354	...	...	...
Nozzle B4 2	SA-182 F316L	0.390	0.354	...	...	...
Nozzle B3 2	SA-182 F316L	0.390	0.354	...	...	...
Nozzle LT3	SA-182 F316L	0.390	0.354	...	...	...
Nozzle LT4	SA-182 F316L	0.390	0.354	...	...	...
Nozzle V 2"	SA-182 F316L	2.000	0.354	...	...	...
Nozzle A 3"	SA-312 TP316L	0.390	0.354	...	...	...
Nozzle B1 6	SA-312 TP316L	1.941	0.354	...	...	...

Note: The Outside projections below do not include the flange thickness.

Nozzle Miscellaneous Data:

Description	Elev/Distance From Datum ft	Layout Angle deg	Proj Outside in	Proj Inside in	Installed in Component

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Schedule: Step: 116 4:21pm Dec 21,2022

Nozzle B2 2"		...		0.0		6.00		0.00		BTM D-END	
Nozzle LT2 2"		0.500		330.0		7.11		0.00		SHELL-1	
Nozzle L2 2"		0.500		225.0		7.11		0.00		SHELL-1	
Nozzle S 2"		0.500		270.0		7.11		0.00		SHELL-1	
Nozzle LT1 2"		4.000		330.0		7.11		0.00		SHELL-1	
Nozzle L1 2"		4.000		225.0		7.11		0.00		SHELL-1	
Nozzle B4 2"		3.500		300.0		7.11		0.00		SHELL-1	
Nozzle B3 2"		3.000		225.0		7.11		0.00		SHELL-1	
Nozzle LT3		4.000		0.0		7.11		0.00		SHELL-1	
Nozzle LT4		0.500		0.0		7.11		0.00		SHELL-1	
Nozzle V 2"		...		305.0		6.89		0.00		NOZZLE M BLIND	
Nozzle A 3"		5.750		270.0		4.86		0.00		SHELL-2	
Nozzle B1 6in.		...		180.0		3.47		0.00		NOZZLE M BLIND	

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Bill of Material:

Step: 115 4:21pm Dec 21,2022

Bill of Materials:

QTY	DESCRIPTION	MATERIAL
1	SKIRT: 0.394" THK X 29.250" ID X 8'-2.43"	SA-516 70
1	SKIRT: 0.394" THK X 29.250" ID X 5'-5.16"	SA-516 70
1	SKIRT: 0.394" THK X 29.250" ID X 3'-1.40"	SA-240 316L
1	ELLIPTICAL HEAD: 2.0 X 1, 0.394" THK X 29.250" ID X 1.97"	SA-240 316L
1	CYLINDER: 0.394" THK X 29.250" ID X 4'-11.06"	SA-240 316L
1	CYLINDER: 0.394" THK X 29.250" ID X 4'-7.04"	SA-240 316L
1	BODY FLANGE: 1.690" THK X 34.940" OD	SA-182 F316L
1	BODY FLANGE: 2.756" THK X 34.940" OD	SA-182 F316L
1	PLATFORM: 42.00" HEIGHT X 45.00" WIDE	
1	PLATFORM: 42.00" HEIGHT X 51.00" WIDE	
2	PACKING: 0.000"	...
1	PLATFORM: 42.00" HEIGHT X 38.00" WIDE	
1	RECTANGULAR CLIP: 0.551" X 15.500" X 8.071" THK	SA-240 316L
1	RECTANGULAR CLIP PAD: 3.268" X 18.268" X 0.394" THK	SA-240 316L
2	LIFTING LUGS:	SA-516 70
2	LIFTING LUG PADS: 6.693" X 8.661" X 0.394" THK	
1	BASERING TOP PLATES: 7.008" X 5.236" X 1.575"	SA-182 F316L
1	BASERING: 40.276" OD X 25.236 ID X 1.260"	SA-516 70
4	BASERING BOLTS: 1.750" DIA	SA-193 B7M
4	NUTS FOR BODY BASERING BOLTS: 1.750" DIA	...
8	BASERING GUSSET PLATES: 5.236" X 5.236" X 8.188" X 0.787"	...
1	GASKET: 31.500" OD X 30.500" ID	...
44	BODY FLANGE BOLTS: 0.750" DIA	SA-193 B7M
88	NUTS FOR BODY FLANGE BOLTS: 0.750" DIA	...
1	NAMEPLATE	...

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

MDMT Summary: Step: 118 4:21pm Dec 21,2022

Minimum Design Metal Temperature Results Summary (°F):

Description	Curve	Basic MDMT	Reduced MDMT	UG-20 (f) MDMT	Thickness ratio	Gov Thk in	E*	PWHT reqd
Notes								

NOZZLE M BLIN[11]		-320						
BTM D-END [16]		-320						
SHELL-1 [16]		-320						
SHELL-2 [16]		-320						
Nozzle B2 2" [15]		-320						
Nozzle LT2 2" [15]		-320						
Nozzle L2 2" [15]		-320						
Nozzle S 2" [15]		-320						
Nozzle LT1 2" [15]		-320						
Nozzle L1 2" [15]		-320						
Nozzle B4 2" [15]		-320						
Nozzle B3 2" [15]		-320						
Nozzle LT3 [15]		-320						
Nozzle LT4 [15]		-320						
Nozzle A 3" [15]		-320						
Nozzle B1 6in[15]		-320						
Nozzle V 2" [15]		-320						
Bolting [21]		-55						

Warmest MDMT: -55

Required Minimum Design Metal Temperature 32.0 °F

Warmest Computed Minimum Design Metal Temperature -55.0 °F

Notes:

- [!] - This was an impact tested material.
- [1] - Governing Nozzle Weld.
- [4] - ASME Flange MDMT Calcs; Thickness ratio per UCS-66(b)(1)(-c).
- [5] - ASME Flange MDMT Calcs; Thickness ratio per UCS-66(b)(1)(-b).
- [6] - MDMT Calculations at the Shell/Head Joint.
- [7] - MDMT Calculations for the Straight Flange.
- [8] - Cylinder/Cone/Flange Junction MDMT.
- [9] - Calculations in the Spherical Portion of the Head.
- [10] - Calculations in the Knuckle Portion of the Head.
- [11] - Calculated (Body Flange) Flange MDMT.
- [12] - Calculated Flat Head MDMT per UCS-66.3
- [13] - Tubesheet MDMT, shell side, if applicable
- [14] - Tubesheet MDMT, tube side, if applicable
- [15] - Nozzle Material
- [16] - Shell or Head Material
- [17] - Impact Testing required
- [18] - Impact Testing not required, see UCS-66(b)(3)
- [20] - Cylinder/Cone Junction MDMT based on Longitudinal Stress considerations
- [21] - Body Flange Bolting Material
- [22] - Nozzle Flange Bolting Material
- [23] - Stiffening Ring to Shell Weld
- [24] - Saddle to Shell Weld

UG-84(b)(2) was not considered.

UCS-66(g) was not considered.

UCS-66(i) was not considered.

Notes:

Impact test temps were not entered in and not considered in the analysis.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

MDMT Summary: Step: 118 4:21pm Dec 21, 2022

UCS-66(i) applies to impact tested materials not by specification and
UCS-66(g) applies to materials impact tested per UG-84.1 General Note (c).
The Basic MDMT includes the (30F) PWHT credit if applicable.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

```
Warnings and Errors:
```

Step: 0 4:21pm Dec 21, 2022

Class From To : Basic Element Checks.

Note	30	50	There is a high jump in the Joint Eff.
Warn.	10	20	Skirt diameter at base is < at the top
Warn.	20	30	Skirt diameter at base is < at the top
Warn.	30	40	Skirt diameter at base is < at the top

Class From To: Check of Additional Element Data

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Units used in this Analysis (ENGLISH_UniCode):

Name	System Unit	Constant	User Unit
Length	Feet	1.0000	ft
Force	Pounds	1.0000	lbf
Mass	Pounds	1.0000	lbm
Area	sq. inches	1.0000	in^2
Moment	ft. lbs.	1.0000	ft-lbf
Stress	lbs./sq.in.	1.0000	psi
Temperature	Degrees F	1.0000	°F
Pressure	psig	1.0000	psig
Elast. Modulus	lbs./sq.in.	1.0000	psi
Pipe Density	lbs./cu.in.	1.0000	lb/in^3
Ins. Density	lbs./cu.ft.	1.0000	lb/ft^3
Fluid Density	lbs./cu.ft.	1.0000	lb/ft^3
Wind Speed	miles/hr	1.0000	mile/hr
Tray Weight	lbs./sq.ft.	1.0000	lb/ft^2
Inertia	in.**4	1.0000	in**4
G Load	G's	1.0000	g's
Wind Load	lbs./sq.ft.	1.0000	psf
Elevation	Feet	1.0000	ft
Volume	in.**3	1.0000	in3
Diameter	inches	1.0000	in
Thickness	inches	1.0000	in

PV Elite Vessel Analysis Program: Input Data

18-D-272

R06

V-1264

Design Internal Pressure (for Hydrotest)	105	psig
Design Internal Temperature	500.0	°F
Projection of Nozzle from Vessel Top	0	in
Projection of Nozzle from Vessel Bottom	0	in
Minimum Design Metal Temperature	32.0	°F
Type of Construction	Welded	
Special Service	Sour	
Degree of Radiography	RT-1	
Use Higher Longitudinal Stresses (Flag)	Y	
Select t for Internal Pressure (Flag)	N	
Select t for External Pressure (Flag)	N	
Select t for Axial Stress (Flag)	N	
Select Location for Stiff. Rings (Flag)	N	
Consider Vortex Shedding	Y	

Shop Pressure Test:

Type of Pressure Test	User Entered Pressure
Pressure Test Position	Horizontal

Load Case 1	NP+EW+1.5WI+FW+BW
Load Case 2	NP+EW+EE+FS+BS
Load Case 3	NP+OW+1.5WI+FW+BW
Load Case 4	NP+OW+EQ+FS+BS
Load Case 5	NP+HW+HI
Load Case 6	NP+HW+HE
Load Case 7	IP+OW+1.5WI+FW+BW
Load Case 8	IP+OW+EQ+FS+BS

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Load Case 9		EP+OW+1.5WI+FW+BW	
Load Case 10		EP+OW+EQ+FS+BS	
Load Case 11		HP+HW+HI	
Load Case 12		HP+HW+HE	
Load Case 13		IP+WE+EW	
Load Case 14		IP+WF+CW	
Load Case 15		IP+VO+OW	
Load Case 16		IP+VE+EW	
Load Case 17		NP+VO+OW	
Load Case 18		FS+BS+IP+OW	
Load Case 19		FS+BS+EP+OW	
Wind Design Code		ASCE/SEI 7-16	
Wind Load Reduction Scale Factor		0.600	
Basic Wind Speed	[V]	101	mile/hr
Surface Roughness Category		C: Open Terrain	
Importance Factor		1.0	
Type of Surface		Moderately Smooth	
Base Elevation		0	ft
Percent Wind for Hydrotest		33.0	
Using User defined Wind Press. Vs Elev.		N	
Height of Hill or Escarpment	H or Hh	0	ft
Distance Upwind of Crest	Lh	0	ft
Distance from Crest to the Vessel	x	0	ft
Type of Terrain (Hill, Escarpment)		Flat	
Damping Factor (Beta) for Wind (Ope)		0.0100	
Damping Factor (Beta) for Wind (Empty)		0.0000	
Damping Factor (Beta) for Wind (Filled)		0.0000	
Site Elevation above Sea Level		0	ft
Seismic Design Code		ASCE/SEI 7-16	
Seismic Load Reduction Scale Factor		0.700	
Importance Factor		1.250	
Table Value Fa		1.000	
Table Value Fv		1.721	
Max. Mapped Res. Acceleration	[Ss]	1.616	
Max. Eff. Ground Acceleration	[S]	0.869	
Force Modification Factor R		3.000	
Site Class		D	
Component Elevation Ratio	z/h	0.000	
Amplification Factor	Ap	0.000	
Force Factor		0.000	
Consider Vertical Acceleration		Yes	
Minimum Acceleration Multiplier		0.333	
User Value of Sds (used if > 0)		1.077	
User Value of Sd1 (used if > 0)		0.996	
Moment Reduction Factor Tau		1.000	
M.A.W.P + Static Head to Nozzle		Y	
Consider MAP New and Cold in Noz. Design		N	
Consider External Loads for Nozzle Des.		Y	
Use ASME VIII-1 Appendix 1-9		N	
Perform Blast Load Analysis		No	
Material Database Year	Current w/Addenda or Code Year		

Configuration Directives:

Do not use Nozzle MDMT Interpretation VIII-1 01-37	No
Use Table G instead of exact equation for "A"	Yes
Shell Head Joints are Tapered	Yes

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Compute "K" in corroded condition	Yes
Use Code Case 2286	No
Use the MAWP to compute the MDMT	Yes
For thickness ratios <= 0.35, MDMT will be -155F (-104C)	Yes
For PWHT & P1 Materials the MDMT can be < -55F (-48C)	No
Using Metric Material Databases, ASME II D	No
Calculate B31.3 type stress for Nozzles with Loads	Yes
Reduce the MDMT due to lower membrane stress	Yes
Consider Longitudinal Stress in MDMT Calculations	Yes

Complete Listing of Vessel Elements and Details:

Element From Node	10
Element To Node	20
Element Type	Skirt Sup.
Description	BTM SKIRT-2
Distance "FROM" to "TO"	8.2021 ft
Skirt Inside Diameter	29.25 in
Diameter of Skirt at Base	29.21 in
Skirt Thickness	0.3937 in
Internal Corrosion Allowance	0.0315 in
Nominal Thickness	0.3937 in
External Corrosion Allowance	0 in
Design Temperature Internal Pressure	500 °F
Design Temperature External Pressure	300 °F
Effective Diameter Multiplier	1.2
Material Name	SA-516 70
Allowable Stress, Ambient	20000 psi
Allowable Stress, Operating	20000 psi
Allowable Stress, Hydrotest	34200 psi
Material Density	0.28 lb/in^3
P Number Thickness	1.25 in
Yield Stress, Operating	31000 psi
UCS-66 Chart Curve Designation	B
External Pressure Chart Name	CS-2
UNS Number	K02700
Product Form	Plate
Efficiency, Longitudinal Seam	0.6
Efficiency, Head-to-Skirt or Circ. Seam	0.6
Weld is pre-Heated	No

Element From Node	20
Element To Node	30
Element Type	Skirt Sup.
Description	BTM SKIRT-1
Distance "FROM" to "TO"	5.4298 ft
Skirt Inside Diameter	29.25 in
Diameter of Skirt at Base	29.21 in
Skirt Thickness	0.3937 in
Internal Corrosion Allowance	0.0315 in
Nominal Thickness	0.3937 in
External Corrosion Allowance	0 in
Design Temperature Internal Pressure	500 °F
Design Temperature External Pressure	300 °F
Effective Diameter Multiplier	1.2
Material Name	SA-516 70
Efficiency, Longitudinal Seam	0.6
Efficiency, Head-to-Skirt or Circ. Seam	0.6

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Weld is pre-Heated	No
Element From Node	20
Detail Type	Platform
Detail ID	PLATFORM 1
Dist. from "FROM" Node / Offset dist	0.32 ft
Platform Start Angle (degrees)	14.03
Platform End Angle (degrees)	195.0
Platform Wind Area	2835 in^2
Platform Weight	1607.9 lbf
Platform Railing Weight	22 lbf/ft
Platform Grating Weight	30 lb/ft^2
Platform Width	45 in
Platform Height	42 in
Platform Clearance or End Offset	0 in
Platform Force Coefficient	1.5
Ladder Layout Angle	0.0
Ladder Start Elevation	0 ft
Ladder End Elevation	0 ft
Unit Weight of Ladder	30 lbf/ft
Platform Length (top head platform)	0 in

Element From Node	30
Element To Node	40
Element Type	Skirt Sup.
Description	TOP SKIRT
Distance "FROM" to "TO"	3.1168 ft
Skirt Inside Diameter	29.25 in
Diameter of Skirt at Base	29.21 in
Skirt Thickness	0.3937 in
Internal Corrosion Allowance	0.0315 in
Nominal Thickness	0.3937 in
External Corrosion Allowance	0 in
Design Temperature Internal Pressure	500 °F
Design Temperature External Pressure	300 °F
Effective Diameter Multiplier	1.2
Material Name	SA-240 316L
Allowable Stress, Ambient	16700 psi
Allowable Stress, Operating	14800 psi
Allowable Stress, Hydrotest	22500 psi
Material Density	0.29 lb/in^3
P Number Thickness	0 in
Yield Stress, Operating	16400 psi
External Pressure Chart Name	HA-4
UNS Number	S31603
Product Form	Plate
Efficiency, Longitudinal Seam	0.6
Efficiency, Head-to-Skirt or Circ. Seam	0.6
Weld is pre-Heated	No

Element From Node	40
Element To Node	50
Element Type	Elliptical
Description	BTM D-END
Distance "FROM" to "TO"	0.164 ft
Inside Diameter	29.25 in
Element Thickness	0.315 in

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Internal Corrosion Allowance	0.0315	in
Nominal Thickness	0.3937	in
External Corrosion Allowance	0	in
Design Internal Pressure	105	psig
Design Temperature Internal Pressure	500	°F
Design External Pressure	15	psig
Design Temperature External Pressure	300	°F
Effective Diameter Multiplier	1.2	
Material Name	SA-240	316L
Efficiency, Longitudinal Seam	1.0	
Efficiency, Circumferential Seam	1.0	
Elliptical Head Factor	2.0	
Weld is pre-Heated	No	
Element From Node	40	
Detail Type	Liquid	
Detail ID	Liquid 30	
Dist. from "FROM" Node / Offset dist	-0.6085	ft
Height/Length of Liquid	0.7725	ft
Liquid Density	61.776	lb/ft^3
Element From Node	40	
Detail Type	Nozzle	
Detail ID	Nozzle B2 2"	
Dist. from "FROM" Node / Offset dist	0	in
Nozzle Diameter	2	in.
Nozzle Schedule	80S	
Nozzle Class	600	
Layout Angle	0.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	30.615	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-312	TP316L

Element From Node	50	
Element To Node	60	
Element Type	Cylinder	! Atype
Description	SHELL-1	
Distance "FROM" to "TO"	4.9213	ft
Inside Diameter	29.25	in
Element Thickness	0.3937	in
Internal Corrosion Allowance	0.0315	in
Nominal Thickness	0.3937	in
External Corrosion Allowance	0	in
Design Internal Pressure	105	psig
Design Temperature Internal Pressure	500	°F
Design External Pressure	15	psig
Design Temperature External Pressure	300	°F
Effective Diameter Multiplier	1.2	
Material Name	SA-240	316L
Efficiency, Longitudinal Seam	1.0	
Efficiency, Circumferential Seam	1.0	
Weld is pre-Heated	No	
Element From Node	50	
Detail Type	Platform	
Detail ID	PLATFORM 2	
Dist. from "FROM" Node / Offset dist	1	ft
Platform Start Angle (degrees)	77.0	

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Platform End Angle (degrees)	347.0	
Platform Wind Area	3213	in^2
Platform Weight	1053.4	lbf
Platform Railing Weight	22	lbf/ft
Platform Grating Weight	30	lb/ft^2
Platform Width	51	in
Platform Height	42	in
Platform Clearance or End Offset	0	in
Platform Force Coefficient	1.5	
Ladder Layout Angle	90.0	
Ladder Start Elevation	0	ft
Ladder End Elevation	0	ft
Unit Weight of Ladder	30	lbf/ft
Platform Length (top head platform)	0	in

Element From Node	50	
Detail Type	Packing	
Detail ID	Pack: [1 of 1]	
Dist. from "FROM" Node / Offset dist	0	ft
Height of Packed Section	0	ft
Density	0	lb/ft^3
Percent Volume Holdup	0.0	
Specific Gravity of Packing Liquid	0.0	

Element From Node	50	
Detail Type	Liquid	
Detail ID	H2S	
Dist. from "FROM" Node / Offset dist	0	ft
Height/Length of Liquid	3.002	ft
Liquid Density	61.776	lb/ft^3

Element From Node	50	
Detail Type	Nozzle	
Detail ID	Nozzle LT2 2"	
Dist. from "FROM" Node / Offset dist	0.5	ft
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	300	
Layout Angle	330.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	21.65	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-182 F316L	

Element From Node	50	
Detail Type	Nozzle	
Detail ID	Nozzle L2 2"	
Dist. from "FROM" Node / Offset dist	0.5	ft
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	600	
Layout Angle	225.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	21.65	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-182 F316L	

Element From Node	50	
Detail Type	Nozzle	
Detail ID	Nozzle S 2"	
Dist. from "FROM" Node / Offset dist	0.5	ft

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	600	
Layout Angle	270.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	21.654	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-182 F316L	

Element From Node	50	
Detail Type	Nozzle	
Detail ID	Nozzle LT1 2"	
Dist. from "FROM" Node / Offset dist	4	ft
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	300	
Layout Angle	330.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	21.644	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-182 F316L	

Element From Node	50	
Detail Type	Nozzle	
Detail ID	Nozzle L1 2"	
Dist. from "FROM" Node / Offset dist	4	ft
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	600	
Layout Angle	225.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	21.65	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-182 F316L	

Element From Node	50	
Detail Type	Nozzle	
Detail ID	Nozzle B4 2"	
Dist. from "FROM" Node / Offset dist	3.5	ft
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	600	
Layout Angle	300.0	
Blind Flange (Y/N)	Y	
Weight of Nozzle (Used if > 0)	21.654	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-182 F316L	

Element From Node	50	
Detail Type	Nozzle	
Detail ID	Nozzle B3 2"	
Dist. from "FROM" Node / Offset dist	3	ft
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	600	
Layout Angle	225.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	21.654	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-182 F316L	

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Element From Node	50
Detail Type	Nozzle
Detail ID	Nozzle LT3
Dist. from "FROM" Node / Offset dist	4 ft
Nozzle Diameter	2 in.
Nozzle Schedule	None
Nozzle Class	300
Layout Angle	0.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	21.65 lbf
Grade of Attached Flange	GR 2.3
Nozzle Matl	SA-182 F316L

Element From Node	50
Detail Type	Nozzle
Detail ID	Nozzle LT4
Dist. from "FROM" Node / Offset dist	0.5 ft
Nozzle Diameter	2 in.
Nozzle Schedule	None
Nozzle Class	300
Layout Angle	0.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	21.65 lbf
Grade of Attached Flange	GR 2.3
Nozzle Matl	SA-182 F316L

Element From Node	60
Element To Node	80
Element Type	Cylinder ! Atype
Description	SHELL-2
Distance "FROM" to "TO"	4.5866 ft
Inside Diameter	29.25 in
Element Thickness	0.3937 in
Internal Corrosion Allowance	0.0315 in
Nominal Thickness	0.3937 in
External Corrosion Allowance	0 in
Design Internal Pressure	105 psig
Design Temperature Internal Pressure	500 °F
Design External Pressure	15 psig
Design Temperature External Pressure	300 °F
Effective Diameter Multiplier	1.2
Material Name	SA-240 316L
Efficiency, Longitudinal Seam	1.0
Efficiency, Circumferential Seam	1.0
Weld is pre-Heated	No

Element From Node	60
Detail Type	Platform
Detail ID	PLATFORM 3
Dist. from "FROM" Node / Offset dist	1 ft
Platform Start Angle (degrees)	270.0
Platform End Angle (degrees)	90.0
Platform Wind Area	4788 in^2
Platform Weight	1290.8 lbf
Platform Railing Weight	22 lbf/ft
Platform Grating Weight	30 lb/ft^2
Platform Width	38 in
Platform Height	42 in
Platform Clearance or End Offset	0 in

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Platform Force Coefficient	1.5	
Ladder Layout Angle	90.0	
Ladder Start Elevation	0	ft
Ladder End Elevation	0	ft
Unit Weight of Ladder	30	lbf/ft
Platform Length (top head platform)	0	in

Element From Node	60	
Detail Type	Packing	
Detail ID	Pack: [1 of 1]	
Dist. from "FROM" Node / Offset dist	0	ft
Height of Packed Section	0	ft
Density	0	lb/ft^3
Percent Volume Holdup	0.0	
Specific Gravity of Packing Liquid	0.0	

Element From Node	60	
Detail Type	Nozzle	
Detail ID	Nozzle A 3"	
Dist. from "FROM" Node / Offset dist	0.8287	ft
Nozzle Diameter	3	in.
Nozzle Schedule	XXS	
Nozzle Class	600	
Layout Angle	270.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	29.633	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-312 TP316L	

Element From Node	60	
Detail Type	Weight	
Detail ID	MIST ELIMINATOR	
Dist. from "FROM" Node / Offset dist	3.6253	ft
Miscellaneous Weight	303	lbf
Offset from Element Centerline	0	in

Element From Node	60	
Detail Type	Weight	
Detail ID	MISC.0	
Dist. from "FROM" Node / Offset dist	3.6253	ft
Miscellaneous Weight	28	lbf
Offset from Element Centerline	0	in

Element From Node	80	
Element To Node	90	
Element Type	Flange	
Description	NOZZLE M FLANGE	
Distance "FROM" to "TO"	0.3183	ft
Flange Inside Diameter	29.25	in
Element Thickness	1.69	in
Internal Corrosion Allowance	0.0315	in
Nominal Thickness	0	in
External Corrosion Allowance	0	in
Design Internal Pressure	105	psig
Design Temperature Internal Pressure	500	°F
Design External Pressure	15	psig
Design Temperature External Pressure	300	°F
Effective Diameter Multiplier	1.2	
Material Name	SA-182 F316L	

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Input Echo: Step: 1 4:21pm Dec 21,2022

Allowable Stress, Ambient	16700	psi
Allowable Stress, Operating	10900	psi
Allowable Stress, Hydrotest	22500	psi
Material Density	0.29	lb/in^3
P Number Thickness	0	in
Yield Stress, Operating	16400	psi
External Pressure Chart Name	HA-4	
UNS Number	S31603	
Class / Thickness / Grade	:: > 5	
Product Form	Forgings	
Perform Flange Stress Calculation (Y/N)	Y	
Weld is pre-Heated	No	

Element From Node	90	
Element To Node	100	
Element Type	Flange	
Description	NOZZLE M BLIND	
Distance "FROM" to "TO"	0.2297	ft
Flange Outside Diameter	34.94	in
Element Thickness	2.7559	in
Internal Corrosion Allowance	0.0315	in
Nominal Thickness	2.7559	in
External Corrosion Allowance	0	in
Design Internal Pressure	105	psig
Design Temperature Internal Pressure	500	°F
Design External Pressure	15	psig
Design Temperature External Pressure	300	°F
Effective Diameter Multiplier	1.2	
Material Name	SA-182 F316L	
Perform Flange Stress Calculation (Y/N)	Y	
Weld is pre-Heated	No	

Element From Node	90	
Detail Type	Nozzle	
Detail ID	Nozzle B1 6in.0	
Dist. from "FROM" Node / Offset dist	10	in
Nozzle Diameter	6	in.
Nozzle Schedule	XXS	
Nozzle Class	300	
Layout Angle	180.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	63.52	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-312 TP316L	

Element From Node	90	
Detail Type	Nozzle	
Detail ID	Nozzle V 2"	
Dist. from "FROM" Node / Offset dist	10	in
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	300	
Layout Angle	305.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	26.367	lbf
Grade of Attached Flange	GR 2.3	
Nozzle Matl	SA-182 F316L	

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

XY Coordinate Calculations: Step: 2 4:21pm Dec 21,2022

XY Coordinate Calculations:

From	To	X (Horiz.) ft	Y (Vert.) ft	DX (Horiz.) ft	DY (Vert.) ft
BTM SKIRT-2		...	8.2021	...	8.2021
BTM SKIRT-1		...	13.6319	...	5.42979
TOP SKIRT		...	16.7487	...	3.1168
BTM D-END		...	16.9127	...	0.164
SHELL-1		...	21.8339	...	4.92126
SHELL-2		...	26.4206	...	4.58661
NOZZLE M FLANGE		...	26.7389	...	0.31833
NOZZLE M BLIND		...	26.9998	...	0.22966

PV Elite includes an 1/8 inch (3.175mm) raised face and gasket thicknesses for girth flanges and tubesheet thicknesses where applicable in the Tangent to Tangent length calculation. The calculated dimensions are based on the given element lengths. Due to variability in manufacturing (weld gaps etc.), the Tangent to Tangent length may not be exact.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Flg Calc [Int P]: FLANGE Flng: 83 4:21pm Dec 21,2022

Flange Input Data Values Description: FLANGE :**NOZZLE M FLANGE**

Flange Type	Integral Weld Neck		
Design Pressure	P	105.00	psig
Design Temperature		500	°F
Internal Corrosion Allowance	ci	0.0315	in
External Corrosion Allowance	ce	0.0000	in
Use Corrosion Allowance in Thickness Calcs.		No	
Flange Inside Diameter	B	29.250	in
Flange Outside Diameter	A	34.940	in
Flange Thickness	t	1.6900	in
Thickness of Hub at Small End	go	0.3937	in
Thickness of Hub at Large End	gl	0.8637	in
Length of Hub	h	2.1300	in
Flange Material		SA-182 F316L	
Flange Material UNS number		S31603	
Flange Allowable Stress At Temperature	Sfo	10900.00	psi
Flange Allowable Stress At Ambient	Sfa	16700.00	psi
Bolt Material		SA-193 B7M	
Bolt Allowable Stress At Temperature	Sb	20000.00	psi
Bolt Allowable Stress At Ambient	Sa	20000.00	psi
Diameter of Bolt Circle	C	33.310	in
Nominal Bolt Diameter	a	0.7500	in
Type of Threads	TEMA Thread Series		
Number of Bolts		44	
Flange Face Outside Diameter	Fod	32.000	in
Flange Face Inside Diameter	Fid	29.250	in
Flange Facing Sketch	1, Code Sketch 1a		
Gasket Outside Diameter	Go	31.500	in
Gasket Inside Diameter	Gi	30.500	in
Gasket Factor	m	3.0000	
Gasket Design Seating Stress	y	10000.00	psi
Column for Gasket Seating	2, Code Column II		
Gasket Thickness	tg	0.1250	in
Flange Class		150	
Flange Grade		GR 2.3	
Flange Series	Series	A	


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Flg Calc [Int P]: FLANGE Fling: 83 4:21pm Dec 21, 2022

**ASME Code, Section VIII Division 1, 2021**

Hub Small End Required Thickness due to Internal Pressure:

$$\begin{aligned}
 &= (P \cdot (D/2 + Ca)) / (S \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (105.0 \cdot (29.25/2 + 0.0315)) / (10900.0 \cdot 1.0 - 0.6 \cdot 105.0) + Ca \\
 &= 0.1735 \text{ in}
 \end{aligned}$$

Hub Small End Hub MAWP:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (10900.0 \cdot 1.0 \cdot 0.3622) / (14.6565 + 0.6 \cdot 0.3622) \\
 &= 265.435 \text{ psig}
 \end{aligned}$$

Corroded Flange ID,	$B_{cor} = B + 2 \cdot F_{cor}$	29.313	in
Corroded Large Hub,	$g1_{cor} = g1 - ci$	0.832	in
Corroded Small Hub,	$g0_{cor} = go - ci$	0.362	in
Code R Dimension,	$R = ((C - B_{cor}) / 2) - g1_{cor}$	1.166	in

Gasket Contact Width,	$N = (Go - Gi) / 2$	0.500	in
Basic Gasket Width,	$bo = N / 2$	0.250	in
Effective Gasket Width,	$b = bo$	0.250	in
Gasket Reaction Diameter,	$G = (Go + Gi) / 2$	31.000	in

Basic Flange and Bolt Loads:

Hydrostatic End Load due to Pressure [H]:

$$\begin{aligned}
 &= 0.785 \cdot G^2 \cdot P_{eq} \\
 &= 0.785 \cdot 31.0^2 \cdot 105.0 \\
 &= 79250.602 \text{ lbf}
 \end{aligned}$$

Contact Load on Gasket Surfaces [Hp]:

$$\begin{aligned}
 &= 2 \cdot b \cdot \pi \cdot G \cdot m \cdot P \\
 &= 2 \cdot 0.25 \cdot \pi \cdot 31.0 \cdot 3.0 \cdot 105.0 \\
 &= 15338.826 \text{ lbf}
 \end{aligned}$$

Hydrostatic End Load at Flange ID [Hd]:

$$\begin{aligned}
 &= \pi \cdot B_{cor}^2 \cdot P / 4 \\
 &= \pi \cdot 29.313^2 \cdot 105.0 / 4 \\
 &= 70859.734 \text{ lbf}
 \end{aligned}$$

Pressure Force on Flange Face [Ht]:

$$\begin{aligned}
 &= H - Hd \\
 &= 79251 - 70860 \\
 &= 8390.867 \text{ lbf}
 \end{aligned}$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Flg Calc [Int P]: FLANGE Flng: 83 4:21pm Dec 21,2022

Operating Bolt Load [Wm1]:

$$\begin{aligned}
 &= \max(H + H_p + H'p, 0) \\
 &= \max(79251 + 15339 + 0, 0) \\
 &= 94589.430 \text{ lbf}
 \end{aligned}$$

Gasket Seating Bolt Load [Wm2]:

$$\begin{aligned}
 &= y * b * \pi * G + y_{Part} * b_{Part} * l_p \\
 &= 10000.0 * 0.25 * \pi * 31.0 + 0.0 * 0.0 * 0.0 \\
 &= 243473.438 \text{ lbf}
 \end{aligned}$$

Required Bolt Area [Am]:

$$\begin{aligned}
 &= \max(Wm1/S_b, Wm2/S_a) \\
 &= \max(94589/20000, 243473/20000) \\
 &= 12.174 \text{ in}^2
 \end{aligned}$$

Min. Gasket Contact Width (Brownell Young) [Not an ASME Calc] [Nmin]:

$$\begin{aligned}
 &= A_b * S_a / (y * \pi (G_o + G_i)) \\
 &= 13.288 * 20000.0 / (10000.0 * \pi (31.5 + 30.5)) \\
 &= 0.136 \text{ in}
 \end{aligned}$$

Note: Recommended Min. Width for Sheet and Composite Gaskets per table 2-4 :

$$= 1.000 \text{ in [Note: Exceeds actual gasket width, 0.500]}$$

Flange Design Bolt Load, Gasket Seating [W]:

$$\begin{aligned}
 &= S_a (A_m + A_b) / 2 \\
 &= 20000.0 (12.1737 + 13.288) / 2 \\
 &= 254616.70 \text{ lbf}
 \end{aligned}$$

Gasket Load for the Operating Condition [HG]:

$$\begin{aligned}
 &= Wm1 - H \\
 &= 94589 - 79251 \\
 &= 15338.83 \text{ lbf}
 \end{aligned}$$

Moment Arm Calculations:

Distance to Gasket Load Reaction [hg]:

$$\begin{aligned}
 &= (C - G) / 2 \\
 &= (33.31 - 31.0) / 2 \\
 &= 1.1550 \text{ in}
 \end{aligned}$$

Distance to Face Pressure Reaction [ht]:

$$\begin{aligned}
 &= (R + g_1 + h_g) / 2 \\
 &= (1.1663 + 0.8322 + 1.155) / 2 \\
 &= 1.5768 \text{ in}
 \end{aligned}$$

Distance to End Pressure Reaction [hd]:

$$\begin{aligned}
 &= R + (g_1 / 2) \\
 &= 1.1663 + (0.8322 / 2.0) \\
 &= 1.5824 \text{ in}
 \end{aligned}$$

Summary of Moments for Internal Pressure: (ft-lbf)

Loading	Force	Distance	Bolt Corr	Moment
End Pressure, Md	70860.	1.5824	1.0000	9344.
Face Pressure, Mt	8391.	1.5768	1.0000	1103.
Gasket Load, Mg	15339.	1.1550	1.0000	1476.
Gasket Seating, Matm	254617.	1.1550	1.0000	24507.
Total Moment for Operation, Mop				11923. ft-lbf

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Flg Calc [Int P]: FLANGE Flng: 83 4:21pm Dec 21,2022

Total Moment for Gasket seating, Matm

24507. ft-lbf

*You chose not to perform Stress Calculations on this Standard Flange.
The pressure rating of the flange will be used to check code compliance.*

Estimated Finished Weight of Flange at given Thk. 177.0 lbm

Estimated Unfinished Weight of Forging at given Thk 317.8 lbm

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264


PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Flg Calc [Int P]: BLIND FLANGE Flng: 84 4:21pm Dec 21,2022

Flange Input Data Values**Description: BLIND FLANGE :****NOZZLE M BLIND**

Flange Type		Blind	
Design Pressure	P	105.00	psig
Design Temperature		500	°F
Internal Corrosion Allowance	ci	0.0315	in
External Corrosion Allowance	ce	0.0000	in
Use Corrosion Allowance in Thickness Calcs.		Yes	
Flange Outside Diameter	A	34.940	in
Flange Thickness	t	2.7559	in
Flange Material		SA-182 F316L	
Flange Material UNS number		S31603	
Flange Allowable Stress At Temperature	Sfo	10900.00	psi
Flange Allowable Stress At Ambient	Sfa	16700.00	psi
Bolt Material		SA-193 B7M	
Bolt Allowable Stress At Temperature	Sb	20000.00	psi
Bolt Allowable Stress At Ambient	Sa	20000.00	psi
Diameter of the Load Reaction, Long Span	D	0.000	in
Diameter of the Load Reaction, Short Span	d	0.000	in
Perimeter along the Center of the Bolts	L	104.646	in
Diameter of Bolt Circle	C	33.310	in
Nominal Bolt Diameter	a	0.7500	in
Type of Threads		TEMA Thread Series	
Number of Bolts		44	
Flange Face Outside Diameter	Fod	32.000	in
Flange Face Inside Diameter	Fid	29.250	in
Flange Facing Sketch		1, Code Sketch 1a	
Gasket Outside Diameter	Go	31.500	in
Gasket Inside Diameter	Gi	30.500	in
Gasket Factor	m	3.0000	
Gasket Design Seating Stress	y	10000.00	psi
Column for Gasket Seating		2, Code Column II	
Gasket Thickness	tg	0.1250	in

**ASME Code, Section VIII Division 1, 2021**

Gasket Contact Width, $N = (Go - Gi) / 2$ 0.500 in

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Flg Calc [Int P]: BLIND FLANGE Flng: 84 4:21pm Dec 21,2022

Basic Gasket Width, $bo = N / 2$ 0.250 in
 Effective Gasket Width, $b = bo$ 0.250 in
 Gasket Reaction Diameter, $G = (Go + Gi) / 2$ 31.000 in

Basic Flange and Bolt Loads:

Hydrostatic End Load due to Pressure [H]:

$$= 0.785 * G^2 * Peq$$

$$= 0.785 * 31.0^2 * 105.0$$

$$= 79250.602 \text{ lbf}$$

Contact Load on Gasket Surfaces [Hp]:

$$= 2 * b * pi * G * m * P$$

$$= 2 * 0.25 * pi * 31.0 * 3.0 * 105.0$$

$$= 15338.826 \text{ lbf}$$

Operating Bolt Load [Wm1]:

$$= \max(H + Hp + H'p, 0)$$

$$= \max(79251 + 15339 + 0, 0)$$

$$= 94589.430 \text{ lbf}$$

Gasket Seating Bolt Load [Wm2]:

$$= y * b * pi * G + yPart * bPart * lp$$

$$= 10000.0 * 0.25 * pi * 31.0 + 0.0 * 0.0 * 0.0$$

$$= 243473.438 \text{ lbf}$$

Required Bolt Area [Am]:

$$= \max(Wm1/Sb, Wm2/Sa)$$

$$= \max(94589/20000, 243473/20000)$$

$$= 12.174 \text{ in}^2$$

ASME Maximum Circumferential Spacing between Bolts per App. 2 eq. (3) [Bsmax]:

$$= 2a + 6t / (m + 0.5)$$

$$= 2 * 0.75 + 6 * 2.724 / (3.0 + 0.5)$$

$$= 6.170 \text{ in}$$

Actual Circumferential Bolt Spacing [Bs]:

$$= C * \sin(pi / n)$$

$$= 33.31 * \sin(pi/44)$$

$$= 2.376 \text{ in}$$

ASME Moment Multiplier for Bolt Spacing per App. 2 eq. (7) [Bsc]:

$$= \max(\sqrt{Bs / (2a + t)}, 1)$$

$$= \max(\sqrt{2.376 / (2 * 0.75 + 2.724)}, 1)$$

$$= 1.0000$$

Bolting Information for TEMA Imperial Thread Series (Non Mandatory):

	Minimum	Actual	Maximum
Bolt Area:	12.174	13.288	
Radial Distance between Bolts and Edge:	0.812	0.815	
Circ. Spacing between the Bolts:	1.750	2.376	6.170

Min. Gasket Contact Width (Brownell Young) [Not an ASME Calc] [Nmin]:

$$= Ab * Sa / (y * pi (Go + Gi))$$

$$= 13.288 * 20000.0 / (10000.0 * pi (31.5 + 30.5))$$

$$= 0.136 \text{ in}$$

Flange Design Bolt Load, Gasket Seating [W]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Flg Calc [Int P]: BLIND FLANGE Flng: 84 4:21pm Dec 21,2022

$$\begin{aligned}
 &= Sa(Am + Ab) / 2 \\
 &= 20000.0(12.1737 + 13.288) / 2 \\
 &= 254616.70 \text{ lbf}
 \end{aligned}$$

Gasket Load for the Operating Condition [HG]:

$$\begin{aligned}
 &= Wm1 \\
 &= 94589.43 \text{ lbf}
 \end{aligned}$$

Moment Arm Calculations:

Distance to Gasket Load Reaction [hg]:

$$\begin{aligned}
 &= (C - G) / 2 \\
 &= (33.31 - 31.0) / 2 \\
 &= 1.1550 \text{ in}
 \end{aligned}$$

Tangential Flange Stress, Flat Head (UG-34), Operating [STo]:

$$\begin{aligned}
 &= 1.9 * Wm1 * hG * Bsc / (t^2 * G) + C * Z * Peq * G^2 / t^2 \\
 &= 1.9 * 94589 * 1.155 * 1.0 / (2.7244^2 * 31.0) + 0.3 * 1.0 * 105.0 * 31.0^2 / 2.7244^2 \\
 &= 4980.51 \text{ psi}
 \end{aligned}$$

Tangential Flange Stress, Flat Head (UG-34), Seating [STa]:

$$\begin{aligned}
 &= 1.9 * W * hG * Bsc / (t^2 * G) \\
 &= 1.9 * 254617 * 1.155 * 1.0 / (2.7244^2 * 31.0) \\
 &= 2428.37 \text{ psi}
 \end{aligned}$$

Bolt Stress, Operating [BSo]:

$$\begin{aligned}
 &= Wm1 / Ab \\
 &= 94589 / 13.288 \\
 &= 7118.41 \text{ psi}
 \end{aligned}$$

Bolt Stress, Seating [BSa]:

$$\begin{aligned}
 &= (Wm2 / Ab) \\
 &= (243473 / 13.288) \\
 &= 18322.81 \text{ psi}
 \end{aligned}$$

Flange Stress Analysis Results: psi

	Actual	Operating Allowed	Gasket Seating Actual Allowed
Tangential Flange	4980.51	10900.00	2428.37 16700.00
Bolting	7118.41	20000.00	18322.81 20000.00
Reqd. Blind Flange Thickness at Center			1.873 in
Reqd. Blind Flange Thickness at Gasket			1.070 in
Estimated M.A.W.P. (Operating)			230 psig
Estimated Finished Weight of Flange at given Thk.			766.3 lbm
Estimated Unfinished Weight of Forging at given Thk			766.3 lbm

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Internal Pressure Calculations: Step: 5 4:21pm Dec 21, 2022

Internal Pressure Results Summary:**Element Thickness, Pressure, Diameter and Allowable Stress :**

From	To	Int. Press + Liq. Hd psig	Nominal Thickness in	Total Corr Allowance in	Element Diameter in	Allowable Stress (SE) psi
BTM SKIRT-2		...	0.3937	0.031496	29.25	...
BTM SKIRT-1		...	0.3937	0.031496	29.25	...
TOP SKIRT		...	0.3937	0.031496	29.25	...
BTM D-END		106.619	0.3937	0.031496	29.25	14800
SHELL-1		106.288	0.3937	0.031496	29.25	14800
SHELL-2		105	0.3937	0.031496	29.25	14800
NOZZLE M FLANGE		105	...	0.031496	29.25	10900
NOZZLE M BLIND		105	2.75591	0.031496	34.94	10900

Element Required Thickness and MAWP :

From	To	Design Pressure psig	M.A.W.P. Corroded psig	M.A.P. New & Cold psig	Minimum Thickness in	Required Thickness in
BTM SKIRT-2		...	No Calc	No Calc	0.3937	No Calc
BTM SKIRT-1		...	No Calc	No Calc	0.3937	No Calc
TOP SKIRT		...	No Calc	No Calc	0.3937	No Calc
BTM D-END		105	284.885	358.874	0.31496	0.13686
SHELL-1		105	359.119	442.414	0.3937	0.13721
SHELL-2		105	360.407	442.413	0.3937	0.13592
NOZZLE M FLANGE		105	150	230	1.69	No Calc
NOZZLE M BLIND		105	229.79	295	2.75591	1.8731
Minimum			150	230		

MAWP: 150 psig, limited by: NOZZLE M FLANGE.

Elements Suitable for Design Internal Pressure.

Internal Pressure Calculation Results:**ASME Code, Section VIII Division 1, 2021****Elliptical Head From 40 To 50 SA-240 316L at 500 °F****BTM D-END**

Longitudinal Joint: User Defined

Material UNS Number: S31603

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned}
 &= (P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P) \text{ Appendix 1-4 (c)} \\
 &= (106.619 \cdot 29.313 \cdot 0.997) / (2 \cdot 14800 \cdot 0.1 - 0.2 \cdot 106.619) \\
 &= 0.1054 + 0.0315 = 0.1369 \text{ in}
 \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 1.619 psig

$$\begin{aligned}
 &= (2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t) \text{ per Appendix 1-4 (c)} \\
 &= (2 \cdot 14800 \cdot 0.1 \cdot 0.2835) / (0.997 \cdot 29.313 + 0.2 \cdot 0.2835)
 \end{aligned}$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Internal Pressure Calculations: Step: 5 4:21pm Dec 21, 2022

$$= 287 - 2 = 285 \text{ psig}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (2 * S * E * t) / (K * D + 0.2 * t) \text{ per Appendix 1-4 (c)}$$

$$= (2 * 16700.0 * 1.0 * 0.315) / (1.0 * 29.25 + 0.2 * 0.315)$$

$$= 359 \text{ psig}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P * (K * D + 0.2 * t)) / (2 * E * t)$$

$$= (106.619 * (0.997 * 29.313 + 0.2 * 0.2835)) / (2 * 1.0 * 0.2835)$$

$$= 5507.651 \text{ psi}$$

Straight Flange Required Thickness:

$$= (P * R) / (S * E - 0.6 * P) + c \text{ per UG-27 (c) (1)}$$

$$= (106.619 * 14.6565) / (14800.0 * 1.0 - 0.6 * 106.619) + 0.031$$

$$= 0.138 \text{ in}$$

Straight Flange Maximum Allowable Working Pressure:

Less Operating Hydrostatic Head Pressure of 1.358 psig

$$= (S * E * t) / (R + 0.6 * t) \text{ per UG-27 (c) (1)}$$

$$= (14800.0 * 1.0 * 0.3622) / (14.6565 + 0.6 * 0.3622)$$

$$= 360 - 1 = 359 \text{ psig}$$

Factor K, corroded condition [Kcor]:

$$= (2 + (\text{Inside Diameter} / (2 * \text{Inside Head Depth}))^2) / 6$$

$$= (2 + (29.313 / (2 * 7.344))^2) / 6$$

$$= 0.997144$$

% Elongation per Table UG-79-1 $(75 * t_{nom} / R_f) * (1 - R_f / R_o)$ 5.712 %

Note: Please Check Requirements of Table UHA-44 for Elongation limits.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

Cylindrical Shell From 50 To 60 SA-240 316L at 500 °F

SHELL-1

Longitudinal Joint: User Defined

Material UNS Number: S31603

Required Thickness due to Internal Pressure [tr]:

$$= (P * R) / (S * E - 0.6 * P) \text{ per UG-27 (c) (1)}$$

$$= (106.288 * 14.6565) / (14800.0 * 1.0 - 0.6 * 106.288)$$

$$= 0.1057 + 0.0315 = 0.1372 \text{ in}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 1.288 psig

$$= (S * E * t) / (R + 0.6 * t) \text{ per UG-27 (c) (1)}$$

$$= (14800.0 * 1.0 * 0.3622) / (14.6565 + 0.6 * 0.3622)$$

$$= 360 - 1 = 359 \text{ psig}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (S * E * t) / (R + 0.6 * t) \text{ per UG-27 (c) (1)}$$

$$= (16700.0 * 1.0 * 0.3937) / (14.625 + 0.6 * 0.3937)$$

$$= 442 \text{ psig}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P * (R + 0.6 * t)) / (E * t)$$

$$= (106.288 * (14.6565 + 0.6 * 0.3622)) / (1.0 * 0.3622)$$

$$= 4364.673 \text{ psi}$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Internal Pressure Calculations: Step: 5 4:21pm Dec 21, 2022

% Elongation per Table UG-79-1 $(50 \cdot t_{nom}/R_f) \cdot (1 - R_f/R_o)$ 1.328 %

Note: Please Check Requirements of Table UHA-44 for Elongation limits.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

Cylindrical Shell From 60 To 80 SA-240 316L at 500 °F

SHELL-2

Longitudinal Joint: User Defined

Material UNS Number: S31603

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned}
 &= (P \cdot R) / (S \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (105.0 \cdot 14.6565) / (14800.0 \cdot 1.0 - 0.6 \cdot 105.0) \\
 &= 0.1044 + 0.0315 = 0.1359 \text{ in}
 \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (14800.0 \cdot 1.0 \cdot 0.3622) / (14.6565 + 0.6 \cdot 0.3622) \\
 &= 360 \text{ psig}
 \end{aligned}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (16700.0 \cdot 1.0 \cdot 0.3937) / (14.625 + 0.6 \cdot 0.3937) \\
 &= 442 \text{ psig}
 \end{aligned}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$\begin{aligned}
 &= (P \cdot (R + 0.6 \cdot t)) / (E \cdot t) \\
 &= (105.0 \cdot (14.6565 + 0.6 \cdot 0.3622)) / (1.0 \cdot 0.3622) \\
 &= 4311.791 \text{ psi}
 \end{aligned}$$

% Elongation per Table UG-79-1 $(50 \cdot t_{nom}/R_f) \cdot (1 - R_f/R_o)$ 1.328 %

Note: Please Check Requirements of Table UHA-44 for Elongation limits.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

Hydrostatic Test Pressure Results:

Pressure per UG99b	= 1.30 * M.A.W.P. * Sa/S	220.034	psig
Pressure per UG99b[35]	= 1.30 * Design Pres * Sa/S	154.024	psig
Pressure per UG99c	= 1.30 * M.A.P. - Head(Hyd)	297.737	psig
Pressure per UG100	= 1.10 * M.A.W.P. * Sa/S	186.182	psig
Pressure per PED	= max(1.43*DP, 1.25*DP*ratio)	150.150	psig
Pressure per App 27-4	= M.A.W.P.	150.000	psig

User Defined Hydrostatic Test Pressure at High Point 312.913 psig

Horizontal Test performed per: User Hydro Pressure

Please note that Nozzle, Shell, Head, Flange, etc MAWPs are all considered when determining the hydrotest pressure for those test types that are based on the MAWP of the vessel.

Stresses on Elements due to Test Pressure (psi & psig):

From To	Stress	Allowable	Ratio	Pressure
BTM D-END	16218.8	22500.0	0.721	313.97

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Internal Pressure Calculations: Step: 5 4:21pm Dec 21, 2022

SHELL-1		12893.1		22500.0		0.573		313.97	
SHELL-2		12893.1		22500.0		0.573		313.97	

Stress ratios for Nozzle and Pad Materials (psi):

Description		Pad/Nozzle		Ambient		Operating		Ratio	
Nozzle B2 2"		Nozzle		16700.00		10900.00		1.532	
Nozzle LT2 2"		Nozzle		16700.00		10900.00		1.532	
Nozzle L2 2"		Nozzle		16700.00		10900.00		1.532	
Nozzle S 2"		Nozzle		16700.00		10900.00		1.532	
Nozzle LT1 2"		Nozzle		16700.00		10900.00		1.532	
Nozzle L1 2"		Nozzle		16700.00		10900.00		1.532	
Nozzle B4 2"		Nozzle		16700.00		10900.00		1.532	
Nozzle B3 2"		Nozzle		16700.00		10900.00		1.532	
Nozzle LT3		Nozzle		16700.00		10900.00		1.532	
Nozzle LT4		Nozzle		16700.00		10900.00		1.532	
Nozzle A 3"		Nozzle		16700.00		10900.00		1.532	
Nozzle B1 6in.		Nozzle		16700.00		10900.00		1.532	
Nozzle V 2"		Nozzle		16700.00		10900.00		1.532	
Minimum								1.532	

Stress ratios for Pressurized Vessel Elements (psi):

Description		Ambient		Operating		Ratio	
BTM D-END		16700.00		14800.00		1.128	
SHELL-1		16700.00		14800.00		1.128	
SHELL-2		16700.00		14800.00		1.128	
NOZZLE M FLANGE		16700.00		10900.00		1.532	
NOZZLE M BLIND		16700.00		10900.00		1.532	
Minimum						1.128	

Hoop Stress in Nozzle Wall during Pressure Test (psi):

Description		Ambient		Operating		Ratio	
Nozzle B2 2"		2215.57		21710.00		0.102	
Nozzle LT2 2"		666.78		21710.00		0.031	
Nozzle L2 2"		666.78		21710.00		0.031	
Nozzle S 2"		666.78		21710.00		0.031	
Nozzle LT1 2"		666.78		21710.00		0.031	
Nozzle L1 2"		666.78		21710.00		0.031	
Nozzle B4 2"		706.72		21710.00		0.033	
Nozzle B3 2"		706.72		21710.00		0.033	
Nozzle LT3		666.78		21710.00		0.031	
Nozzle LT4		666.78		21710.00		0.031	
Nozzle A 3"		987.77		21710.00		0.045	
Nozzle B1 6in.		1310.77		21710.00		0.060	
Nozzle V 2"		707.18		21710.00		0.033	

Elements Suitable for Test Pressure.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

External Pressure Calculations: Step: 6 4:21pm Dec 21,2022

External Pressure Calculation Results :**External Pressure Calculations:**

From	To	Section Length ft	Outside Diameter in	Corroded Thickness in	Factor A	Factor B psi
10	20	16.7487	...	...	No Calc	No Calc
20	30	16.7487	...	...	No Calc	No Calc
30	40	16.7487	...	...	No Calc	No Calc
40	50	No Calc	29.8799	0.28346	0.0013176	7815.78
50	60	9.875	30.0374	0.3622	0.00041039	5417.14
60	80	9.875	30.0374	0.3622	0.00041039	5417.13
80	90	No Calc	...	1.6585	No Calc	No Calc
90	100	No Calc	...	2.72441	No Calc	No Calc

External Pressure Calculations:

From	To	External Actual T. in	External Required T. in	External Design Pressure psig	External M.A.W.P. psig
10	20	...	No Calc	...	No Calc
20	30	...	No Calc	...	No Calc
30	40	...	No Calc	...	No Calc
40	50	0.31496	0.11258	15	82.3852
50	60	0.3937	0.20846	15	87.0964
60	80	0.3937	0.20846	15	87.0963
80	90	1.69	No Calc	15	No Calc
90	100	2.75591	1.071	15	No Calc

Minimum

82

External Pressure Calculations:

From	To	Actual Length Bet. Stiffeners ft	Allowable Length Bet. Stiffeners ft	Ring Inertia Required in**4	Ring Inertia Available in**4
10	20	16.7487	No Calc	No Calc	No Calc
20	30	16.7487	No Calc	No Calc	No Calc
30	40	16.7487	No Calc	No Calc	No Calc
40	50	No Calc	No Calc	No Calc	No Calc
50	60	9.875	200.986	No Calc	No Calc
60	80	9.875	200.985	No Calc	No Calc
80	90	No Calc	No Calc	No Calc	No Calc
90	100	No Calc	No Calc	No Calc	No Calc

Elements Suitable for External Pressure.

ASME Code, Section VIII Division 1, 2021**Elliptical Head From 40 to 50 Ext. Chart: HA-4 at 300 °F**

BTM D-END

Elastic Modulus from Chart: HA-4 at 300 °F: 26400000 psi

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

External Pressure Calculations: Step: 6 4:21pm Dec 21, 2022

Results for Maximum Allowable Ext. Pressure					MAEP
Tca	Outer Dia	Do/t	Factor A	Factor B	
0.283	29.88	105.41	0.0013176	7815.78	

$$MAEP = B / (K0 * Do/t) = 7815.7837 / (0.9 * 105.4097) = 82.3852 \text{ psig}$$

Results for Required Thickness					Tca
Tca	Outer Dia	Do/t	Factor A	Factor B	
0.081	29.88	368.50	0.0003769	4975.13	

$$MAEP = B / (K0 * Do/t) = 4975.126 / (0.9 * 368.4999) = 15.0011 \text{ psig}$$

Cylindrical Shell From 50 to 60 Ext. Chart: HA-4 at 300 °F

SHELL-1

Elastic Modulus from Chart: HA-4 at 300 °F: 26400000 psi

Results for Maximum Allowable Ext. Pressure								MAEP
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B		
0.362	30.04	118.50	82.93	3.9451	0.0004104	5417.14		

$$MAEP = (4*B) / (3*(Do/t)) = (4*5417.1353) / (3*82.9293) = 87.0964 \text{ psig}$$

Results for Required Thickness								Tca
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B		
0.177	30.04	118.50	169.73	3.9451	0.0001447	1909.62		

$$MAEP = (4*B) / (3*(Do/t)) = (4*1909.6219) / (3*169.7339) = 15.0009 \text{ psig}$$

Results for Maximum Stiffened Length								Slen
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B		
0.362	30.04	2411.83	82.93	50.0000	0.0001615	2131.56		

$$MAEP = (4*B) / (3*(Do/t)) = (4*2131.563) / (3*82.9293) = 34.2712 \text{ psig}$$

Cylindrical Shell From 60 to 80 Ext. Chart: HA-4 at 300 °F

SHELL-2

Elastic Modulus from Chart: HA-4 at 300 °F: 26400000 psi

Results for Maximum Allowable Ext. Pressure								MAEP
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B		
0.362	30.04	118.50	82.93	3.9451	0.0004104	5417.13		

$$MAEP = (4*B) / (3*(Do/t)) = (4*5417.1299) / (3*82.9293) = 87.0963 \text{ psig}$$

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

External Pressure Calculations: Step: 6 4:21pm Dec 21,2022

Results for Required Thickness							Tca
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
0.177	30.04	118.50	169.73	3.9451	0.0001447	1909.62	

$$MAEP = (4*B)/(3*(Do/t)) = (4*1909.6219)/(3*169.7339) = 15.0009 \text{ psig}$$

Results for Maximum Stiffened Length							Slen
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
0.362	30.04	2411.82	82.93	50.0000	0.0001615	2131.56	

$$MAEP = (4*B)/(3*(Do/t)) = (4*2131.5608)/(3*82.9293) = 34.2711 \text{ psig}$$

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Element and Detail Weights: Step: 7 4:21pm Dec 21,2022

Element and Detail Weights:

From	To	Element Metal Wgt. lbf	Element ID Volume in3	Corroded Metal Wgt. lbf	Corroded ID Volume in3	Extra due Misc % lbf
10	20	1423.07	...	1383.2	...	142.307
20	30	668.463	...	642.066	...	66.8463
30	40	397.414	...	381.72	...	39.7414
40	50	141.005	4598.2	129.725	4625.12	14.1005
50	60	627.92	39682.5	578.299	39853.6	62.792
60	80	585.221	36984.1	538.975	37143.6	58.5221
80	90	177.043	2571.77	173.833	2577.94	17.7043
90	100	766.3	...	766.3	...	76.63
Total		4786	83836	4594	84200	478

Weight of Details:

From	Type	Weight of Detail lbf	X Offset, Dtl. Cent. ft	Y Offset, Dtl. Cent. ft	Z Offset Dtl. Cent. ft	Description
20	Plat	1768.67	-2.15164	0.32	-0.55705	PLATFORM 1
40	Liqd	164.385	...	-0.30427	...	Liquid 30
40	Nozl	33.6769	...	-1.01025	...	Nozzle B2 2"
50	Plat	1158.71	1.81005	1	-2.89669	PLATFORM 2
50	Pack	...	...	...	...	Pack: [1 of 1]
50	Liqd	865.376	...	1.50098	...	H2S
50	Nozl	23.815	-0.7574	0.5	-1.31185	Nozzle LT2 2"
50	Nozl	23.815	-1.07112	0.5	1.07112	Nozzle L2 2"
50	Nozl	23.8198	-1.51492	0.5	...	Nozzle S 2"
50	Nozl	23.808	-0.7574	4	-1.31185	Nozzle LT1 2"
50	Nozl	23.815	-1.07112	4	1.07112	Nozzle L1 2"
50	Nozl	23.8198	-1.31196	3.5	-0.75746	Nozzle B4 2"
50	Nozl	23.8198	-1.07121	3	1.07121	Nozzle B3 2"
50	Nozl	23.815	...	4	-1.51479	Nozzle LT3
50	Nozl	23.815	...	0.5	-1.51479	Nozzle LT4
60	Plat	1419.86	...	1	1.97372	PLATFORM 3
60	Pack	...	...	...	...	Pack: [1 of 1]
60	Nozl	32.5969	-1.42129	0.82874	...	Nozzle A 3"
60	Wght	303	...	3.62533	...	MIST ELIMINATOR
60	Wght	28	...	3.62533	...	MISC.
60	Clip	28.7807	1.21875	1.88025	...	Type-1
90	Nozl	69.8721	...	0.37433	0.83333	Nozzle B1 6in.
90	Nozl	29.0038	-0.68263	0.51674	-0.47798	Nozzle V 2"

Total Weight of Each Detail Type:

Platforms	4347.2
Liquid	1029.8
Nozzles	379.5
Weights	331.0
Clips	28.8

Sum of the Detail Weights	6116.3 lbf

Weight Summation Results: (lbf)

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Element and Detail Weights: Step: 7 4:21pm Dec 21,2022

	Fabricated	Shop Test	Shipping	Erected	Empty	Operating
Main Elements	5265.1	5265.1	5265.1	5265.1	5265.1	5265.1
Nozzles	379.5	379.5	379.5	379.5	379.5	379.5
Wld Weights	303.0	303.0	303.0	303.0	303.0	303.0
Clips	28.8	28.8	28.8	28.8	28.8	28.8
Platforms	...	...	...	4347.2	4347.2	4347.2
Empty Weights	...	...	...	28.0	28.0	...
Test Weights	...	28.0	...	...	...	...
Ope Weights	...	...	...	...	...	28.0
Ope. Liquid	...	...	...	...	...	1029.8
Test Liquid	...	3027.4	...	...	...	...
Totals	5976.4	9031.8	5976.4	10351.6	10351.6	11381.3

Field Installation Options:

Platforms installed before lifting.

Miscellaneous Weight Percent: 10.0 %

Note that the above value for the miscellaneous weight percent has been applied to the shells/heads/flange/tubesheets/tubes etc. in the weight calculations for metallic components.

Weight Summary:

Fabricated Wt.	- Bare Weight without Removable Internals	5976.4 lbf
Shop Test Wt.	- Fabricated Weight + Water (Full)	9031.8 lbf
Shipping Wt.	- Fab. Weight + removable Intls.+ Shipping App.	5976.4 lbf
Erected Wt.	- Fab. Wt + or - loose items (trays,platforms etc.)	10351.6 lbf
Ope. Wt. no Liq	- Fab. Weight + Internals. + Details + Weights	10351.6 lbf
Operating Wt.	- Empty Weight + Operating Liq. Uncorroded	11381.3 lbf
Field Test Wt.	- Empty Weight + Water (Full)	13180.6 lbf

Weights used in Vortex Shedding Calculations:

Mass of the Upper 1/3 of the Vertical Vessel (operating)	4676.0 lbf
Mass of the Upper 1/3 of the Vertical Vessel (filled w/water)	6232.4 lbf
Mass of the Upper 1/3 of the Vertical Vessel (empty)	4221.0 lbf

Note: The Field Test weight as computed in the corroded condition.

Outside Surface Areas of Elements:

From	To	Surface Area in^2
10	20	9287.92
20	30	6148.6
30	40	3529.41
40	50	1163.73
50	60	5572.75
60	80	5193.81
80	90	679.654
90	100	1261.33
Total		32837.207 in^2 [228.0 Square Feet]

Element and Detail Weights:

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Element and Detail Weights: Step: 7 4:21pm Dec 21,2022

From	To	Total Ele. Empty Wgt. lbm	Total. Ele. Oper. Wgt. lbm	Total. Ele. Hydro. Wgt. lbm	Total Dtl. Offset Mom. ft-lbf	Oper. Wgt. No Liquid lbm
10	20	1565.38	1565.38	1521.52	...	1565.38
20	30	735.309	2503.98	2474.94	3805.54	2503.98
30	40	437.155	437.155	419.892	...	437.155
40	50	188.782	353.168	343.392	...	188.782
50	60	905.055	2929.14	3448.34	1917.38	2063.76
60	80	1036.12	2455.98	3746.4	11.2531	2455.98
80	90	194.747	194.747	284.309	...	194.747
90	100	941.806	941.806	941.806	19.7988	941.806

Cumulative Vessel Weight

From	To	Cumulative Ope Wgt. No Liquid lbm	Cumulative Oper. Wgt. lbm	Cumulative Hydro. Wgt. lbm
10	20	10351.6	11381.3	13180.6
20	30	8786.21	9815.97	11659.1
30	40	6282.23	7311.99	9184.14
40	50	5845.08	6874.84	8764.25
50	60	5656.29	6521.67	8420.85
60	80	3592.53	3592.53	4972.52
80	90	1136.55	1136.55	1226.11
90	100	941.806	941.806	941.806

The cumulative operating weights no liquid in the column above are the cumulative operating weights minus the operating liquid weight minus any weights absent in the empty condition.

Cumulative Vessel Moment

From	To	Cumulative Empty Mom. ft-lbf	Cumulative Oper. Mom. ft-lbf	Cumulative Hydro. Mom. ft-lbf
10	20	5753.98	5753.98	5753.98
20	30	5753.98	5753.98	5753.98
30	40	1948.44	1948.44	1948.44
40	50	1948.44	1948.44	1948.44
50	60	1948.44	1948.44	1948.44
60	80	31.0519	31.0519	31.0519
80	90	19.7988	19.7988	19.7988
90	100	19.7988	19.7988	19.7988

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Flange MAWP: Step: 8 4:21pm Dec 21,2022

Nozzle Flange MAWP Results: (psig & °F)

Nozzle Description	Flange Rating		Design Temp	Class	Grade/Group	Equiv. Press	Max Pressure			
	Ope.	Ambient					UG-44(b)	50%	DNV	
Nozzle B2 2"	785.0	1200.0	500	600	GR 2.3	...	...	...	...	
Nozzle LT2 2"	395.0	600.0	500	300	GR 2.3	...	...	...	...	
Nozzle L2 2"	785.0	1200.0	500	600	GR 2.3	...	...	...	...	
Nozzle S 2"	785.0	1200.0	500	600	GR 2.3	...	...	...	...	
Nozzle LT1 2"	395.0	600.0	500	300	GR 2.3	...	...	...	...	
Nozzle L1 2"	785.0	1200.0	500	600	GR 2.3	...	...	...	...	
Nozzle B4 2"	785.0	1200.0	500	600	GR 2.3	...	...	...	...	
Nozzle B3 2"	785.0	1200.0	500	600	GR 2.3	...	...	...	...	
Nozzle LT3	395.0	600.0	500	300	GR 2.3	...	...	...	...	
Nozzle LT4	395.0	600.0	500	300	GR 2.3	...	...	...	...	
Nozzle A 3"	785.0	1200.0	500	600	GR 2.3	...	...	...	...	
Nozzle B1 6in.	395.0	600.0	500	300	GR 2.3	...	...	...	...	
Nozzle V 2"	395.0	600.0	500	300	GR 2.3	...	...	...	...	
Min Rating	395.0	600.0 psig [for Core Elements]					...	...	...	

Pressure Ratings are per ASME B16.5 2017 Edition

Warning:

There are nozzles in this model, but no flange MAWPs were de-rated. Be sure this is what you intended. There is a check box in the nozzle dialog that instructs PV Elite to perform the de-rating for each nozzle flange. See ASME VIII-1, UG-44(b) for more information.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Natural Frequency Calculation: Step: 9 4:21pm Dec 21, 2022

The Natural Frequencies for the vessel have been computed iteratively by solving a system of matrices. These matrices describe the mass and the stiffness of the vessel. This is the generalized eigenvalue/eigenvector problem and is referenced in some mathematical texts.

The Natural Frequency for the Vessel (Empty.) is 4.64009 Hz.

The Natural Frequency for the Vessel (Ope...) is 4.43877 Hz.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Wind Load Calculation: Step: 10 4:21pm Dec 21,2022

Wind Load Calculation Results:**Input Values:**

Wind Design Code	ASCE/SEI 7-16
Wind Load Reduction Scale Factor	0.600
Basic Wind Speed	[V] 101 mile/hr
Surface Roughness Category	C: Open Terrain
Importance Factor	1.0
Type of Surface	Moderately Smooth
Base Elevation	0 ft
Percent Wind for Hydrotest	33.0
Using User defined Wind Press. Vs Elev.	N
Height of Hill or Escarpment H or Hh	0 ft
Distance Upwind of Crest Lh	0 ft
Distance from Crest to the Vessel x	0 ft
Type of Terrain (Hill, Escarpment)	Flat
Damping Factor (Beta) for Wind (Ope)	0.0100
Damping Factor (Beta) for Wind (Empty)	0.0000
Damping Factor (Beta) for Wind (Filled)	0.0000
Site Elevation above Sea Level	0 ft

Wind Analysis Results**Static Gust-Effect Factor, Operating Case [G]:**

$$\begin{aligned}
 &= \min(0.85, 0.925((1 + 1.7 * gQ * Izbar * Q)/(1 + 1.7 * gV * Izbar))) \\
 &= \min(0.85, 0.925((1 + 1.7 * 3.4 * 0.225 * 0.947)/(1 + 1.7 * 3.4 * 0.225))) \\
 &= \min(0.85, 0.897) \\
 &= 0.850
 \end{aligned}$$



Note: Vortex shedding loads have been applied at the analyst's request, even though the vessel was determined to be stable and not susceptible to vortex shedding.

Vortex Shedding Loads, per NBC 1990 Supplement, pages 149-150

Compute the critical wind speed using the weighted average diameter of the top one-third of the vessel [Vh(ope)]

$$\begin{aligned}
 &= Fn(ope) * Davg / 0.2 * 0.6818 \\
 &= 4.4388 * 2.533 / 0.2 * 0.6818 \\
 &= 38.33 \text{ mile/hr}
 \end{aligned}$$

Compute the aspect ratio (gamma) for the entire structure [Gamma]

$$\begin{aligned}
 &= (Total \text{ Height})^2 / \text{Sum of the Wind Area} \\
 &= 27.0^2 / 9668 = 10.8578
 \end{aligned}$$

Determine the Velocity Pressure Qh(ope) (English Units only)

$$\begin{aligned}
 &= 0.5 * 0.0668 * \rho * Vh(ope)^2 \\
 &= 0.5 * 0.0668 * 0.0749 * 38.3299^2 = 3.6786 \text{ psf}
 \end{aligned}$$

Compute the equivalent force per unit area which will act on the top one-third of the vessel [F/area]:

$$\begin{aligned}
 &= (qh(ope) * C1) / ((Gamma * (Beta(ope) - (C2 * \rho * Davg^2 / M3))))^{0.5} \text{ [English Units]} \\
 &= (3.679 * 2.5) / ((10.86 * (0.01 - (0.6 * 0.0749 * 2.533^2 / 519.6))))^{0.5} \\
 &= 28.388630 \text{ psf}
 \end{aligned}$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Wind Load Calculation: Step: 10 4:21pm Dec 21, 2022

Platform Load Calculations

ID	Wind Area in^2	Elevation ft	Pressure psf	Force lbf	Cf
PLATFORM 1	2835.00	8.52	0.00	0.00	1.50
PLATFORM 2	3213.00	17.91	27.00	602.51	1.50
PLATFORM 3	4788.00	22.83	28.01	931.39	1.50

Wind Loads on Masses/Equipment/Piping

ID	Wind Area in^2	Elevation ft	Pressure psf	Force lbf
MIST ELIMINAT	0.00	25.46	28.39	0.00
MISC.	0.00	25.46	28.39	0.00

The following table contains results for Vortex Shedding Case (Ope).

Wind Load Calculation:

From	To	Wind Height ft	Wind Diameter ft	Wind Area in^2	Wind Pressure psf	Element Wind Load lbf
10	20	4.10199	3.00174	3545.36	...	...
20	30	10.9176	3.00174	2347.03	...	...
30	40	15.1906	3.00174	1347.24	...	...
40	50	16.8307	2.98799	70.5644	...	...
50	60	19.3733	3.00374	2128.63	27.0032	805.137
60	80	24.1273	3.00374	1983.89	28.3886	1124.51
80	90	26.5797	2.925	134.082	28.3886	16.4265
90	100	26.885	3.494	115.55	28.3886	14.1561

End of Vortex Shedding Calculations

Natural Frequency of Vessel (Operating)	4.439 Hz
Natural Frequency of Vessel (Empty)	4.640 Hz
Natural Frequency of Vessel (Test)	4.064 Hz
User Entered Importance Factor is	1.000
Force Coefficient	[Cf] 0.621
Structure Height to Diameter ratio	10.858
Height to top of Structure	27.000 ft

This is classified as a rigid structure. Static analysis performed.

Sample Calculation for the First Element:

The ASCE code performs all calculations in Imperial Units only. The wind pressure is therefore computed in these units.

Value of [Alpha] and [Zg]:
 Exposure Category: C from Table 26.11-1
 Alpha = 9.5: Zg = 900.0 ft

Effective Height [z]:

= Centroid Height + Vessel Base Elevation
 = 4.102 + 0.0 = 4.102 ft

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Wind Load Calculation: Step: 10 4:21pm Dec 21, 2022

Velocity Pressure coefficient evaluated at height z [Kz]:

$$\begin{aligned}
 &\text{Because } z(4.102 \text{ ft.}) < 15 \text{ ft.} \\
 &= 2.01 (15 / z_g)^{2/\alpha} \\
 &= 2.01 (15/900.0)^{2/9.5} \\
 &= 0.849
 \end{aligned}$$

Type of Hill: No Hill

Wind Directionality Factor [Kd]:

$$= 1, \text{ per Table 26.6-1}$$

As there is No Hill Present: [Kzt]:

$$K1 = 0, K2 = 0, K3 = 0$$

Topographical Factor [Kzt]:

$$\begin{aligned}
 &= (1 + K1 * K2 * K3)^2 \\
 &= (1 + 0.0 * 0.0 * 0.0)^2 \\
 &= 1.0
 \end{aligned}$$

Velocity Pressure evaluated at height z, Imperial Units [qz]:

$$\begin{aligned}
 &= \max(16, 0.00256 * Kz * Kzt * Kd * Ke * V(\text{mph})^2) \\
 &= \max(16, 0.00256 * 0.849 * 1.0 * 1.0 * 1.0 * 101.0^2) \\
 &= 22.2 \text{ psf}
 \end{aligned}$$

Force on the first element [F]:

$$\begin{aligned}
 &= qz * G * Cf * \text{WindArea} \\
 &= 22.168 * 0.85 * 0.621 * 24.621 \\
 &= 288.3 \text{ lbf}
 \end{aligned}$$

Element	Hgt (z) ft	K1	K2	K3	Kz	Kzt	qz psf
BTM SKIRT-2	4.1	0.000	0.000	0.000	0.849	1.000	22.168
BTM SKIRT-1	10.9	0.000	0.000	0.000	0.849	1.000	22.168
TOP SKIRT	15.2	0.000	0.000	0.000	0.851	1.000	22.227
BTM D-END	16.8	0.000	0.000	0.000	0.870	1.000	22.712
SHELL-1	19.4	0.000	0.000	0.000	0.896	1.000	23.395
SHELL-2	24.1	0.000	0.000	0.000	0.938	1.000	24.501
NOZZLE M FLANGE	26.6	0.000	0.000	0.000	0.958	1.000	25.006
NOZZLE M BLIND	26.9	0.000	0.000	0.000	0.960	1.000	25.066

Wind Vibration Calculations

This evaluation is based on work by Kanti Mahajan and Ed Zorilla

Nomenclature

- Cf - Correction factor for natural frequency
- D - Average outer insulated diameter of vessel, ft
- Df - Damping Factor < 0.75 Unstable, > 0.95 Stable
- Dr - Average outer insulated of top half of vessel, ft
- f - Natural frequency of vibration (Hertz)
- f1 - Natural frequency of bare vessel based on a unit value of $(D/L^2) (10^4)$
- L - Total height of structure ft
- Lc - Total length of conical section(s) of vessel, ft
- tb - Uncorroded plate thickness at bottom of vessel, in
- V30 - Design Wind Speed provided by user, mile/hr
- Vc - Critical wind velocity, mile/hr
- Vw - Maximum wind speed at top of structure, mile/hr

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Wind Load Calculation: Step: 10 4:21pm Dec 21,2022

W - Total corroded weight of structure, lbf
 Ws - Cor. vessel weight excl. weight of parts which do not effect stiff. lbf
 Z - Maximum amplitude of vibration at top of vessel, in
 D1 - Logarithmic decrement (taken as 0.03 for Welded Structures)
 Vp - Vib. Chance, $\leq 0.200\text{E}+02$ (High); $0.200\text{E}+02 < 0.250\text{E}+02$ (Probable)
 P30 - wind pressure 30 feet above the base

Check other Conditions and Basic Assumptions:

:: Total Cone Length / Total Length < 0.5
 :: $0.0/27.0 = 0.0$

:: $[D / L^2] * 10^4 < 8$ (English Units, ft.)
 :: $[2.5/27.0^2] * 10^4 = 34.319$ [Geometry Violation]

Compute the vibration possibility. If $V_p > 0.250\text{E}+02$ no chance. [Vp]:

= $W / (L * D_r^2)$
 = $11170 / (27.0 * 2.523^2)$
 = $0.64998\text{E}+02$

Since V_p is $> 0.250\text{E}+02$ no further vibration analysis is required !**Platform Load Calculations**

ID	Wind Area in ²	Elevation ft	Pressure psf	Force lbf	Cf
PLATFORM 1	2835.00	8.52	22.17	436.44	1.50
PLATFORM 2	3213.00	17.91	23.00	513.25	1.50
PLATFORM 3	4788.00	22.83	24.20	804.66	1.50

Wind Loads on Masses/Equipment/Piping

ID	Wind Area in ²	Elevation ft	Pressure psf	Force lbf
MIST ELIMINAT	0.00	25.46	24.78	0.00
MISC.	0.00	25.46	24.78	0.00

The Natural Frequency for the Vessel (Ope...) is 4.43877 Hz.

Wind Load Calculation:

From	To	Wind Height ft	Wind Diameter ft	Wind Area in ²	Wind Pressure psf	Element Wind Load lbf
10	20	4.10199	3.00174	3545.36	22.1682	172.979
20	30	10.9176	3.00174	2347.03	22.1682	318.917
30	40	15.1906	3.00174	1347.24	22.2273	65.907
40	50	16.8307	2.98799	70.5644	22.7122	3.52734
50	60	19.3733	3.00374	2128.63	23.395	394.336
60	80	24.1273	3.00374	1983.89	24.5012	563.896
80	90	26.5797	2.925	134.082	25.0057	7.37922
90	100	26.885	3.494	115.55	25.0658	6.3746

Note:

The Wind Loads calculated and printed in the Wind Load calculation report have been factored by the input

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Wind Load Calculation: Step: 10 4:21pm Dec 21, 2022

scalar/load reduction factor of: 0.600.

*Be sure the wind speed is in accordance with the specified
wind design code.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Earthquake Load Calculation: Step: 11 4:21pm Dec 21,2022

Earthquake Load Calculation Results:**Earthquake Load Calculation:****Input Values:**

Seismic Design Code		ASCE/SEI 7-16
Seismic Load Reduction Scale Factor		0.700
Importance Factor		1.250
Table Value Fa		1.000
Table Value Fv		1.721
Max. Mapped Res. Acceleration	[Ss]	1.616
Max. Eff. Ground Acceleration	[S]	0.869
Force Modification Factor R		3.000
Site Class		D
Component Elevation Ratio	z/h	0.000
Amplification Factor	Ap	0.000
Force Factor		0.000
Consider Vertical Acceleration		Yes
Minimum Acceleration Multiplier		0.333
User Value of Sds (used if > 0)		1.077
User Value of Sd1 (used if > 0)		0.996
Moment Reduction Factor Tau		1.000

Seismic Analysis Results:

$S_{ms} = F_a * S_s = 1.0 * 1.616 = 1.616$
 $S_{m1} = F_v * S_1 = 1.721 * 0.869 = 1.496$
 $S_{ds} = 2/3 * S_{ms} = 2/3 * 1.616 = 1.077$

$S_{ds} = \text{Max}(0.8 * S_{ds}, S_{dsUser})$
 $= \text{Max}(0.862, 1.077)$
 $= 1.077$

$S_{d1} = 2/3 * S_{m1} = 2/3 * 1.496 = 0.997$

$S_{d1} = \text{Max}(0.8 * S_{d1}, S_{d1User})$
 $= \text{Max}(0.798, 0.996)$
 $= 0.996$

Check Approximate Fundamental Period from 12.8-7 [Ta]:

$= C_t * h_n^x$ where $C_t = 0.020$, $x = 0.75$ and h_n = Structural Height (ft.)
 $= 0.020 * (27.0^{0.75})$
 $= 0.237$ seconds

The Coefficient C_u from Table 12.8-1 is : 1.400

Fundamental Period (1/Frequency) [T]:

$= (1/\text{Natural Frequency}) = (1/4.439)$
 $= 0.225$

Check the Value of T which is the smaller of $C_u * T_a$ and T:

$= \text{Minimum Value of}(1.4 * 0.237, 0.225)$ per 12.8.2
 $= 0.225$

Compute the Seismic Response Coefficient per equation 12.8-2 [Cs]:

$= S_{ds} / (R / I)$
 $= 1.077 / (3.0/1.25)$
 $= 0.449$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Earthquake Load Calculation: Step: 11 4:21pm Dec 21,2022

Check the Maximum value of Cs per equation 12.8-3 [Cs]:

$$= Sd1 / (T * (R / I_e))$$

$$= 0.996 / (0.225 * (3.0 / 1.25))$$

$$= 1.842$$

Check the Minimum value of Cs per equation 15.4-1 [Cs]:

$$= \max((0.044 * SDS * I_e), 0.030)$$

$$= \max((0.044 * 1.077 * 1.25), 0.030)$$

$$= 0.059$$

Because $S1 \geq 0.6$, check Minimum value of Cs per 15.4-2:

$$= 0.8 * S1 / (R / I_e)$$

$$= 0.8 * 0.87 / (3.0 / 1.25)$$

$$= 0.290$$

Total Base Shear [V]:

$$= Cs * W \text{ (Equation 12.8-1):}$$

$$= 0.4487 * 11381.3$$

$$= 5107.379 \text{ lbf}$$

Vertical load per 12.4-4, [Ev]:

$$= 0.2 * Sds * W$$

$$= 0.2 * 1.077 * 11381$$

$$= 2451.5 \text{ lbf}$$

Minimum Vertical load YEq = Gy * Total Weight, [YEq]:

$$= 0.333 * 11381 = 3789.99 \text{ lbf}$$

Final Base Shear, V = 3575.17 lbf

Final Vertical Load, Ev = 2652.99 lbf

Distribute the Base shear force to each element according to the equations

 $F_x = C_{vx} * V$ (eqn. 12.8-11) and the vertical distribution factor $C_{vx} = W_x * h_x^k / (\text{Sum of } W_i * h_i^k)$ and k is an exponent which is related to the period of Vibration.

In this case, the value of k was 1.0

The Natural Frequency for the Vessel (Ope...) is 4.43877 Hz.

Earthquake Load Calculation:

From	To	Earthquake Height ft	Earthquake Weight lbf	Element Ope Load lbf	Element Emp Load lbf	Element Vertical Load lbf
10	20	4.10105	1565.38	119.018	124.45	2652.99
20	30	10.917	2503.98	506.795	155.616	2288.1
30	40	15.1903	437.155	123.112	128.731	1704.43
40	50	16.8307	353.168	110.2	61.5949	1602.52
50	60	19.3733	2929.14	1052.07	339.907	1520.2
60	80	24.1273	2455.98	1098.58	484.618	837.419
80	90	26.5797	194.747	95.9667	100.347	264.93
90	100	26.885	941.806	469.429	490.854	219.535

Note:

The Earthquake Loads calculated and printed in the Earthquake Load calculation report have been factored by the input scalar/load reduction factor of: 0.700.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Earthquake Load Calculation: Step: 11 4:21pm Dec 21, 2022

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Wind/Earthquake Shear, Bending: Step: 12 4:21pm Dec 21, 2022

The following table is for the Operating Case + Vortex Shedding.**Wind/Earthquake Shear, Bending:**

From	To	Distance to Support ft	Cumulative Wind Shear lbf	Earthquake Shear lbf	Wind Bending ft-lbf	Earthquake Bending ft-lbf
10	20	4.10105	1533.32	3575.17	43546.8	71804.7
20	30	10.917	1360.34	3456.15	27468.7	42968.9
30	40	15.1903	1041.42	2949.35	16825.1	25578.7
40	50	16.8307	975.514	2826.24	10715.5	16578
50	60	19.3733	971.986	2716.04	10394	16123.5
60	80	24.1273	577.65	1663.97	2728.31	5345.92
80	90	26.5797	13.7538	565.396	9.18884	233.283
90	100	26.885	6.3746	469.429	1.62555	53.9045

The following table is for the Operating Case.**Wind/Earthquake Shear, Bending:**

From	To	Distance to Support ft	Cumulative Wind Shear lbf	Earthquake Shear lbf	Wind Bending ft-lbf	Earthquake Bending ft-lbf
10	20	4.10105	1533.32	3575.17	26863.9	71804.7
20	30	10.917	1360.34	3456.15	14996.9	42968.9
30	40	15.1903	1041.42	2949.35	8476.37	25578.7
40	50	16.8307	975.514	2826.24	5333.18	16578
50	60	19.3733	971.986	2716.04	5173.49	16123.5
60	80	24.1273	577.65	1663.97	1360.41	5345.92
80	90	26.5797	13.7538	565.396	4.13497	233.283
90	100	26.885	6.3746	469.429	0.732	53.9045

Note:

The Wind Shears/Moments and the Earthquake Shears/Moments calculated and printed in the Wind/Earthquake Shear and Bending report have been factored by the input Scalar/Load reductions factors of;
Wind: 0.600; Earthquake: 0.700.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Wind/Earthquake Deflection: Step: 13 4:21pm Dec 21,2022

Wind and Earthquake Deflection Calculations:

The following table is for Earthquake Deflection; Operating Case.

Earthquake Load Deflection:

From	To	Cumulative Shear lbf	Centroid Deflection in	Elem. End Deflection in	Elem. Ang. Rotation
10	20	3575.17	0.0086	0.03192	0.00059842
20	30	3456.15	0.053662	0.079232	0.00083377
30	40	2949.35	0.095289	0.11216	0.00092069
40	50	2826.24	0.11306	0.11397	0.00092545
50	60	2716.04	0.142	0.17105	0.00099531
60	80	1663.97	0.19862	0.22639	0.0010103
80	90	565.396	0.22832	0.23025	0.0010103
90	100	469.429	0.23164	0.23303	0.0010103

Allowable deflection at the Tower Top (Ope) (6.000"/100ft. Criteria)

Allowable deflection : 1.620 Actual deflection : 0.233 in

The following table is for Wind Deflection; Operating Case + Vortex Shedding.

Wind Load Deflection:

From	To	Cumulative Shear lbf	Centroid Deflection in	Elem. End Deflection in	Elem. Ang. Rotation
10	20	1960.23	0.0056278	0.021035	0.00039744
20	30	1960.23	0.035534	0.052706	0.00056154
30	40	1960.23	0.063538	0.074948	0.00062328
40	50	1960.23	0.075562	0.076178	0.00062661
50	60	1960.23	0.095162	0.11481	0.00067247
60	80	1155.09	0.13341	0.15209	0.00067891
80	90	30.5827	0.15339	0.15468	0.00067891
90	100	14.1561	0.15562	0.15655	0.00067891

Allowable deflection at the Tower Top (Emp) (6.000"/100ft. Criteria)

Allowable deflection : 1.620 Actual deflection : 0.157 in

The following table is for Wind Deflection; Operating Case.

Wind Load Deflection:

From	To	Cumulative Shear lbf	Centroid Deflection in	Elem. End Deflection in	Elem. Ang. Rotation
10	20	1533.32	0.0034148	0.012554	0.00023295
20	30	1360.34	0.020976	0.030793	0.00031885
30	40	1041.42	0.036922	0.04334	0.00034973
40	50	975.514	0.043684	0.04403	0.00035139
50	60	971.986	0.054645	0.065594	0.00037424
60	80	577.65	0.075939	0.086323	0.00037744
80	90	13.7538	0.087043	0.087764	0.00037744
90	100	6.3746	0.088284	0.088805	0.00037744

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Wind/Earthquake Deflection: Step: 13 4:21pm Dec 21,2022

Critical Wind Velocity for Tower Vibration:

From	To	1st Crit. Wind Speed mile/hr	2nd Crit. Wind Speed mile/hr
10	20	45.3017	283.136
20	30	45.3017	283.136
30	40	45.3017	283.136
40	50	45.0943	281.839
50	60	45.3319	283.325
60	80	45.3319	283.325
80	90	44.1436	275.897
90	100	52.7308	329.568

Allowable deflection at the Tower Top (Ope) (6.000"/100ft. Criteria)

Allowable deflection : 1.620 Actual deflection : 0.089 in

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Longitudinal Stress Constants: Step: 14 4:21pm Dec 21,2022

Longitudinal Stress Constants:

From	To	Metal Area New in ²	Metal Area Corroded in ²	Section Modulus New in ³	Section Modulus Corroded in ³
10	20	36.6152	33.7218	267.477	246.859
20	30	36.6152	33.7218	267.477	246.859
30	40	36.6152	33.7218	267.477	246.859
40	50	29.2539	26.3565	213.967	193.183
50	60	36.6647	33.7674	268.205	247.53
60	80	36.6647	33.7674	268.205	247.53
80	90	36.6647	33.7674	268.205	247.53
90	100	36.6647	33.7674	268.205	247.53

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Longitudinal Allowable Stresses: Step: 15 4:21pm Dec 21,2022

Longitudinal Allowable Stresses:

From	To	Tensile psi	Hydrotest Tensile psi	Compressive psi	Hydrotest Compressive psi
10	20	14400	24624	-14808.1	-19495
20	30	14400	24624	-14808.1	-19495
30	40	10656	16200	-8705.73	-14001.6
40	50	17760	27000	-8382.42	-13430.6
50	60	17760	27000	-8703.96	-13998.5
60	80	17760	27000	-8703.96	-13998.5
80	90	13080	27000	-8703.96	-13998.5
90	100	13080	27000	-8703.96	-13998.5

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Longitudinal Stresses due to: Step: 16 4:21pm Dec 21, 2022

Longitudinal Stress Report

Longitudinal Operating and Empty Stresses are computed in the corroded condition. Stresses due to loads in the hydrostatic test cases have also been computed in the corroded condition.

Longitudinal Pressure Stresses due to:

From	To	Longitudinal Stress Internal Pressure psi	Longitudinal Stress External Pressure psi	Longitudinal Stress Hydrotest Pressure psi
10	20	...	...	...
20	30	...	...	...
30	40	...	...	...
40	50	2693.5	-399.073	8026.99
50	60	2103.39	-314.781	6268.38
60	80	2103.4	-314.781	6268.39
80	90	...	...	...
90	100	...	...	...

Longitudinal Stresses due to Weight Loads for these Conditions:

From	To	Wght. Str. Empty psi	Wght. Str. Operating psi	Wght. Str. Hydrotest psi	Wght. Str. Emp. Mom. psi	Wght. Str. Opr. Mom. psi
10	20	-306.97	-337.507	...	279.706	279.706
20	30	-260.549	-291.086	...	279.706	279.706
30	40	-186.296	-216.833	...	94.715	94.715
40	50	-221.77	-221.77	...	121.032	121.032
50	60	-167.508	-167.508	...	94.4583	94.4583
60	80	-106.391	-106.391	...	1.50537	1.50537
80	90	-33.6583	-33.6583	...	0.95983	0.95983
90	100	-27.891	-27.891	...	0.95983	0.95983

Longitudinal Stresses due to Weight Loads and Bending for these Conditions:

From	To	Wght. Str. Hyd. Mom. psi	Bend. Str. Oper. Wind psi	Bend. Str. Oper. Equ. psi	Bend. Str. Hyd. Wind psi	Bend. Str. Hyd. Equ. psi
10	20	...	1305.88	3490.48	...	...
20	30	...	729.011	2088.75	...	...
30	40	...	412.043	1243.4	...	...
40	50	...	331.283	1029.78	...	...
50	60	...	250.806	781.653	...	...
60	80	...	65.9512	259.165	...	...
80	90	...	0.20046	11.3094	...	...
90	100	...	0.035486	2.61324	...	...

Longitudinal Stresses due to these Conditions:

| | Vortex Shedding | Vortex Shedding | Vortex Shedding | Earthquake |

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Longitudinal Stresses due to: Step: 16 4:21pm Dec 21,2022

From	To	Operating Case psi	Empty Case psi	Test Case psi	Empty Case psi
10	20	2116.84	...	...	1912.48
20	30	1335.28	...	...	1185.28
30	40	817.881	...	...	740.83
40	50	665.616	...	...	648.189
50	60	503.89	...	...	494.374
60	80	132.266	...	...	197.16
80	90	0.44547	...	...	11.8255
90	100	0.078805	...	...	2.73251

Longitudinal Stresses due to Applied Axial Forces:

From	To	Longitudinal Stress Y Forces Wind psi	Longitudinal Stress Y Forces Seismic psi
10	20	...	78.6728
20	30	...	67.8522
30	40	...	50.5437
40	50	...	60.8018
50	60	...	45.0198
60	80	...	24.7997
80	90	...	7.84575
90	100	...	6.50139

Longitudinal Stresses due to User Forces and Moments:

From	To	Wind For/Mom Corroded psi	Earthquake For/Mom Corroded psi	Wind For/Mom No Corrosion psi	Earthquake For/Mom No Corrosion psi
10	20	...	...	...	...
20	30	...	...	...	...
30	40	...	...	...	...
40	50	...	...	...	...
50	60	...	...	...	...
60	80	...	...	...	...
80	90	...	...	...	...
90	100	...	...	...	...

Bending Stresses due to Blast Load:

From	To	Bending Stress psi
10	20	...
20	30	...
30	40	...
40	50	...
50	60	...
60	80	...
80	90	...
90	100	...

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Longitudinal Stresses due to: Step: 16 4:21pm Dec 21, 2022

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Stress due to Combined Loads: Step: 17 4:21pm Dec 21, 2022

Stress Combination Load Cases for Vertical Vessels:**Load Case Definition Key**

IP = Longitudinal Stress due to Internal Pressure
 EP = Longitudinal Stress due to External Pressure
 HP = Longitudinal Stress due to Hydrotest Pressure
 NP = No Pressure
 EW = Longitudinal Stress due to Weight (No Liquid)
 OW = Longitudinal Stress due to Weight (Operating)
 HW = Longitudinal Stress due to Weight (Hydrotest)
 WI = Bending Stress due to Wind Moment (Operating)
 EQ = Bending Stress due to Earthquake Moment (Operating)
 EE = Bending Stress due to Earthquake Moment (Empty)
 HI = Bending Stress due to Wind Moment (Hydrotest)
 HE = Bending Stress due to Earthquake Moment (Hydrotest)
 WE = Bending Stress due to Wind Moment (Empty) (no CA)
 WF = Bending Stress due to Wind Moment (Filled) (no CA)
 CW = Longitudinal Stress due to Weight (Empty) (no CA)
 VO = Bending Stress due to Vortex Shedding Loads (Ope)
 VE = Bending Stress due to Vortex Shedding Loads (Emp)
 VF = Bending Stress due to Vortex Shedding Loads (Test No CA.)
 FW = Axial Stress due to Vertical Forces for the Wind Case
 FS = Axial Stress due to Vertical Forces for the Seismic Case
 BW = Bending Stress due to Lat. Forces for the Wind Case, Corroded
 BS = Bending Stress due to Lat. Forces for the Seismic Case, Corroded
 BN = Bending Stress due to Lat. Forces for the Wind Case, UnCorroded
 BU = Bending Stress due to Lat. Forces for the Seismic Case, UnCorroded
 BL = Bending Stress due to Blast Loads, Corroded

General Notes:

Case types HI and HE are in the Corroded condition.

Case types WE, WF, and CW are in the Un-Corroded condition.

A blank stress and stress ratio indicates that the corresponding stress comprising those components that did not contribute to that type of stress.

An asterisk (*) in the final column denotes overstress.

Analysis of Load Case 1 : NP+EW+WI+FW+BW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	1278.61	14400.00	-1892.55	14808.10	0.0888	0.1278
20	748.17	14400.00	-1269.27	14808.10	0.0520	0.0857
30	320.46	10656.00	-693.05	8705.73	0.0301	0.0796
40	230.55	17760.00	-674.08	8382.42	0.0130	0.0804
50	177.76	17760.00	-512.77	8703.96	0.0100	0.0589
60		17760.00	-173.85	8703.96		0.0200

Analysis of Load Case 2 : NP+EW+EE+FS+BS

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	1963.89	14400.00	-2420.49	14808.10	0.1364	0.1635
20	1272.29	14400.00	-1657.68	14808.10	0.0884	0.1119
30	699.79	10656.00	-971.30	8705.73	0.0657	0.1116
40	608.25	17760.00	-930.19	8382.42	0.0342	0.1110

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Stress due to Combined Loads: Step: 17 4:21pm Dec 21,2022

50	466.34	17760.00	-711.32	8703.96	0.0263	0.0817
60	117.07	17760.00	-280.26	8703.96	0.0066	0.0322

Analysis of Load Case 3 : NP+OW+WI+FW+BW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	1248.07	14400.00	-1923.09	14808.10	0.0867	0.1299
20	717.63	14400.00	-1299.80	14808.10	0.0498	0.0878
30	289.93	10656.00	-723.59	8705.73	0.0272	0.0831
40	230.55	17760.00	-674.08	8382.42	0.0130	0.0804
50	177.76	17760.00	-512.77	8703.96	0.0100	0.0589
60		17760.00	-173.85	8703.96		0.0200

Analysis of Load Case 4 : NP+OW+EQ+FS+BS

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	3511.35	14400.00	-4029.02	14808.10	0.2438	0.2721
20	2145.22	14400.00	-2591.69	14808.10	0.1490	0.1750
30	1171.82	10656.00	-1504.40	8705.73	0.1100	0.1728
40	989.84	17760.00	-1311.78	8382.42	0.0557	0.1565
50	753.62	17760.00	-998.60	8703.96	0.0424	0.1147
60	179.08	17760.00	-342.26	8703.96	0.0101	0.0393

Analysis of Load Case 5 : NP+HW+HI

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	0.00	24624.00	0.00	19495.02	0.0000	0.0000
20	0.00	24624.00	0.00	19495.02	0.0000	0.0000
30	0.00	16200.00	0.00	14001.60	0.0000	0.0000
40	0.00	27000.00	0.00	13430.58	0.0000	0.0000
50	0.00	27000.00	0.00	13998.49	0.0000	0.0000
60	0.00	27000.00	0.00	13998.48	0.0000	0.0000

Analysis of Load Case 6 : NP+HW+HE

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	0.00	24624.00	0.00	19495.02	0.0000	0.0000
20	0.00	24624.00	0.00	19495.02	0.0000	0.0000
30	0.00	16200.00	0.00	14001.60	0.0000	0.0000
40	0.00	27000.00	0.00	13430.58	0.0000	0.0000
50	0.00	27000.00	0.00	13998.49	0.0000	0.0000
60	0.00	27000.00	0.00	13998.48	0.0000	0.0000

Analysis of Load Case 7 : IP+OW+WI+FW+BW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	1248.07	14400.00	-1923.09	14808.10	0.0867	0.1299
20	717.63	14400.00	-1299.80	14808.10	0.0498	0.0878
30	289.93	10656.00	-723.59	8705.73	0.0272	0.0831
40	2924.05	17760.00		8382.42	0.1646	
50	2281.15	17760.00		8703.96	0.1284	
60	2064.46	17760.00		8703.96	0.1162	

Analysis of Load Case 8 : IP+OW+EQ+FS+BS

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
-----------	----------------	-------------------	--------------	-------------------	-------------	-------------

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Stress due to Combined Loads: Step: 17 4:21pm Dec 21,2022

10	3511.35	14400.00	-4029.02	14808.10	0.2438	0.2721
20	2145.22	14400.00	-2591.69	14808.10	0.1490	0.1750
30	1171.82	10656.00	-1504.40	8705.73	0.1100	0.1728
40	3683.35	17760.00		8382.42	0.2074	
50	2857.02	17760.00		8703.96	0.1609	
60	2282.47	17760.00		8703.96	0.1285	

Analysis of Load Case 9 : EP+OW+WI+FW+BW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	1248.07	14400.00	-1923.09	14808.10	0.0867	0.1299
20	717.63	14400.00	-1299.80	14808.10	0.0498	0.0878
30	289.93	10656.00	-723.59	8705.73	0.0272	0.0831
40		17760.00	-1073.16	8382.42		0.1280
50		17760.00	-827.55	8703.96		0.0951
60		17760.00	-488.63	8703.96		0.0561

Analysis of Load Case 10 : EP+OW+EQ+FS+BS

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	3511.35	14400.00	-4029.02	14808.10	0.2438	0.2721
20	2145.22	14400.00	-2591.69	14808.10	0.1490	0.1750
30	1171.82	10656.00	-1504.40	8705.73	0.1100	0.1728
40	590.77	17760.00	-1710.85	8382.42	0.0333	0.2041
50	438.84	17760.00	-1313.38	8703.96	0.0247	0.1509
60		17760.00	-657.04	8703.96		0.0755

Analysis of Load Case 11 : HP+HW+HI

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	0.00	24624.00	0.00	19495.02	0.0000	0.0000
20	0.00	24624.00	0.00	19495.02	0.0000	0.0000
30	0.00	16200.00	0.00	14001.60	0.0000	0.0000
40	8026.99	27000.00		13430.58	0.2973	
50	6268.38	27000.00		13998.49	0.2322	
60	6268.39	27000.00		13998.48	0.2322	

Analysis of Load Case 12 : HP+HW+HE

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	0.00	24624.00	0.00	19495.02	0.0000	0.0000
20	0.00	24624.00	0.00	19495.02	0.0000	0.0000
30	0.00	16200.00	0.00	14001.60	0.0000	0.0000
40	8026.99	27000.00		13430.58	0.2973	
50	6268.38	27000.00		13998.49	0.2322	
60	6268.39	27000.00		13998.48	0.2322	

Analysis of Load Case 13 : IP+WE+EW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10		14400.00	-586.68	14808.10		0.0396
20	19.16	14400.00	-540.26	14808.10	0.0013	0.0365
30		10656.00	-281.01	8705.73		0.0323
40	2592.77	17760.00		8382.42	0.1460	
50	2030.34	17760.00		8703.96	0.1143	

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Stress due to Combined Loads: Step: 17 4:21pm Dec 21,2022

60	1998.51	17760.00	8703.96	0.1125
----	---------	----------	---------	--------

Analysis of Load Case 14 : IP+WF+CW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10		14400.00	-310.84	14808.10		0.0210
20		14400.00	-268.08	14808.10		0.0181
30		10656.00	-199.70	8705.73		0.0229
40	2493.70	17760.00		8382.42	0.1404	
50	1949.12	17760.00		8703.96	0.1097	
60	2005.41	17760.00		8703.96	0.1129	

Analysis of Load Case 15 : IP+VO+OW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	2059.04	14400.00	-2734.05	14808.10	0.1430	0.1846
20	1323.90	14400.00	-1906.07	14808.10	0.0919	0.1287
30	695.76	10656.00	-1129.43	8705.73	0.0653	0.1297
40	3258.38	17760.00		8382.42	0.1835	
50	2534.24	17760.00		8703.96	0.1427	
60	2130.78	17760.00		8703.96	0.1200	

Analysis of Load Case 16 : IP+VE+EW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10		14400.00	-586.68	14808.10		0.0396
20	19.16	14400.00	-540.26	14808.10	0.0013	0.0365
30		10656.00	-281.01	8705.73		0.0323
40	2592.77	17760.00		8382.42	0.1460	
50	2030.34	17760.00		8703.96	0.1143	
60	1998.51	17760.00		8703.96	0.1125	

Analysis of Load Case 17 : NP+VO+OW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	2059.04	14400.00	-2734.05	14808.10	0.1430	0.1846
20	1323.90	14400.00	-1906.07	14808.10	0.0919	0.1287
30	695.76	10656.00	-1129.43	8705.73	0.0653	0.1297
40	564.88	17760.00	-1008.42	8382.42	0.0318	0.1203
50	430.84	17760.00	-765.86	8703.96	0.0243	0.0880
60	27.38	17760.00	-240.16	8703.96	0.0015	0.0276

Analysis of Load Case 18 : FS+BS+IP+OW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	20.87	14400.00	-538.54	14808.10	0.0014	0.0364
20	56.47	14400.00	-502.94	14808.10	0.0039	0.0340
30		10656.00	-261.00	8705.73		0.0300
40	2653.57	17760.00		8382.42	0.1494	
50	2075.36	17760.00		8703.96	0.1169	
60	2023.31	17760.00		8703.96	0.1139	

Analysis of Load Case 19 : FS+BS+EP+OW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
-----------	----------------	-------------------	--------------	-------------------	-------------	-------------

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Stress due to Combined Loads: Step: 17 4:21pm Dec 21,2022

10	20.87	14400.00	-538.54	14808.10	0.0014	0.0364
20	56.47	14400.00	-502.94	14808.10	0.0039	0.0340
30		10656.00	-261.00	8705.73		0.0300
40		17760.00	-681.07	8382.42		0.0813
50		17760.00	-531.73	8703.96		0.0611
60		17760.00	-397.88	8703.96		0.0457

Absolute Maximum of the all of the Stress Ratio's

0.2973

Governing Element: BTM D-END

Governing Load Case 11 : HP+HW+HI

Element Description	Long Pressure Stress	Weight + Axial Load Stress	Eccentric Moment Stress	Wind or Earthquake Stress	Combined Stress	Which Side
BTM SKIRT-2	...	...	...	...	...	+ Tens
BTM SKIRT-2	...	...	...	...	...	- Comp
BTM SKIRT-1	...	...	...	...	...	+ Tens
BTM SKIRT-1	...	...	...	...	...	- Comp
TOP SKIRT	...	...	...	...	...	+ Tens
TOP SKIRT	...	...	...	...	...	- Comp
BTM D-END	8027.0	...	...	...	8027.0	+ Tens
BTM D-END	8027.0	...	...	...	...	- Comp
SHELL-1	6268.4	...	...	...	6268.4	+ Tens
SHELL-1	6268.4	...	...	...	...	- Comp
SHELL-2	6268.4	...	...	...	6268.4	+ Tens
SHELL-2	6268.4	...	...	...	...	- Comp

Fatigue Stress Calculations due to Wind Induced Vortex Shedding Loads

From	Elevation	Alternating Stress	Sif	Number of Cycles	Hours of Total Vibration
10	8.20	4652.40	2.0	1000000	62.58
20	13.63	2934.68	2.0	1000000	62.58
30	16.75	2842.06	3.0	1000000	62.58
40	16.91	1541.97	2.0	1000000	62.58
50	21.83	1167.31	2.0	1000000	62.58
60	26.42	306.41	2.0	1000000	62.58
80	26.74	1.03	2.0	1000000	62.58
90	27.00	0.18	2.0	1000000	62.58

Cycle Life Determination based on ASME Div. II, Table 5-110.1

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Skirt Opening Stress Calcs: Step: 18 4:21pm Dec 21, 2022

Skirt Support Analysis Per EN 13445-3 Section 16.12:**NOTE:**

The skirt comprises more than one piece. If this is the case, the Openings will only be considered in this Section of the Skirt! Otherwise, make the whole skirt all one piece.

Item: BTM SKIRT-1

Type B Skirt per EN-13445 Figure 16.12-2:

Total vessel (empty) weight	Fg	6004.354	lbf
Weight of vessel contents (liquid)	Ff	1029.762	lbf
Vessel Gross Weight	Fg + Ff = F4	7034.115	lbf
Skirt Mean Diameter	Dz	29.635	in
Skirt Analysis Thickness (Corroded)	ez	0.362	in
Skirt Height	H	65.157	in
Force at section 1-1	F1	7034.115	lbf
Moment at section 1-1	M1	25578.650	ft-lbf
Applied Moment - Bottom of Skirt	Mb	42968.914	ft-lbf
Weight Above the Skirt	W	9815.970	lbf

Frame Input Data:

Access #	Diameter in	Layout Angle deg	Cntr. Dist. From Bottom in	Obround Cntr-Cntr in	Frame Width in	Frame Thickness in
1	10.7480	135.0	58.31	0.00	5.354	0.354
2	4.4882	180.0	23.03	0.00	4.528	0.236

Interference check:

Access	Access	Pitch in	Ligament in
1	2	16.5603	8.9422
1	2	16.5603	8.9422

INTERFERENCE CHECK: No Interference Detected between Openings

Minimum Pitch between openings is: 16.5603 in
Minimum Ligament between Openings is: 8.9422 in

Recommended minimum Ligament:

= 2 * Sqrt(D * t)
= 2 * Sqrt(29.635 * 0.362) = 6.553 in
Please evaluate the suitability of this result

Section properties at least metal area [A]:

Number of Openings At Critical Height = 1

Access No	Layout Angle 1 Deg.	Layout Angle 2 Deg.
1	113.7353	156.2647

The points for integrating Ixx, Iyy is as follows:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Skirt Opening Stress Calcs: Step: 18 4:21pm Dec 21, 2022

FROM THETA1 Deg	TO THETA2 Deg
-203.735	113.735

Height of Weakest Section	H	58.308	in
Rotation of Principle Axes	a	0.000	Deg.
Centroid Position in X direction	g	0.112	in
Centroid Position in Y direction	h	-0.112	in
Principle Moment of Inertia	Ixx	3681.798	in**4
Principle Moment of Inertia	Iyy	3681.798	in**4
Distance to Extreme Fiber	ybar	15.110	in
Distance to Extreme Fiber	xbar	15.110	in
Minimum Section Modulus	W4	243.663	in ^3
Metal Area at the Cutting Plane	A4	33.532	in^2

Half Opening Width Subtended Angle at Weakest Section: [delta]:

$$= \sin^{-1} (\text{Largest Opening Width} / D_z)$$

$$= \sin^{-1} (10.748/29.635) = 0.3711 \text{ rad}(21.2647 \text{ deg})$$

Skirt Mean Radius at Section 4-4 [r]:

$$= D_z/2 = 29.635/2 = 14.8176 \text{ in}$$

Opening Ratio At Weakest Section: EN 13445 Equation 16.12-76 [ratio]:

$$= \text{delta} * \sqrt{r/ez}$$

$$= 0.371 * \sqrt{14.818/0.362} = 2.3738$$

WARNING: ratio Exceeds 2 - See EN 13445 16.12.76(a).**This equation is a precaution against radial buckling at the opening.****The frame (if there is one), may prevent this. The code does not say what size this frame should be. Your judgement is required.****Analysis of the Section at Weakest Section Modulus [Section 4-4]:**

Skirt Corroded Thickness [ez]:

$$= ex(\text{new}) - ci - cext = 0.394 - 0.031 - 0.0 = 0.3622 \text{ in}$$

Please note:

There is more than one opening in the skirt

EN-13445 and AD-2000 considers only one opening per Figure 16.12-4

this skirt has 2 openings. Please check results

Note: Sometimes the moments are expressed in ft-lbf and other times in in-lbf. Please be aware of this.

Find the moment acting at the Critical Height [M4]:

$$= (M_{\text{bottom}} - M_{\text{top}}) * (H - \text{CutHeight}) / H + M_{\text{top}}$$

$$= (42968.914 - 25578.65) * (65.157 - 58.308) / 65.157 + 25578.65$$

$$= 27406.834 \text{ ft-lbf}$$

Compute the section modulus [Zxx and Zyy]:

$$Z_{xx} = I_{xx}/ybar = 3681.798/15.11 = 243.6627 \text{ in}^3$$

$$Z_{yy} = I_{yy}/xbar = 3681.798/15.11 = 243.6627 \text{ in}^3$$

$$Z = \min(Z_{xx}, Z_{yy}) = \min(243.663, 243.663) = 243.6627 \text{ in}^3$$

The balance of the calculations are per EN-13445, and they may be treated as academic if the designated code is not EN-13445

Radius of Gyration of Skirt at 4-4 [rg]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Skirt Opening Stress Calcs: Step: 18 4:21pm Dec 21,2022

```

= sqrt( min( Ixx, Iyy ) / Area(A4) )
= sqrt( min( 3681.798, 3681.798 )/33.532 ) )
= 10.478 in

```

Note: rg is not included in the analysis of EN 13445

Skirt Slenderness Ratio [r/L]:

$$= 10.478/65.157 = 0.161$$

Location of the Skirt Centroid at critical height [e]:

```

= sqrt( ex^2 + ey^2 ) = sqrt( 0.112^2 + -0.112^2 )
= 0.000 in

```

Where $ex = 0.112$: $ey = -0.112$

Note: Moment Converted to ft-lbf units

Moment Increment at Centroid [DeltaM4]:

```

= ( Fg + Ff ) * e = F4 * e
= ( 6004.35 + 1029.76 ) * 0.15772 = 92.451 ft-lbf

```

Nomenclature per EN-13445:

Note: Moments are displayed as in-lbf units.

Check of the Skirt in Regions with Openings, per 16.12.4.3:

Weakening Factor, 16.12-70(b) [psi_1]:

```

= min( 1; A4/( pi * D_3 * e_(a3) ) )
= min( 1; 33.532/( pi * 29.675 * 0.362 ) )
= 0.993

```

Weakening Factor, 16.12-70(c) [psi_2]:

```

= min( 1; 4 * W4 / ( pi * D^2_3 / ( pi * D_3 * e_(a3) ) ) )
= min( 1; 4.0 * 243.663 / ( pi * 29.675^2 * 0.362 ) )
= 0.973

```

Maximum Bending Moment [M_(max)]:

```

= pi/4 * d3^2 * e_(a3) * sigmac_(all)
= pi/4 * 29.675^2 * 0.362 * 14808.1
= 309135.9 ft-lbf

```

Maximum Compressive Force [Fc_(,max)]:

```

= pi * d3 * e_(a3) * sigmac_(all)
= pi * 29.675 * 0.362 * 14808.1
= 500031.1 lbf

```

Unity Check of Weakened Section, 16.12-70 [UC_1]:

```

= F_4 / ( psi_1 * F_(c,max) ) + ( abs( M_4 ) + F_4 * abs( y_g ) ) / ( psi_2 * M_(max) ) )
= 7034.1 / ( 0.993 * 500031 ) + ( abs( 27406.8 ) + 7034.1 * abs( 0.158 ) ) / ( 0.973 * 309135.9 )
= 0.106 must be <= to 1, Passed

```

The stresses are satisfactory in the region with the opening(s).

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Skirt Opening Stress Calcs: Step: 19 4:21pm Dec 21, 2022

Skirt Support Analysis Per EN 13445-3 Section 16.12:

Item: TOP SKIRT

Type B Skirt per EN-13445 Figure 16.12-2:

Total vessel (empty) weight	Fg	6004.354	lbf
Head Weight below section 2-2	DeltaFg	188.782	lbf
Weight of vessel contents (liquid)	Ff	1029.762	lbf
Vessel Gross Weight	Fg + Ff = F4	7034.115	lbf
Skirt Mean Diameter	Dz	29.635	in
Skirt Analysis Thickness (Corroded)	ez	0.362	in
Skirt Height	H	37.402	in
Force at section 1-1	F1	6845.333	lbf
Moment at section 1-1	M1	16577.975	ft-lbf
Applied Moment - Bottom of Skirt	Mb	25578.650	ft-lbf
Weight Above the Skirt	W	7311.992	lbf

Frame Input Data:

Access #	Diameter in	Layout Angle deg	Cntr. Dist. From Bottom in	Obround Cntr-Cntr in	Frame Width in	Frame Thickness in
1	2.8740	90.0	29.41	0.00	2.362	0.203
2	2.8740	270.0	29.41	0.00	2.362	0.203

Interference check:

Access	Access	Pitch in	Ligament in
1	2	46.5509	43.6723
1	2	46.5509	43.6723

INTERFERENCE CHECK: No Interference Detected between Openings

Minimum Pitch between openings is: 46.5509 in
 Minimum Ligament between Openings is: 43.6723 in

Recommended minimum Ligament:

= 2 * Sqrt(D * t)
 = 2 * Sqrt(29.635 * 0.362) = 6.553 in
 Please evaluate the suitability of this result

Section properties at least metal area [A]:

Number of Openings At Critical Height = 2

Access No	Layout Angle 1 Deg.	Layout Angle 2 Deg.
1	84.4347	95.5653
2	264.4347	275.5653

The points for integrating Ixx, Iyy is as follows:
 FROM THETA1 TO THETA2
 Deg Deg

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Skirt Opening Stress Calcs: Step: 19 4:21pm Dec 21, 2022

95.565 264.435
-84.435 84.435

Height of Weakest Section	H	29.406	in
Rotation of Principle Axes	a	-0.000	Deg.
Centroid Position in X direction	g	0.000	in
Centroid Position in Y direction	h	0.000	in
Principle Moment of Inertia	Ixx	3663.991	in**4
Principle Moment of Inertia	Iyy	3704.002	in**4
Distance to Extreme Fiber	ybar	14.999	in
Distance to Extreme Fiber	xbar	14.999	in
Minimum Section Modulus	W4	244.287	in ^3
Metal Area at the Cutting Plane	A4	33.556	in^2

Half Opening Width Subtended Angle at Weakest Section: [delta]:

$$= \sin^{-1} (\text{Largest Opening Width} / \text{Dz})$$

$$= \sin^{-1} (2.874/29.635) = 0.0971 \text{ rad}(5.5653 \text{ deg})$$

Skirt Mean Radius at Section 4-4 [r]:

$$= \text{Dz}/2 = 29.635/2 = 14.8176 \text{ in}$$

Opening Ratio At Weakest Section: EN 13445 Equation 16.12-76 [ratio]:

$$= \text{delta} * \text{sqrt}(r/\text{ez})$$

$$= 0.097 * \text{sqrt}(14.818/0.362) = 0.6213$$

Ok as the ratio is < 2 - See EN 13445 16.12.76(a).

Analysis of the Section at Weakest Section Modulus [Section 4-4]:

Skirt Corroded Thickness [ez]:

$$= \text{ex}(\text{new}) - \text{ci} - \text{cext} = 0.394 - 0.031 - 0.0 = 0.3622 \text{ in}$$

Please note:

There is more than one opening in the skirt

EN-13445 and AD-2000 considers only one opening per Figure 16.12-4

this skirt has 2 openings. Please check results

Note: Sometimes the moments are expressed in ft-lbf
and other times in in-lbf. Please be aware of this.

Find the moment acting at the Critical Height [M4]:

$$= (\text{Mbottom} - \text{Mtop}) * (\text{H} - \text{CutHeight}) / \text{H} + \text{Mtop}$$

$$= (25578.65 - 16577.975) * (37.402 - 29.406) / 37.402 + 16577.975$$

$$= 18502.078 \text{ ft-lbf}$$

Compute the section modulus [Zxx and Zyy]:

$$\text{Zxx} = \text{Ixx}/\text{ybar} = 3663.991/15.0 = 244.2872 \text{ in}^3$$

$$\text{Zyy} = \text{Iyy}/\text{xbar} = 3704.002/15.0 = 246.9548 \text{ in}^3$$

$$\text{Z} = \min(\text{Zxx}, \text{Zyy}) = \min(244.287, 246.955) = 244.2872 \text{ in}^3$$

The balance of the calculations are per EN-13445, and
they may be treated as academic if the designated code
is not EN-13445

Radius of Gyration of Skirt at 4-4 [rg]:

$$= \text{sqrt}(\min(\text{Ixx}, \text{Iyy}) / \text{Area}(\text{A4}))$$

$$= \text{sqrt}(\min(3663.991, 3704.002) / 33.556)$$

$$= 10.449 \text{ in}$$

Note: rg is not included in the analysis of EN 13445

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Skirt Opening Stress Calcs: Step: 19 4:21pm Dec 21, 2022

Skirt Slenderness Ratio [r/L]:

$$= 10.449/37.402 = 0.279$$

Location of the Skirt Centroid at critical height [e]:

$$= \sqrt{e_x^2 + e_y^2} = \sqrt{0.0^2 + 0.0^2}$$

$$= 0.158 \text{ in}$$

Where $e_x = 0.0$: $e_y = 0.0$

Note: Moment Converted to ft-lbf units

Moment Increment at Centroid [DeltaM4]:

$$= (F_g + F_f) * e = F_4 * e$$

$$= (6004.35 + 1029.76) * 0. = 0.0 \text{ ft-lbf}$$

Nomenclature per EN-13445:

Note: Moments are displayed as in-lbf units.

Check of the Skirt in Regions with Openings, per 16.12.4.3:

Weakening Factor, 16.12-70(b) [psi_1]:

$$= \min(1; A_4 / (\pi * D_3 * e_{(a3)}))$$

$$= \min(1; 33.556 / (\pi * 29.675 * 0.362))$$

$$= 0.994$$

Weakening Factor, 16.12-70(c) [psi_2]:

$$= \min(1; 4 * W_4 / (\pi * D_3^2 * e_{(a3)}))$$

$$= \min(1; 4.0 * 246.955 / (\pi * 29.675^2 * 0.362))$$

$$= 0.986$$

Maximum Bending Moment [M_(max)]:

$$= \pi/4 * d_3^2 * e_{(a3)} * \sigma_{mac_all}$$

$$= \pi/4 * 29.675^2 * 0.362 * 14808.1$$

$$= 309135.9 \text{ ft-lbf}$$

Maximum Compressive Force [Fc_(,max)]:

$$= \pi * d_3 * e_{(a3)} * \sigma_{mac_all}$$

$$= \pi * 29.675 * 0.362 * 14808.1$$

$$= 500031.1 \text{ lbf}$$

Unity Check of Weakened Section, 16.12-70 [UC_1]:

$$= F_4 / (\psi_1 * F_{(c,max)}) + (abs(M_4) + F_4 * abs(y_g)) / (\psi_2 * M_{(max)})$$

$$= 7034.1 / (0.994 * 500031) + (abs(18502.1) + 7034.1 * abs(0.0)) / (0.986 * 309135.9)$$

$$= 0.075 \text{ must be } \leq \text{ to } 1, \text{ Passed}$$

The stresses are satisfactory in the region with the opening(s).

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Center of Gravity Calculation: Step: 20 4:21pm Dec 21, 2022

Shop/Field Installation Options :

Platform(s) installed in the Field before being lifted.

Note : The CG is computed from the first Element From Node

Center of Gravity of the Platforms	15.699 ft
Center of Gravity of the Liquid	18.099 ft
Center of Gravity of the Nozzles	21.266 ft
Center of Gravity of the Added Weights (Operating)	25.459 ft
Center of Gravity of the Added Weights (Empty)	25.459 ft
Center of Gravity of Bare Shell New and Cold	15.271 ft
Center of Gravity of Bare Shell Corroded	15.249 ft
Vessel CG in the Operating Condition	16.197 ft
Vessel CG in the Fabricated (Shop/Empty) Condition	16.216 ft
Vessel CG in the Test Condition	18.005 ft

Rigging Analysis Results:

Lifting Weight based the calculated Erected Weight.

Total Effective Length of Vessel for this analysis	26.97 ft
Total vessel weight (No Liquid) Twt	10351.59 lbf
Impact weight multiplication factor Imp	1.35
Design lifting weight, DWT = Imp * Twt	13974.64 lbf
Elevation of the Tailing Lug (bottom)	0.45 ft
Elevation of the Lifting Lug (top)	25.75 ft
Design Reaction force at the tailing lug	5264.58 lbf
Design Reaction force at the lifting lug	8710.06 lbf
CG Distance from Tailing Lug	15.77 ft
CG Distance from the Nearer Lifting Lug/Trunnion	9.53 ft
Compressive Allowable Increase Factor	1.00

Critical Values:

	Max Stress	Elevation	Allowables	
	psi	ft	psi	
Bending	1558.12	16.75	11401.38	(UG-23)
Shear	149.74	25.50	11690.00	(0.7*S)

The compressive bending allowable stress is the minimum of the tensile allowable and the compressive allowable times the specified compressive allowable increase factor.

Forces and Moments at selected elevations (not all analysis points shown):

Distance ft	Bending Moment ft-lbf	Bending Stress psi	Shear Force lbf	Shear Stress psi
0.00	0.0	0.0	374.3	10.2
10.37	28406.3	1273.0	655.0	17.9
16.13	28422.7	1272.4	1185.9	32.4
17.90	25748.5	1152.0	1875.9	51.2
24.59	3255.0	145.6	5008.0	136.6
26.74	251.7	7.9	2192.0	50.2

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Center of Gravity Calculation: Step: 20 4:21pm Dec 21, 2022

Unity Check (Actual Stress / Allowable Stress):

Maximum Unity Check is 0.1367 at elevation 16.7487 ft - Must be ≤ 1

Note: The rigging analysis is performed using a uniformly distributed load.

--- Plot data successfully generated ...----

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.


FileName : V-1264_R06

Lifting Lug Calcs: Step: 21 4:21pm Dec 21,2022

Lifting Lug Calculations:**Input Values:**

Lifting Lug Material	SA-516 70
Lifting Lug Yield Stress	Yield 38000.00 psi
Total Height of Lifting Lug	w 5.9055 in
Thickness of Lifting Lug	t 1.7717 in
Diameter of Hole in Lifting Lug	dh 0.9055 in
Radius of Semi-Circular Arc of Lifting Lug	r 2.9528 in
Height of Lug from bottom to Center of Hole	h 2.9528 in
Offset from Vessel OD to Center of Hole	off 10.2362 in
Lug Fillet Weld Size	tw 0.7874 in
Length of weld along side of Lifting Lug	wl 5.9055 in
Length of Weld along Bottom of Lifting Lug	wb 4.1339 in
Thickness of Collar (if any)	tc 0.0000 in
Diameter of Collar (if any)	dc 0.0000 in
Impact Factor	Impfac 1.35
Sling Angle from Horizontal	90.0 deg
Number of Lugs in Group	2

Lifting Lug Orientation to Vessel: Perpendicular
 Lift Orientation : From Horizontal to Vertical

**Lifting Lug and Weld Stresses at various Angles: psi**

Angle	----- Weld Stresses			----- Lug Stresses		Maximum Ratio
	Primary	Secondary	Allowable	Combined	Allowable	
0	4502.5	...	15200.0	14430.0	25080.0	0.575
5	4701.4	...	15200.0	14789.8	25080.0	0.590
10	4868.4	...	15200.0	15038.6	25080.0	0.600
15	5002.4	...	15200.0	15174.6	25080.0	0.605
20	5102.3	...	15200.0	15196.8	25080.0	0.606
25	5167.5	...	15200.0	15105.2	25080.0	0.602
30	5197.7	...	15200.0	14900.7	25080.0	0.594
35	5192.7	...	15200.0	14585.1	25080.0	0.582
40	5153.0	...	15200.0	14161.1	25080.0	0.565
45	5079.2	...	15200.0	13632.6	25080.0	0.544
50	4972.4	...	15200.0	13004.3	25080.0	0.519
55	4834.3	...	15200.0	12282.2	25080.0	0.490
60	4667.2	...	15200.0	11473.7	25080.0	0.457
65	4474.7	...	15200.0	10588.2	25080.0	0.422
70	4262.3	...	15200.0	9638.5	25080.0	0.384
75	4040.6	...	15200.0	8644.5	25080.0	0.345
80	3833.5	...	15200.0	7645.9	25080.0	0.305
85	3721.7	...	15200.0	6764.6	25080.0	0.270
90	4356.0	...	15200.0	6945.6	25080.0	0.287

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Lifting Lug Calcs: Step: 21 4:21pm Dec 21, 2022

Computed Results:

Total vessel weight (No Liquid)	10351.59 lbf
Design Reaction force at the tailing lug	5264.58 lbf
Design Reaction force at the lifting lug	8710.06 lbf
Worst Case Lift Angle for Primary Weld Stresses	32 deg
Tangential Force at this Angle	3758.4 lbf
Axial Force at this Angle	2348.5 lbf
Worst Case Lift Angle for Secondary Weld Stresses	0 deg
Tangential Force at this Angle	4355.0 lbf
Axial Force at this Angle	0.0 lbf
Worst Case Lift Angle for Lug Stresses	18 deg
Tangential Force at this Angle	4180.4 lbf
Axial Force at this Angle	1358.3 lbf

*Converting the weld leg dimension (tw) to the weld throat dimension.***Weld Group Inertia Calculations:**

Weld Group Inertia about the Circumferential Axis	Ilc	67.279 in**4
Weld Group Centroid distance in the Long. Direction	Yll	3.509 in
Dist. of Weld Group Centroid from Lug bottom	Yll_b	2.953 in
Weld Group Inertia about the Longitudinal Axis	Ill	15.635 in**4
Weld Group Centroid Distance in the Circ. Direction	Ylc	1.443 in

*Note: The Impact Factor is applied to the Forces acting on the Lug.***Primary Shear Stress in the Welds due to Shear Loads [Ssll]:**

$$\begin{aligned}
 &= \sqrt{(Fax^2 + Ft^2 + Fn^2) / ((2 * (wl + wb)) * tw)} \\
 &= \sqrt{(2349^2 + 3758^2 + 0^2) / ((2 * (5.9 + 4.1)) * 0.5567)} \\
 &= 396.49 \text{ psi}
 \end{aligned}$$

Shear Stress in the Welds due to Bending Loads [Sblf]:

$$\begin{aligned}
 &= (Fn(h - Yll_b))Yll/Ilc + (Fax * off * Yll/Ilc) + (Ft * off * Ylc/Ill) \\
 &= (0(2.953 - 2.953))3.509/67.279 + \\
 &\quad (2349 * 10.236 * 3.509/67.279) + \\
 &\quad (3758 * 10.236 * 1.443/15.635) \\
 &= 4803.40 \text{ psi}
 \end{aligned}$$

Total Shear Stress for Combined Loads [St]:

$$\begin{aligned}
 &= Ssll + Sblf \\
 &= 396.49 + 4803.402 \\
 &= 5199.89 \text{ psi}
 \end{aligned}$$

Allowable Shear Stress for Combined Loads [Sta]:

$$\begin{aligned}
 &= 0.4 * Yield * Occfac \text{ (AISC Shear Allowable)} \\
 &= 0.4 * 38000 * 1.0 \\
 &= 15200.00 \text{ psi}
 \end{aligned}$$

Shear Stress in Lug above Hole [Shs]:

$$\begin{aligned}
 &= \sqrt{(Pl^2 + Fax^2)} / Sha \\
 &= \sqrt{(6987^2 + 2349^2)} / 8.858 \\
 &= 832.15 \text{ psi}
 \end{aligned}$$

Allowable Shear Stress in Lug above Hole [Sas]:

$$= 0.4 * Yield * Occfac$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Lifting Lug Calcs: Step: 21 4:21pm Dec 21,2022

$$= 0.4 * 38000 * 1.0$$

$$= 15200.00 \text{ psi}$$

Pin Hole Bearing Width [Pbw]:

$$= \text{Lug Thickness} + 2 * \text{Collar Thickness}$$

$$= 1.772 + 2 * 0.0$$

$$= 1.772 \text{ in}$$

Pin Hole Bearing Stress [Pbs]:

$$= \sqrt{P_l^2 + F_{axial}^2} / (Pbw * dh)$$

$$= \sqrt{6987^2 + 2349^2} / (1.772 * 0.906)$$

$$= 4594.94 \text{ psi}$$

Allowable Bearing Stress [Pba]:

$$= \min(0.75 * \text{Yield} * \text{Occfac}, 0.9 * \text{Yield}) \text{ AISC Bearing All.}$$

$$= \min(0.75 * 38000 * 1.0, 34200.0)$$

$$= 28500.00 \text{ psi}$$

Bending Stress at the Base of the Lug [Fbs]:

$$= F_t * \text{off} / (w * t^2 / 6) + F_{ax} * \text{off} / (w^2 * t / 6)$$

$$= 4180 * 10.236 / (5.906 * 1.772^2 / 6) +$$

$$1358 * 10.236 / (5.906^2 * 1.772 / 6)$$

$$= 14787.67 \text{ psi}$$

Tensile Stress at the Base of the Lug [Fa]:

$$= F_n / (w * t)$$

$$= 0 / (5.906 * 1.772)$$

$$= 0.00 \text{ psi}$$

Total Combined Stress at the Base of the Lug:

$$= Fbs + Fa$$

$$= 14787.7 + 0.0$$

$$= 14787.67 \text{ psi}$$

Lug Allowable Stress for Bending and Tension:

$$= \min(0.66 * \text{Yield} * \text{Occfac}, 0.75 * \text{Yield})$$

$$= \min(0.66 * 38000 * 1.0, 28500.0)$$

$$= 25080.00 \text{ psi}$$

Required Shackle Pin Diameter [Spd]:

$$= \sqrt{(2(F_n^2 + F_{ax}^2)^{0.5} / (\pi * Sta))}$$

$$= \sqrt{(2(6987^2 + 2349^2)^{0.5} / (\pi * 15200))}$$

$$= 0.5556 \text{ in}$$

WRC 107/537 Stress Analysis for the Lifting Lug to Shell Junction in the new and Cold Condition (no corrosion applied).

Note: The full lug load is applied in both the circumferential and longitudinal directions simultaneously.

Note: Attachment dimensions (C11P, C22P etc.) may be modified accounting for attachment welds where applicable.

Input Echo, WRC107/537 Item 1, Description: Lift Lug

Diameter Basis for Vessel	Vbasis	ID
Cylindrical or Spherical Vessel	Cylsph	Cylindrical
Internal Corrosion Allowance	Cas	0.0000 in
Vessel Diameter	Dv	29.250 in
Vessel Thickness	Tv	0.394 in

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Lifting Lug Calcs: Step: 21 4:21pm Dec 21,2022

Note: Lifting lug calculations are performed at ambient temperature conditions.

Attachment Type	Type	Rectangular
Parameter C11	C11	4.13 in
Parameter C22	C22	5.91 in
Thickness of Reinforcing Pad	Tpad	0.394 in
Pad Parameter C11P	C11p	7.244 in
Pad Parameter C22P	C22p	8.937 in
Design Internal Pressure	Dp	0.000 psig
Include Pressure Thrust		No


External Forces and Moments in WRC 107/537 Convention:

Radial Load	(SUS)	P	0.0	lbf
Longitudinal Shear	(SUS)	Vl	6987.3	lbf
Circumferential Shear	(SUS)	Vc	6987.3	lbf
Circumferential Moment	(SUS)	Mc	5960.3	ft-lbf
Longitudinal Moment	(SUS)	Ml	0.0	ft-lbf
Torsional Moment	(SUS)	Mt	0.0	ft-lbf

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".



WRC 107/537 has dimensional limitations that can be found in the bulletin's Foreword and which can also be inferred by review of the non-dimensional curve limits.

WRC 107 Stress Calculation for SUStained loads:

Radial Load	P	0.0	lbf
Circumferential Shear	VC	6987.3	lbf
Longitudinal Shear	VL	6987.3	lbf
Circumferential Moment	MC	5960.3	ft-lbf
Longitudinal Moment	ML	0.0	ft-lbf
Torsional Moment	MT	0.0	ft-lbf

Dimensionless Parameters used : Gamma = 19.07

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.196	4C	3.035	(A,B)
N(PHI) / (P/Rm)	0.196	3C	2.356	(C,D)
M(PHI) / (P)	0.157	2C1	0.079	(A,B)
M(PHI) / (P)	0.157	1C	0.111	(C,D)

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Lifting Lug Calcs: Step: 21 4:21pm Dec 21,2022

N(PHI) / (MC/(Rm**2 * Beta))	0.155	3A	0.620	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.171	1A	0.094	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.175	3B	2.089	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.173	1B	0.042	(A,B,C,D)
N(x) / (P/Rm)	0.178	3C	2.522	(A,B)
N(x) / (P/Rm)	0.178	4C	3.121	(C,D)
M(x) / (P)	0.181	1C1	0.101	(A,B)
M(x) / (P)	0.181	2C	0.067	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.155	4A	0.928	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.202	2A	0.047	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.175	4B	0.643	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.190	2B	0.061	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (psi)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		0	0	0	0	0	0	0	0
Circ. Bend. P		0	0	0	0	0	0	0	0
Circ. Memb. MC		0	0	0	0	-1243	-1243	1243	1243
Circ. Bend. MC		0	0	0	0	-25246	25246	25246	-25246
Circ. Memb. ML		0	0	0	0	0	0	0	0
Circ. Bend. ML		0	0	0	0	0	0	0	0
Tot. Circ. Str.		0	0	0	0	-26490	24003	26490	-24003
Long. Memb. P		0	0	0	0	0	0	0	0
Long. Bend. P		0	0	0	0	0	0	0	0
Long. Memb. MC		0	0	0	0	-1982	-1982	1982	1982
Long. Bend. MC		0	0	0	0	-10752	10752	10752	-10752
Long. Memb. ML		0	0	0	0	0	0	0	0
Long. Bend. ML		0	0	0	0	0	0	0	0
Tot. Long. Str.		0	0	0	0	-12735	8770	12735	-8770
Shear VC		1073	1073	-1073	-1073	0	0	0	0
Shear VL		0	0	0	0	-751	-751	751	751
Shear MT		0	0	0	0	0	0	0	0
Tot. Shear		1073	1073	-1073	-1073	-751	-751	751	751
Str. Int.		2146	2146	2146	2146	26531	24040	26531	24040

Dimensionless Parameters used : Gamma = 37.65

Dimensionless Loads for Cylindrical Shells at Pad Edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.304	4C	4.215	(A,B)
N(PHI) / (P/Rm)	0.304	3C	2.061	(C,D)
M(PHI) / (P)	0.263	2C1	0.022	(A,B)
M(PHI) / (P)	0.263	1C	0.062	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.262	3A	1.466	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.289	1A	0.068	(A,B,C,D)

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Lifting Lug Calcs: Step: 21 4:21pm Dec 21, 2022

N(PHI) / (ML/(Rm**2 * Beta))	0.281	3B	3.017	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.283	1B	0.015	(A,B,C,D)
N(x) / (P/Rm)	0.285	3C	2.248	(A,B)
N(x) / (P/Rm)	0.285	4C	4.394	(C,D)
M(x) / (P)	0.289	1C1	0.042	(A,B)
M(x) / (P)	0.289	2C !	0.032	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.262	4A	3.327	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.328	2A	0.027	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.281	4B	1.467	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.301	2B	0.022	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (psi)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		0	0	0	0	0	0	0	0
Circ. Bend. P		0	0	0	0	0	0	0	0
Circ. Memb. MC		0	0	0	0	-3741	-3741	3741	3741
Circ. Bend. MC		0	0	0	0	-44118	44118	44118	-44118
Circ. Memb. ML		0	0	0	0	0	0	0	0
Circ. Bend. ML		0	0	0	0	0	0	0	0
Tot. Circ. Str.		0	0	0	0	-47859	40376	47859	-40376
Long. Memb. P		0	0	0	0	0	0	0	0
Long. Bend. P		0	0	0	0	0	0	0	0
Long. Memb. MC		0	0	0	0	-8970	-8970	8970	8970
Long. Bend. MC		0	0	0	0	-15246	15246	15246	-15246
Long. Memb. ML		0	0	0	0	0	0	0	0
Long. Bend. ML		0	0	0	0	0	0	0	0
Tot. Long. Str.		0	0	0	0	-24216	6275	24216	-6275
Shear VC		1224	1224	-1224	-1224	0	0	0	0
Shear VL		0	0	0	0	-992	-992	992	992
Shear MT		0	0	0	0	0	0	0	0
Tot. Shear		1224	1224	-1224	-1224	-992	-992	992	992
Str. Int.		2449	2449	2449	2449	47901	40405	47901	40405

WRC 107/537 Stress Summations:**Vessel Stress Summation at Attachment Junction (psi)**

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		0	0	0	0	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Lifting Lug Calcs:

Step: 21 4:21pm Dec 21, 2022

Circ. Pl (SUS)		0	0	0	0	-1243	-1243	1243	1243
Circ. Q (SUS)		0	0	0	0	-25246	25246	25246	-25246
Long. Pm (SUS)		0	0	0	0	0	0	0	0
Long. Pl (SUS)		0	0	0	0	-1982	-1982	1982	1982
Long. Q (SUS)		0	0	0	0	-10752	10752	10752	-10752
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		1073	1073	-1073	-1073	-751	-751	751	751
Shear Q (SUS)		0	0	0	0	0	0	0	0
Pm (SUS)		0	0	0	0	0	0	0	0
Pm+Pl (SUS)		2146	2146	2146	2146	2450	2450	2450	2450
Pm+Pl+Q (Total)		2146	2146	2146	2146	26531	24040	26531	24040

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	0	16700	Passed
Pm+Pl (SUS)	2450	25050	Passed
Pm+Pl+Q (TOTAL)	26531	50100	Passed

Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.

WRC 107/537 Stress Summations:**Vessel Stress Summation at Reinforcing Pad Edge (psi)**

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		0	0	0	0	0	0	0	0
Circ. Pl (SUS)		0	0	0	0	-3741	-3741	3741	3741
Circ. Q (SUS)		0	0	0	0	-44118	44118	44118	-44118
Long. Pm (SUS)		0	0	0	0	0	0	0	0
Long. Pl (SUS)		0	0	0	0	-8970	-8970	8970	8970
Long. Q (SUS)		0	0	0	0	-15246	15246	15246	-15246
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		1224	1224	-1224	-1224	-992	-992	992	992
Shear Q (SUS)		0	0	0	0	0	0	0	0
Pm (SUS)		0	0	0	0	0	0	0	0
Pm+Pl (SUS)		2449	2449	2449	2449	9152	9152	9152	9152
Pm+Pl+Q (Total)		2449	2449	2449	2449	47901	40405	47901	40405

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	0	16700	Passed
Pm+Pl (SUS)	2449	25050	Passed
Pm+Pl+Q (TOTAL)	26531	50100	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Lifting Lug Calcs: Step: 21 4:21pm Dec 21, 2022

Pm (SUS)		0	16700		Passed	
Pm+Pl (SUS)		9152	25050		Passed	
Pm+Pl+Q (TOTAL)		47901	50100		Passed	

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Basing Calculations: Step: 22 4:21pm Dec 21,2022

Skirt Data :

Skirt Outside Diameter at Base	SOD, D6	29.9974	in
Skirt Thickness	STHK	0.3937	in
Skirt Internal Corrosion Allowance	SCA	0.0315	in
Skirt External Corrosion Allowance		0.0000	in
Skirt Material		SA-516 70	

Basing Input: Type of Geometry: Basing W/Gussets & Chair Cap

Thickness of Basing	TBA, ea4	1.2598	in
Design Temperature of the Basing		100.00	°F
Basing Material		SA-516 70	
Basing Ope. All. Stress	BASOPE, f4	20000.00	psi
Basing Yield Stress		38000.00	psi
Inside Diameter of Basing	DI, D4	25.2362	in
Outside Diameter of Basing	DOU, D5	40.2756	in
Nominal Diameter of Bolts	BND, d(b0)	1.7500	in
Bolt Corrosion Allowance	BCA	0.0000	in
Bolt Material		SA-193 B7M	
Bolt Material Class/Thickness Range		<= 2 1/2	
Bolt Operating Allowable Stress	SA, fB	20000.00	psi
Number of Bolts	RN, nb	4	
Diameter of Bolt Circle	DC, DBC	35.5000	in
Bolt Allowable Shear Stress		13050.000	psi
Ultimate Comp. Strength of Concrete	FPC	3000.0	psi
Allowable Comp. Strength of Concrete	FC	4000.0	psi
Modular ratio Steel/Concrete		9.833	
Thickness of Gusset Plates	TGA, e7	0.7874	in
Width of Gussets at Top Plate	TWDT	5.2360	in
Width of Gussets at Base Plate	BWDT	5.2360	in
Gusset Plate Elastic Modulus	E	29000000.0	psi
Gusset Plate Yield Stress	SY	38000.0	psi
Height of Gussets	HG, h1	8.1880	in
Distance between Gussets	RG, b6	4.0157	in
Dist. from Bolt Center to Gusset (Rg/2)	CG	2.0079	in
Number of Gussets per bolt	NG	2	
Thickness of Top Plate or Ring	TTA, e5	1.5748	in
Radial Width of the Top Plate	TOPWTH, b5	5.2362	in
Circum. Width of the Top Plate	CMWTH, b4	7.0079	in
Anchor Bolt Hole Dia. in Top Plate	BHOLE	2.1250	in
External Corrosion Allowance	CA	0.0630	in
Dead Weight of Vessel	DW	10351.6	lbf
Operating Weight of Vessel	ROW	11381.3	lbf
Earthquake Moment on Basing	EQMOM	71804.7	ft-lbf
Wind Moment on Basing	WIMOM	26863.9	ft-lbf
Vortex Shedding Moment on Basing	Vormom	43546.8	ft-lbf
Percent Bolt Preload	ppl	100.0	
Use AISC A5.2 Increase in Fc and Bolt Stress		No	
Use Allowable Weld Stress per AISC J2.5		No	
Factor for Increase of Allowables	Fact	1.0000	

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Basing Calculations: Step: 22 4:21pm Dec 21,2022

Results for Basing Analysis : Analyze Option

Basing Thickness Calculation method used : Neutral Axis Shift

Calculation of Bolt Loads for Multiple Loading Conditions:

Bolt Load, Earthquake Operating Case [F_(B,e)]:

$$= ((4 * M/DC) - \text{abs}(W - \text{vertical force}))/nb \quad \text{per Jawad \& Farr, Eq. 12.3}$$

$$= ((4 * 861656/35.5) - 8728)/4$$

$$= 22089.9 \text{ lbf}$$

Bolt Load, Windload Empty Case [F_(B,w)]:

$$= ((4 * M/DC) - W)/nb \quad \text{per Jawad \& Farr, Eq. 12.3}$$

$$= ((4 * 322367/35.5) - 10352)/4$$

$$= 6492.9 \text{ lbf}$$

Bolt Load, Windload Vortex Shedding Case [F_(B,v)]:

$$= ((4 * M/DC) - W)/nb \quad \text{per Jawad \& Farr, Eq. 12.3}$$

$$= ((4 * 522561/35.5) - 11381)/4$$

$$= 11874.7 \text{ lbf}$$

Calculation of Maximum Load per Bolt [W/Bolt], Earthquake + Operating Condition:

where: W = ROW - Yforce (from gy Acceleration or user force), M = EQMOM

$$= ((4 * M/DC) - W)/nb \quad \text{per Jawad \& Farr, Eq. 12.3}$$

$$= ((4 * 861656/35.5) - 8728)/4$$

$$= 22089.9 \text{ lbf}$$

Area Available in all the Bolts (Corr) 7.9200 in²

Shear Stress in a Single Bolt [taub]:

$$= \text{Shear Force} / (\text{Bolt Area} * \text{Number of Bolts})$$

$$= 3575 / (1.98 * 4)$$

$$= 451.4 \text{ psi. Must be less than 13050.0 psi.}$$

Concrete Contact Area of Base Ring CCA 773.82 in²Concrete Contact Section Modulus of Base Ring 5425.28 in³

Concrete Load (Simplified method), Earthquake in Operating Condition [Sc]:

$$= ((ppl/100 * (Abt * Sa) + W) / Cca) + M/CZ \quad \text{per Jawad \& Farr Eq. 12.1}$$

$$= (1.0(7.92 * 20000 + 14034) / 773.82) + 861656 / 5425.28$$

$$= 381.66 \text{ psi}$$

Neutral Axis Shift Method Per Singh and Soler:

Trial#	Alpha	k	Rho1	Rho2	Rho3	Rho4	Ftstr	Fcstr
0	60.226	0.252	1.375	2.547	0.779	0.448	7192.4	204.3
2	58.529	0.619	1.337	2.575	0.778	0.451	7106.2	209.8
4	58.529	0.334	1.337	2.575	0.778	0.451	7106.2	209.8
6	58.529	0.263	1.337	2.575	0.778	0.451	7106.2	209.8
8	58.529	0.245	1.337	2.575	0.778	0.451	7106.2	209.8
10	58.529	0.240	1.337	2.575	0.778	0.451	7106.2	209.8
12	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
14	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
16	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
18	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
20	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
22	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
24	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Basing Calculations: Step: 22 4:21pm Dec 21,2022

26	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
28	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
30	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
32	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
34	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
36	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
38	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
40	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
42	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
44	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
46	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
48	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
50	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
52	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
54	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
56	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
58	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
60	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
62	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
64	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
66	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
68	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
70	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
72	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
74	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
76	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
78	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
80	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
82	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
84	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
86	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
88	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
90	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
92	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
94	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
96	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
98	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8
**	58.529	0.239	1.337	2.575	0.778	0.451	7106.2	209.8

Results of Neutral Axis Shift Calculation:

Bearing Pressure on Concrete	209.81	psi
Concrete Allowable Stress	4000.00	psi
Stress developed in Bolt	7106.23	psi
Allowable Bolt Stress 20000.0 [Fact]	20000.00	psi

Calculation of Basing Thickness, (N.A. Shift) [Tbna]:

$$\begin{aligned}
 &= R_w * \sqrt{(3 * S_{cna} / S) + CA \text{ per Jawad \& Farr Eq. 12.12}} \\
 &= 5.1391 * \sqrt{(3 * 209.814 / 30000.0) + 0.063} \\
 &= 0.807 \text{ in}
 \end{aligned}$$

Required Thickness of Top Plate in Tension:

(Calculated as a fixed beam per Megyesy)

$$\begin{aligned}
 F_t &= (S_a * A_{bss}), && \text{Bolt Allowable Stress * Area} \\
 R_m &= (F_t * 2 * C_g) / 8, && \text{Bending Moment} \\
 S_b &&& \text{Allowable Bending Stress} \\
 W_t &= (Topw_{th} - B_{nd}), && \text{Width of Section}
 \end{aligned}$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Basing Calculations: Step: 22 4:21pm Dec 21,2022

Required Thickness of Top Plate [T]:

$$\begin{aligned}
 &= \sqrt{6 * Rm / (Sb * Wt)} + CA \\
 &= \sqrt{6 * 19878 / (30000 * 3.4862)} + 0.063 \\
 &= 1.131 \text{ in}
 \end{aligned}$$

Required Thickness of Top Chair Cap Plate per Moss:

$$\begin{aligned}
 P &= (Sa * Abss) && \text{Bolt Allowable Stress * Area} \\
 e &= (Topwth - Bhole) / 2 && \text{Distance to Edge of Hole} \\
 Sb &&& \text{Allowable Bending Stress} \\
 b &= Cg && \text{Gusset Plate Dimension} \\
 db &= Bhole && \text{Bolt Hole Diameter}
 \end{aligned}$$

Top Chair Cap Plate Required Thickness [Tc]

$$\begin{aligned}
 &= (P / (Sb * e) * \sqrt{0.375 * b - 0.22 * db}) + CA \\
 &= (39600 / (30000 * 1.422) * \sqrt{0.375 * 4.02 - 0.22 * 2.125}) + 0.063 \\
 &= 1.0446 \text{ in}
 \end{aligned}$$

Stress in the Top Plate at given Thickness [Stpl]:

$$\begin{aligned}
 &= P (0.375 * b - 0.22 * db) / e / (Tta - Ca)^2 \\
 &= 39600 (0.375 * 4.016 - 0.22 * 2.125) / 1.422 / (1.575 - 0.063)^2 \\
 &= 12648.564 \text{ psi, must be less than } 30000.0 \text{ psi}
 \end{aligned}$$

Required Thickness of Gusset in Compression, per AISC E2-1:

1. Allowed Compression at Given Thickness:

Factor Kl/r Per E2-1	36.0217	
Factor Cc Per E2-1	122.7360	
Allowable Buckling Str. per E2-1	20503.00	psi
Actual Buckling Str. at Given Thickness	4802.52	psi

Required Gusset/Support Plate thickness, + CA	0.3467	in
---	--------	----

2. Allowed Compression at Calculated Thickness:

Factor Kl/r Per E2-1	99.9898	
Factor Cc Per E2-1	122.7360	
Allowable Buckling Str. per E2-1	13330.92	psi
Act. Buckling Str. at Calculated Thickness	13330.92	psi

Summary of Basing Thickness Calculations:

Required Basing Thickness (N.A. Shift)	0.8074	in
Actual Basing Thickness	1.2598	in
Required Top Ring/Plate Thickness as a Fixed Beam	1.1309	in
Required Thickness of Chair Cap per Moss/AISI	1.0446	in
Actual Top Plate/Ring Thickness	1.5748	in
Required Gusset/Support Plate thickness, + CA	0.3467	in
Actual Gusset/Support Plate Thickness	0.7874	in

Local Stress at the Top Plate per AISI, including axial Stress [S]:

$$\begin{aligned}
 &= Wmax * e / t^2 [1.32 * Z / (1.43 * Cmwth * (Hg + Tta)^2 / (R * Tskirt) \\
 &\quad + (4 * Cmwth * (Hg + Tta)^2)^{.333} + 0.031 / \sqrt{R * Tskirt}) \\
 &= 14070 * 2.75 / 0.36^2 [1.32 * 0.11 / (1.43 * 7.01 * (8.98)^2 / (14.64 * 0.36) \\
 &\quad + (4 * 7.01 * (8.19 + 0.79)^2)^{.333} + 0.031 / \sqrt{14.64 * 0.36}) \\
 &= 4190.752 \text{ psi}
 \end{aligned}$$

Where [Z]:

$$\begin{aligned}
 &= 1 / [(0.177 * Wgp * Tba / \sqrt{R * t}) * (Tba / t)^2 + 1] \\
 &= 1 / [(0.177 * 7.008 * 1.26 / \sqrt{14.636 * 0.362}) * (1.26 / 0.362)^2 + 1] \\
 &= 0.109
 \end{aligned}$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Basing Calculations: Step: 22 4:21pm Dec 21,2022

Where [e]:

$$\begin{aligned}
 &= (Dc - Ds) / 2 \\
 &= (35.5 - 29.997) / 2 \\
 &= 2.751 \text{ in}
 \end{aligned}$$

Local Stress in the Skirt due to the Gussets	4190	psi
Weight plus Bending Stress in the Skirt (Highest)	4029	psi
Comb. loc. + bending stress Worst Load Case	8219	psi
Allowed membrane+bending stress(1.5* Skirt All.)	30000	psi

Weld Size Calculations per Steel Plate Engineering Data - Vol. 2

Compute the Weld load at the Skirt/Base Junction [W]

$$\begin{aligned}
 &= \text{SkirtStress} * (\text{SkirtThickness} - CA) \\
 &= 4029.021 * (0.394 - 0.031) \\
 &= 1459.33 \text{ lbf/in}
 \end{aligned}$$

Results for Computed Minimum Basing Weld Size [BWeld]

$$\begin{aligned}
 &= W / [(0.4 * \text{Yield}) * 2 * 0.707] \\
 &= 1459 / [(0.4 * 31000) * 2 * 0.707] \\
 &= 0.083 \text{ in}
 \end{aligned}$$

Results for Computed Minimum Gusset and Top Plate to Skirt Weld Size

Vertical Plate Load [Wv]

$$\begin{aligned}
 &= \text{Bolt Load} / (\text{Cmwth} + 2 * (Hg + Tta)) \\
 &= 39600.0 / (5.591 + 2 * (8.188 + 1.575)) \\
 &= 1576.675 \text{ lbf/in}
 \end{aligned}$$

Horizontal Plate Load [Wh]

$$\begin{aligned}
 &= \text{Bolt Load} * e / (\text{Cmwth} * (Hg + Tta) + 0.6667 * (Hg + Tta)^2) \\
 &= 39600.0 * 2.751 / (5.591 * (9.763) + 0.6667 * (9.763)^2) \\
 &= 922.37 \text{ lbf/in}
 \end{aligned}$$

Resultant Weld Load [Wr]

$$\begin{aligned}
 &= \text{sqrt}(Wv^2 + Wh^2) \\
 &= \text{sqrt}(1576.67^2 + 922.37^2) \\
 &= 1826.655 \text{ lbf/in}
 \end{aligned}$$

Results for Computed Min Gusset and Top Plate to Skirt Weld Size [GsWeld]

$$\begin{aligned}
 &= Wr / [(0.4 * \text{Yield}) * 2 * 0.707] \\
 &= 1826.65 / [(0.4 * 31000) * 2 * 0.707] \\
 &= 0.104 \text{ in}
 \end{aligned}$$

Results for Computed Minimum Gusset to Top Plate Weld Size

Weld Load [Wv]

$$\begin{aligned}
 &= \text{Bolt Load} / (2 * \text{TopWth}) \\
 &= 39600.0 / (2 * 5.236) \\
 &= 3781.512 \text{ lbf/in}
 \end{aligned}$$

Weld Load [Wh]

$$\begin{aligned}
 &= \text{Bolt Load} * e / (2 * Hgt * \text{TopWth}) \\
 &= 39600.0 * 2.75 / (2 * 9.763 * 5.236) \\
 &= 1065.686 \text{ lbf/in}
 \end{aligned}$$

Resultant Weld Load [Wr]

$$\begin{aligned}
 &= \text{sqrt}(Wv^2 + Wh^2) \\
 &= \text{sqrt}(3781.51^2 + 1065.69^2) \\
 &= 3928.807 \text{ lbf/in}
 \end{aligned}$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Basing Calculations: Step: 22 4:21pm Dec 21, 2022

Results for Computed Min Gusset to Top Plate Weld Size [GtpWeld]

= $W_r / [(0.4 * Yield) * 2 * 0.707]$ = $3928.81 / [(0.4 * 31000) * 2 * 0.707]$

= 0.224 in

Note: The calculated weld sizes need not exceed the component thickness framing into the weld. At the same time, the weld must meet a minimum size specification which is 3/16 in. (4.76 mm) or 1/4 in. (6.35 mm), depending on the component thickness.

Summary of Required Weld Sizes:

Required Basing to Skirt Double Fillet Weld Size	0.1875 in
Required Gusset to Skirt Double Fillet Weld Size	0.2500 in
Required Top Plate to Skirt Weld Size	0.2500 in
Required Gusset to Top Plate Double Fillet Weld Size	0.2241 in

Warning:

Please note that nozzle loadings, if included, are assumed to be local in nature and will not contribute to or create a net section bending moment. Therefore, the addition of nozzle loads will not affect the support load calculation. If you wish to create a load on the legs/lugs etc. from forces or moments, use the Force/Moment dialog and add the appropriate forces and moments at the correct locations in the model. Ensure that all supports are designed to take into account all possible loading conditions.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

WRC Clip Analysis: Type-1 Step: 23 4:21pm Dec 21, 2022

Input Echo, WRC107/537 Item 1, Description: Type-1 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	0.0315	in
Vessel Diameter	Dv	29.250	in
Vessel Thickness	Tv	0.394	in
Design Temperature	T1	500.0	F
Vessel Material		SA-240 316L	
Vessel UNS Number		S31603	
Vessel Cold S.I. Allowable	Smc	16700.00	psi
Vessel Hot S.I. Allowable	Smh	14800.00	psi
Attachment Type	Type	Rectangular	
Parameter C11	C11	0.55	in
Parameter C22	C22	15.50	in
Thickness of Reinforcing Pad	Tpad	0.394	in
Pad Parameter C11P	C11p	3.268	in
Pad Parameter C22P	C22p	18.268	in
Design Internal Pressure	Dp	150.000	psig
Include Pressure Thrust		No	


External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	500.0	lbf
Longitudinal Shear (SUS)	Vl	3000.0	lbf
Circumferential Shear (SUS)	Vc	500.0	lbf
Circumferential Moment (SUS)	Mc	1000.0	ft-lbf
Longitudinal Moment (SUS)	Ml	7500.0	ft-lbf
Torsional Moment (SUS)	Mt	0.0	ft-lbf

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".



WRC 107/537 has dimensional limitations that can be found in the bulletin's Foreword and which can also be inferred by review of the non-dimensional curve limits.

WRC 107 Stress Calculation for SUSstained loads:

Radial Load	P	500.0	lbf
Circumferential Shear	VC	500.0	lbf
Longitudinal Shear	VL	3000.0	lbf
Circumferential Moment	MC	1000.0	ft-lbf

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

WRC Clip Analysis: Type-1 Step: 23 4:21pm Dec 21, 2022

Longitudinal Moment ML 7500.0 ft-lbf
Torsional Moment MT 0.0 ft-lbf

Dimensionless Parameters used : Gamma = 19.89

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.157	4C	3.335	(A,B)
N(PHI) / (P/Rm)	0.157	3C	2.808	(C,D)
M(PHI) / (P)	0.082	2C1	0.139	(A,B)
M(PHI) / (P)	0.082	1C	0.175	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.056	3A !	0.199	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.072	1A	0.103	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.170	3B !	2.167	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.152	1B	0.045	(A,B,C,D)
N(x) / (P/Rm)	0.122	3C	3.185	(A,B)
N(x) / (P/Rm)	0.122	4C	3.574	(C,D)
M(x) / (P)	0.128	1C1	0.133	(A,B)
M(x) / (P)	0.128	2C	0.096	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.056	4A !	0.255	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.101	2A	0.058	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.170	4B !	0.666	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.209	2B	0.056	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (psi)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-146	-146	-146	-146	-123	-123	-123	-123
Circ. Bend. P		-729	729	-729	729	-917	917	-917	917
Circ. Memb. MC		0	0	0	0	-74	-74	74	74
Circ. Bend. MC		0	0	0	0	-11926	11926	11926	-11926
Circ. Memb. ML		-4513	-4513	4513	4513	0	0	0	0
Circ. Bend. ML		-18476	18476	18476	-18476	0	0	0	0
Tot. Circ. Str.		-23866	14545	22113	-13379	-13041	12646	10960	-11058
Long. Memb. P		-140	-140	-140	-140	-157	-157	-157	-157
Long. Bend. P		-699	699	-699	699	-502	502	-502	502
Long. Memb. MC		0	0	0	0	-156	-156	156	156
Long. Bend. MC		0	0	0	0	-4833	4833	4833	-4833
Long. Memb. ML		-2462	-2462	2462	2462	0	0	0	0
Long. Bend. ML		-16858	16858	16858	-16858	0	0	0	0
Tot. Long. Str.		-20160	14954	18480	-13836	-5649	5022	4330	-4332
Shear VC		600	600	-600	-600	0	0	0	0
Shear VL		0	0	0	0	-128	-128	128	128
Shear MT		0	0	0	0	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

WRC Clip Analysis: Type-1 Step: 23 4:21pm Dec 21,2022

Tot. Shear	600	600	-600	-600	-128	-128	128	128
Str. Int.	23961	15384	22210	14249	13044	12648	10962	11061

Dimensionless Parameters used : Gamma = 40.96

Dimensionless Loads for Cylindrical Shells at Pad Edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.397	4C	3.547	(A,B)
N(PHI) / (P/Rm)	0.397	3C	1.438	(C,D)
M(PHI) / (P)	0.226	2C1	0.028	(A,B)
M(PHI) / (P)	0.226	1C !	0.063	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.195	3A !	1.656	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.246	1A	0.070	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.347	3B !	2.488	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.302	1B	0.012	(A,B,C,D)
N(x) / (P/Rm)	0.317	3C	2.017	(A,B)
N(x) / (P/Rm)	0.317	4C	4.315	(C,D)
M(x) / (P)	0.332	1C1	0.032	(A,B)
M(x) / (P)	0.332	2C !	0.032	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.195	4A !	3.151	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.328	2A	0.026	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.347	4B !	1.365	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.417	2B	0.011	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (psi)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-330	-330	-330	-330	-133	-133	-133	-133
Circ. Bend. P		-629	629	-629	629	-1435	1435	-1435	1435
Circ. Memb. MC		0	0	0	0	-300	-300	300	300
Circ. Bend. MC		0	0	0	0	-10461	10461	10461	-10461
Circ. Memb. ML		-5084	-5084	5084	5084	0	0	0	0
Circ. Bend. ML		-11338	11338	11338	-11338	0	0	0	0
Tot. Circ. Str.		-17381	6553	15462	-5954	-12331	11462	9192	-8858
Long. Memb. P		-187	-187	-187	-187	-401	-401	-401	-401
Long. Bend. P		-729	729	-729	729	-738	738	-738	738
Long. Memb. MC		0	0	0	0	-1134	-1134	1134	1134
Long. Bend. MC		0	0	0	0	-2923	2923	2923	-2923
Long. Memb. ML		-5100	-5100	5100	5100	0	0	0	0
Long. Bend. ML		-7579	7579	7579	-7579	0	0	0	0
Tot. Long. Str.		-13597	3021	11762	-1937	-5198	2126	2918	-1451
Shear VC		211	211	-211	-211	0	0	0	0
Shear VL		0	0	0	0	-226	-226	226	226
Shear MT		0	0	0	0	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

WRC Clip Analysis: Type-1 Step: 23 4:21pm Dec 21, 2022

Tot. Shear	211	211	-211	-211	-226	-226	226	226
Str. Int.	17393	6566	15474	5965	12338	11467	9200	8865

Note : The ratio Beta1/Beta2 for rectangular attachments was outside the range of values in tables 7 & 8 and was set to be an acceptable (maximum or minimum) value.

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (psi)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		2835	2985	2835	2985	2835	2985	2835	2985
Circ. Pl (SUS)		-4660	-4660	4367	4367	-197	-197	-49	-49
Circ. Q (SUS)		-19206	19206	17746	-17746	-12844	12844	11009	-11009
Long. Pm (SUS)		1417	1417	1417	1417	1417	1417	1417	1417
Long. Pl (SUS)		-2602	-2602	2322	2322	-313	-313	-1	-1
Long. Q (SUS)		-17557	17557	16158	-16158	-5335	5335	4331	-4331
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		600	600	-600	-600	-128	-128	128	128
Shear Q (SUS)		0	0	0	0	0	0	0	0
Pm (SUS)		2835	2985	2835	2985	2835	2985	2835	2985
Pm+Pl (SUS)		2185	2078	7303	7449	2648	2797	2797	2946
Pm+Pl+Q (Total)		21179	17785	25019	12582	10209	15633	13797	8076

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	2985	14800	Passed
Pm+Pl (SUS)	7449	22200	Passed
Pm+Pl+Q (TOTAL)	25019	44400	Passed

Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (psi)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		5995	6145	5995	6145	5995	6145	5995	6145
Circ. Pl (SUS)		-5414	-5414	4754	4754	-434	-434	166	166
Circ. Q (SUS)		-11967	11967	10708	-10708	-11896	11896	9025	-9025

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

WRC Clip Analysis: Type-1 Step: 23 4:21pm Dec 21,2022

Long. Pm (SUS)		2997	2997	2997	2997	2997	2997	2997	2997
Long. Pl (SUS)		-5287	-5287	4912	4912	-1536	-1536	733	733
Long. Q (SUS)		-8309	8309	6850	-6850	-3662	3662	2185	-2185
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		211	211	-211	-211	-226	-226	226	226
Shear Q (SUS)		0	0	0	0	0	0	0	0
Pm (SUS)		5995	6145	5995	6145	5995	6145	5995	6145
Pm+Pl (SUS)		2902	3051	10765	10914	5573	5723	6183	6332
Pm+Pl+Q (Total)		11439	12706	21464	1108	6348	17612	15193	4282

Vessel Stress Summation Comparison (psi):

Type of Stress Int.		Max. S.I.	S.I. Allowable		Result	
Pm (SUS)		6145	14800		Passed	
Pm+Pl (SUS)		10914	22200		Passed	
Pm+Pl+Q (TOTAL)		21464	44400		Passed	

Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B2 2" Nozl: 27 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle B2 2"**From: 40**

Pressure for Reinforcement Calculations	P	151.619	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F
Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi
Inside Diameter of Elliptical Head	D	29.2500	in
Aspect Ratio of Elliptical Head	Ar	2.00	
Head Finished (Minimum) Thickness	t	0.3150	in
Head Internal Corrosion Allowance	c	0.0315	in
Head External Corrosion Allowance	co	0.0000	in
Distance from Head Centerline	L1	0.0000	in
User Entered Minimum Design Metal Temperature		32.00	°F

Type of Element Connected to the Parent : Nozzle

Material		SA-312 TP316L	
Material UNS Number		S31603	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi
Diameter Basis (for tr calc only)		Outside	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness		80S	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	0.0315	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	6.0000	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.1960	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3140	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in
Flange Class		600	
Flange Grade		GR 2.3	
Piping Exit Angle [North Clockwise reference]		90.0	deg
Bend Radius Multiplier		1.50	
Horizontal Run Length		28.0	in
Centerline Distance to Tangent		77.0	in

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)

18-D-272


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B2 2" Nozl: 27 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle B2 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Outside Diameter Used in Calculation 2.375 in.
 Actual Thickness Used in Calculation 0.191 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Elliptical Head, tr [Int. Press]

= $P \cdot D \cdot K_1 / (2 \cdot S_v \cdot E - 0.2 \cdot P)$ per Appendix 1-4(c)
 = $0.9 \cdot 151.619 \cdot 29.313 / (2 \cdot 14800.0 \cdot 1.0 - 0.2 \cdot 151.62)$
 = 0.1350 in

Reqd thk per UG-37(a) of Nozzle Wall, trn [Int. Press]

= $P \cdot R_o / (S_n \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a) (1)
 = $151.62 \cdot 1.1875 / (10900 \cdot 1.0 + 0.4 \cdot 151.62)$
 = 0.0164 in

Required Nozzle thickness under External Pressure per UG-28 : 0.0117 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	4.1130 in
Parallel to Vessel Wall, opening length	d	2.0565 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.3981 in

Weld Strength Reduction Factor [fr1]:

= $\min(1, S_n / S_v)$
 = $\min(1, 10900.0 / 14800.0)$
 = 0.736

Weld Strength Reduction Factor [fr2]:

= $\min(1, S_n / S_v)$
 = $\min(1, 10900.0 / 14800.0)$
 = 0.736

Weld Strength Reduction Factor [fr3]:

= $\min(fr2, fr4)$
 = $\min(0.736, 1.0)$
 = 0.736

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.289	0.087	NA
Area in Shell	A1	0.293	0.399	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B2 2" Nozl: 27 4:21pm Dec 21, 2022

Area in Nozzle Wall	A2	0.084	0.087	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.028	0.028	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	0.405	0.514	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.**Area Required [A]:**

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.0565 * 0.135 * 1.0 + 2 * 0.1593 * 0.135 * 1.0 * (1 - 0.74))$$

$$= 0.289 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1**Area Available in Shell [A1]:**

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.056 (1.0 * 0.2835 - 1.0 * 0.135) - 2 * 0.159$$

$$(1.0 * 0.2835 - 1.0 * 0.135) * (1 - 0.736)$$

$$= 0.293 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.398) (0.1593 - 0.0164) 0.7365$$

$$= 0.084 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.196^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.028 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0479 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1814 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1814 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0463 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.1661 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.166, \max(0.1814, 0.094)]$$

$$= 0.1661 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0479, 0.1661)$$

$$= 0.1661 \text{ in}$$

Available Nozzle Neck Thickness = 0.1908 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME**B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained :	7013.9,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	27486.1 psi	Passed
Occasional :	454.3,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B2 2" Nozl: 27 4:21pm Dec 21,2022

Shear : 5044.1, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-312 TP316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 151.62/1200.00 = 0.126

Weld Size Calculations, Description: Nozzle B2 2"

Intermediate Calc. for nozzle/shell Welds Tmin 0.1593 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.1115 = 0.7 * tmin.	0.1386 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (0.2889 - 0.2929 + 2 * 0.1593 * 0.7365 * (1.0 * 0.2835 - 0.135) * 14800)) \\
 &= 457.49 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (0.0838 + 0.0 + 0.0283 - 0.0 * 0.74) * 14800 \\
 &= 1658.38 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.0838 + 0.0 + 0.0283 + (0.0665)) * 14800 \\
 &= 2642.49 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.0838 + 0.0 + 0.0283 + 0.0 + (0.0665)) * 14800 \\
 &= 2642.49 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 2.375 * 0.196 * 0.49 * 10900 \\
 &= 3905. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 1.1079) * (0.1908 - 0.0315) * 0.7 * 10900 \\
 &= 4229. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B2 2" Nozl: 27 4:21pm Dec 21,2022

$$= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng$$

$$= (3.1416/2.0) * 2.375 * (0.315 - 0.0315) * 0.74 * 14800$$

$$= 11582. \text{ lbf}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (3905 + 4229) = 8135 \text{ lbf}$$

Failure Path [Path 2-2]:

$$= (Sonw + Tpgw + Tngw + Sinw)$$

$$= (3905 + 0 + 11582 + 0) = 15487 \text{ lbf}$$

Failure Path [Path 3-3]:

$$= (Sonw + Tngw + Sinw)$$

$$= (3905 + 11582 + 0) = 15487 \text{ lbf}$$
Summary of Failure Path Calculations:

Path 1-1 = 8134	lbf, must exceed W = 457 lbf	or W1 = 1658 lbf
Path 2-2 = 15487	lbf, must exceed W = 457 lbf	or W2 = 2642 lbf
Path 3-3 = 15487	lbf, must exceed W = 457 lbf	or W3 = 2642 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 183 psig

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0265 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 6.3415 in

Input Echo, WRC107/537 Item 1, Description: Nozzle B2 2" :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Spherical	
Internal Corrosion Allowance	Cas	0.0315	in
Vessel Diameter	Dv	52.650	in
Vessel Thickness	Tv	0.315	in
Design Temperature	T1	500.0	F
Vessel Material		SA-240 316L	
Vessel UNS Number		S31603	
Vessel Cold S.I. Allowable	Smc	16700.00	psi
Vessel Hot S.I. Allowable	Smh	14800.00	psi
Attachment Type	Type	Round	
WRC107 Attachment Classification	Holsol	Hollow	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	0.0315	in
Nozzle Diameter	Dn	2.375	in
Nozzle Thickness	Tn	0.191	in
Nozzle Material		SA-312 TP316L	
Nozzle UNS Number		S31603	
Nozzle Cold S.I. Allowable	SNmc	16700.00	psi
Nozzle Hot S.I. Allowable	SNmh	10900.00	psi
Design Internal Pressure	Dp	151.619	psig
Include Pressure Thrust		No	

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B2 2" Nozl: 27 4:21pm Dec 21, 2022


External Forces and Moments in WRC 107/537 Convention:

Radial Load	(SUS)	P	-630.0	lbf
Longitudinal Shear	(SUS)	(Vl) V1	630.0	lbf
Circumferential Shear	(SUS)	(Vc) V2	470.0	lbf
Circumferential Moment	(SUS)	(Mc) M1	210.0	ft-lbf
Longitudinal Moment	(SUS)	(Ml) M2	270.0	ft-lbf
Torsional Moment	(SUS)	Mt	310.0	ft-lbf

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".



WRC 107/537 has dimensional limitations that can be found in the bulletin's Foreword and which can also be inferred by review of the non-dimensional curve limits.

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$\begin{aligned}
 &= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(t - ca)) \\
 &= 2.375 + 2 * 1.65 * \text{sqrt}(26.498 (0.315 - 0.031)) \\
 &= 11.419 \text{ in}
 \end{aligned}$$

WRC 107 Stress Calculation for SUSstained loads:

Radial Load	P	-630.0	lbf
Circumferential Shear	(VC) V2	470.0	lbf
Longitudinal Shear	(VL) V1	630.0	lbf
Circumferential Moment	(MC) M1	210.0	ft-lbf
Longitudinal Moment	(ML) M2	270.0	ft-lbf
Torsional Moment	MT	310.0	ft-lbf

Dimensionless Parameters: U = 0.43 TAU = 6.96 RHO = 1.78

Dimensionless Loads for Spherical Shells at Attachment Junction:

Curves read for 1979	Figure	Value	Location
N(x) * T / P	SP 2	0.07982	(A,B,C,D)
M(x) / P	SP 2	0.06844	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / MC	SM 2	0.18588	(A,B,C,D)
M(x) * SQRT(Rm * T) / MC	SM 2	0.18317	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / ML	SM 2	0.18588	(A,B,C,D)
M(x) * SQRT(Rm * T) / ML	SM 2	0.18317	(A,B,C,D)
N(y) * T / P	SP 2	0.20039	(A,B,C,D)
M(y) / P	SP 2	0.05294	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / MC	SM 2	0.14008	(A,B,C,D)
M(y) * SQRT(Rm * T) / MC	SM 2	0.19369	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / ML	SM 2	0.14008	(A,B,C,D)

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B2 2" Nozl: 27 4:21pm Dec 21, 2022

M(y) * SQRT(Rm * T) / ML SM 2 0.19369 (A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (psi)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Rad. Memb. P		625	625	625	625	625	625	625	625
Rad. Bend. P		3219	-3219	3219	-3219	3219	-3219	3219	-3219
Rad. Memb. MC		0	0	0	0	-2127	-2127	2127	2127
Rad. Bend. MC		0	0	0	0	-12576	12576	12576	-12576
Rad. Memb. ML		-2734	-2734	2734	2734	0	0	0	0
Rad. Bend. ML		-16169	16169	16169	-16169	0	0	0	0
Tot. Rad. Str.		-15059	10841	22750	-16028	-10858	7855	18549	-13043
Tang. Memb. P		1571	1571	1571	1571	1571	1571	1571	1571
Tang. Bend. P		2490	-2490	2490	-2490	2490	-2490	2490	-2490
Tang. Memb. MC		0	0	0	0	-1602	-1602	1602	1602
Tang. Bend. MC		0	0	0	0	-13298	13298	13298	-13298
Tang. Memb. ML		-2060	-2060	2060	2060	0	0	0	0
Tang. Bend. ML		-17098	17098	17098	-17098	0	0	0	0
Tot. Tang. Str.		-15097	14118	23220	-15956	-10840	10776	18963	-12615
Shear VC		444	444	-444	-444	0	0	0	0
Shear VL		0	0	0	0	-595	-595	595	595
Shear MT		1481	1481	1481	1481	1481	1481	1481	1481
Tot. Shear		1925	1925	1036	1036	885	885	2076	2076
Str. Int.		17004	15007	24048	17030	11734	11023	20843	14916

WRC 107/537 Stress Summations:**Vessel Stress Summation at Attachment Junction (psi)**

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Rad. Pm (SUS)		7049	7049	7049	7049	7049	7049	7049	7049
Rad. Pl (SUS)		-2108	-2108	3360	3360	-1501	-1501	2752	2752
Rad. Q (SUS)		-12950	12950	19389	-19389	-9356	9356	15796	-15796
Long. Pm (SUS)		7049	7049	7049	7049	7049	7049	7049	7049
Long. Pl (SUS)		-489	-489	3632	3632	-31	-31	3174	3174
Long. Q (SUS)		-14607	14607	19588	-19588	-10808	10808	15789	-15789
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		444	444	-444	-444	-595	-595	595	595
Shear Q (SUS)		1481	1481	1481	1481	1481	1481	1481	1481
Pm (SUS)		7049	7049	7049	7049	7049	7049	7049	7049
Pm+Pl (SUS)		6673	6673	11010	11010	7228	7228	10644	10644

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B2 2" Nozl: 27 4:21pm Dec 21,2022

Pm+Pl+Q (Total)		9954		22057		31097		9980		4685		18073		27892		7867	
-----------------	--	------	--	-------	--	-------	--	------	--	------	--	-------	--	-------	--	------	--

Vessel Stress Summation Comparison (psi):

Type of Stress Int.		Max. S.I.	S.I. Allowable		Result	

Pm (SUS)		7049	14800		Passed	
Pm+Pl (SUS)		11010	22200		Passed	
Pm+Pl+Q (TOTAL)		31097	44400		Passed	

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle LT2 2"**From: 50**

Pressure for Reinforcement Calculations	P	151.073	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F
Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi
Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in
Distance from Bottom/Left Tangent		0.66	ft
User Entered Minimum Design Metal Temperature		32.00	°F

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi
Diameter Basis (for tr calc only)		Inside	
Layout Angle		330.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in
Flange Type		Long Weld Neck	
Corrosion Allowance	can	0.0000	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	7.1050	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in
Flange Class		300	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle LT2 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 151.07 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 151.07)$$

$$= 0.1505 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.0 \left(\exp \left(\frac{151.07}{10900.0 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0140 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	4.0370 in
Parallel to Vessel Wall	Rn+tn+t	2.0185 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.353	0.208	NA
Area in Shell	A1	0.358	0.313	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21, 2022

Area in Nozzle Wall	A2	0.857	0.855	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.307	1.261	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.0 * 0.1505 * 1.0 + 2 * 0.6563 * 0.1505 * 1.0 * (1 - 0.74))$$

$$= 0.353 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.037 (1.0 * 0.3622 - 1.0 * 0.151) - 2 * 0.656$$

$$(1.0 * 0.3622 - 1.0 * 0.1505) * (1 - 0.736)$$

$$= 0.358 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.6563 - 0.014) 0.7365$$

$$= 0.857 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.3543^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0151 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1820 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1820 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.1890 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.189, \max(0.182, 0.094)]$$

$$= 0.1820 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0151, 0.182)$$

$$= 0.1820 \text{ in}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained :	1298.1,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33201.9 psi	Passed
Occasional :	86.7,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21,2022

Shear : 1283.3, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 151.07/600.00 = 0.252

Weld Size Calculations, Description: Nozzle LT2 2"

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (0.3531 - 0.358 + 2 * 0.6563 * 0.7365 * \\
 &\quad (1.0 * 0.3622 - 0.1505)) * 14800) \\
 &= 2956.87 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - \text{Can} / .707)^2 * f_{r2}) * S_v \\
 &= (0.8568 + 0.0 + 0.0925 - 0.0 * 0.74) * 14800 \\
 &= 14048.45 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.8568 + 0.0 + 0.0925 + (0.3501)) * 14800 \\
 &= 19230.63 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.8568 + 0.0 + 0.0925 + 0.0 + (0.3501)) * 14800 \\
 &= 19230.63 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 3.3126 * 0.3543 * 0.49 * 10900 \\
 &= 9847. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - \text{Can}) * 0.7 * S_n \\
 &= (3.1416 * 1.3281) * (0.6563 - 0.0) * 0.7 * 10900 \\
 &= 20894. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9847 + 20894) = 30741 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9847 + 0 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9847 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 30741	lbf, must exceed W = 2956 lbf	or W1 = 14048 lbf
Path 2-2 = 30488	lbf, must exceed W = 2956 lbf	or W2 = 19230 lbf
Path 3-3 = 30488	lbf, must exceed W = 2956 lbf	or W3 = 19230 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5928 in

Input Echo, WRC297 Item 1, Description: Nozzle LT2 2" :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0000	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21,2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	151.07	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.656 in
T / t	=	0.552
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.106
Mr/P	=	0.218
M0/P	=	0.065
N0/P	=	0.132
MrD/Mc	=	0.304
NrDL/Mc	=	0.097
M0d/Mc	=	0.097
N0DL/Mc	=	0.031
MrD/Ml	=	0.195
NrDL/Ml	=	0.090
M0D/Ml	=	0.064
N0DL/Ml	=	0.120

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-891	-891	891	891
Outplane Bending (ML)	-2871	2871	2871	-2871
Normal Pressure Stress	6038	6189	6038	6189

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21, 2022

Outplane Stress Summary	4787	6926	12311	2966
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	B1
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-669	-669	669	669
Inplane Bending (ML)	-8720	8720	8720	-8720
Inplane Pressure Stress	3019	3019	3019	3019

Inplane Stress Summary	433	5287	19211	-10815

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	B1
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	B1
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4944	7282	19228	13798

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	D1
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	-181	-181	181	181
Outplane Bending (Mc)	-3389	3389	3389	-3389
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	3019	3019	3019	3019

Outplane Stress Summary	1960	4984	9100	-1432

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	D1
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	-562	-562	562	562
Inplane Bending (Mc)	-10562	10562	10562	-10562
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21,2022

Inplane Pressure Stress	6038	6189	6038	6189
Inplane Stress Summary	1717	10406	23965	-9594

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside
Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595
Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside
Two * Max Shear Stress	2126	10418	24022	9698

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside
Hoop Membrane (P)	634	634	634	634
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-891	-891	891	891
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	207	389	207	389
Hoop Stress Summary	-50	132	1732	1914

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside
Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1047	-1047	1047	1047
Axial Bending (ML)	-2044	2044	2044	-2044
Axial Pressure Stress	103	103	103	103
Axial Stress Summary	-1423	-235	4759	-2229

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside
Shear due to (Vc)	137	137	-137	-137
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	328	328	328	328
Shear Stress Summary	465	465	191	191

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

```

Nozzle Calcs.: Nozzle LT2 2"          Nozl: 28    4:21pm  Dec 21, 2022

```

LONGITUDINAL PLANE (Stress Intensities	Au Outside	Al Inside	Bu Outside	Bl Inside
Two * Max Shear Stress	1658	999	4771	4160

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			634	634	634	634
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-181	-181	181	181
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			207	389	207	389
Hoop Stress Summary			660	842	1022	1204

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	-814	-814	814	814
Axial Bending (Mc)	-2703	2703	2703	-2703
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	103	103	103	103
Axial Stress Summary	-1849	657	5185	-3121

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-184	-184	184	184
Shear due to Torsion	328	328	328	328
Shear Stress Summary	144	144	512	512

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2525	920	5247	4444

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
------------------------------------	----	----	----	----	----	----	----	----

Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264 R06

Nozzle Calcs.: Nozzle LT2 2"

Noz1: 28 4:21pm Dec 21, 2022

Circ. Pm (SUS)		6038	6189	6038	6189	6038	6189	6038	6189
Circ. Pl (SUS)		-257	-257	1525	1525	-52	-52	1072	1072
Circ. Q (SUS)		-994	994	4748	-4748	-4269	4269	16855	-16855
Long. Pm (SUS)		3019	3019	3019	3019	3019	3019	3019	3019
Long. Pl (SUS)		-159	-159	1179	1179	453	453	815	815
Long. Q (SUS)		-2427	2427	15013	-15013	-1512	1512	5266	-5266
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		249	249	-249	-249	-334	-334	334	334
Shear Q (SUS)		595	595	595	595	595	595	595	595
Pm (SUS)		6038	6189	6038	6189	6038	6189	6038	6189
Pm+Pl (SUS)		5802	5952	7581	7731	6029	6178	7143	7293
Pm+Pl+Q (Total)		4944	7282	19228	13798	2126	10418	24022	9698

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	6189	14800	Passed
Pm+Pl (SUS)	7731	22200	Passed
Pm+Pl+Q (TOTAL)	24022	44400	Passed

*Because only sustained loads were specified, the Pm+Pl+Q allowable was $3 * S_{mh}$.*

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:

Nozzle Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Stress Values at							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)	207	389	207	389	207	389	207	389
Circ. Pl (SUS)	-257	-257	1525	1525	453	453	815	815
Circ. Q (SUS)	0	0	0	0	0	0	0	0
Long. Pm (SUS)	103	103	103	103	103	103	103	103
Long. Pl (SUS)	-932	-932	1162	1162	-699	-699	929	929
Long. Q (SUS)	-594	594	3494	-3494	-1253	1253	4153	-4153
Shear Pm (SUS)	0	0	0	0	0	0	0	0
Shear Pl (SUS)	137	137	-137	-137	-184	-184	184	184
Shear Q (SUS)	328	328	328	328	328	328	328	328
Pm (SUS)	207	389	207	389	207	389	207	389
Pm+Pl (SUS)	852	999	1769	1941	1308	1484	1211	1321
Pm+Pl+Q (Total)	1658	999	4771	4160	2525	920	5247	4444

Nozzle Stress Summation Comparison (psi):

Type of		Max. S.I.	S.I. Allowable		Result
Stress Int.					

18-D-272
R06
V-1264
PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.
FileName : V-1264_R06 -----
Nozzle Calcs.: Nozzle LT2 2" Nozl: 28 4:21pm Dec 21,2022

Pm (SUS)		389	10900		Passed	
Pm+Pl (SUS)		1941	16350		Passed	
Pm+Pl+Q (TOTAL)		5247	32700		Passed	

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21, 2022

Input, Nozzle Desc: Nozzle L2 2"**From: 50**

Pressure for Reinforcement Calculations	P	151.073	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F

Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi

Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in

Distance from Bottom/Left Tangent		0.66	ft
-----------------------------------	--	------	----

User Entered Minimum Design Metal Temperature		32.00	°F
---	--	-------	----

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi

Diameter Basis (for tr calc only)		Inside	
Layout Angle		225.00	deg
Diameter		2.0000	in.

Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in

Flange Type		Long Weld Neck	
-------------	--	----------------	--

Corrosion Allowance	can	0.0000	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	

Outside Projection	ho	7.1050	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3540	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in

Flange Class		600	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle L2 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 151.07 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 151.07)$$

$$= 0.1505 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.0 \left(\exp \left(\frac{151.07}{10900.0 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0140 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	4.0370 in
Parallel to Vessel Wall	Rn+tn+t	2.0185 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.353	0.208	NA
Area in Shell	A1	0.358	0.313	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21, 2022

Area in Nozzle Wall	A2	0.857	0.855	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.307	1.261	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.**Area Required [A]:**

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.0 * 0.1505 * 1.0 + 2 * 0.6563 * 0.1505 * 1.0 * (1 - 0.74))$$

$$= 0.353 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1**Area Available in Shell [A1]:**

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.037 (1.0 * 0.3622 - 1.0 * 0.151) - 2 * 0.656$$

$$(1.0 * 0.3622 - 1.0 * 0.1505) * (1 - 0.736)$$

$$= 0.358 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.6563 - 0.014) 0.7365$$

$$= 0.857 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.354^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0151 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1820 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1820 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.1890 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.189, \max(0.182, 0.094)]$$

$$= 0.1820 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0151, 0.182)$$

$$= 0.1820 \text{ in}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME**B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained :	1298.1,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33201.9 psi	Passed
Occasional :	86.7,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21,2022

Shear : 1283.3, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 151.07/1200.00 = 0.126

Weld Size Calculations, Description: Nozzle L2 2"

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2503 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * tn * fr1 * (E1 * t - tr)) * Sv)$$

$$= \max(0, (0.3531 - 0.358 + 2 * 0.6563 * 0.7365 * (1.0 * 0.3622 - 0.1505)) * 14800)$$

$$= 2956.87 \text{ lbf}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (Wi - Can / .707)^2 * fr2) * Sv$$

$$= (0.8568 + 0.0 + 0.0923 - 0.0 * 0.74) * 14800$$

$$= 14045.90 \text{ lbf}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (0.8568 + 0.0 + 0.0923 + (0.3501)) * 14800$$

$$= 19228.08 \text{ lbf}$$

Weld Load [W3]:

$$= (A2 + A3 + A4 + A5 + (2 * tn * t * fr1)) * S$$

$$= (0.8568 + 0.0 + 0.0923 + 0.0 + (0.3501)) * 14800$$

$$= 19228.08 \text{ lbf}$$
Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi / 2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.1416 / 2.0) * 3.3126 * 0.354 * 0.49 * 10900$$

$$= 9838. \text{ lbf}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.1416 * 1.3281) * (0.6563 - 0.0) * 0.7 * 10900$$

$$= 20894. \text{ lbf}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (T - c_{as}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9838 + 20894) = 30732 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9838 + 0 + 20641 + 0) = 30479 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9838 + 20641 + 0) = 30479 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 30732	lbf, must exceed W = 2956 lbf	or W1 = 14045 lbf
Path 2-2 = 30479	lbf, must exceed W = 2956 lbf	or W2 = 19228 lbf
Path 3-3 = 30479	lbf, must exceed W = 2956 lbf	or W3 = 19228 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5928 in

Input Echo, WRC297 Item 1, Description: Nozzle L2 2" :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0000	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21,2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	151.07	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.656 in
T / t	=	0.552
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.106
Mr/P	=	0.218
M0/P	=	0.065
N0/P	=	0.132
MrD/Mc	=	0.304
NrDL/Mc	=	0.097
M0d/Mc	=	0.097
N0DL/Mc	=	0.031
MrD/Ml	=	0.195
NrDL/Ml	=	0.090
M0D/Ml	=	0.064
N0DL/Ml	=	0.120

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
-----	-----	-----	-----	-----
Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-891	-891	891	891
Outplane Bending (ML)	-2871	2871	2871	-2871
Normal Pressure Stress	6038	6189	6038	6189
-----	-----	-----	-----	-----

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21, 2022

Outplane Stress Summary	4787	6926	12311	2966
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-669	-669	669	669
Inplane Bending (ML)	-8720	8720	8720	-8720
Inplane Pressure Stress	3019	3019	3019	3019

Inplane Stress Summary	433	5287	19211	-10815

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4944	7282	19228	13798

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	-181	-181	181	181
Outplane Bending (Mc)	-3389	3389	3389	-3389
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	3019	3019	3019	3019

Outplane Stress Summary	1960	4984	9100	-1432

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	-562	-562	562	562
Inplane Bending (Mc)	-10562	10562	10562	-10562
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21, 2022

Inplane Pressure Stress	6038	6189	6038	6189

Inplane Stress Summary	1717	10406	23965	-9594

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595

Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	2126	10418	24022	9698

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	634	634	634	634
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-891	-891	891	891
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	207	389	207	389

Hoop Stress Summary	-50	132	1732	1914

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1047	-1047	1047	1047
Axial Bending (ML)	-2044	2044	2044	-2044
Axial Pressure Stress	103	103	103	103

Axial Stress Summary	-1423	-235	4759	-2229

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

Shear due to (Vc)	137	137	-137	-137
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	328	328	328	328

Shear Stress Summary	465	465	191	191

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21, 2022

LONGITUDINAL PLANE (Stress Intensities	Au Outside	Al Inside	Bu Outside	Bl Inside
Two * Max Shear Stress	1658	999	4771	4160

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			634	634	634	634
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-181	-181	181	181
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			207	389	207	389
Hoop Stress Summary			660	842	1022	1204

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	-814	-814	814	814
Axial Bending (Mc)	-2703	2703	2703	-2703
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	103	103	103	103
Axial Stress Summary	-1849	657	5185	-3121

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-184	-184	184	184
Shear due to Torsion	328	328	328	328
Shear Stress Summary	144	144	512	512

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2525	920	5247	4444

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
------------------------------------	----	----	----	----	----	----	----	----

PV Elite 24

Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264 R06

```

Nozzle Calcs.: Nozzle L2 2"          Nozl:      29      4:21pm  Dec 21, 2022

```

Vessel Stress Summation Comparison (psi):

*Because only sustained loads were specified, the Pm+Pl+Q allowable was $3 * S_{mh}$.*

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:

Nozzle Stress Summation at Vessel-Nozzle Junction (psi):

Nozzle Stress Summation Comparison (psi):

Type of		Max. S.I.	S.I. Allowable		Result
Stress Int.					

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L2 2" Nozl: 29 4:21pm Dec 21,2022

Pm (SUS)		389	10900		Passed	
Pm+Pl (SUS)		1941	16350		Passed	
Pm+Pl+Q (TOTAL)		5247	32700		Passed	

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21, 2022

Input, Nozzle Desc: Nozzle S 2"**From: 50**

Pressure for Reinforcement Calculations	P	151.073	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F
Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi
Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in
Distance from Bottom/Left Tangent		0.66	ft
User Entered Minimum Design Metal Temperature		32.00	°F

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi
Diameter Basis (for tr calc only)		Inside	
Layout Angle		270.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in
Flange Type		Long Weld Neck	
Corrosion Allowance	can	0.0000	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	7.1078	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in
Flange Class		600	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle S 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 151.07 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 151.07)$$

$$= 0.1505 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.0 \left(\exp \left(\frac{151.07}{10900.0 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0140 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	4.0370 in
Parallel to Vessel Wall	Rn+tn+t	2.0185 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.353	0.208	NA
Area in Shell	A1	0.358	0.313	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21, 2022

Area in Nozzle Wall	A2	0.857	0.855	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.307	1.261	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.0 * 0.1505 * 1.0 + 2 * 0.6563 * 0.1505 * 1.0 * (1 - 0.74))$$

$$= 0.353 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.037 (1.0 * 0.3622 - 1.0 * 0.151) - 2 * 0.656$$

$$(1.0 * 0.3622 - 1.0 * 0.1505) * (1 - 0.736)$$

$$= 0.358 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.6563 - 0.014) 0.7365$$

$$= 0.857 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.3543^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0151 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1820 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1820 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.1890 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.189, \max(0.182, 0.094)]$$

$$= 0.1820 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0151, 0.182)$$

$$= 0.1820 \text{ in}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained :	1298.1,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33201.9 psi	Passed
Occasional :	86.7,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21,2022

Shear : 1283.3, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 151.07/1200.00 = 0.126

Weld Size Calculations, Description: Nozzle S 2"

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (0.3531 - 0.358 + 2 * 0.6563 * 0.7365 * \\
 &\quad (1.0 * 0.3622 - 0.1505)) * 14800) \\
 &= 2956.87 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - \text{Can} / .707)^2 * f_{r2}) * S_v \\
 &= (0.8568 + 0.0 + 0.0925 - 0.0 * 0.74) * 14800 \\
 &= 14048.45 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.8568 + 0.0 + 0.0925 + (0.3501)) * 14800 \\
 &= 19230.63 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.8568 + 0.0 + 0.0925 + 0.0 + (0.3501)) * 14800 \\
 &= 19230.63 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 3.3126 * 0.3543 * 0.49 * 10900 \\
 &= 9847. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - \text{Can}) * 0.7 * S_n \\
 &= (3.1416 * 1.3281) * (0.6563 - 0.0) * 0.7 * 10900 \\
 &= 20894. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9847 + 20894) = 30741 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9847 + 0 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9847 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 30741	lbf, must exceed W = 2956 lbf	or W1 = 14048 lbf
Path 2-2 = 30488	lbf, must exceed W = 2956 lbf	or W2 = 19230 lbf
Path 3-3 = 30488	lbf, must exceed W = 2956 lbf	or W3 = 19230 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5956 in

Input Echo, WRC297 Item 1, Description: Nozzle S 2" :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0000	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21,2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	151.07	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.656 in
T / t	=	0.552
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.106
Mr/P	=	0.218
M0/P	=	0.065
N0/P	=	0.132
MrD/Mc	=	0.304
NrDL/Mc	=	0.097
M0d/Mc	=	0.097
N0DL/Mc	=	0.031
MrD/Ml	=	0.195
NrDL/Ml	=	0.090
M0D/Ml	=	0.064
N0DL/Ml	=	0.120

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
-----	-----	-----	-----	-----
Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-891	-891	891	891
Outplane Bending (ML)	-2871	2871	2871	-2871
Normal Pressure Stress	6038	6189	6038	6189
-----	-----	-----	-----	-----

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21, 2022

Outplane Stress Summary	4787	6926	12311	2966
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-669	-669	669	669
Inplane Bending (ML)	-8720	8720	8720	-8720
Inplane Pressure Stress	3019	3019	3019	3019

Inplane Stress Summary	433	5287	19211	-10815

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4944	7282	19228	13798

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	-181	-181	181	181
Outplane Bending (Mc)	-3389	3389	3389	-3389
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	3019	3019	3019	3019

Outplane Stress Summary	1960	4984	9100	-1432

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	-562	-562	562	562
Inplane Bending (Mc)	-10562	10562	10562	-10562
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21, 2022

Inplane Pressure Stress	6038	6189	6038	6189

Inplane Stress Summary	1717	10406	23965	-9594

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595

Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	2126	10418	24022	9698

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	634	634	634	634
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-891	-891	891	891
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	207	389	207	389

Hoop Stress Summary	-50	132	1732	1914

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1047	-1047	1047	1047
Axial Bending (ML)	-2044	2044	2044	-2044
Axial Pressure Stress	103	103	103	103

Axial Stress Summary	-1423	-235	4759	-2229

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

Shear due to (Vc)	137	137	-137	-137
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	328	328	328	328

Shear Stress Summary	465	465	191	191

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21, 2022

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Outside	Inside	Outside	Inside
Two * Max Shear Stress	1658	999	4771	4160

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			634	634	634	634
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-181	-181	181	181
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			207	389	207	389
Hoop Stress Summary			660	842	1022	1204

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	-814	-814	814	814
Axial Bending (Mc)	-2703	2703	2703	-2703
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	103	103	103	103
Axial Stress Summary	-1849	657	5185	-3121

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-184	-184	184	184
Shear due to Torsion	328	328	328	328
Shear Stress Summary	144	144	512	512

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2525	920	5247	4444

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of	Stress Values at							
Stress Int.								
Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264 R06 -----

```

Nozzle Calcs.: Nozzle S 2"          Nozl: 30    4:21pm  Dec 21,2022

```

Vessel Stress Summation Comparison (psi):

*Because only sustained loads were specified, the P_m+P_l+Q allowable was $3 * S_mh$.*

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:

Nozzle Stress Summation at Vessel-Nozzle Junction (psi):

Nozzle Stress Summation Comparison (psi):

Type of		Max. S.I.	S.I. Allowable		Result
Stress Int.					

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264 R06 -----

Nozzle Calcs.: Nozzle S 2" Nozl: 30 4:21pm Dec 21, 2022

Pm (SUS)		389	10900		Passed
Pm+Pl (SUS)		1941	16350		Passed
Pm+Pl+Q (TOTAL)		5247	32700		Passed

Pm+Pl (SUS)		1941	16350		Passed
-------------	--	------	-------	--	--------

Pm+Pl+Q (TOTAL)	5247	32700		Passed
-----------------	------	-------	--	--------

*Because only sustained loads were specified, the P_m+P_l+Q allowable was $3 * S_mh$.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle LT1 2"**From: 50**

Pressure for Reinforcement Calculations	P	150.000	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F
Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi
Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in
Distance from Bottom/Left Tangent		4.16	ft
User Entered Minimum Design Metal Temperature		32.00	°F

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi
Diameter Basis (for tr calc only)		Inside	
Layout Angle		330.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in
Flange Type		Long Weld Neck	
Corrosion Allowance	can	0.0000	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	7.1050	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in
Flange Class		300	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle LT1 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 150.0 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 150.0)$$

$$= 0.1495 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.0 \left(\exp \left(\frac{150.0}{10900 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0139 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	4.0370 in
Parallel to Vessel Wall	Rn+tn+t	2.0185 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.351	0.208	NA
Area in Shell	A1	0.360	0.313	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21,2022

Area in Nozzle Wall	A2	0.857	0.855	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.309	1.261	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.0 * 0.1495 * 1.0 + 2 * 0.6563 * 0.1495 * 1.0 * (1 - 0.74))$$

$$= 0.351 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.037 (1.0 * 0.3622 - 1.0 * 0.149) - 2 * 0.656$$

$$(1.0 * 0.3622 - 1.0 * 0.1495) * (1 - 0.736)$$

$$= 0.360 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.6563 - 0.0139) 0.7365$$

$$= 0.857 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.3543^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0151 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1810 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1810 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.1890 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.189, \max(0.181, 0.094)]$$

$$= 0.1810 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0151, 0.181)$$

$$= 0.1810 \text{ in}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained :	1297.4,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33202.6 psi	Passed
Occasional :	86.0,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21,2022

Shear : 1283.3, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 150.00/600.00 = 0.250

Weld Size Calculations, Description: Nozzle LT1 2"

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v)$$

$$= \max(0, (0.3506 - 0.3598 + 2 * 0.6563 * 0.7365 * (1.0 * 0.3622 - 0.1495)) * 14800)$$

$$= 2907.97 \text{ lbf}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v$$

$$= (0.8569 + 0.0 + 0.0925 - 0.0 * 0.74) * 14800$$

$$= 14050.42 \text{ lbf}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (0.8569 + 0.0 + 0.0925 + (0.3501)) * 14800$$

$$= 19232.60 \text{ lbf}$$

Weld Load [W3]:

$$= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S$$

$$= (0.8569 + 0.0 + 0.0925 + 0.0 + (0.3501)) * 14800$$

$$= 19232.60 \text{ lbf}$$
Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416 / 2.0) * 3.3126 * 0.3543 * 0.49 * 10900$$

$$= 9847. \text{ lbf}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n$$

$$= (3.1416 * 1.3281) * (0.6563 - 0.0) * 0.7 * 10900$$

$$= 20894. \text{ lbf}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9847 + 20894) = 30741 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9847 + 0 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9847 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 30741	lbf, must exceed W = 2907 lbf	or W1 = 14050 lbf
Path 2-2 = 30488	lbf, must exceed W = 2907 lbf	or W2 = 19232 lbf
Path 3-3 = 30488	lbf, must exceed W = 2907 lbf	or W3 = 19232 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5928 in

Input Echo, WRC297 Item 1, Description: Nozzle LT1 2" :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0000	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21,2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	150.00	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.656 in
T / t	=	0.552
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.106
Mr/P	=	0.218
M0/P	=	0.065
N0/P	=	0.132
MrD/Mc	=	0.304
NrDL/Mc	=	0.097
M0d/Mc	=	0.097
N0DL/Mc	=	0.031
MrD/Ml	=	0.195
NrDL/Ml	=	0.090
M0D/Ml	=	0.064
N0DL/Ml	=	0.120

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-891	-891	891	891
Outplane Bending (ML)	-2871	2871	2871	-2871
Normal Pressure Stress	5995	6145	5995	6145

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21, 2022

Outplane Stress Summary	4744	6882	12268	2922
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-669	-669	669	669
Inplane Bending (ML)	-8720	8720	8720	-8720
Inplane Pressure Stress	2997	2997	2997	2997

Inplane Stress Summary	411	5265	19189	-10837

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4902	7242	19206	13776

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	-181	-181	181	181
Outplane Bending (Mc)	-3389	3389	3389	-3389
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	2997	2997	2997	2997

Outplane Stress Summary	1938	4962	9078	-1454

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	-562	-562	562	562
Inplane Bending (Mc)	-10562	10562	10562	-10562
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21,2022

Inplane Pressure Stress	5995	6145	5995	6145

Inplane Stress Summary	1674	10362	23922	-9638

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595

Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	2098	10374	23979	9742

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	634	634	634	634
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-891	-891	891	891
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	206	386	206	386

Hoop Stress Summary	-51	129	1731	1911

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1047	-1047	1047	1047
Axial Bending (ML)	-2044	2044	2044	-2044
Axial Pressure Stress	103	103	103	103

Axial Stress Summary	-1423	-235	4759	-2229

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

Shear due to (Vc)	137	137	-137	-137
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	328	328	328	328

Shear Stress Summary	465	465	191	191

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

```
Nozzle Calcs.: Nozzle LT1 2"           Nozl: 31    4:21pm  Dec 21,2022
```

LONGITUDINAL PLANE (Stress Intensities	Au Outside	Al Inside	Bu Outside	Bl Inside
Two * Max Shear Stress	1657	998	4771	4157

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			634	634	634	634
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-181	-181	181	181
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			206	386	206	386
Hoop Stress Summary			659	839	1021	1201

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	-814	-814	814	814
Axial Bending (Mc)	-2703	2703	2703	-2703
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	103	103	103	103
Axial Stress Summary	-1849	657	5185	-3121

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-184	-184	184	184
Shear due to Torsion	328	328	328	328
Shear Stress Summary	144	144	512	512

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2524	918	5247	4441

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
------------------------------------	----	----	----	----	----	----	----	----

Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264 R06

```

Nozzle Calcs.: Nozzle LT1 2"           Nozl:    31    4:21pm  Dec 21,2022

```

Circ. Pm (SUS)		5995	6145	5995	6145	5995	6145	5995	6145
Circ. Pl (SUS)		-257	-257	1525	1525	-52	-52	1072	1072
Circ. Q (SUS)		-994	994	4748	-4748	-4269	4269	16855	-16855
Long. Pm (SUS)		2997	2997	2997	2997	2997	2997	2997	2997
Long. Pl (SUS)		-159	-159	1179	1179	453	453	815	815
Long. Q (SUS)		-2427	2427	15013	-15013	-1512	1512	5266	-5266
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		249	249	-249	-249	-334	-334	334	334
Shear Q (SUS)		595	595	595	595	595	595	595	595
Pm (SUS)		5995	6145	5995	6145	5995	6145	5995	6145
Pm+Pl (SUS)		5759	5908	7538	7687	5986	6134	7100	7249
Pm+Pl+Q (Total)		4902	7242	19206	13776	2098	10374	23979	9742

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	6145	14800	Passed
Pm+Pl (SUS)	7687	22200	Passed
Pm+Pl+Q (TOTAL)	23979	44400	Passed

*Because only sustained loads were specified, the Pm+Pl+Q allowable was $3 * S_{mh}$.*

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:

Nozzle Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Stress Values at							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)	206	386	206	386	206	386	206	386
Circ. Pl (SUS)	-257	-257	1525	1525	453	453	815	815
Circ. Q (SUS)	0	0	0	0	0	0	0	0
Long. Pm (SUS)	103	103	103	103	103	103	103	103
Long. Pl (SUS)	-932	-932	1162	1162	-699	-699	929	929
Long. Q (SUS)	-594	594	3494	-3494	-1253	1253	4153	-4153
Shear Pm (SUS)	0	0	0	0	0	0	0	0
Shear Pl (SUS)	137	137	-137	-137	-184	-184	184	184
Shear Q (SUS)	328	328	328	328	328	328	328	328
Pm (SUS)	206	386	206	386	206	386	206	386
Pm+Pl (SUS)	852	996	1768	1938	1307	1481	1210	1318
Pm+Pl+Q (Total)	1657	998	4771	4157	2524	918	5247	4441

Nozzle Stress Summation Comparison (psi):

Type of		Max. S.I.	S.I. Allowable		Result
Stress Int.					

18-D-272
R06
V-1264
PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.
FileName : V-1264_R06 -----
Nozzle Calcs.: Nozzle LT1 2" Nozl: 31 4:21pm Dec 21,2022

Pm (SUS)		386	10900		Passed	
Pm+Pl (SUS)		1938	16350		Passed	
Pm+Pl+Q (TOTAL)		5247	32700		Passed	

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle L1 2"**From: 50**

Pressure for Reinforcement Calculations	P	150.000	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F

Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi

Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in

Distance from Bottom/Left Tangent		4.16	ft
-----------------------------------	--	------	----

User Entered Minimum Design Metal Temperature		32.00	°F
---	--	-------	----

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi

Diameter Basis (for tr calc only)		Inside	
Layout Angle		225.00	deg
Diameter		2.0000	in.

Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in

Flange Type		Long Weld Neck	
-------------	--	----------------	--

Corrosion Allowance	can	0.0000	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	

Outside Projection	ho	7.1050	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in

Flange Class		600	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle L1 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 150.0 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 150.0)$$

$$= 0.1495 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.0 \left(\exp \left(\frac{150.0}{10900.0 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0139 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	4.0370 in
Parallel to Vessel Wall	Rn+tn+t	2.0185 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.351	0.208	NA
Area in Shell	A1	0.360	0.313	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21, 2022

Area in Nozzle Wall	A2	0.857	0.855	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.309	1.261	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.0 * 0.1495 * 1.0 + 2 * 0.6563 * 0.1495 * 1.0 * (1 - 0.74))$$

$$= 0.351 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.037 (1.0 * 0.3622 - 1.0 * 0.149) - 2 * 0.656$$

$$(1.0 * 0.3622 - 1.0 * 0.1495) * (1 - 0.736)$$

$$= 0.360 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.6563 - 0.0139) 0.7365$$

$$= 0.857 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.3543^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0151 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1810 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1810 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.1890 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.189, \max(0.181, 0.094)]$$

$$= 0.1810 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0151, 0.181)$$

$$= 0.1810 \text{ in}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained :	1297.4,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33202.6 psi	Passed
Occasional :	86.0,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21,2022

Shear : 1283.3, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 150.00/1200.00 = 0.125

Weld Size Calculations, Description: Nozzle L1 2"

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (0.3506 - 0.3598 + 2 * 0.6563 * 0.7365 * \\
 &\quad (1.0 * 0.3622 - 0.1495) * 14800) \\
 &= 2907.97 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v \\
 &= (0.8569 + 0.0 + 0.0925 - 0.0 * 0.74) * 14800 \\
 &= 14050.42 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.8569 + 0.0 + 0.0925 + (0.3501)) * 14800 \\
 &= 19232.60 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.8569 + 0.0 + 0.0925 + 0.0 + (0.3501)) * 14800 \\
 &= 19232.60 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 3.3126 * 0.3543 * 0.49 * 10900 \\
 &= 9847. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n \\
 &= (3.1416 * 1.3281) * (0.6563 - 0.0) * 0.7 * 10900 \\
 &= 20894. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9847 + 20894) = 30741 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9847 + 0 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9847 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 30741 lbf, must exceed W = 2907 lbf	or W1 = 14050 lbf
Path 2-2 = 30488 lbf, must exceed W = 2907 lbf	or W2 = 19232 lbf
Path 3-3 = 30488 lbf, must exceed W = 2907 lbf	or W3 = 19232 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5928 in

Input Echo, WRC297 Item 1, Description: Nozzle L1 2" :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0000	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21,2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	150.00	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.656 in
T / t	=	0.552
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.106
Mr/P	=	0.218
M0/P	=	0.065
N0/P	=	0.132
MrD/Mc	=	0.304
NrDL/Mc	=	0.097
M0d/Mc	=	0.097
N0DL/Mc	=	0.031
MrD/Ml	=	0.195
NrDL/Ml	=	0.090
M0D/Ml	=	0.064
N0DL/Ml	=	0.120

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-891	-891	891	891
Outplane Bending (ML)	-2871	2871	2871	-2871
Normal Pressure Stress	5995	6145	5995	6145

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21, 2022

Outplane Stress Summary	4744	6882	12268	2922
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-669	-669	669	669
Inplane Bending (ML)	-8720	8720	8720	-8720
Inplane Pressure Stress	2997	2997	2997	2997

Inplane Stress Summary	411	5265	19189	-10837

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4902	7242	19206	13776

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	-181	-181	181	181
Outplane Bending (Mc)	-3389	3389	3389	-3389
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	2997	2997	2997	2997

Outplane Stress Summary	1938	4962	9078	-1454

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	-562	-562	562	562
Inplane Bending (Mc)	-10562	10562	10562	-10562
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21, 2022

Inplane Pressure Stress	5995	6145	5995	6145

Inplane Stress Summary	1674	10362	23922	-9638

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595

Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	2098	10374	23979	9742

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	634	634	634	634
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-891	-891	891	891
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	206	386	206	386

Hoop Stress Summary	-51	129	1731	1911

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1047	-1047	1047	1047
Axial Bending (ML)	-2044	2044	2044	-2044
Axial Pressure Stress	103	103	103	103

Axial Stress Summary	-1423	-235	4759	-2229

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

Shear due to (Vc)	137	137	-137	-137
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	328	328	328	328

Shear Stress Summary	465	465	191	191

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

```
Nozzle Calcs.: Nozzle L1 2"           Nozl: 32    4:21pm  Dec 21,2022
```

LONGITUDINAL PLANE (Stress Intensities	Au Outside	Al Inside	Bu Outside	Bl Inside
Two * Max Shear Stress	1657	998	4771	4157

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			634	634	634	634
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-181	-181	181	181
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			206	386	206	386
Hoop Stress Summary			659	839	1021	1201

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	-814	-814	814	814
Axial Bending (Mc)	-2703	2703	2703	-2703
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	103	103	103	103
Axial Stress Summary	-1849	657	5185	-3121

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-184	-184	184	184
Shear due to Torsion	328	328	328	328
Shear Stress Summary	144	144	512	512

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2524	918	5247	4441

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
------------------------------------	----	----	----	----	----	----	----	----

V-1264

Licensee: THE ANUP ENGINEERING LIMITED.

Noz1: 32 4:21pm Dec 21, 2022

Vessel Stress Summation Comparison (psi):

*Because only sustained loads were specified, the P_m+P_l+Q allowable was $3 * S_mh$.*

Nozzle Stress Summation at Vessel-Nozzle Junction (psi):

Nozzle Stress Summation Comparison (psi):

Type of		Max. S.I.	S.I. Allowable		Result
Stress Int.					

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle L1 2" Nozl: 32 4:21pm Dec 21, 2022

Pm (SUS)	386	10900	Passed
Pm+Pl (SUS)	1938	16350	Passed
Pm+Pl+Q (TOTAL)	5247	32700	Passed

Pm+Pl (SUS)	1938	16350	Passed
-------------	------	-------	--------

Pm+Pl+Q (TOTAL)	5247	32700		Passed
-----------------	------	-------	--	--------

Because only sustained loads were specified, the P_m+P_l+Q allowable was $3 * S_mh$.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle B4 2"**From: 50**

Pressure for Reinforcement Calculations	P	150.000	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F
Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi
Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in
Distance from Bottom/Left Tangent		3.66	ft
User Entered Minimum Design Metal Temperature		32.00	°F

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi
Diameter Basis (for tr calc only)		Inside	
Layout Angle		300.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in
Flange Type		Long Weld Neck	
Corrosion Allowance	can	0.0315	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	7.1078	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in
Flange Class		600	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle B4 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 150.0 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 150.0)$$

$$= 0.1495 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.031 \left(\exp \left(\frac{150.0}{10900.0 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0143 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 4.1260 in
 Parallel to Vessel Wall, opening length d 2.0630 in
 Normal to Vessel Wall (Thickness Limit), no pad Tlnp 0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.358	0.212	NA
Area in Shell	A1	0.369	0.321	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21, 2022

Area in Nozzle Wall	A2	0.814	0.813	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.276	1.227	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$\begin{aligned}
 &= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)} \\
 &= (2.063 * 0.1495 * 1.0 + 2 * 0.6248 * 0.1495 * 1.0 * (1 - 0.74)) \\
 &= 0.358 \text{ in}^2
 \end{aligned}$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1) \\
 &= 2.063(1.0 * 0.3622 - 1.0 * 0.149) - 2 * 0.625 \\
 &\quad (1.0 * 0.3622 - 1.0 * 0.1495) * (1 - 0.736) \\
 &= 0.369 \text{ in}^2
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 * tlnp) (tn - trn) fr2 \\
 &= (2 * 0.906) (0.6248 - 0.0143) 0.7365 \\
 &= 0.814 \text{ in}^2
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2 \\
 &= 0.3543^2 * 0.7365 + (0.0)^2 * 0.7365 \\
 &= 0.092 \text{ in}^2
 \end{aligned}$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0466 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1810 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1810 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.2205 in

Determine Nozzle Thickness candidate [tb]:

$$\begin{aligned}
 &= \min[tb3, \max(tb1, tb2)] \\
 &= \min[0.22, \max(0.181, 0.094)] \\
 &= 0.1810 \text{ in}
 \end{aligned}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$\begin{aligned}
 &= \max(ta, tb) \\
 &= \max(0.0466, 0.181) \\
 &= 0.1810 \text{ in}
 \end{aligned}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained :	1329.5,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33170.5 psi	Passed
Occasional :	95.0,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21,2022

Shear : 1278.8, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 150.00/1200.00 = 0.125

Weld Size Calculations, Description: Nozzle B4 2"

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (0.3575 - 0.3688 + 2 * 0.6248 * 0.7365 * \\
 &\quad (1.0 * 0.3622 - 0.1495) * 14800) \\
 &= 2730.43 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (0.8143 + 0.0 + 0.0925 - 0.0 * 0.74) * 14800 \\
 &= 13420.07 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.8143 + 0.0 + 0.0925 + (0.3333)) * 14800 \\
 &= 18353.55 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.8143 + 0.0 + 0.0925 + 0.0 + (0.3333)) * 14800 \\
 &= 18353.55 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 3.3126 * 0.3543 * 0.49 * 10900 \\
 &= 9847. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 1.3439) * (0.6563 - 0.0315) * 0.7 * 10900 \\
 &= 20127. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9847 + 20127) = 29975 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9847 + 0 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9847 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 29974	lbf, must exceed W = 2730 lbf	or W1 = 13420 lbf
Path 2-2 = 30488	lbf, must exceed W = 2730 lbf	or W2 = 18353 lbf
Path 3-3 = 30488	lbf, must exceed W = 2730 lbf	or W3 = 18353 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5956 in

Input Echo, WRC297 Item 1, Description: Nozzle B4 2" :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0315	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21,2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	150.00	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.625 in
T / t	=	0.580
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.108
Mr/P	=	0.217
M0/P	=	0.065
N0/P	=	0.131
MrD/Mc	=	0.302
NrDL/Mc	=	0.100
M0d/Mc	=	0.098
N0DL/Mc	=	0.027
MrD/Ml	=	0.195
NrDL/Ml	=	0.091
M0D/Ml	=	0.065
N0DL/Ml	=	0.119

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
-----	-----	-----	-----	-----
Outplane Membrane (P)	630	630	630	630
Outplane Bending (P)	1876	-1876	1876	-1876
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-889	-889	889	889
Outplane Bending (ML)	-2899	2899	2899	-2899
Normal Pressure Stress	5995	6145	5995	6145
-----	-----	-----	-----	-----

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21, 2022

Outplane Stress Summary	4713	6909	12289	2889
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	516	516	516	516
Inplane Bending (P)	6238	-6238	6238	-6238
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-679	-679	679	679
Inplane Bending (ML)	-8728	8728	8728	-8728
Inplane Pressure Stress	2997	2997	2997	2997

Inplane Stress Summary	344	5324	19158	-10774

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4870	7274	19175	13680

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	630	630	630	630
Outplane Bending (P)	1876	-1876	1876	-1876
Outplane Membrane (Mc)	-156	-156	156	156
Outplane Bending (Mc)	-3411	3411	3411	-3411
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	2997	2997	2997	2997

Outplane Stress Summary	1936	5006	9070	-1504

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	516	516	516	516
Inplane Bending (P)	6238	-6238	6238	-6238
Inplane Membrane (Mc)	-579	-579	579	579
Inplane Bending (Mc)	-10510	10510	10510	-10510
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21, 2022

Inplane Pressure Stress	5995	6145	5995	6145

Inplane Stress Summary	1660	10354	23838	-9508

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595

Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	2093	10366	23896	9614

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	630	630	630	630
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-889	-889	889	889
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	228	408	228	408

Hoop Stress Summary	-31	149	1747	1927

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	119	119	119	119
Axial Bending (P)	1575	-1575	1575	-1575
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1068	-1068	1068	1068
Axial Bending (ML)	-2247	2247	2247	-2247
Axial Pressure Stress	114	114	114	114

Axial Stress Summary	-1507	-163	5123	-2521

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

Shear due to (Vc)	144	144	-144	-144
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	345	345	345	345

Shear Stress Summary	489	489	201	201

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21, 2022

LONGITUDINAL PLANE (Stress Intensities	Au Outside	Al Inside	Bu Outside	Bl Inside
Two * Max Shear Stress	1770	1026	5134	4466

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			630	630	630	630
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-156	-156	156	156
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			228	408	228	408
Hoop Stress Summary			702	882	1014	1194

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	119	119	119	119
Axial Bending (P)	1575	-1575	1575	-1575
Axial Membrane (Mc)	-831	-831	831	831
Axial Bending (Mc)	-2947	2947	2947	-2947
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	114	114	114	114
Axial Stress Summary	-1970	774	5586	-3458

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-193	-193	193	193
Shear due to Torsion	345	345	345	345
Shear Stress Summary	152	152	538	538

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2689	989	5648	4774

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
------------------------------------	----	----	----	----	----	----	----	----

Type of		Max. S.I.	S.I. Allowable		Result	
Stress Int.						

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B4 2" Nozl: 33 4:21pm Dec 21, 2022

Pm (SUS)	408	10900	Passed
Pm+Pl (SUS)	1958	16350	Passed
Pm+Pl+Q (TOTAL)	5648	32700	Passed

Pm+Pl (SUS)		1958	16350		Passed
-------------	--	------	-------	--	--------

Pm+Pl+Q (TOTAL)	5648	32700		Passed
-----------------	------	-------	--	--------

Because only sustained loads were specified, the P_m+P_l+Q allowable was $3 * S_mh$.

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21, 2022

Input, Nozzle Desc: Nozzle B3 2"**From: 50**

Pressure for Reinforcement Calculations	P	150.001	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F

Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi

Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in

Distance from Bottom/Left Tangent		3.16	ft
-----------------------------------	--	------	----

User Entered Minimum Design Metal Temperature		32.00	°F
---	--	-------	----

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi

Diameter Basis (for tr calc only)		Inside	
Layout Angle		225.00	deg
Diameter		2.0000	in.

Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in

Flange Type		Long Weld Neck	
-------------	--	----------------	--

Corrosion Allowance	can	0.0315	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	

Outside Projection	ho	7.1078	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3540	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in

Flange Class		600	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle B3 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 150.0 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 150.0)$$

$$= 0.1495 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.031 \left(\exp \left(\frac{150.0}{10900.0 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0143 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 4.1260 in
 Parallel to Vessel Wall, opening length d 2.0630 in
 Normal to Vessel Wall (Thickness Limit), no pad Tlnp 0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.358	0.212	NA
Area in Shell	A1	0.369	0.321	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21, 2022

Area in Nozzle Wall	A2	0.814	0.813	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.275	1.227	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.063 * 0.1495 * 1.0 + 2 * 0.6248 * 0.1495 * 1.0 * (1 - 0.74))$$

$$= 0.358 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.063 (1.0 * 0.3622 - 1.0 * 0.149) - 2 * 0.625$$

$$(1.0 * 0.3622 - 1.0 * 0.1495) * (1 - 0.736)$$

$$= 0.369 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.6248 - 0.0143) 0.7365$$

$$= 0.814 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.354^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0466 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1810 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1810 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.2205 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.22, \max(0.181, 0.094)]$$

$$= 0.1810 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0466, 0.181)$$

$$= 0.1810 \text{ in}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained :	1329.5,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33170.5 psi	Passed
Occasional :	95.0,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21,2022

Shear : 1278.8, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 150.00/1200.00 = 0.125

Weld Size Calculations, Description: Nozzle B3 2"

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2503 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (0.3575 - 0.3688 + 2 * 0.6248 * 0.7365 * \\
 &\quad (1.0 * 0.3622 - 0.1495) * 14800) \\
 &= 2730.47 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (0.8143 + 0.0 + 0.0923 - 0.0 * 0.74) * 14800 \\
 &= 13417.51 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.8143 + 0.0 + 0.0923 + (0.3333)) * 14800 \\
 &= 18351.00 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.8143 + 0.0 + 0.0923 + 0.0 + (0.3333)) * 14800 \\
 &= 18351.00 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 3.3126 * 0.354 * 0.49 * 10900 \\
 &= 9838. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 1.3439) * (0.6563 - 0.0315) * 0.7 * 10900 \\
 &= 20127. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9838 + 20127) = 29965 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9838 + 0 + 20641 + 0) = 30479 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9838 + 20641 + 0) = 30479 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 29965	lbf, must exceed W = 2730 lbf	or W1 = 13417 lbf
Path 2-2 = 30479	lbf, must exceed W = 2730 lbf	or W2 = 18350 lbf
Path 3-3 = 30479	lbf, must exceed W = 2730 lbf	or W3 = 18350 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5956 in

Input Echo, WRC297 Item 1, Description: Nozzle B3 2" :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0315	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21, 2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	150.00	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.625 in
T / t	=	0.580
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.108
Mr/P	=	0.217
M0/P	=	0.065
N0/P	=	0.131
MrD/Mc	=	0.302
NrDL/Mc	=	0.100
M0d/Mc	=	0.098
N0DL/Mc	=	0.027
MrD/Ml	=	0.195
NrDL/Ml	=	0.091
M0D/Ml	=	0.065
N0DL/Ml	=	0.119

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
-----	-----	-----	-----	-----
Outplane Membrane (P)	630	630	630	630
Outplane Bending (P)	1876	-1876	1876	-1876
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-889	-889	889	889
Outplane Bending (ML)	-2899	2899	2899	-2899
Normal Pressure Stress	5995	6145	5995	6145
-----	-----	-----	-----	-----

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21, 2022

Outplane Stress Summary	4713	6909	12289	2889
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	516	516	516	516
Inplane Bending (P)	6238	-6238	6238	-6238
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-679	-679	679	679
Inplane Bending (ML)	-8728	8728	8728	-8728
Inplane Pressure Stress	2997	2997	2997	2997

Inplane Stress Summary	344	5324	19158	-10774

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4870	7274	19175	13680

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	630	630	630	630
Outplane Bending (P)	1876	-1876	1876	-1876
Outplane Membrane (Mc)	-156	-156	156	156
Outplane Bending (Mc)	-3411	3411	3411	-3411
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	2997	2997	2997	2997

Outplane Stress Summary	1936	5006	9070	-1504

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	516	516	516	516
Inplane Bending (P)	6238	-6238	6238	-6238
Inplane Membrane (Mc)	-579	-579	579	579
Inplane Bending (Mc)	-10510	10510	10510	-10510
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21, 2022

Inplane Pressure Stress	5995	6145	5995	6145

Inplane Stress Summary	1660	10354	23838	-9508

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595

Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	2093	10366	23896	9614

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	630	630	630	630
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-889	-889	889	889
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	228	408	228	408

Hoop Stress Summary	-31	149	1747	1927

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	119	119	119	119
Axial Bending (P)	1575	-1575	1575	-1575
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1068	-1068	1068	1068
Axial Bending (ML)	-2247	2247	2247	-2247
Axial Pressure Stress	114	114	114	114

Axial Stress Summary	-1507	-163	5123	-2521

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

Shear due to (Vc)	144	144	-144	-144
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	345	345	345	345

Shear Stress Summary	489	489	201	201

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21, 2022

LONGITUDINAL PLANE (Stress Intensities	Au Outside	Al Inside	Bu Outside	Bl Inside
Two * Max Shear Stress	1770	1026	5134	4466

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			630	630	630	630
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-156	-156	156	156
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			228	408	228	408
Hoop Stress Summary			702	882	1014	1194

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	119	119	119	119
Axial Bending (P)	1575	-1575	1575	-1575
Axial Membrane (Mc)	-831	-831	831	831
Axial Bending (Mc)	-2947	2947	2947	-2947
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	114	114	114	114
Axial Stress Summary	-1970	774	5586	-3458

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-193	-193	193	193
Shear due to Torsion	345	345	345	345
Shear Stress Summary	152	152	538	538

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2689	989	5648	4774

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
------------------------------------	----	----	----	----	----	----	----	----

PV Elite 24

FileName : V-1264 R06

Noz1: 34 4:21pm Dec 21, 2022

Shear Pm (SUS)		0	0	0	0	0	0	0	
Shear Pl (SUS)		249	249	-249	-249	-334	-334	334	334
Shear Q (SUS)		595	595	595	595	595	595	595	
Pm (SUS)		5995	6145	5995	6145	5995	6145	5995	6145
Pm+Pl (SUS)		5757	5906	7532	7681	5976	6124	7123	7271
Pm+Pl+Q (Total)		4870	7274	19175	13680	2093	10366	23896	9614

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	6145	14800	Passed
Pm+Pl (SUS)	7681	22200	Passed
Pm+Pl+Q (TOTAL)	23896	44400	Passed

*Because only sustained loads were specified, the P_m+P_l+Q allowable was $3 * S_mh$.*

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:

Nozzle Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Stress Values at							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)	228	408	228	408	228	408	228	408
Circ. Pl (SUS)	-259	-259	1519	1519	474	474	786	786
Circ. Q (SUS)	0	0	0	0	0	0	0	0
Long. Pm (SUS)	114	114	114	114	114	114	114	114
Long. Pl (SUS)	-949	-949	1187	1187	-712	-712	950	950
Long. Q (SUS)	-672	672	3822	-3822	-1372	1372	4522	-4522
Shear Pm (SUS)	0	0	0	0	0	0	0	0
Shear Pl (SUS)	144	144	-144	-144	-193	-193	193	193
Shear Q (SUS)	345	345	345	345	345	345	345	345
Pm (SUS)	228	408	228	408	228	408	228	408
Pm+Pl (SUS)	860	1025	1789	1958	1356	1529	1233	1332
Pm+Pl+Q (Total)	1770	1026	5134	4466	2689	989	5648	4774

Nozzle Stress Summation Comparison (psi):

Type of		Max. S.I.	S.I. Allowable		Result
Stress Int.					

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B3 2" Nozl: 34 4:21pm Dec 21,2022

Pm (SUS)		408	10900		Passed	
Pm+Pl (SUS)		1958	16350		Passed	
Pm+Pl+Q (TOTAL)		5648	32700		Passed	

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle LT3**From: 50**

Pressure for Reinforcement Calculations	P	150.000	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F
Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi
Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in
Distance from Bottom/Left Tangent		4.16	ft
User Entered Minimum Design Metal Temperature		32.00	°F

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi
Diameter Basis (for tr calc only)		Inside	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in
Flange Type		Long Weld Neck	
Corrosion Allowance	can	0.0000	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	7.1050	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in
Flange Class		300	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle LT3

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 150.0 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 150.0)$$

$$= 0.1495 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.0 \left(\exp \left(\frac{150.0}{10900.0 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0139 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	4.0370 in
Parallel to Vessel Wall	Rn+tn+t	2.0185 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.351	0.208	NA
Area in Shell	A1	0.360	0.313	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21,2022

Area in Nozzle Wall	A2	0.857	0.855	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.309	1.261	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.0 * 0.1495 * 1.0 + 2 * 0.6563 * 0.1495 * 1.0 * (1 - 0.74))$$

$$= 0.351 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.037 (1.0 * 0.3622 - 1.0 * 0.149) - 2 * 0.656$$

$$(1.0 * 0.3622 - 1.0 * 0.1495) * (1 - 0.736)$$

$$= 0.360 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.6563 - 0.0139) 0.7365$$

$$= 0.857 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.3543^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0151 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1810 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1810 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.1890 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.189, \max(0.181, 0.094)]$$

$$= 0.1810 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0151, 0.181)$$

$$= 0.1810 \text{ in}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained :	1297.4,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33202.6 psi	Passed
Occasional :	86.0,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21,2022

Shear : 1283.3, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 150.00/600.00 = 0.250

Weld Size Calculations, Description: Nozzle LT3

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (0.3506 - 0.3598 + 2 * 0.6563 * 0.7365 * \\
 &\quad (1.0 * 0.3622 - 0.1495) * 14800) \\
 &= 2907.97 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v \\
 &= (0.8569 + 0.0 + 0.0925 - 0.0 * 0.74) * 14800 \\
 &= 14050.42 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.8569 + 0.0 + 0.0925 + (0.3501)) * 14800 \\
 &= 19232.60 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.8569 + 0.0 + 0.0925 + 0.0 + (0.3501)) * 14800 \\
 &= 19232.60 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 3.3126 * 0.3543 * 0.49 * 10900 \\
 &= 9847. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n \\
 &= (3.1416 * 1.3281) * (0.6563 - 0.0) * 0.7 * 10900 \\
 &= 20894. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9847 + 20894) = 30741 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9847 + 0 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9847 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 30741 lbf, must exceed W = 2907 lbf	or W1 = 14050 lbf
Path 2-2 = 30488 lbf, must exceed W = 2907 lbf	or W2 = 19232 lbf
Path 3-3 = 30488 lbf, must exceed W = 2907 lbf	or W3 = 19232 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5928 in

Input Echo, WRC297 Item 1, Description: Nozzle LT3 :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0000	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21,2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	150.00	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.656 in
T / t	=	0.552
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.106
Mr/P	=	0.218
M0/P	=	0.065
N0/P	=	0.132
MrD/Mc	=	0.304
NrDL/Mc	=	0.097
M0d/Mc	=	0.097
N0DL/Mc	=	0.031
MrD/Ml	=	0.195
NrDL/Ml	=	0.090
M0D/Ml	=	0.064
N0DL/Ml	=	0.120

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
-----	-----	-----	-----	-----
Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-891	-891	891	891
Outplane Bending (ML)	-2871	2871	2871	-2871
Normal Pressure Stress	5995	6145	5995	6145
-----	-----	-----	-----	-----

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21, 2022

Outplane Stress Summary	4744	6882	12268	2922
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	B1
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-669	-669	669	669
Inplane Bending (ML)	-8720	8720	8720	-8720
Inplane Pressure Stress	2997	2997	2997	2997

Inplane Stress Summary	411	5265	19189	-10837

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	B1
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	B1
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4902	7242	19206	13776

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	D1
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	-181	-181	181	181
Outplane Bending (Mc)	-3389	3389	3389	-3389
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	2997	2997	2997	2997

Outplane Stress Summary	1938	4962	9078	-1454

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	D1
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	-562	-562	562	562
Inplane Bending (Mc)	-10562	10562	10562	-10562
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21, 2022

Inplane Pressure Stress	5995	6145	5995	6145

Inplane Stress Summary	1674	10362	23922	-9638

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595

Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	2098	10374	23979	9742

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	634	634	634	634
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-891	-891	891	891
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	206	386	206	386

Hoop Stress Summary	-51	129	1731	1911

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1047	-1047	1047	1047
Axial Bending (ML)	-2044	2044	2044	-2044
Axial Pressure Stress	103	103	103	103

Axial Stress Summary	-1423	-235	4759	-2229

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

Shear due to (Vc)	137	137	-137	-137
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	328	328	328	328

Shear Stress Summary	465	465	191	191

```
Nozzle Calcs.: Nozzle LT3          Nozl: 35    4:21pm  Dec 21,2022
```

LONGITUDINAL PLANE (Stress Intensities	Au Outside	Al Inside	Bu Outside	Bl Inside
Two * Max Shear Stress	1657	998	4771	4157

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			634	634	634	634
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-181	-181	181	181
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			206	386	206	386
Hoop Stress Summary			659	839	1021	1201

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	-814	-814	814	814
Axial Bending (Mc)	-2703	2703	2703	-2703
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	103	103	103	103
Axial Stress Summary	-1849	657	5185	-3121

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-184	-184	184	184
Shear due to Torsion	328	328	328	328
Shear Stress Summary	144	144	512	512

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2524	918	5247	4441

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of	Stress Values at							
Stress Int.								
Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl

Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264 R06

Nozzle Calcs.: Nozzle LT3 Noz1: 35 4:21pm Dec 21, 2022

Circ. Pm (SUS)		5995	6145	5995	6145	5995	6145	5995	6145
Circ. Pl (SUS)		-257	-257	1525	1525	-52	-52	1072	1072
Circ. Q (SUS)		-994	994	4748	-4748	-4269	4269	16855	-16855
Long. Pm (SUS)		2997	2997	2997	2997	2997	2997	2997	2997
Long. Pl (SUS)		-159	-159	1179	1179	453	453	815	815
Long. Q (SUS)		-2427	2427	15013	-15013	-1512	1512	5266	-5266
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		249	249	-249	-249	-334	-334	334	334
Shear Q (SUS)		595	595	595	595	595	595	595	595
Pm (SUS)		5995	6145	5995	6145	5995	6145	5995	6145
Pm+Pl (SUS)		5759	5908	7538	7687	5986	6134	7100	7249
Pm+Pl+Q (Total)		4902	7242	19206	13776	2098	10374	23979	9742

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	6145	14800	Passed
Pm+Pl (SUS)	7687	22200	Passed
Pm+Pl+Q (TOTAL)	23979	44400	Passed

*Because only sustained loads were specified, the P_m+P_l+Q allowable was $3 * S_mh$.*

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:

Nozzle Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Stress Values at							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)	206	386	206	386	206	386	206	386
Circ. Pl (SUS)	-257	-257	1525	1525	453	453	815	815
Circ. Q (SUS)	0	0	0	0	0	0	0	0
Long. Pm (SUS)	103	103	103	103	103	103	103	103
Long. Pl (SUS)	-932	-932	1162	1162	-699	-699	929	929
Long. Q (SUS)	-594	594	3494	-3494	-1253	1253	4153	-4153
Shear Pm (SUS)	0	0	0	0	0	0	0	0
Shear Pl (SUS)	137	137	-137	-137	-184	-184	184	184
Shear Q (SUS)	328	328	328	328	328	328	328	328
Pm (SUS)	206	386	206	386	206	386	206	386
Pm+Pl (SUS)	852	996	1768	1938	1307	1481	1210	1318
Pm+Pl+Q (Total)	1657	998	4771	4157	2524	918	5247	4441

Nozzle Stress Summation Comparison (psi):

Type of		Max. S.I.	S.I. Allowable		Result
Stress Int.					

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT3 Nozl: 35 4:21pm Dec 21,2022

Pm (SUS)		386	10900		Passed	
Pm+Pl (SUS)		1938	16350		Passed	
Pm+Pl+Q (TOTAL)		5247	32700		Passed	

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle LT4**From: 50**

Pressure for Reinforcement Calculations	P	151.073	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F
Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi
Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in
Distance from Bottom/Left Tangent		0.66	ft
User Entered Minimum Design Metal Temperature		32.00	°F

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi
Diameter Basis (for tr calc only)		Inside	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in
Flange Type		Long Weld Neck	
Corrosion Allowance	can	0.0000	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	7.1050	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in
Flange Class		300	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle LT4

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

$$= P \cdot R / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= 151.07 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 151.07)$$

$$= 0.1505 \text{ in}$$

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 1.0 \left(\exp \left(\frac{151.07}{10900.0 \cdot 1.0} \right) - 1 \right)$$

$$= 0.0140 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0151 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	4.0370 in
Parallel to Vessel Wall	Rn+tn+t	2.0185 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.9055 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 14800.0)$$

$$= 0.736$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.736, 1.0)$$

$$= 0.736$$

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.353	0.208	NA
Area in Shell	A1	0.358	0.313	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21,2022

Area in Nozzle Wall	A2	0.857	0.855	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.307	1.261	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.0 * 0.1505 * 1.0 + 2 * 0.6563 * 0.1505 * 1.0 * (1 - 0.74))$$

$$= 0.353 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.037 (1.0 * 0.3622 - 1.0 * 0.151) - 2 * 0.656$$

$$(1.0 * 0.3622 - 1.0 * 0.1505) * (1 - 0.736)$$

$$= 0.358 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.6563 - 0.014) 0.7365$$

$$= 0.857 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.3543^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0151 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1820 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1820 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.1890 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.189, \max(0.182, 0.094)]$$

$$= 0.1820 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0151, 0.182)$$

$$= 0.1820 \text{ in}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained :	1298.1,	Allowable :	10900.0 psi	Passed
Expansion :	0.0,	Allowable :	33201.9 psi	Passed
Occasional :	86.7,	Allowable :	14497.0 psi	Passed

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21,2022

Shear : 1283.3, Allowable : 7630.0 psi Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 151.07/600.00 = 0.252

Weld Size Calculations, Description: Nozzle LT4

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (0.3531 - 0.358 + 2 * 0.6563 * 0.7365 * \\
 &\quad (1.0 * 0.3622 - 0.1505)) * 14800) \\
 &= 2956.87 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v \\
 &= (0.8568 + 0.0 + 0.0925 - 0.0 * 0.74) * 14800 \\
 &= 14048.45 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.8568 + 0.0 + 0.0925 + (0.3501)) * 14800 \\
 &= 19230.63 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.8568 + 0.0 + 0.0925 + 0.0 + (0.3501)) * 14800 \\
 &= 19230.63 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 3.3126 * 0.3543 * 0.49 * 10900 \\
 &= 9847. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n \\
 &= (3.1416 * 1.3281) * (0.6563 - 0.0) * 0.7 * 10900 \\
 &= 20894. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21, 2022

$$\begin{aligned}
 &= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (0.3937 - 0.0315) * 0.74 * 14800 \\
 &= 20641. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

$$= (SONW + SNW) = (9847 + 20894) = 30741 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9847 + 0 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$\begin{aligned}
 &= (Sonw + Tngw + Sinw) \\
 &= (9847 + 20641 + 0) = 30489 \text{ lbf}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 30741 lbf, must exceed W = 2956 lbf	or W1 = 14048 lbf
Path 2-2 = 30488 lbf, must exceed W = 2956 lbf	or W2 = 19230 lbf
Path 3-3 = 30488 lbf, must exceed W = 2956 lbf	or W3 = 19230 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 359 psig

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.0941 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 7.5928 in

Input Echo, WRC297 Item 1, Description: Nozzle LT4 :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240 316L	
Vessel Cold S.I. Allowable	Smc 16700.00	psi
Vessel Hot S.I. Allowable	Smh 14800.00	psi
Diameter Basis for Nozzle	ID	
Nozzle Corrosion Allowance	0.0000	in
Nozzle Diameter	2.000	in
Nozzle Thickness	0.6563	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-182 F316L	
Nozzle Cold S.I. Allowable	SNmc 16700.00	psi
Nozzle Hot S.I. Allowable	SNmh 10900.00	psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-182 F316L

Note:

External Forces and Moments in WRC 107/537 Convention:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21,2022

These loads are assumed to be SUSTAINED loads.

Design Internal Pressure	Dp	151.07	psig
Radial Load	P	-630.00	lbf
Circumferential Shear	Vc	470.00	lbf
Longitudinal Shear	Vl	630.00	lbf
Circumferential Moment	Mc	210.00	ft-lbf
Longitudinal Moment	Ml	270.00	ft-lbf
Torsional Moment	Mt	310.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

*Warning - The ratio, Dn/Tn (5.047) is < 10
check the limitations of WRC bulletin 297.*

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 3.313 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
 = 10.963 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.313 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.656 in
T / t	=	0.552
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.010

Nr/P	=	0.106
Mr/P	=	0.218
M0/P	=	0.065
N0/P	=	0.132
MrD/Mc	=	0.304
NrDL/Mc	=	0.097
M0d/Mc	=	0.097
N0DL/Mc	=	0.031
MrD/Ml	=	0.195
NrDL/Ml	=	0.090
M0D/Ml	=	0.064
N0DL/Ml	=	0.120

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	Bl Bottom Inside
Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-891	-891	891	891
Outplane Bending (ML)	-2871	2871	2871	-2871
Normal Pressure Stress	6038	6189	6038	6189

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21,2022

Outplane Stress Summary	4787	6926	12311	2966
-------------------------	------	------	-------	------

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-669	-669	669	669
Inplane Bending (ML)	-8720	8720	8720	-8720
Inplane Pressure Stress	3019	3019	3019	3019

Inplane Stress Summary	433	5287	19211	-10815

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	249	249	-249	-249
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	595	595	595	595

Shear Stress Summary	844	844	346	346

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	4944	7282	19228	13798

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	634	634	634	634
Outplane Bending (P)	1877	-1877	1877	-1877
Outplane Membrane (Mc)	-181	-181	181	181
Outplane Bending (Mc)	-3389	3389	3389	-3389
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	3019	3019	3019	3019

Outplane Stress Summary	1960	4984	9100	-1432

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	510	510	510	510
Inplane Bending (P)	6293	-6293	6293	-6293
Inplane Membrane (Mc)	-562	-562	562	562
Inplane Bending (Mc)	-10562	10562	10562	-10562
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21, 2022

Inplane Pressure Stress	6038	6189	6038	6189

Inplane Stress Summary	1717	10406	23965	-9594

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-334	-334	334	334
Torsional Shear (Mt)	595	595	595	595

Shear Stress Summary	261	261	929	929

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	2126	10418	24022	9698

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	634	634	634	634
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-891	-891	891	891
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	207	389	207	389

Hoop Stress Summary	-50	132	1732	1914

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-1047	-1047	1047	1047
Axial Bending (ML)	-2044	2044	2044	-2044
Axial Pressure Stress	103	103	103	103

Axial Stress Summary	-1423	-235	4759	-2229

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

Shear due to (Vc)	137	137	-137	-137
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	328	328	328	328

Shear Stress Summary	465	465	191	191

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

```

Nozzle Calcs.: Nozzle LT4          Nozl:   36    4:21pm  Dec 21,2022

```

LONGITUDINAL PLANE (Stress Intensities	Au Outside	Al Inside	Bu Outside	Bl Inside
Two * Max Shear Stress	1658	999	4771	4160

CIRCUMFERENTIAL PLANE			Cu	Cl	Du	Dl
(Stresses in the			Left	Left	Right	Right
hoop direction)			Outside	Inside	Outside	Inside
Hoop Membrane (P)			634	634	634	634
Hoop Bending (P)			0	0	0	0
Hoop Membrane (Mc)			-181	-181	181	181
Hoop Bending (Mc)			0	0	0	0
Hoop Membrane (ML)			0	0	0	0
Hoop Bending (ML)			0	0	0	0
Hoop Pressure Stress			207	389	207	389
Hoop Stress Summary			660	842	1022	1204

CIRCUMFERENTIAL PLANE (Stresses Normal to pipe cross-section)	Cu Left Outside	Cl Left Inside	Du Right Outside	Dl Right Inside
Axial Membrane (P)	115	115	115	115
Axial Bending (P)	1450	-1450	1450	-1450
Axial Membrane (Mc)	-814	-814	814	814
Axial Bending (Mc)	-2703	2703	2703	-2703
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	103	103	103	103
Axial Stress Summary	-1849	657	5185	-3121

CIRCUMFERENTIAL PLANE (Shear stress)	Cu Outside	Cl Inside	Du Outside	Dl Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-184	-184	184	184
Shear due to Torsion	328	328	328	328
Shear Stress Summary	144	144	512	512

CIRCUMFERENTIAL PLANE (Stress Intensities	Cu Outside	Cl Inside	Du Outside	Dl Inside
Two * Max Shear Stress	2525	920	5247	4444

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
------------------------------------	----	----	----	----	----	----	----	----

V-1264

Licensee: THE ANUP ENGINEERING LIMITED.

Noz1: 36 4:21pm Dec 21, 2022

Circ. Pm (SUS)		6038	6189	6038	6189	6038	6189	6038	6189
Circ. Pl (SUS)		-257	-257	1525	1525	-52	-52	1072	1072
Circ. Q (SUS)		-994	994	4748	-4748	-4269	4269	16855	-16855
Long. Pm (SUS)		3019	3019	3019	3019	3019	3019	3019	3019
Long. Pl (SUS)		-159	-159	1179	1179	453	453	815	815
Long. Q (SUS)		-2427	2427	15013	-15013	-1512	1512	5266	-5266
Shear Pm (SUS)		0	0	0	0	0	0	0	0
Shear Pl (SUS)		249	249	-249	-249	-334	-334	334	334
Shear Q (SUS)		595	595	595	595	595	595	595	595
Pm (SUS)		6038	6189	6038	6189	6038	6189	6038	6189
Pm+Pl (SUS)		5802	5952	7581	7731	6029	6178	7143	7293
Pm+Pl+Q (Total)		4944	7282	19228	13798	2126	10418	24022	9698

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	6189	14800	Passed
Pm+Pl (SUS)	7731	22200	Passed
Pm+Pl+Q (TOTAL)	24022	44400	Passed

*Because only sustained loads were specified, the P_m+P_l+Q allowable was $3 * S_mh$.*

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:

Nozzle Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Stress Values at							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)	207	389	207	389	207	389	207	389
Circ. Pl (SUS)	-257	-257	1525	1525	453	453	815	815
Circ. Q (SUS)	0	0	0	0	0	0	0	0
Long. Pm (SUS)	103	103	103	103	103	103	103	103
Long. Pl (SUS)	-932	-932	1162	1162	-699	-699	929	929
Long. Q (SUS)	-594	594	3494	-3494	-1253	1253	4153	-4153
Shear Pm (SUS)	0	0	0	0	0	0	0	0
Shear Pl (SUS)	137	137	-137	-137	-184	-184	184	184
Shear Q (SUS)	328	328	328	328	328	328	328	328
Pm (SUS)	207	389	207	389	207	389	207	389
Pm+Pl (SUS)	852	999	1769	1941	1308	1484	1211	1321
Pm+Pl+Q (Total)	1658	999	4771	4160	2525	920	5247	4444

Nozzle Stress Summation Comparison (psi):

Type of		Max. S.I.	S.I. Allowable		Result	
Stress Int.						

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle LT4 Nozl: 36 4:21pm Dec 21,2022

Pm (SUS)		389	10900		Passed	
Pm+Pl (SUS)		1941	16350		Passed	
Pm+Pl+Q (TOTAL)		5247	32700		Passed	

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle A 3"**From: 60**

Pressure for Reinforcement Calculations	P	150.000	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F

Parent Material		SA-240 316L	
Parent Allowable Stress at Temperature	Sv	14800.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi

Inside Diameter of Cylindrical Shell	D	29.2500	in
Design Length of Section	L	118.5000	in
Shell Finished (Minimum) Thickness	t	0.3937	in
Shell Internal Corrosion Allowance	c	0.0315	in
Shell External Corrosion Allowance	co	0.0000	in

Distance from Bottom/Left Tangent		5.91	ft
-----------------------------------	--	------	----

User Entered Minimum Design Metal Temperature		32.00	°F
---	--	-------	----

Type of Element Connected to the Parent : Nozzle

Material		SA-312 TP316L	
Material UNS Number		S31603	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi

Diameter Basis (for tr calc only)		Outside	
Layout Angle		270.00	deg
Diameter		3.0000	in.

Size and Thickness Basis		Minimum	
Nominal Thickness		XXS	

Flange Type		Weld Neck Flange	
-------------	--	------------------	--

Corrosion Allowance	can	0.0315	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	

Outside Projection	ho	4.8613	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	0.3900	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in

Flange Class		600	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle A 3"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	3.500 in.
Actual Thickness Used in Calculation	0.525 in.

Error and Warning Messages for the Current Nozzle:

The nominal thickness selection seems to indicate that carbon steel was selected, but at the same time a stainless steel pipe material was selected. Please check the input to be sure this is what you intended.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, tr [Int. Press]

= $P \cdot R / (S_v \cdot E - 0.6 \cdot P)$ per UG-27 (c) (1)
 = $150.0 \cdot 14.6565 / (14800 \cdot 1.0 - 0.6 \cdot 150.0)$
 = 0.1495 in

Reqd thk per UG-37(a) of Nozzle Wall, trn [Int. Press]

= $P \cdot R_o / (S_n \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a) (1)
 = $150.0 \cdot 1.75 / (10900 \cdot 1.0 + 0.4 \cdot 150.0)$
 = 0.0240 in

Required Nozzle thickness under External Pressure per UG-28 : 0.0134 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	5.0260 in
Parallel to Vessel Wall, opening length	d	2.5130 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	0.9055 in

Weld Strength Reduction Factor [fr1]:

= $\min(1, S_n / S_v)$
 = $\min(1, 10900.0 / 14800.0)$
 = 0.736

Weld Strength Reduction Factor [fr2]:

= $\min(1, S_n / S_v)$
 = $\min(1, 10900.0 / 14800.0)$
 = 0.736

Weld Strength Reduction Factor [fr3]:

= $\min(fr2, fr4)$
 = $\min(0.736, 1.0)$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21, 2022

= 0.736

Results of Nozzle Reinforcement Area Calculations: (in²)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
Area Required	Ar	0.414	0.245	NA
Area in Shell	A1	0.479	0.417	NA
Area in Nozzle Wall	A2	0.626	0.640	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.092	0.092	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	1.198	1.150	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (2.513 * 0.1495 * 1.0 + 2 * 0.4935 * 0.1495 * 1.0 * (1 - 0.74))$$

$$= 0.414 \text{ in}^2$$

Reinforcement Areas per Figure UG-37.1**Area Available in Shell [A1]:**

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 2.513 (1.0 * 0.3622 - 1.0 * 0.149) - 2 * 0.494$$

$$(1.0 * 0.3622 - 1.0 * 0.1495) * (1 - 0.736)$$

$$= 0.479 \text{ in}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 0.906) (0.4935 - 0.024) 0.7365$$

$$= 0.626 \text{ in}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 0.3543^2 * 0.7365 + (0.0)^2 * 0.7365$$

$$= 0.092 \text{ in}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0554 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 0.1810 in
Wall Thickness	tb1 = max(trb1, tr16b) = 0.1810 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.2205 in

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[0.22, \max(0.181, 0.094)]$$

$$= 0.1810 \text{ in}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(0.0554, 0.181)$$

$$= 0.1810 \text{ in}$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21,2022

Available Nozzle Neck Thickness = 0.5250 in --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME**B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	: 2533.1,	Allowable	: 10900.0 psi	Passed
Expansion	: 0.0,	Allowable	: 31966.9 psi	Passed
Occasional	: 159.6,	Allowable	: 14497.0 psi	Passed
Shear	: 1991.3,	Allowable	: 7630.0 psi	Passed

The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

SA-240 316L, Min Metal Temp without impact per UHA-51: -320 °F

SA-312 TP316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 150.00/1200.00 = 0.125

Weld Size Calculations, Description: Nozzle A 3"

Intermediate Calc. for nozzle/shell Welds Tmin 0.3622 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)**Weld Load [W]:**

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (0.4144 - 0.4793 + 2 * 0.4935 * 0.7365 * (1.0 * 0.3622 - 0.1495))14800)$$

$$= 1328.98 \text{ lbf}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (0.6263 + 0.0 + 0.0925 - 0.0 * 0.74) * 14800$$

$$= 10637.55 \text{ lbf}$$
Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (0.6263 + 0.0 + 0.0925 + (0.2633)) * 14800$$

$$= 14534.29 \text{ lbf}$$
Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (0.6263 + 0.0 + 0.0925 + 0.0 + (0.2633)) * 14800$$

$$= 14534.29 \text{ lbf}$$
Strength of Connection Elements for Failure Path Analysis**Shear, Outward Nozzle Weld [Sonw]:**

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.1416/2.0) * 3.5 * 0.3543 * 0.49 * 10900$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21, 2022

= 10404. lbf

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.1416 * 1.5032) * (0.525 - 0.0315) * 0.7 * 10900$$

$$= 17783. \text{ lbf}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (T - cas) * 0.74 * Sng$$

$$= (3.1416/2.0) * 3.5 * (0.3937 - 0.0315) * 0.74 * 14800$$

$$= 21809. \text{ lbf}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

Failure Path [Path 1-1]:

= (SONW + SNW) = (10404 + 17783) = 28187 lbf

Failure Path [Path 2-2]:

$$= (Sonw + Tpgw + Tngw + Sinw)$$

$$= (10404 + 0 + 21809 + 0) = 32213 \text{ lbf}$$

Failure Path [Path 3-3]:

$$= (Sonw + Tngw + Sinw)$$

$$= (10404 + 21809 + 0) = 32213 \text{ lbf}$$
Summary of Failure Path Calculations:

Path 1-1 = 28187	lbf, must exceed W = 1328 lbf	or W1 = 10637 lbf
Path 2-2 = 32213	lbf, must exceed W = 1328 lbf	or W2 = 14534 lbf
Path 3-3 = 32213	lbf, must exceed W = 1328 lbf	or W3 = 14534 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 298 psig

Nozzle is O.K. for the External Pressure: 15 psig

The Drop for this Nozzle is : 0.1051 in

The Cut Length for this Nozzle is, Drop + Ho + H + T : 5.3601 in

Input Echo, WRC297 Item 1, Description: Nozzle A 3" :

Diameter Basis for Cylindrical Shell	ID	
Shell Corrosion Allowance	0.0315	in
Shell Diameter	29.250	in
Shell Thickness	0.3937	in
Shell Stress Concentration Factor	1.000	
Vessel Material	SA-240	316L
Vessel Cold S.I. Allowable	Smc	16700.00 psi
Vessel Hot S.I. Allowable	Smh	14800.00 psi
Diameter Basis for Nozzle	OD	
Nozzle Corrosion Allowance	0.0315	in
Nozzle Diameter	3.500	in
Nozzle Thickness	0.5250	in
Nozzle Stress Concentration Factor	1.000	
Nozzle Material	SA-312	TP316L
Nozzle Cold S.I. Allowable	SNmc	16700.00 psi
Nozzle Hot S.I. Allowable	SNmh	10900.00 psi

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21,2022

Make sure that material properties at this temperature are not
time-dependent for Material: SA-312 TP316L

Note:*External Forces and Moments in WRC 107/537 Convention:**These loads are assumed to be SUStained loads.*

Design Internal Pressure	Dp	150.00	psig
Radial Load	P	-810.00	lbf
Circumferential Shear	Vc	610.00	lbf
Longitudinal Shear	Vl	810.00	lbf
Circumferential Moment	Mc	400.00	ft-lbf
Longitudinal Moment	Ml	520.00	ft-lbf
Torsional Moment	Mt	600.00	ft-lbf

Include Axial Pressure Thrust	No
Include Pressure Stress Indices per Div. 2	No
Local Loads applied at end of Nozzle/Attachment	No

Warning - The ratio, Dn/Tn (6.667) is < 10
check the limitations of WRC bulletin 297.

Stress Computations at the Edge of the Nozzle:**Stress Attenuation Diameter (for Insert Plates) per WRC 297:**

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
= 3.5 + 2 * 1.65 * sqrt(14.838(0.394 - 0.031))
= 11.150 in

WRC 297 Curve Access Parameters:

Vessel Mean Diameter	(D) =	29.675 in
Nozzle Outside Diameter	(d) =	3.500 in
Vessel Thickness used	(T) =	0.362 in
Nozzle Thickness used	(t) =	0.494 in
T / t	=	0.734
d / t	=	10.000

Lambda = [(d/D) * sqrt(D/T)] = 1.068

Nr/P	=	0.111
Mr/P	=	0.199
M0/P	=	0.062
N0/P	=	0.125
MrD/Mc	=	0.293
NrDL/Mc	=	0.117
M0d/Mc	=	0.101
N0DL/Mc	=	0.040
MrD/Ml	=	0.189
NrDL/Ml	=	0.097
M0D/Ml	=	0.066
N0DL/Ml	=	0.121

Vessel Stresses (psi):

LONGITUDINAL PLANE (Stresses Normal to longitudinal plane)	Au Top Outside	Al Top Inside	Bu Bottom Outside	B1 Bottom Inside
-----	-----	-----	-----	-----
Outplane Membrane (P)	769	769	769	769
Outplane Bending (P)	2313	-2313	2313	-2313

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21, 2022

Outplane Membrane (Mc)	0	0	0	0
Outplane Bending (Mc)	0	0	0	0
Outplane Membrane (ML)	-1650	-1650	1650	1650
Outplane Bending (ML)	-5350	5350	5350	-5350
Normal Pressure Stress	5995	6145	5995	6145

Outplane Stress Summary	2077	8301	16077	901

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses parallel to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Inplane Membrane (P)	687	687	687	687
Inplane Bending (P)	7364	-7364	7364	-7364
Inplane Membrane (Mc)	0	0	0	0
Inplane Bending (Mc)	0	0	0	0
Inplane Membrane (ML)	-1319	-1319	1319	1319
Inplane Bending (ML)	-15406	15406	15406	-15406
Inplane Pressure Stress	2997	2997	2997	2997

Inplane Stress Summary	-5677	10407	27773	-17767

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress normal to	Top	Top	Bottom	Bottom
longitudinal plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	306	306	-306	-306
Outplane Shear (Vl)	0	0	0	0
Outplane Shear (Mt)	1033	1033	1033	1033

Shear Stress Summary	1339	1339	727	727

Vessel Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Top	Top	Bottom	Bottom
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	8203	11057	27818	18724

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Membrane (P)	769	769	769	769
Outplane Bending (P)	2313	-2313	2313	-2313
Outplane Membrane (Mc)	-415	-415	415	415
Outplane Bending (Mc)	-6317	6317	6317	-6317
Outplane Membrane (ML)	0	0	0	0
Outplane Bending (ML)	0	0	0	0
Normal Pressure Stress	2997	2997	2997	2997

Outplane Stress Summary	-653	7355	12811	-4449

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses parallel to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21, 2022

Inplane Membrane (P)	687	687	687	687
Inplane Bending (P)	7364	-7364	7364	-7364
Inplane Membrane (Mc)	-1226	-1226	1226	1226
Inplane Bending (Mc)	-18362	18362	18362	-18362
Inplane Membrane (ML)	0	0	0	0
Inplane Bending (ML)	0	0	0	0
Inplane Pressure Stress	5995	6145	5995	6145

Inplane Stress Summary	-5542	16604	33634	-17668

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress normal to	Left	Left	Right	Right
circumferential plane)	Outside	Inside	Outside	Inside

Outplane Shear (Vc)	0	0	0	0
Outplane Shear (Vl)	-406	-406	406	406
Torsional Shear (Mt)	1033	1033	1033	1033

Shear Stress Summary	627	627	1439	1439

Vessel Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Left	Left	Right	Right
	Outside	Inside	Outside	Inside

Two * Max Shear Stress	5621	16646	33732	17822

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses in the	Top	Top	Bottom	Bottom
hoop direction)	Outside	Inside	Outside	Inside

Hoop Membrane (P)	769	769	769	769
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	0	0	0	0
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	-1650	-1650	1650	1650
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	383	563	383	563

Hoop Stress Summary	-498	-318	2802	2982

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stresses Normal to	Top	Top	Bottom	Bottom
pipe cross-section)	Outside	Inside	Outside	Inside

Axial Membrane (P)	173	173	173	173
Axial Bending (P)	2856	-2856	2856	-2856
Axial Membrane (Mc)	0	0	0	0
Axial Bending (Mc)	0	0	0	0
Axial Membrane (ML)	-2019	-2019	2019	2019
Axial Bending (ML)	-6167	6167	6167	-6167
Axial Pressure Stress	191	191	191	191

Axial Stress Summary	-4966	1656	11406	-6640

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Shear stress)	Outside	Inside	Outside	Inside

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle A 3"

Nozl: 37 4:21pm Dec 21,2022

Shear due to (Vc)	224	224	-224	-224
Shear due to (Vl)	0	0	0	0
Shear due to Torsion	758	758	758	758
Shear Stress Summary	982	982	534	534

Nozzle Stresses (psi):

LONGITUDINAL PLANE	Au	Al	Bu	Bl
(Stress Intensities	Outside	Inside	Outside	Inside
Two * Max Shear Stress	5172	2784	11439	9681

Nozzle Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses in the	Left	Left	Right	Right
hoop direction)	Outside	Inside	Outside	Inside
Hoop Membrane (P)	769	769	769	769
Hoop Bending (P)	0	0	0	0
Hoop Membrane (Mc)	-415	-415	415	415
Hoop Bending (Mc)	0	0	0	0
Hoop Membrane (ML)	0	0	0	0
Hoop Bending (ML)	0	0	0	0
Hoop Pressure Stress	383	563	383	563
Hoop Stress Summary	737	917	1567	1747

Nozzle Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stresses Normal to	Left	Left	Right	Right
pipe cross-section)	Outside	Inside	Outside	Inside
Axial Membrane (P)	173	173	173	173
Axial Bending (P)	2856	-2856	2856	-2856
Axial Membrane (Mc)	-1553	-1553	1553	1553
Axial Bending (Mc)	-7909	7909	7909	-7909
Axial Membrane (ML)	0	0	0	0
Axial Bending (ML)	0	0	0	0
Axial Pressure Stress	191	191	191	191
Axial Stress Summary	-6242	3864	12682	-8848

Nozzle Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Shear stress)	Outside	Inside	Outside	Inside
Shear due to (Vc)	0	0	0	0
Shear due to (Vl)	-298	-298	298	298
Shear due to Torsion	758	758	758	758
Shear Stress Summary	460	460	1056	1056

Nozzle Stresses (psi):

CIRCUMFERENTIAL PLANE	Cu	Cl	Du	Dl
(Stress Intensities	Outside	Inside	Outside	Inside
Two * Max Shear Stress	7039	3934	12781	10803

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21, 2022

Vessel Stress Summation at Vessel-Nozzle Junction (psi):

Type of Stress Int. Location	Stress Values at							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)	5995	6145	5995	6145	5995	6145	5995	6145
Circ. Pl (SUS)	-881	-881	2419	2419	-539	-539	1913	1913
Circ. Q (SUS)	-3037	3037	7663	-7663	-10998	10998	25726	-25726
Long. Pm (SUS)	2997	2997	2997	2997	2997	2997	2997	2997
Long. Pl (SUS)	-632	-632	2006	2006	354	354	1184	1184
Long. Q (SUS)	-8042	8042	22770	-22770	-4004	4004	8630	-8630
Shear Pm (SUS)	0	0	0	0	0	0	0	0
Shear Pl (SUS)	306	306	-306	-306	-406	-406	406	406
Shear Q (SUS)	1033	1033	1033	1033	1033	1033	1033	1033
Pm (SUS)	5995	6145	5995	6145	5995	6145	5995	6145
Pm+Pl (SUS)	5147	5295	8441	8590	5531	5676	7951	8100
Pm+Pl+Q (Total)	8203	11057	27818	18724	5621	16646	33732	17822

Vessel Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	6145	14800	Passed
Pm+Pl (SUS)	8590	22200	Passed
Pm+Pl+Q (TOTAL)	33732	44400	Passed

Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.

WRC 297 Stress Summations per ASME Sec. VIII Div. 2:**Nozzle Stress Summation at Vessel-Nozzle Junction (psi):**

Type of Stress Int. Location	Stress Values at							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)	383	563	383	563	383	563	383	563
Circ. Pl (SUS)	-881	-881	2419	2419	354	354	1184	1184
Circ. Q (SUS)	0	0	0	0	0	0	0	0
Long. Pm (SUS)	191	191	191	191	191	191	191	191
Long. Pl (SUS)	-1846	-1846	2192	2192	-1380	-1380	1726	1726
Long. Q (SUS)	-3311	3311	9023	-9023	-5053	5053	10765	-10765
Shear Pm (SUS)	0	0	0	0	0	0	0	0
Shear Pl (SUS)	224	224	-224	-224	-298	-298	298	298
Shear Q (SUS)	758	758	758	758	758	758	758	758
Pm (SUS)	383	563	383	563	383	563	383	563
Pm+Pl (SUS)	1696	1691	2899	3056	2016	2188	2087	2141
Pm+Pl+Q (Total)	5172	2784	11439	9681	7039	3934	12781	10803

18-D-272

212

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle A 3" Nozl: 37 4:21pm Dec 21,2022

Nozzle Stress Summation Comparison (psi):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	563	10900	Passed
Pm+Pl (SUS)	3056	16350	Passed
Pm+Pl+Q (TOTAL)	12781	32700	Passed

*Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.*

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B1 6in. Nozl: 38 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle B1 6in.**From: 90**

Pressure for Reinforcement Calculations	P	150.000	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F

Parent Material		SA-182 F316L	
Parent Allowable Stress at Temperature	Sv	10900.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi

Outside Diameter of Bolted Blind Flange	D	34.9400	in
Head Finished (Minimum) Thickness	t	2.7559	in
Head Internal Corrosion Allowance	c	0.0315	in
Head External Corrosion Allowance	co	0.0000	in

Distance from Head Centerline	L1	10.0000	in
-------------------------------	----	---------	----

User Entered Minimum Design Metal Temperature		32.00	°F
---	--	-------	----

Type of Element Connected to the Parent : Nozzle

Material		SA-312 TP316L	
Material UNS Number		S31603	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi

Diameter Basis (for tr calc only)		Outside	
Layout Angle		180.00	deg
Diameter		6.0000	in.

Size and Thickness Basis		Minimum	
Nominal Thickness		XXS	

Flange Type		Weld Neck Flange	
-------------	--	------------------	--

Corrosion Allowance	can	0.0315	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	

Outside Projection	ho	3.4724	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	1.9409	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in

Flange Class		300	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)

18-D-272


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B1 6in. Nozl: 38 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle B1 6in.

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	6.625 in.
Actual Thickness Used in Calculation	0.756 in.

Error and Warning Messages for the Current Nozzle:

The nominal thickness selection seems to indicate that carbon steel was selected, but at the same time a stainless steel pipe material was selected. Please check the input to be sure this is what you intended.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Nozzle Wall, trn [Int. Press]

$$= P \cdot R_o / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= 150.0 \cdot 3.3125 / (10900 \cdot 1.0 + 0.4 \cdot 150.0)$$

$$= 0.0453 \text{ in}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.0169 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	12.0738 in
Parallel to Vessel Wall	Rn+tn+t	6.0369 in
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	1.8113 in

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 10900.0)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 10900.0 / 10900.0)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(1.0, 1.0)$$

$$= 1.000$$
Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP		External		Mapnc
--------------------------	--	------	--	----------	--	-------

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B1 6in. Nozl: 38 4:21pm Dec 21,2022

Area Required	Ar	5.697	2.690	NA
Area in Shell	A1	3.609	11.622	NA
Area in Nozzle Wall	A2	2.460	2.563	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.126	0.126	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	6.195	14.311	NA

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$\begin{aligned}
 &= 0.5 * d * t + t * t * \ln(1 - fr1) \text{ per UG-39(a) (1)} \\
 &= 0.5 * 5.176 * 2.2011 + 2.2011 * 0.7245 (1 - 1.0) \\
 &= 5.697 \text{ in}^2
 \end{aligned}$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d (E1 * t - F * tr) - 2 * t * \ln(E1 * t - F * tr) * (1 - fr1) \\
 &= 6.898 (1.0 * 2.7244 - 1.0 * 2.201) - 2 * 0.725 \\
 &\quad (1.0 * 2.7244 - 1.0 * 2.201) * (1 - 1.0) \\
 &= 3.609 \text{ in}^2
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 * t * \ln p) (t * \ln - trn) fr2 \\
 &= (2 * 1.811) (0.7245 - 0.0453) 1.0 \\
 &= 2.460 \text{ in}^2
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= W_o^2 * fr2 + (W_i - can / 0.707)^2 * fr2 \\
 &= 0.3543^2 * 1.0 + (0.0)^2 * 1.0 \\
 &= 0.126 \text{ in}^2
 \end{aligned}$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0768 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 2.2326 in
Wall Thickness	tb1 = max(trb1, tr16b) = 2.2326 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.2764 in

Determine Nozzle Thickness candidate [tb]:

$$\begin{aligned}
 &= \min[tb3, \max(tb1, tb2)] \\
 &= \min[0.276, \max(2.2326, 0.094)] \\
 &= 0.2764 \text{ in}
 \end{aligned}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$\begin{aligned}
 &= \max(ta, tb) \\
 &= \max(0.0768, 0.2764) \\
 &= 0.2764 \text{ in}
 \end{aligned}$$

Available Nozzle Neck Thickness = 0.7560 in --> OK

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B1 6in. Nozl: 38 4:21pm Dec 21, 2022

SA-312 TP316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = $150.00/600.00 = 0.250$

Weld Size Calculations, Description: Nozzle B1 6in.

Intermediate Calc. for nozzle/shell Welds Tmin 0.7245 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$0.2500 = \text{Min per Code}$	$0.2505 = 0.7 * W_o \text{ in}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)**Weld Load [W]:**

$$\begin{aligned}
 &= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) * S_v) \\
 &= \max(0, (5.6965 - 3.6094 + 2 * 0.7245 * 1.0 * (1.0 * 2.7244 - 2.2011)) * 10900) \\
 &= 31014.01 \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2 + A5 + A4 - (W_i - \text{Can} / .707)^2 * f_{r2}) * S_v \\
 &= (2.4603 + 0.0 + 0.1256 - 0.0 * 1.0) * 10900 \\
 &= 28185.79 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (2.4603 + 0.0 + 0.1256 + (3.9477)) * 10900 \\
 &= 71215.69 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S \\
 &= (2.4603 + 0.0 + 0.1256 + 0.0 + (3.9477)) * 10900 \\
 &= 71215.69 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis**Shear, Outward Nozzle Weld [Sonw]:**

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416/2.0) * 6.625 * 0.3543 * 0.49 * 10900 \\
 &= 19694. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - \text{Can}) * 0.7 * S_n \\
 &= (3.1416 * 2.9502) * (0.756 - 0.0315) * 0.7 * 10900 \\
 &= 51236. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * W_{gnvi} * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 6.625 * (1.9409 - 0.0) * 0.74 * 10900 \\
 &= 162921. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle B1 6in. Nozl: 38 4:21pm Dec 21,2022

Failure Path [Path 1-1]:

$$= (\text{SONW} + \text{SNW}) = (19694 + 51236) = 70930 \text{ lbf}$$

Failure Path [Path 2-2]:

$$= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (19694 + 0 + 162921 + 0) = 182615 \text{ lbf}$$

Failure Path [Path 3-3]:

$$= (\text{Sonw} + \text{Tngw} + \text{Sinw})$$

$$= (19694 + 162921 + 0) = 182615 \text{ lbf}$$

Summary of Failure Path Calculations:

Path 1-1 = 70929 lbf, must exceed W = 31014 lbf or W1 = 28185 lbf
 Path 2-2 = 182614 lbf, must exceed W = 31014 lbf or W2 = 71215 lbf
 Path 3-3 = 182614 lbf, must exceed W = 31014 lbf or W3 = 71215 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 157 psig

Nozzle is O.K. for the External Pressure: 15 psig

The Cut Length for this Nozzle is, Drop + Ho + H + T : 6.2303 in

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle V 2" Nozl: 39 4:21pm Dec 21,2022

Input, Nozzle Desc: Nozzle V 2"**From: 90**

Pressure for Reinforcement Calculations	P	150.000	psig
Temperature for Internal Pressure	Temp	500	°F
Design External Pressure	Pext	15.00	psig
Temperature for External Pressure	Tempex	300	°F

Parent Material		SA-182 F316L	
Parent Allowable Stress at Temperature	Sv	10900.00	psi
Parent Allowable Stress At Ambient	Sva	16700.00	psi

Outside Diameter of Bolted Blind Flange	D	34.9400	in
Head Finished (Minimum) Thickness	t	2.7559	in
Head Internal Corrosion Allowance	c	0.0315	in
Head External Corrosion Allowance	co	0.0000	in

Distance from Head Centerline	L1	10.0000	in
-------------------------------	----	---------	----

User Entered Minimum Design Metal Temperature		32.00	°F
---	--	-------	----

Type of Element Connected to the Parent : Nozzle

Material		SA-182 F316L	
Material UNS Number		S31603	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	10900.00	psi
Allowable Stress At Ambient	Sna	16700.00	psi

Diameter Basis (for tr calc only)		Inside	
Layout Angle		305.00	deg
Diameter		2.0000	in.

Size and Thickness Basis		Actual	
Actual Thickness	tn	0.6563	in

Flange Type		Long Weld Neck	
-------------	--	----------------	--

Corrosion Allowance	can	0.0315	in
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	

Outside Projection	ho	6.8898	in
Weld leg size between Nozzle and Pad/Shell	Wo	0.3543	in
Groove weld depth between Nozzle and Vessel	Wgnv	2.0000	in
Inside Projection	h	0.0000	in
Weld leg size, Inside Element to Shell	Wi	0.0000	in

Flange Class		300	
Flange Grade		GR 2.3	

The Pressure Design option was MAWP + static head (to the nozzle).

Nozzle Sketch (may not represent actual weld type/configuration)


R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle V 2" Nozl: 39 4:21pm Dec 21, 2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: Nozzle V 2"

ASME Code, Section VIII, Div. 1, 2021, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.656 in.

Nozzle input data check completed without errors.

Reqd thk per App. 1 of Nozzle Wall, trn [Int. Press]
 = $R \left(\exp\left(\frac{P}{S_n E}\right) - 1 \right)$ per Appendix 1-2 (a) (1)
 = $1.031 \left(\exp\left(\frac{150.0}{10900.0 \times 1.0}\right) - 1 \right)$
 = 0.0143 in

Required Nozzle thickness under External Pressure per UG-28 : 0.0149 in

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 8.7614 in
 Parallel to Vessel Wall Rn+tn+t 4.3807 in
 Normal to Vessel Wall (Thickness Limit), no pad Tlnp 1.5620 in

Weld Strength Reduction Factor [fr1]:

= $\min(1, S_n/S_v)$
 = $\min(1, 10900.0/10900.0)$
 = 1.000

Weld Strength Reduction Factor [fr2]:

= $\min(1, S_n/S_v)$
 = $\min(1, 10900.0/10900.0)$
 = 1.000

Weld Strength Reduction Factor [fr3]:

= $\min(fr2, fr4)$
 = $\min(1.0, 1.0)$
 = 1.000

Results of Nozzle Reinforcement Area Calculations: (in^2)

AREA AVAILABLE, A1 to A5		MAWP	External	Mapnc
-----		-----	-----	-----
Area Required	Ar	2.270	1.072	NA
Area in Shell	A1	3.505	11.286	NA
Area in Nozzle Wall	A2	1.907	1.905	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.126	0.126	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	5.538	13.317	NA

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle V 2" Nozl: 39 4:21pm Dec 21,2022

The MAWP Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degr.

The area available without a pad is Sufficient.

Area Required [A]:

$$\begin{aligned}
 &= 0.5 * d * t + t * t_n(1-fr1) \text{ per UG-39(a) (1)} \\
 &= 0.5 * 2.063 * 2.2011 + 2.2011 * 0.6248(1-1.0) \\
 &= 2.270 \text{ in}^2
 \end{aligned}$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1*t - F*tr) - 2 * t_n(E1*t - F*tr) * (1 - fr1) \\
 &= 6.698(1.0 * 2.7244 - 1.0 * 2.201) - 2 * 0.625 \\
 &\quad (1.0 * 2.7244 - 1.0 * 2.2011) * (1 - 1.0) \\
 &= 3.505 \text{ in}^2
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 * t_{lnp}) (t_n - t_{rn}) fr2 \\
 &= (2 * 1.562) (0.6248 - 0.0143) 1.0 \\
 &= 1.907 \text{ in}^2
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= W_o^2 * fr2 + (W_i - can / 0.707)^2 * fr2 \\
 &= 0.3543^2 * 1.0 + (0.0)^2 * 1.0 \\
 &= 0.126 \text{ in}^2
 \end{aligned}$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 0.0464 in
Wall Thickness per UG16(b),	tr16b = 0.0940 in
Wall Thickness, shell/head, internal pressure	trb1 = 2.2326 in
Wall Thickness	tb1 = max(trb1, tr16b) = 2.2326 in
Wall Thickness, shell/head, external pressure	trb2 = 0.0464 in
Wall Thickness	tb2 = max(trb2, tr16b) = 0.0940 in
Wall Thickness per table UG-45	tb3 = 0.2205 in

Determine Nozzle Thickness candidate [tb]:

$$\begin{aligned}
 &= \min[tb3, \max(tb1, tb2)] \\
 &= \min[0.22, \max(2.2326, 0.094)] \\
 &= 0.2205 \text{ in}
 \end{aligned}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$\begin{aligned}
 &= \max(ta, tb) \\
 &= \max(0.0464, 0.2205) \\
 &= 0.2205 \text{ in}
 \end{aligned}$$

Available Nozzle Neck Thickness = 0.6563 in --> OK

SA-182 F316L, Min Metal Temp without impact per UHA-51: -320 °F

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 150.00/600.00 = 0.250

Weld Size Calculations, Description: Nozzle V 2"

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle V 2" Nozl: 39 4:21pm Dec 21, 2022

Intermediate Calc. for nozzle/shell Welds Tmin 0.6248 in

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	0.2500 = Min per Code	0.2505 = 0.7 * Wo in

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)**Weld Load [W]:**

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (2.2705 - 3.5051 + 2 * 0.6248 * 1.0 * \\
 &\quad (1.0 * 2.7244 - 2.2011)) 10900) \\
 &= \max(0, -6330.23) \text{ lbf}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (1.9072 + 0.0 + 0.1256 - 0.0 * 1.0) * 10900 \\
 &= 22157.43 \text{ lbf}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (1.9072 + 0.0 + 0.1256 + (3.4044)) * 10900 \\
 &= 59265.86 \text{ lbf}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (1.9072 + 0.0 + 0.1256 + 0.0 + (3.4044)) * 10900 \\
 &= 59265.86 \text{ lbf}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis**Shear, Outward Nozzle Weld [Sonw]:**

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 3.3126 * 0.3543 * 0.49 * 10900 \\
 &= 9847. \text{ lbf}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 1.3439) * (0.6563 - 0.0315) * 0.7 * 10900 \\
 &= 20127. \text{ lbf}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wgnvi * 0.74 * Sng \\
 &= (3.1416/2.0) * 3.3126 * (2.0 - 0.0) * 0.74 * 10900 \\
 &= 83942. \text{ lbf}
 \end{aligned}$$

See UG-41 and UW-15 for clarification of allowable stresses.

Strength of Failure Paths:**Failure Path [Path 1-1]:**

$$= (SONW + SNW) = (9847 + 20127) = 29975 \text{ lbf}$$

Failure Path [Path 2-2]:

$$\begin{aligned}
 &= (Sonw + Tpgw + Tngw + Sinw) \\
 &= (9847 + 0 + 83942 + 0) = 93789 \text{ lbf}
 \end{aligned}$$

Failure Path [Path 3-3]:

$$= (Sonw + Tngw + Sinw)$$

18-D-272

R06

V-1264

PV Elite 24 Licensee: THE ANUP ENGINEERING LIMITED.

FileName : V-1264_R06 -----

Nozzle Calcs.: Nozzle V 2" Nozl: 39 4:21pm Dec 21,2022

$$= (9847 + 83942 + 0) = 93789 \text{ lbf}$$

Summary of Failure Path Calculations:

Path 1-1 = 29974	lbf, must exceed W = 0 lbf	or W1 = 22157 lbf
Path 2-2 = 93788	lbf, must exceed W = 0 lbf	or W2 = 59265 lbf
Path 3-3 = 93788	lbf, must exceed W = 0 lbf	or W3 = 59265 lbf

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Maximum Allowable Pressure in the Operating case: 213 psig

Nozzle is O.K. for the External Pressure: 15 psig

The Cut Length for this Nozzle is, Drop + Ho + H + T : 9.6477 in

PV Elite is a trademark of Hexagon AB, 2022, All rights reserved.

Adsorbent Chamber

APPD	BMP
------	-----

Revision No.	6
--------------	---

Additional properties of base block:																
Skirt Thk	t1	=	10	mm	Di	=	742	mm	L2a	=	70	mm	L2a + L2b	=	130.5	mm
Skirt ID	Di	=	742	mm	t1	=	10	mm	L2b	=	60.5	mm	Rm=(Di+t1)/2	=	376	mm
Skirt OD	=	762	mm	T2	=	14	mm	L4	=	200	mm					
Base Ring ID	=	641	mm	T3	=	14	mm	L	=	208	mm					
Base Ring OD	=	1023	mm													

Anup LALBHAI GROUP		The Anup Engineering Limited	CALC PAGE NO. 224
			PREPD KRK
Job No : V-1264	Adsorbent Chamber		CHKD DMP
Item No.: 18-D-272	Client : Airproducts	APPD BMP	Revision No. 6
DESIGN CALCULATION FOR TAILING LUG & STIFFENING BEAM			
Effective Length of Skirt, $Le = 0.78 \times \text{sqrt}(Rm \times t1) = 47.83 \text{ mm}$ HENCE $Le < L$, SO SECTION 3 IS NOT CONSIDERD AS STIFFNING SECTION			
$A1 = t1 \times Le$ $= 478.29 \text{ mm}^2$ $A2 = t2 \times (L2a + L2b)$ $= 1827 \text{ mm}^2$ $A = A1 + A2$ $= 2305.29 \text{ mm}^2$ $h1$ $= 75 \text{ mm}$ $h2$ $= 65.25 \text{ mm}$ $c = \frac{(A1 \times h1) + (A2 \times h2)}{A}$ 67.273 mm $R = (\text{Base pl.OD}/2) - C$ $= 444.227 \text{ mm}$ Moment Of Inertia Of Area $I1 = (Le \times t1^3/12) + A1(h1-C)^2 = 32543.53 \text{ mm}^4$ $I2 = t2(L2a+L2b)^3/12 + A2(h2-C)^2 = 2600332 \text{ mm}^4$ $\text{Total M.I} = I1 + I2 = 2632875 \text{ mm}^4$ $\text{Min Section Modulus, } Z = I/C = 39137.25 \text{ mm}^3$			
Stresses in Base Block due to TV			
$\pi = 3.14159$ $TV = 3000.4782 \text{ kg}$ $R = 444.227 \text{ mm}$ $W = TV/(2 \times \pi \times R) = 0.8205$ $KO = 1 + 0.5 \cos x - 3.14 \sin x + x \sin x$ $M = W \times R^2 \times KO$ $M \text{ max} = 416893.59 \text{ kg-mm}$ $\text{Modulus Of Elasticity, } E = 20510 \text{ kg/mm}^2$ $\text{Total Moment OF Inertia } I = 2632875.191 \text{ mm}^4$ $\text{Deflection, } Dx = \frac{(-) 0.4292 \times W \times R^4}{E \times I} = -0.748 \text{ mm}$ $Z = 39137.25 \text{ mm}^4$ $\text{Stress In The Base Block} = \frac{M_{\text{max at 0}}}{Z} = 10.65 \text{ kg/mm}^2$ $\text{Allowable Stress } 0.9 fy = 23.4 \text{ kg/mm}^2$ Actual Stress Is Less Than Allowable. Design is Safe			

HYDRO-TEST CALCULATION FOR HORIZONTAL CONDITION

Description	: H2S RECOVERY UNIT	Calculation Page No. : 225
AEL WO No.	: V-1264	Date : 21-12-2022
Document No.	:	Rev No. : 6
Item No.	: 18-D-272	

Hydrostatic Test Pressure in Vertical Position	P_v	$=$	21.000 kgf/cm ²
Static Head in Vertical Position	H_1	$=$	5411.00 mm
Static Head in Horizontal Position (i.e. Inside Diameter of Equipment)	H_2	$=$	742.95 mm
Effective Static Head in Horizontal Position (H = $H_1 - H_2$)	H	$=$	4668.05 mm
		$=$	4.668 m
Acceleration due to gravity	g	$=$	9.8067 m/s ²
Density of Water	ρ	$=$	1000.00 kg/m ³

Additional Static Head Pressure in Horizontal Position	P	$=$	$\rho g H$
		$=$	$1000 \times 9.80665 \times 4.66805$
		$=$	45777.933 N/m ² = Pa
		$=$	45.778 kPa
		$=$	0.47 kgf/cm ²

Effective Static Head Pressure in Horizontal Position	P_H	$=$	$P_v + P$
		$=$	21 + 0.47
		$=$	21.47 kgf/cm ²
	Roundup Value	$=$	22.00 kgf/cm ²

$= 312.91$ psig

DESIGN OF CHANNEL COVER DAVIT

MDC NO : AEL/MDC/V-1264

Client : Airproducts

Page : 226

JOB NO : V-1264

Consultant : Consultant Rev. : 6

Made By : The Anup Engineering Limited

Eqpt. No. : 18-D-272

Date : 21-12-2022

DESIGN OF COLUMN DAVIT AS PER " PRESSURE VESSEL DESIGN MANUAL " BY DENNIS R MOSS.

Circumferencial moment at guide & support Mo [lb-inch] 9,175.670
= Fr X L4

Axial load on Davit mast P [lb] 1,659.060
= fv + Wd

Longitudinal Moment at support Mx [lb-inch] 7,315.810
= P X L4

AXIAL STRESS (MAST) = P / A fa [lb/ft²] 89,482.125

BENDING STRESS (MAST) = M1 / Z fb [lb/ft²] 14,54,081.976

COMBINED STRESSES (MAST)

Material of construction for mast - [-] SA-106 Gr. B

Yield Stress of the Davit material Sy [lb/ft²] 50,12,301.647

Allowable axial stress in the mast=0.6XSy Fa [lb/ft²] 30,07,380.980

Allowable bending stress in the mast=0.66XSy Fb [lb/ft²] 33,08,118.678

Ratio fa / Fa - [-] 0.030

Ratio fb / Fb - [-] 0.440

fa / Fa + fb / Fb - [-] 0.469

As fa/Fa+fb/Fb <=1, the design is adequate.

BENDING STRESS (BOOM)

fb = fv X L5 / Z fb [lb/ft²] 10,68,974.372

Allowable bending stress in the Boost=0.66XSy Fb [lb/ft²] 33,08,118.678

As actual stress < allowable, the design is adequate


FileName : Nozzle D 2in -----

Flg Calc [Int P]: FLANGE

Flng: 4 11:21am Jan 1,2022

Flange Input Data Values**Description: FLANGE :****Nozzle D 2" WNRFFlange**

Description of Flange Geometry (Type)		Integral Weld Neck
Design Pressure	P	105.00 psig
Design Temperature		500 °F
Internal Corrosion Allowance	ci	0.0315 in
External Corrosion Allowance	ce	0.0000 in
Use Corrosion Allowance in Thickness Calcs.		No
Flange Inside Diameter	B	2.070 in
Flange Outside Diameter	A	6.500 in
Flange Thickness	t	0.8800 in
Thickness of Hub at Small End	go	0.2063 in
Thickness of Hub at Large End	gl	0.6713 in
Length of Hub	h	1.8700 in
Flange Material		SA-182 F316L
Flange Material UNS number		S31603
Flange Allowable Stress At Temperature	Sfo	10900.00 psi
Flange Allowable Stress At Ambient	Sfa	16700.00 psi
Bolt Material		SA-193 B7M
Bolt Allowable Stress At Temperature	Sb	20000.00 psi
Bolt Allowable Stress At Ambient	Sa	20000.00 psi
Diameter of Bolt Circle	C	5.000 in
Nominal Bolt Diameter	a	0.6250 in
Type of Threads		TEMA Thread Series
Number of Bolts		8
Flange Face Outside Diameter	Fod	3.620 in
Flange Face Inside Diameter	Fid	2.070 in
Flange Facing Sketch		1, Code Sketch 1a
Gasket Outside Diameter	Go	3.380 in
Gasket Inside Diameter	Gi	2.750 in
Gasket Factor	m	0.0000
Gasket Design Seating Stress	y	0.00 psi
Column for Gasket Seating		2, Code Column II
Gasket Thickness	tg	0.1250 in
Flange Class		300
Flange Grade		GR 2.3

**ASME Code, Section VIII Division 1, 2019**

Hub Small End Required Thickness due to Internal Pressure:

$$\begin{aligned}
 &= (P \cdot (D/2 + Ca)) / (S \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (105 \cdot (2.07/2 + 0.031)) / (10900 \cdot 1 - 0.6 \cdot 105) + Ca \\
 &= 0.0418 \text{ in}
 \end{aligned}$$

FileName : Nozzle D 2in

Flg Calc [Int P]: FLANGE

Fling: 4 11:21am Jan 1,2022

Hub Small End Hub MAWP:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (10900 \cdot 1 \cdot 0.17) / (1.07 + 0.6 \cdot 0.17) \\
 &= 1626.590 \text{ psig}
 \end{aligned}$$

Corroded Flange ID,	Bcor = B+2*Fcor	2.133	in
Corroded Large Hub,	g1Cor = g1-ci	0.640	in
Corroded Small Hub,	g0Cor = go-ci	0.175	in
Code R Dimension,	R = ((C-Bcor)/2)-g1cor	0.794	in

Gasket Contact Width,	N = (Go - Gi) / 2	0.315	in
Basic Gasket Width,	bo = N / 2	0.158	in
Effective Gasket Width,	b = bo	0.158	in
Gasket Reaction Diameter,	G = Go (Self-Energizing)	3.380	in

Basic Flange and Bolt Loads:**Hydrostatic End Load due to Pressure [H]:**

$$\begin{aligned}
 &= 0.785 \cdot G^2 \cdot P_{eq} \\
 &= 0.79 \cdot 3.38^2 \cdot 105 \\
 &= 942.134 \text{ lbf}
 \end{aligned}$$

Contact Load on Gasket Surfaces [Hp]:

$$\begin{aligned}
 &= 2 \cdot b \cdot P_i \cdot G \cdot m \cdot P \\
 &= 2 \cdot 0.16 \cdot 3.14 \cdot 3.38 \cdot 0 \cdot 105 \\
 &= 0.000 \text{ lbf}
 \end{aligned}$$

Hydrostatic End Load at Flange ID [Hd]:

$$\begin{aligned}
 &= P_i \cdot B_{cor}^2 \cdot P / 4 \\
 &= 3.14 \cdot 2.13^2 \cdot 105 / 4 \\
 &= 375.196 \text{ lbf}
 \end{aligned}$$

Pressure Force on Flange Face [Ht]:

$$\begin{aligned}
 &= H - H_d \\
 &= 942 - 375 \\
 &= 566.938 \text{ lbf}
 \end{aligned}$$

Operating Bolt Load [Wm1]:

$$\begin{aligned}
 &= \max(H + H_p + H'p, 0) \\
 &= \max(942 + 0 + 0, 0) \\
 &= 942.134 \text{ lbf}
 \end{aligned}$$

Gasket Seating Bolt Load [Wm2]:

$$\begin{aligned}
 &= y \cdot b \cdot P_i \cdot G + y_{Part} \cdot b_{Part} \cdot l_p \\
 &= 0 \cdot 0.16 \cdot 3.14 \cdot 3.38 + 0 \cdot 0 \cdot 0 \\
 &= 0.000 \text{ lbf}
 \end{aligned}$$

Required Bolt Area [Am]:

$$\begin{aligned}
 &= \text{Maximum of } W_{m1}/S_b, W_{m2}/S_a \\
 &= \text{Maximum of } 942/20000, 0/20000 \\
 &= 0.047 \text{ in}^2
 \end{aligned}$$

Flange Design Bolt Load, Gasket Seating [W]:

$$\begin{aligned}
 &= S_a \cdot (A_m + A_b) / 2 \\
 &= 20000 \cdot (0.047 + 1.62) / 2 \\
 &= 16631.07 \text{ lbf}
 \end{aligned}$$

Gasket Load for the Operating Condition [HG]:

$$\begin{aligned}
 &= W_{m1} - H \\
 &= 942 - 942 \\
 &= 0.00 \text{ lbf}
 \end{aligned}$$

Moment Arm Calculations:**Distance to Gasket Load Reaction [hg]:**

$$\begin{aligned}
 &= (C - G) / 2 \\
 &= (5 - 3.38) / 2 \\
 &= 0.8100 \text{ in}
 \end{aligned}$$

Distance to Face Pressure Reaction [ht]:

$$\begin{aligned}
 &= (R + g_1 + h_g) / 2 \\
 &= (0.79 + 0.64 + 0.81) / 2 \\
 &= 1.1218 \text{ in}
 \end{aligned}$$

FileName : Nozzle D 2in

Flg Calc [Int P]: FLANGE

Fling: 4 11:21am Jan 1,2022

Distance to End Pressure Reaction [hd]:

$$\begin{aligned}
 &= R + (g1 / 2) \\
 &= 0.79 + (0.64/2.0) \\
 &= 1.1136 \text{ in}
 \end{aligned}$$

Summary of Moments for Internal Pressure: (ft-lbf)

Loading		Force		Distance		Bolt Corr		Moment	
End Pressure,	Md	375.		1.1136		1.0000		35.	
Face Pressure,	Mt	567.		1.1218		1.0000		53.	
Gasket Load,	Mg	0.		0.8100		1.0000		0.	
Gasket Seating,	Matm	16631.		0.8100		1.0000		1123.	
Total Moment for Operation,								Mop	88. ft-lbf
Total Moment for Gasket seating,								Matm	1123. ft-lbf

*You chose not to perform Stress Calculations on this Standard Flange.
The pressure rating of the flange will be used to check code compliance.*

Estimated Finished Weight of Flange at given Thk. 9.5 lbm
Estimated Unfinished Weight of Forging at given Thk 23.8 lbm

Note:

The flange pressure ratio is less than 0.35. Impact testing is not required due to low stress per UHA-51(g).

Design Pressure/Ambient Rating = 105.00/600.00 = 0.175

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

FileName : Nozzle D 2in -----

Internal Pressure Calculations: Step: 4 11:21am Jan 1,2022

Internal Pressure Results Summary:

Element Thickness, Pressure, Diameter and Allowable Stress :

From	To	Int. Press + Liq. Hd psig	Nominal Thickness in	Total Corr Allowance in	Element Diameter in	Allowable Stress (SE) psi
Nozzle D 2" Pipe		105	0.2063	0.031496	1.93898	10900
Nozzle D 2" WNRFF		105	0.958	0.031496	2.07	10900

Element Required Thickness and MAWP :

From	To	Design Pressure psig	M.A.W.P. Corroded psig	M.A.P. New & Cold psig	Minimum Thickness in	Required Thickness in
Nozzle D 2" Pipe		105	1723	3151	0.2063	0.093996
Nozzle D 2" WNRFF		105	395	600	0.88	No Calc
Minimum			395	600		

MAWP: 395 psig, limited by: Nozzle D 2" WNRFFlange.

Elements Suitable for Design Internal Pressure.

Internal Pressure Calculation Results:

ASME Code, Section VIII Division 1, 2019

Cylindrical Shell From 10 To 20 SA-312 TP316L at 500 °F

Nozzle D 2" Pipe

Material UNS Number: S31603

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned}
 &= (P \cdot R) / (S \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (105 \cdot 1) / (10900 \cdot 1 - 0.6 \cdot 105) \\
 &= 0.0097 + 0.0315 = 0.0412 \text{ in}
 \end{aligned}$$

Note: The thickness required was less than the Code Minimum, therefore the Code Minimum value of 0.0625 in per UG-16 will be used.

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (10900 \cdot 1 \cdot 0.17) / (1 + 0.6 \cdot 0.17) \\
 &= 1723 \text{ psig}
 \end{aligned}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (16700 \cdot 1 \cdot 0.21) / (0.97 + 0.6 \cdot 0.21) \\
 &= 3151 \text{ psig}
 \end{aligned}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$\begin{aligned}
 &= (P \cdot (R + 0.6 \cdot t)) / (E \cdot t) \\
 &= (105 \cdot (1 + 0.6 \cdot 0.17)) / (1 \cdot 0.17) \\
 &= 664.267 \text{ psi}
 \end{aligned}$$

SA-312 TP316L, Min Metal Temp without impact per UHA-51: -320 °F

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Sat Oct 23 14:10:05 2021.

- [Model Notes](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Stress Intensification Factors](#)
- [Allowable Loads](#)
- [Compressive Stress Summary](#)
- [Flexibilities](#)
- [Graphical Results](#)

Model Notes

Model Notes

Input Echo:

Description:

V-1264
Nozzle A 3"

Model Type : Cylindrical Shell

Parent Geometry

Parent Outside Diam. : 30.030 in.
Thickness : 0.394 in.

Parent Properties:

Cold Allowable : 16700.0 psi
Hot Allowable : 14800.0 psi
Material DB # 1071122.
Ultimate Tensile (Amb) : 70000.0 psi
Yield Strength (Amb) : 25000.0 psi
Yield Strength (Hot) : 16400.0 psi
Elastic Modulus (Amb) : 28300000.0 psi
Poissons Ratio : 0.300
Expansion Coefficient : 0.9700E-05 in./in./deg.
Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Nozzle Geometry

Nozzle Outside Diam. : 3.500 in.
Thickness : 0.438 in.
Length : 5.590 in.
Nozzle Tilt Angle : 0.000 deg.
Distance from Top : 29.520 in.
Distance from Bottom : 30.480 in.

Nozzle Properties

Cold Allowable : 16700.0 psi
Hot Allowable : 14800.0 psi
Material DB # 1071622.
Ultimate Tensile (Amb) : 70000.0 psi
Yield Strength (Amb) : 25000.0 psi
Yield Strength (Hot) : 16400.0 psi
Elastic Modulus (Amb) : 28300000.0 psi
Poissons Ratio : 0.300
Expansion Coefficient : 0.9700E-05 in./in./deg.
Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Design Operating Cycles : 7000.
Ambient Temperature (Deg.) : 70.00

Uniform thermal expansion produces no stress in this geometry.
Any thermal loads will come through operating forces and moments applied through the nozzle.

Nozzle Inside Temperature : 500.00 deg.
Nozzle Outside Temperature : 500.00 deg.
Vessel Inside Temperature : 500.00 deg.
Vessel Outside Temperature : 500.00 deg.

Nozzle Pressure : 105.0 psi
Vessel Pressure : 105.0 psi

Operating Pressure : 105.0 psi

The operating pressure is used for secondary and peak stress cases. The design pressure is used for primary cases. The ratio of the operating/design pressure = 1.000

User Defined Load Input Echo for the ATTACHMENT:
Loads are given at the End of Nozzle
Loads are defined in Local Coordinates

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	810.0	810.0	610.0	600.0	400.0	520.0

FEA Model Loads:
These are the actual Attachment loads applied to the FEA model.
These are the User Defined Loads translated to the end of the nozzle and reported in global coordinates.

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	810.0	810.0	610.0	600.0	400.0	520.0

The "top" or "positive" end of this model is "free" in the axial and translational directions.

Stresses ARE nodally AVERAGED.

No weld dimensions have been given for the nozzle connection to the shell. This will produce conservative results for external loads and may tend to produce more realistic inside surface pressure stresses.

Vessel Centerline Vector : 0.000 1.000 0.000
Nozzle Orientation Vector : 1.000 0.000 0.000

[Table of Contents](#)

Load Case Report
FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 2:09pm OCT 23,2021

Load Case Report \$X

Inner and outer element temperatures are the same throughout the model. No thermal ratcheting calculations will be performed.

THE 7 LOAD CASES ANALYZED ARE:

1 SUSTAINED (Pr Only)

Sustained case run to satisfy local primary membrane and bending stress limits.

```

/----- Loads in Case   1
  Pressure Case       1

2  OPERATING          (Fatigue Calc Performed)

Case run to compute the operating stresses used in
secondary, peak and range calculations as needed.

/----- Loads in Case   2
  Pressure Case       1
  Loads from (Operating)

3  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   3
  Loads from (Axial)

4  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   4
  Loads from (Inplane)

5  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   5
  Loads from (Outplane)

6  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   6
  Loads from (Torsion)

7  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   7
  Pressure Case       1

```

[Table of Contents](#)

Solution Data
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 2:09pm OCT 23,2021

Solution Data

Maximum Solution Row Size = 1278
 Number of Nodes = 3318
 Number of Elements = 1098
 Number of Solution Cases = 7

Summation of Loads per Case

Case #	FX	FY	FZ
1	-205.	72438.	0.
2	605.	73248.	610.
3	84267.	0.	0.
4	0.	0.	0.
5	0.	0.	0.
6	0.	0.	0.
7	-205.	72438.	0.

[Table of Contents](#)

ASME Code Stress Output Plots
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 2:10pm OCT 23,2021

ASME Code Stress Output Plots \$X

- 1) $P_l < SPL$ (SUS,Membrane) Case 1
- 2) $Q_b < SPS$ (SUS,Bending) Case 1
- 3) $P_l+P_b+Q < SPS$ (SUS,Inside) Case 1
- 4) $P_l+P_b+Q < SPS$ (SUS,Outside) Case 1
- 5) $S_1+S_2+S_3 < 4S$ (SUS, $S_1+S_2+S_3$) Case 1
- 6) $P_l+P_b+Q < SPS$ (OPE,Inside) Case 2
- 7) $P_l+P_b+Q < SPS$ (OPE,Outside) Case 2
- 8) $P_l+P_b+Q+F < 2S_a$ (EXP,Inside) Case 2
- 9) $P_l+P_b+Q+F < 2S_a$ (EXP,Outside) Case 2
- 10) Membrane < User (OPE,Membrane) Case 2
- 11) Bending < User (OPE,Bending) Case 2
- 12) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 3
- 13) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 4
- 14) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 5
- 15) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 6
- 16) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 7

[Table of Contents](#)

Stress Results - Notes
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 2:10pm OCT 23,2021

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = 1.000000
 Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. ($P_b=0$)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
 $S_1+S_2+S_3$ evaluation omitted from operating stress.
 Include $S_1+S_2+S_3$ evaluation in primary case evaluation.
 Bending stress NOT included for all $S_1+S_2+S_3$ calculations.

- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 2:10pm OCT 23,2021

ASME Overstressed Areas \$X

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 2:10pm OCT 23,2021

Highest Primary Stress Ratios \$X

Header Next to Nozzle Weld

Pl	SPL	Primary Membrane Load Case 1
5,501	22,200	Min Prin. Stress = -514. (24% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
24%		

Branch Next to Header Weld

Pl	SPL	Primary Membrane Load Case 1
4,734	22,200	Min Prin. Stress = -1187. (63% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
21%		

Branch Transition

Pl	SPL	Primary Membrane Load Case 1
545	22,200	Min Prin. Stress = -574. (22% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
2%		

Header away from Junction

Pl	SPL	Primary Membrane Load Case 1
4,028	22,200	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
18%		

Branch away from Junction

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 1
1,404	47,250	Min Prin. Stress = -882. (43% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
2%		

[Table of Contents](#)

Highest Secondary Stress Ratios

FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 2:10pm OCT 23,2021

Highest Secondary Stress Ratios \$X

Header Next to Nozzle Weld

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
27,780	47,250	Min Prin. Stress = -5081. (72% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
58%		

Branch Next to Header Weld

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
19,788	47,250	Min Prin. Stress = -7877. (86% Neg, 0% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
41%		

Branch Transition

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
4,270	47,250	Min Prin. Stress = -3491. (84% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
9%		

Header away from Junction

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
12,736	47,250	Min Prin. Stress = -2107. (21% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
26%		

Branch away from Junction

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
4,442	47,250	Min Prin. Stress = -3085. (97% Neg, 0% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
9%		

[Table of Contents](#)

Highest Fatigue Stress Ratios

FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 2:10pm OCT 23,2021

Highest Fatigue Stress Ratios \$X

Header Next to Nozzle Weld

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
18,752	0.008 Life	Stress Concentration Factor = 1.350
psi	0.317 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 861,644.
Allowable		"B31" Fatigue Stress Allowable = 39375.0

59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 786,456.
31%		WRC 474 99% Probability Cycles = 182,704.
		WRC 474 95% Probability Cycles = 253,666.
		BS5500 Allowed Cycles(Curve F) = 110,560.
		Membrane-to-Bending Ratio = 0.415
		Bending-to-PL+PB+Q Ratio = 0.707
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Branch Next to Header Weld		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2
13,357	0.000 Life	Stress Concentration Factor = 1.350
psi	0.226 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 2,094,036.
22%		WRC 474 99% Probability Cycles = 486,473.
		WRC 474 95% Probability Cycles = 675,416.
		BS5500 Allowed Cycles(Curve F) = 305,904.
		Membrane-to-Bending Ratio = 0.667
		Bending-to-PL+PB+Q Ratio = 0.600
		Plot Reference:
		8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Branch Transition		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
2,135	0.000 Life	Stress Concentration Factor = 1.000
psi	0.036 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 2.2386E8
3%		WRC 474 99% Probability Cycles = 52,005,048.
		WRC 474 95% Probability Cycles = 72,203,488.
		BS5500 Allowed Cycles(Curve F) = 64,868,344.
		Membrane-to-Bending Ratio = 2.387
		Bending-to-PL+PB+Q Ratio = 0.295
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Header away from Junction		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
6,368	0.000 Life	Stress Concentration Factor = 1.000
psi	0.108 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 8,180,146.
10%		WRC 474 99% Probability Cycles = 1,900,358.
		WRC 474 95% Probability Cycles = 2,638,446.
		BS5500 Allowed Cycles(Curve F) = 1,147,386.
		Membrane-to-Bending Ratio = 0.976
		Bending-to-PL+PB+Q Ratio = 0.506
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Branch away from Junction		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2
2,221	0.000 Life	Stress Concentration Factor = 1.000
psi	0.038 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 1.9704E8
3%		WRC 474 99% Probability Cycles = 45,775,296.
		WRC 474 95% Probability Cycles = 63,554,144.
		BS5500 Allowed Cycles(Curve F) = 53,247,956.
		Membrane-to-Bending Ratio = 2.985
		Bending-to-PL+PB+Q Ratio = 0.251
		Plot Reference:
		8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2

[Table of Contents](#)

Highest Stress Ratios Per Region

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

2:10pm OCT 23,2021

Highest Stress Ratios Per Region

\$X

Header Next to Nozzle Weld

Pl 5,501 psi	SPL 22,200 psi	Primary Membrane Load Case 1 Min Prin. Stress = -514. (24% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 1
24%		
Qb 1,877 psi	SPS 47,250 psi	Primary Bending Load Case 1 Min Prin. Stress = -514. (24% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 1
3%		
Pl+Pb+Q 6,562 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 1 Min Prin. Stress = -514. (24% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
13%		
Pl+Pb+Q 4,951 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 1 Min Prin. Stress = -514. (24% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
10%		
S1+S2+S3 8,311 psi	4S 59,200 psi	Part 5 (5.3.2) Load Case 1 Min Prin. Stress = -514. (24% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
14%		
Pl+Pb+Q 20,459 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -5081. (72% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
43%		
Pl+Pb+Q 27,780 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -5081. (72% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
58%		
Pl+Pb+Q+F 13,810 psi	Damage Ratio 0.000 Life 0.233 Stress	Primary+Secondary+Peak (Inner) Load Case 2 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 2.8216E9 "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 2,454,090. WRC 474 99% Probability Cycles = 570,118. WRC 474 95% Probability Cycles = 791,549. BS5500 Allowed Cycles(Curve F) = 276,814. Membrane-to-Bending Ratio = 0.449 Bending-to-PL+PB+Q Ratio = 0.690 Plot Reference: 8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Allowable 59,224 psi		
23%		
Pl+Pb+Q+F 18,752 psi	Damage Ratio 0.008 Life 0.317 Stress	Primary+Secondary+Peak (Outer) Load Case 2 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 861,644. "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 786,456.
Allowable 59,224 psi		

31%			WRC 474 99% Probability Cycles = 182,704. WRC 474 95% Probability Cycles = 253,666. BS5500 Allowed Cycles(Curve F) = 110,560. Membrane-to-Bending Ratio = 0.415 Bending-to-PL+PB+Q Ratio = 0.707 Plot Reference: 9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Membrane 10,051 psi	User 47,250 psi		Component Evaluation Load Case 2 Min Prin. Stress = -5081. (72% Neg, 0% NegHi) Plot Reference: 10) Membrane < User (OPE,Membrane) Case 2
21%			
Bending 22,377 psi	User 47,250 psi		Component Evaluation Load Case 2 Min Prin. Stress = -5081. (72% Neg, 0% NegHi) Plot Reference: 11) Bending < User (OPE,Bending) Case 2
47%			
Branch Next to Header Weld			
Pl 4,734 psi	SPL 22,200 psi		Primary Membrane Load Case 1 Min Prin. Stress = -1187. (63% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 1
21%			
Qb 2,230 psi	SPS 47,250 psi		Primary Bending Load Case 1 Min Prin. Stress = -1187. (63% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 1
4%			
Pl+Pb+Q 6,505 psi	SPS 47,250 psi		Primary+Secondary (Inner) Load Case 1 Min Prin. Stress = -1187. (63% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
13%			
Pl+Pb+Q 3,255 psi	SPS 47,250 psi		Primary+Secondary (Outer) Load Case 1 Min Prin. Stress = -1187. (63% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
6%			
S1+S2+S3 5,499 psi	4S 59,200 psi		Part 5 (5.3.2) Load Case 1 Min Prin. Stress = -1187. (63% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
9%			
Pl+Pb+Q 19,788 psi	SPS 47,250 psi		Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -7877. (86% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
41%			
Pl+Pb+Q 18,110 psi	SPS 47,250 psi		Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -7877. (86% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
38%			
Pl+Pb+Q+F 13,357 psi	Damage Ratio 0.000 Life 0.226 Stress		Primary+Secondary+Peak (Inner) Load Case 2 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11
Allowable 59,224 psi			"B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 2,094,036. WRC 474 99% Probability Cycles = 486,473. WRC 474 95% Probability Cycles = 675,416. BS5500 Allowed Cycles(Curve F) = 305,904. Membrane-to-Bending Ratio = 0.667 Bending-to-PL+PB+Q Ratio = 0.600 Plot Reference: 8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
22%			
Pl+Pb+Q+F 12,224	Damage Ratio 0.000 Life		Primary+Secondary+Peak (Outer) Load Case 2 Stress Concentration Factor = 1.350

psi	0.206	Stress	Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 39375.0 Markl Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 2,861,285. WRC 474 99% Probability Cycles = 664,715. WRC 474 95% Probability Cycles = 922,886. BS5500 Allowed Cycles(Curve F) = 399,096. Membrane-to-Bending Ratio = 0.656 Bending-to-PL+PB+Q Ratio = 0.604 Plot Reference: 9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Allowable			
59,224			
psi			
20%			
Membrane	User		Component Evaluation Load Case 2
10,435	47,250		Min Prin. Stress = -7877. (86% Neg, 0% NegHi)
psi	psi		Plot Reference:
			10) Membrane < User (OPE,Membrane) Case 2
22%			
Bending	User		Component Evaluation Load Case 2
15,646	47,250		Min Prin. Stress = -7877. (86% Neg, 0% NegHi)
psi	psi		Plot Reference:
			11) Bending < User (OPE,Bending) Case 2
33%			
Branch Transition			
Pl	SPL		Primary Membrane Load Case 1
545	22,200		Min Prin. Stress = -574. (22% Neg, 0% NegHi)
psi	psi		Plot Reference:
			1) Pl < SPL (SUS,Membrane) Case 1
2%			
Qb	SPS		Primary Bending Load Case 1
452	47,250		Min Prin. Stress = -574. (22% Neg, 0% NegHi)
psi	psi		Plot Reference:
			2) Qb < SPS (SUS,Bending) Case 1
0%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 1
655	47,250		Min Prin. Stress = -574. (22% Neg, 0% NegHi)
psi	psi		Plot Reference:
			3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
1%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 1
950	47,250		Min Prin. Stress = -574. (22% Neg, 0% NegHi)
psi	psi		Plot Reference:
			4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
2%			
S1+S2+S3	4S		Part 5 (5.3.2) Load Case 1
854	59,200		Min Prin. Stress = -574. (22% Neg, 0% NegHi)
psi	psi		Plot Reference:
			5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
1%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 2
3,767	47,250		Min Prin. Stress = -3491. (84% Neg, 0% NegHi)
psi	psi		Plot Reference:
			6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
7%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 2
4,270	47,250		Min Prin. Stress = -3491. (84% Neg, 0% NegHi)
psi	psi		Plot Reference:
			7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
9%			
Pl+Pb+Q+F	Damage Ratio		Primary+Secondary+Peak (Inner) Load Case 2
1,883	0.000	Life	Stress Concentration Factor = 1.000
psi	0.032	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			Markl Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 3.2629E8
			WRC 474 99% Probability Cycles = 75,801,496.
			WRC 474 95% Probability Cycles = 1.0524E8
			BS5500 Allowed Cycles(Curve F) = 1.2144E8
			Membrane-to-Bending Ratio = 6.790
3%			Bending-to-PL+PB+Q Ratio = 0.128

Plot Reference:		
8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
2,135	0.000 Life	Stress Concentration Factor = 1.000
psi	0.036 Stress	Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11		
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Mark1 Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 2.2386E8
3%		WRC 474 99% Probability Cycles = 52,005,048.
WRC 474 95% Probability Cycles = 72,203,488.		
BS5500 Allowed Cycles(Curve F) = 64,868,344.		
Membrane-to-Bending Ratio = 2.387		
Bending-to-PL+PB+Q Ratio = 0.295		
Plot Reference:		
9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2		
Membrane	User	Component Evaluation Load Case 2
3,780	47,250	Min Prin. Stress = -3491. (84% Neg, 0% NegHi)
psi	psi	Plot Reference:
10) Membrane < User (OPE,Membrane) Case 2		
8%		
Bending	User	Component Evaluation Load Case 2
1,339	47,250	Min Prin. Stress = -3491. (84% Neg, 0% NegHi)
psi	psi	Plot Reference:
11) Bending < User (OPE,Bending) Case 2		
2%		
Header away from Junction		
Pl	SPL	Primary Membrane Load Case 1
4,028	22,200	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
1) Pl < SPL (SUS,Membrane) Case 1		
18%		
Qb	SPS	Primary Bending Load Case 1
681	47,250	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
2) Qb < SPS (SUS,Bending) Case 1		
1%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 1
4,567	47,250	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
3) Pl+Pb+Q < SPS (SUS,Inside) Case 1		
9%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 1
3,742	47,250	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
4) Pl+Pb+Q < SPS (SUS,Outside) Case 1		
7%		
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 1
6,732	59,200	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1		
11%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
11,112	47,250	Min Prin. Stress = -2107. (21% Neg, 0% NegHi)
psi	psi	Plot Reference:
6) Pl+Pb+Q < SPS (OPE,Inside) Case 2		
23%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
12,736	47,250	Min Prin. Stress = -2107. (21% Neg, 0% NegHi)
psi	psi	Plot Reference:
7) Pl+Pb+Q < SPS (OPE,Outside) Case 2		
26%		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2
5,556	0.000 Life	Stress Concentration Factor = 1.000
psi	0.094 Stress	Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11		
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Mark1 Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 12,799,586.

9%			WRC 474 99% Probability Cycles = 2,973,514. WRC 474 95% Probability Cycles = 4,128,408. BS5500 Allowed Cycles(Curve F) = 1,727,606. Membrane-to-Bending Ratio = 1.057 Bending-to-PL+PB+Q Ratio = 0.486 Plot Reference: 8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Pl+Pb+Q+F 6,368 psi	Damage Ratio 0.000 Life 0.108 Stress		Primary+Secondary+Peak (Outer) Load Case 2 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 8,180,146. WRC 474 99% Probability Cycles = 1,900,358. WRC 474 95% Probability Cycles = 2,638,446. BS5500 Allowed Cycles(Curve F) = 1,147,386. Membrane-to-Bending Ratio = 0.976 Bending-to-PL+PB+Q Ratio = 0.506 Plot Reference: 9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Allowable 59,224 psi			
10%			
Membrane 7,195 psi	User 47,250 psi		Component Evaluation Load Case 2 Min Prin. Stress = -2107. (21% Neg, 0% NegHi) Plot Reference: 10) Membrane < User (OPE,Membrane) Case 2
15%			
Bending 7,383 psi	User 47,250 psi		Component Evaluation Load Case 2 Min Prin. Stress = -2107. (21% Neg, 0% NegHi) Plot Reference: 11) Bending < User (OPE,Bending) Case 2
15%			
Branch away from Junction			
Pl 656 psi	SPL 22,200 psi		Primary Membrane Load Case 1 Min Prin. Stress = -882. (43% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 1
2%			
Qb 911 psi	SPS 47,250 psi		Primary Bending Load Case 1 Min Prin. Stress = -882. (43% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 1
1%			
Pl+Pb+Q 1,253 psi	SPS 47,250 psi		Primary+Secondary (Inner) Load Case 1 Min Prin. Stress = -882. (43% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
2%			
Pl+Pb+Q 1,404 psi	SPS 47,250 psi		Primary+Secondary (Outer) Load Case 1 Min Prin. Stress = -882. (43% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
2%			
S1+S2+S3 980 psi	4S 59,200 psi		Part 5 (5.3.2) Load Case 1 Min Prin. Stress = -882. (43% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
1%			
Pl+Pb+Q 4,442 psi	SPS 47,250 psi		Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -3085. (97% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
9%			
Pl+Pb+Q 4,056 psi	SPS 47,250 psi		Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -3085. (97% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
8%			
Pl+Pb+Q+F 2,221	Damage Ratio 0.000 Life		Primary+Secondary+Peak (Inner) Load Case 2 Stress Concentration Factor = 1.000

psi	0.038	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			MarkI Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 1.9704E8
			WRC 474 99% Probability Cycles = 45,775,296.
3%			WRC 474 95% Probability Cycles = 63,554,144.
			BS5500 Allowed Cycles(Curve F) = 53,247,956.
			Membrane-to-Bending Ratio = 2.985
			Bending-to-PL+PB+Q Ratio = 0.251
			Plot Reference:
			8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Pl+Pb+Q+F	Damage Ratio		Primary+Secondary+Peak (Outer) Load Case 2
2,028	0.000	Life	Stress Concentration Factor = 1.000
psi	0.034	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			MarkI Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 2.6254E8
			WRC 474 99% Probability Cycles = 60,990,476.
3%			WRC 474 95% Probability Cycles = 84,678,808.
			BS5500 Allowed Cycles(Curve F) = 83,939,232.
			Membrane-to-Bending Ratio = 2.428
			Bending-to-PL+PB+Q Ratio = 0.292
			Plot Reference:
			9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Membrane	User		Component Evaluation Load Case 2
3,841	47,250		Min Prin. Stress = -3085. (97% Neg, 0% NegHi)
psi	psi		Plot Reference:
			10) Membrane < User (OPE,Membrane) Case 2
	8%		
Bending	User		Component Evaluation Load Case 2
1,524	47,250		Min Prin. Stress = -3085. (97% Neg, 0% NegHi)
psi	psi		Plot Reference:
			11) Bending < User (OPE,Bending) Case 2
	3%		

[Table of Contents](#)

Stress Intensification Factors
 FEPIPE Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 2:10pm OCT 23,2021

Stress Intensification Factors \$X

Branch/Nozzle Sif Summary

	Peak	Primary	Secondary	SSI
Axial :	13.575	10.056	20.111	2.027
Inplane :	3.748	2.776	5.552	1.727
Outplane:	5.164	3.825	7.650	1.623
Torsion :	0.638	0.810	0.946	0.889
Pressure:	1.106	1.374	1.639	1.139

The above stress intensification factors are to be used in a beam-type analysis of the piping system. Inplane, Outplane and Torsional sif's should be used with the matching branch pipe whose diameter and thickness is given below. The axial sif should be used to intensify the axial stress in the branch pipe calculated by F/A. The pressure sif should be used to intensify the nominal pressure stress in the PARENT or HEADER, calculated from PDo/2T. B31 calculations use mean diameters and Section VIII calculations use outside diameters. SSIs are based on peak stress factors and correlated test results.

Pipe OD : 3.500 in.
 Pipe Thk: 0.438 in.
 Z approx: 3.225 cu.in.
 Z exact : 2.879 cu.in.

(SSI = SIF^x)	Axial	Inpl	Outpl	Tors	Pres
SIF/SSI Exponents:	0.885	0.773	0.817	0.471	3.148

SIF/SSI exponent based on relationship between primary and peak stress factors from the finite element analysis.

B31.3 Branch Pressure i-factor =	24.138
Header Pressure i-factor =	2.242

The B31.3 pressure i-factors should be used with with F/A, where F is the axial force due to pressure, and A is the area of the pipe wall. This is equivalent to finding the pressure stress from (ip) (PD/4T).

B31.3 (Branch)		
Peak Stress Sif	0.000	Axial
	8.712	Inplane
	11.245	Outplane
	1.000	Torsional
B31.1 (Branch)		
Peak Stress Sif	0.000	Axial
	5.270	Inplane
	5.270	Outplane
	5.270	Torsional
WRC 330 (Branch)		
Peak Stress Sif	0.000	Axial
	3.558	Inplane
	3.558	Outplane
	1.000	Torsional

[Table of Contents](#)

Allowable Loads		
FEPipe Version 15.0	Jobname: NOZZLE	\$P
Released Jan. 2021	2:10pm OCT 23, 2021	

Allowable Loads	\$X
-----------------	-----

SECONDARY		Maximum	Conservative	Realistic
Load Type (Range):		Individual	Simultaneous	Simultaneous
		Occuring	Occuring	Occuring
Axial Force (lb.)		9899.	2954.	4431.
Inplane Moment (in. lb.)		24505.	5171.	10969.
Outplane Moment (in. lb.)		17784.	3753.	7960.
Torsional Moment (in. lb.)		143841.	44644.	66966.
Pressure (psi)		756.01	105.00	105.00

PRIMARY		Maximum	Conservative	Realistic
Load Type:		Individual	Simultaneous	Simultaneous
		Occuring	Occuring	Occuring
Axial Force (lb.)		9302.	2332.	3498.
Inplane Moment (in. lb.)		23027.	4082.	8660.
Outplane Moment (in. lb.)		16711.	2963.	6285.
Torsional Moment (in. lb.)		78954.	20615.	30922.
Pressure (psi)		423.71	105.00	105.00

NOTES:

- 1) Maximum Individual Occuring Loads are the maximum allowed values of the respective loads if all other load components are zero, i.e. the listed axial force may be applied if the inplane, outplane and torsional moments, and the pressure are zero.
- 2) The Conservative Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A conservative stress combination equation is used that typically produces stresses within 50-70% of the allowable stress.
- 3) The Realistic Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A more realistic stress combination equation is used

based on experience at Paulin Research. Stresses are typically produced within 80-105% of the allowable.

- 4) Secondary allowable loads are limits for expansion and operating piping loads.
- 5) Primary allowable loads are limits for weight, primary and sustained type piping loads.
- 6) High D/T low pressure systems may be subject to instability and should be checked when compressive stresses are present.

[Table of Contents](#)

Compressive Stress Summary

FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
2:10pm OCT 23,2021

\$P

Compressive Stress Summary (psi)

\$X

Nomenclature:

 Min Stress - Compressive Membrane and Bending Stress
 Pts in Region - No. of nodes in the model region
 >5% Compression - 5% or more of Compressive Stress Limit
 >50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = $-0.55 \text{ Min}(S_y, kE_t/R)$, Section slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	>5% Compression and Bending	>50% Compression and Bending	Region
1	SUSTAINED	1	-514.	696	24%	0%	Header Next to Nozzle Weld
2	OPERATING	2	-5081.	696	72%	0%	Header Next to Nozzle Weld
3	EXPANSION	2	-5081.	696	72%	0%	Header Next to Nozzle Weld
4	OPERATING	2	-5081.	696	72%	0%	Header Next to Nozzle Weld
5	SUSTAINED	1	-11.	1032	0%	0%	Header away from Junction
6	OPERATING	2	-2107.	1032	21%	0%	Header away from Junction
7	EXPANSION	2	-2107.	1032	21%	0%	Header away from Junction
8	OPERATING	2	-2107.	1032	21%	0%	Header away from Junction
9	SUSTAINED	1	-1187.	840	63%	0%	Branch Next to Header Weld
10	OPERATING	2	-7877.	840	86%	0%	Branch Next to Header Weld
11	EXPANSION	2	-7877.	840	86%	0%	Branch Next to Header Weld
12	OPERATING	2	-7877.	840	86%	0%	Branch Next to Header Weld
13	SUSTAINED	1	-882.	192	43%	0%	Branch away from Junction
14	OPERATING	2	-3085.	192	97%	0%	Branch away from Junction
15	EXPANSION	2	-3085.	192	97%	0%	Branch away from Junction
16	OPERATING	2	-3085.	192	97%	0%	Branch away from Junction
17	SUSTAINED	1	-574.	696	22%	0%	Branch Transition
18	OPERATING	2	-3491.	696	84%	0%	Branch Transition
19	EXPANSION	2	-3491.	696	84%	0%	Branch Transition
20	OPERATING	2	-3491.	696	84%	0%	Branch Transition

[Table of Contents](#)

Flexibilities

FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
2:10pm OCT 23,2021

\$P

Flexibilities

\$X

The following stiffnesses should be used in a piping, "beam-type" analysis of the intersection. The stiff-

nesses should be inserted at the surface of the branch/header or nozzle/vessel junction. The general characteristics used for the branch pipe should be:

Outside Diameter = 3.500 in.
Wall Thickness = 0.438 in.

Axial Translational Stiffness = 297564. lb./in.
Inplane Rotational Stiffness = 71095. in.lb./deg
Outplane Rotational Stiffness = 35455. in.lb./deg
Torsional Rotational Stiffness = 1551009. in.lb./deg

Estimated Radial Shell Displacement due to Allowable Loads

SECONDARY:

Axial (in.) = 0.033 In-Plane (in.) = 0.009 Out-Plane (in.) = 0.013

PRIMARY

Axial (in.) = 0.031 In-Plane (in.) = 0.009 Out-Plane (in.) = 0.013

Secondary Conservative Displacement = 0.015 in.

Secondary Realistic Displacement = 0.025 in.

Primary Conservative Displacement = 0.012 in.

Primary Realistic Displacement = 0.020 in.

Intersection Flexibility Factors for Branch/Nozzle

:

Find axial stiffness: $K = 3EI/(kd)^3$ lb./in.

Find bending and torsional stiffnesses: $K = EI/(kd)$ in.lb.per radian.

The EI product is 0.14260E+09 lb.in.²

The value of (d) to use is: 3.062 in..

The resulting bending stiffness is in units of force x length per radian.

Axial Flexibility Factor (k) = 3.686

Inplane Flexibility Factor (k) = 11.433

Outplane Flexibility Factor (k) = 22.926

Torsional Flexibility Factor (k) = 0.524

[Table of Contents](#)


Finite Element Model

- [Finite Element Model](#)

Elements at Discontinuity


- [1\) \$Pl < SPL\$ \(SUS Membrane\) Case 1](#)
- [2\) \$Qb < SPS\$ \(SUS Bending\) Case 1](#)
- [3\) \$Pl+Pb+Q < SPS\$ \(SUS Inside\) Case 1](#)
- [4\) \$Pl+Pb+Q < SPS\$ \(SUS Outside\) Case 1](#)
- [5\) \$S1+S2+S3 < 4S\$ \(SUS \$S1+S2+S3\$ \) Case 1](#)
- [6\) \$Pl+Pb+Q < SPS\$ \(OPE Inside\) Case 2](#)
- [7\) \$Pl+Pb+Q < SPS\$ \(OPE Outside\) Case 2](#)
- [8\) \$Pl+Pb+Q+F < 2Sa\$ \(EXP Inside\) Case 2](#)
- [9\) \$Pl+Pb+Q+F < 2Sa\$ \(EXP Outside\) Case 2](#)
- [10\) Membrane < User \(OPE Membrane\) Case 2](#)
- [11\) Bending < User \(OPE Bending\) Case 2](#)
- [12\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 3](#)
- [13\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 4](#)
- [14\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 5](#)
- [15\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 6](#)
- [16\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 7](#)
- ---

Finite Element Model



3d


1) P1 < SPL (SUS Membrane) Case 1




3d(Small)

3d


3d(Deformed)

2) $Q_b < SPS$ (SUS Bending) Case 1

3d(Deformed)

3) $P_l + P_b + Q < SPS$ (SUS Inside) Case 1


3d(Deformed)

4) $P1+Pb+Q < SPS$ (SUS Outside) Case 1

3d(Small)

3d


3d(Deformed)

5) $S1+S2+S3 < 45$ (SUS $S1+S2+S3$) Case 1

3d(Small)

3d


3d(Deformed)

6) $P1+Pb+Q < SPS$ (OPE Inside) Case 2

3d(Small)

3d


3d(Deformed)

7) $P1+Pb+Q < SPS$ (OPE Outside) Case 2

3d(Small)

3d


3d(Deformed)

8) $P1+Pb+Q+F < 2Sa$ (EXP Inside) Case 2

3d(Small)

3d

3d(Deformed)


9) $P1+Pb+Q+F < 2Sa$ (EXP Outside) Case 2

3d(Small)

3d

3d(Deformed)

10) Membrane < User (OPE Membrane) Case 2




3d(Small)

3d

3d(Deformed)

11) Bending < User (OPE Bending) Case 2




3d(Small)

3d

3d(Deformed)

12) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 3




3d(Small)

3d

3d(Deformed)

13) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 4




3d(Small)

3d

3d(Deformed)

14) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 5




3d(Small)

3d

3d(Deformed)

15) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 6




3d(Small)

3d

3d(Deformed)

16) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 7



•

3d(Deformed)

3d(Small)

3d

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Mon Oct 25 19:08:56 2021.

- [Model Notes](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Stress Intensification Factors](#)
- [Allowable Loads](#)
- [Compressive Stress Summary](#)
- [Flexibilities](#)
- [Graphical Results](#)

Model Notes

Model Notes

Input Echo:

Model Type : Flat Head

Parent Geometry

Parent Outside Diam.	:	34.900 in.
Thickness	:	2.755 in.
Attached Shell Length	:	33.320 in.
Attached Shell Thick	:	0.394 in.
Shell Transition Length:	:	5.230 in.
Shell Transition SCF	:	1.350 in.

Parent Properties:

Cold Allowable	:	16700.0 psi
Hot Allowable	:	14800.0 psi
Material DB # 1070322.		
Ultimate Tensile (Amb)	:	65000.0 psi
Yield Strength (Amb)	:	25000.0 psi
Yield Strength (Hot)	:	16400.0 psi
Elastic Modulus (Amb)	:	28300000.0 psi
Poissons Ratio	:	0.300
Expansion Coefficient	:	0.9700E-05 in./in./deg.
Weight Density	:	0.0000E+00 lb./cu.in. (NOT USED)

Nozzle Geometry

Nozzle Outside Diam.	:	6.625 in.
Thickness	:	0.864 in.
Length	:	6.500 in.
Location perpendicular to the head centerline	:	8.000 in.
Nozzle Tilt Angle	:	0.000 deg.

Nozzle Properties

Cold Allowable	:	16700.0 psi
Hot Allowable	:	14800.0 psi
Material DB # 1071622.		
Ultimate Tensile (Amb)	:	70000.0 psi
Yield Strength (Amb)	:	25000.0 psi
Yield Strength (Hot)	:	16400.0 psi
Elastic Modulus (Amb)	:	28300000.0 psi
Poissons Ratio	:	0.300
Expansion Coefficient	:	0.9700E-05 in./in./deg.
Weight Density	:	0.0000E+00 lb./cu.in. (NOT USED)

Design Operating Cycles : 7000.
 Ambient Temperature (Deg.) : 70.00

Uniform thermal expansion produces no stress in this geometry.
 Any thermal loads will come through operating forces and
 moments applied through the nozzle.

Nozzle Inside Temperature : 500.00 deg.
 Nozzle Outside Temperature : 500.00 deg.
 Vessel Inside Temperature : 500.00 deg.
 Vessel Outside Temperature : 500.00 deg.

Nozzle Pressure : 105.0 psi
 Vessel Pressure : 105.0 psi

User Defined Load Input Echo for the ATTACHMENT:
 Loads are given at the End of Nozzle
 Loads are defined in Local Coordinates

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	1600.0	1600.0	1200.0	2400.0	1600.0	2100.0

FEA Model Loads:

These are the actual Attachment loads applied to
 the FEA model.

These are the User Defined Loads translated to the
 end of the nozzle and reported in global coordinates.

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	1600.0	1600.0	-1200.0	1600.0	2400.0	-2100.0

Stresses ARE nodally AVERAGED.

No weld dimensions have been given for the nozzle
 connection to the shell. This will produce conservative
 results for external loads and may tend to produce more
 realistic inside surface pressure stresses.

Vessel Centerline Vector: 0.000 1.000 0.000
 Nozzle Centerline Vector: 0.000 1.000 0.000
 Zero Degree Orientation Vector: 1.000 0.000 0.000

[Table of Contents](#)

Load Case Report
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: NOZZLE
 7:08pm OCT 25,2021

\$P

Load Case Report

\$X

Inner and outer element temperatures are the same
 throughout the model. No thermal ratcheting
 calculations will be performed.

THE 9 LOAD CASES ANALYZED ARE:

1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range
 between the installed and the operating states.

/----- Loads in Case 1
 Loads due to Weight

2 SUSTAINED (Wgt+Pr)

Sustained case run to satisfy local primary
 membrane and bending stress limits.

```

/----- Loads in Case  2
  Loads due to Weight
  Pressure Case  1

3  OPERATING

Case run to compute the operating stresses used in
secondary, peak and range calculations as needed.

/----- Loads in Case  3
  Pressure Case  1
  Loads from (Operating)

4  RANGE          (Fatigue Calc Performed)

Case run to get the RANGE of stresses.
as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case  4
  Plus Stress Results from CASE  3
  Minus Stress Results from CASE  1

5  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case  5
  Loads from (Axial)

6  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case  6
  Loads from (Inplane)

7  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case  7
  Loads from (Outplane)

8  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case  8
  Loads from (Torsion)

9  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case  9
  Pressure Case  1

```

[Table of Contents](#)

```

Solution Data
FEPipe Version 15.0          Jobname: NOZZLE          $P
Released Jan. 2021          7:08pm  OCT 25,2021

```

Solution Data

```

Maximum Solution Row Size =    816
Number of Nodes           =   2101
Number of Elements        =    708
Number of Solution Cases  =     8

```

Summation of Loads per Case

Case #	FX	FY	FZ
1	0.	0.	0.
2	0.	98192.	0.
3	1600.	99792.	-1200.

4	0.	312746.	0.
5	0.	0.	0.
6	0.	0.	0.
7	0.	0.	0.
8	0.	98192.	0.

[Table of Contents](#)

ASME Code Stress Output Plots
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 7:08pm OCT 25,2021

ASME Code Stress Output Plots \$X

- 1) $P_1 < SPL$ (SUS,Membrane) Case 2
- 2) $Q_b < SPS$ (SUS,Bending) Case 2
- 3) $P_1+P_b+Q < SPS$ (SUS,Inside) Case 2
- 4) $P_1+P_b+Q < SPS$ (SUS,Outside) Case 2
- 5) $S_1+S_2+S_3 < 4S$ (SUS, $S_1+S_2+S_3$) Case 2
- 6) $P_1+P_b+Q < SPS$ (OPE,Inside) Case 3
- 7) $P_1+P_b+Q < SPS$ (OPE,Outside) Case 3
- 8) Membrane < User (OPE,Membrane) Case 3
- 9) Bending < User (OPE,Bending) Case 3
- 10) $P_1+P_b+Q+F < 2S_a$ (SIF,Outside) Case 5
- 11) $P_1+P_b+Q+F < 2S_a$ (SIF,Outside) Case 6
- 12) $P_1+P_b+Q+F < 2S_a$ (SIF,Outside) Case 7
- 13) $P_1+P_b+Q+F < 2S_a$ (SIF,Outside) Case 8
- 14) $P_1+P_b+Q+F < 2S_a$ (SIF,Outside) Case 9
- 15) $P_1+P_b+Q < SPS$ (EXP,Inside) Case 4
- 16) $P_1+P_b+Q < SPS$ (EXP,Outside) Case 4
- 17) $P_1+P_b+Q+F < 2S_a$ (EXP,Inside) Case 4
- 18) $P_1+P_b+Q+F < 2S_a$ (EXP,Outside) Case 4

[Table of Contents](#)

Stress Results - Notes
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 7:08pm OCT 25,2021

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = 1.000000
 Range cases use operating pressure. Primary cases

- use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
 - Primary bending stresses at discontinuities are treated like secondary stresses. (Pb=0)
 - Use Equivalent Stress (Von Mises).
 - TRIAXIAL Stress Guidelines:
 S1+S2+S3 evaluation omitted from operating stress.
 Include S1+S2+S3 evaluation in primary case evaluation.
 Bending stress NOT included for all S1+S2+S3 calculations.
 - Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas	Jobname: NOZZLE	\$P
FEPipe Version 15.0		
Released Jan. 2021	7:08pm OCT 25,2021	

ASME Overstressed Areas \$X

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios	Jobname: NOZZLE	\$P
FEPipe Version 15.0		
Released Jan. 2021	7:08pm OCT 25,2021	

Highest Primary Stress Ratios \$X

Shell Next to Nozzle 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
3,304	47,250	Min Prin. Stress = -752. (88% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
6%		

Nozzle 1 Next to Shell

Pl	SPL	Primary Membrane Load Case 2
2,492	22,200	Min Prin. Stress = -1877. (58% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
11%		

Nozzle 1

Pl	SPL	Primary Membrane Load Case 2
350	22,200	Min Prin. Stress = -78. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
1%		

[Table of Contents](#)

Highest Secondary Stress Ratios

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

7:08pm OCT 25,2021

Highest Secondary Stress Ratios

\$X

In combination case 4 the max range stress divided by the max component stress is 1.00. The case tensor components are NEVER additive and so the combination case will have LOWER stresses than the largest of any of the individual cases by between 1 and 20%.

Load Case	Combined/Max (Inside)	Combined/Max (Outside)
-----	-----	-----
4	1.000	1.000

Shell Next to Nozzle 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3
4,415	47,250	Min Prin. Stress = -1532. (97% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
9%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
4,415	47,250	Min Prin. Stress = -1532. (97% Neg, 0% NegHi)
psi	psi	Plot Reference:
		16) Pl+Pb+Q < SPS (EXP,Outside) Case 4
9%		

Nozzle 1 Next to Shell

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3
7,755	47,250	Min Prin. Stress = -1880. (76% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
16%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
7,755	47,250	Min Prin. Stress = -1880. (76% Neg, 0% NegHi)
psi	psi	Plot Reference:
		16) Pl+Pb+Q < SPS (EXP,Outside) Case 4
16%		

Nozzle 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3
2,354	47,250	Min Prin. Stress = -1811. (76% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
4%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
2,354	47,250	Min Prin. Stress = -1811. (76% Neg, 0% NegHi)
psi	psi	Plot Reference:
		16) Pl+Pb+Q < SPS (EXP,Outside) Case 4
4%		

[Table of Contents](#)

Highest Fatigue Stress Ratios

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

7:08pm OCT 25,2021

Highest Fatigue Stress Ratios

\$X

Shell Next to Nozzle 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
5,961	0.000 Life	Stress Concentration Factor = 1.350
psi	0.050 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 78750.0
118,449		Mark1 Fatigue Stress Allowable = 95657.0
psi		WRC 474 Mean Cycles to Failure = 70,354,992.
		WRC 474 99% Probability Cycles = 16,344,413.
5%		WRC 474 95% Probability Cycles = 22,692,484.
		BS5500 Allowed Cycles(Curve F) = 12,919,162.
		Membrane-to-Bending Ratio = 0.190
		Bending-to-PL+PB+Q Ratio = 0.840
		Plot Reference:
		18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

Nozzle 1 Next to Shell

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
10,469	0.000 Life	Stress Concentration Factor = 1.350
psi	0.088 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 78750.0
118,449		Mark1 Fatigue Stress Allowable = 95657.0
psi		WRC 474 Mean Cycles to Failure = 24,950,874.
		WRC 474 99% Probability Cycles = 5,796,419.
8%		WRC 474 95% Probability Cycles = 8,047,713.
		BS5500 Allowed Cycles(Curve F) = 5,082,974.
		Membrane-to-Bending Ratio = 0.559
		Bending-to-PL+PB+Q Ratio = 0.642
		Plot Reference:
		18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

Nozzle 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
2,354	0.000 Life	Stress Concentration Factor = 1.000
psi	0.020 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 78750.0
118,449		Mark1 Fatigue Stress Allowable = 95657.0
psi		WRC 474 Mean Cycles to Failure = 8.8296E8
		WRC 474 99% Probability Cycles = 2.0512E8
1%		WRC 474 95% Probability Cycles = 2.8479E8
		BS5500 Allowed Cycles(Curve F) = 1.2733E9
		Membrane-to-Bending Ratio = 7.529
		Bending-to-PL+PB+Q Ratio = 0.117
		Plot Reference:
		18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

[Table of Contents](#)

Highest Stress Ratios Per Region

FEPipe Version 15.0	Jobname: NOZZLE	\$P
Released Jan. 2021	7:08pm	OCT 25,2021

Highest Stress Ratios Per Region

\$X

Shell Next to Nozzle 1

Pl	SPL	Primary Membrane Load Case 2
678	22,200	Min Prin. Stress = -752. (88% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
3%		
Qb	SPS	Primary Bending Load Case 2
3,055	47,250	Min Prin. Stress = -752. (88% Neg, 0% NegHi)
psi	psi	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 2

	6%		
Pl+Pb+Q 2,957 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -752. (88% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2	
	6%		
Pl+Pb+Q 3,304 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -752. (88% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2	
	6%		
S1+S2+S3 641 psi	4S 59,200 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -752. (88% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2	
	1%		
Pl+Pb+Q 4,313 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -1532. (97% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3	
	9%		
Pl+Pb+Q 4,415 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -1532. (97% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3	
	9%		
Membrane 1,426 psi	User 47,250 psi	Component Evaluation Load Case 3 Min Prin. Stress = -1532. (97% Neg, 0% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3	
	3%		
Bending 4,288 psi	User 47,250 psi	Component Evaluation Load Case 3 Min Prin. Stress = -1532. (97% Neg, 0% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3	
	9%		
Pl+Pb+Q 4,313 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -1532. (97% Neg, 0% NegHi) Plot Reference: 15) Pl+Pb+Q < SPS (EXP,Inside) Case 4	
	9%		
Pl+Pb+Q 4,415 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -1532. (97% Neg, 0% NegHi) Plot Reference: 16) Pl+Pb+Q < SPS (EXP,Outside) Case 4	
	9%		
Pl+Pb+Q+F 5,823 psi	Damage Ratio 0.000 Life 0.049 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78750.0 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 77,036,216. WRC 474 99% Probability Cycles = 17,896,554. WRC 474 95% Probability Cycles = 24,847,464. BS5500 Allowed Cycles(Curve F) = 14,527,700. Membrane-to-Bending Ratio = 0.190 Bending-to-PL+PB+Q Ratio = 0.840 Plot Reference: 17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4	
Allowable 118,449 psi			
	4%		
Pl+Pb+Q+F 5,961 psi	Damage Ratio 0.000 Life 0.050 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78750.0 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 70,354,992. WRC 474 99% Probability Cycles = 16,344,413. WRC 474 95% Probability Cycles = 22,692,484. BS5500 Allowed Cycles(Curve F) = 12,919,162. Membrane-to-Bending Ratio = 0.190	
Allowable 118,449 psi			
	5%		

Bending-to-PL+PB+Q Ratio = 0.840
 Plot Reference:
 18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

Nozzle 1 Next to Shell

Pl 2,492 psi	SPL 22,200 psi	Primary Membrane Load Case 2 Min Prin. Stress = -1877. (58% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
11%		
Qb 3,718 psi	SPS 47,250 psi	Primary Bending Load Case 2 Min Prin. Stress = -1877. (58% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
7%		
Pl+Pb+Q 5,127 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -1877. (58% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
10%		
Pl+Pb+Q 3,858 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -1877. (58% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
8%		
S1+S2+S3 1,837 psi	4S 59,200 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -1877. (58% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
3%		
Pl+Pb+Q 7,150 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -1880. (76% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
15%		
Pl+Pb+Q 7,755 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -1880. (76% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
16%		
Membrane 3,642 psi	User 47,250 psi	Component Evaluation Load Case 3 Min Prin. Stress = -1880. (76% Neg, 0% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
7%		
Bending 6,492 psi	User 47,250 psi	Component Evaluation Load Case 3 Min Prin. Stress = -1880. (76% Neg, 0% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
13%		
Pl+Pb+Q 7,150 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -1880. (76% Neg, 0% NegHi) Plot Reference: 15) Pl+Pb+Q < SPS (EXP,Inside) Case 4
15%		
Pl+Pb+Q 7,755 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -1880. (76% Neg, 0% NegHi) Plot Reference: 16) Pl+Pb+Q < SPS (EXP,Outside) Case 4
16%		
Pl+Pb+Q+F 9,653 psi	Damage Ratio 0.000 Life 0.081 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78750.0 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 33,323,274. WRC 474 99% Probability Cycles = 7,741,438. WRC 474 95% Probability Cycles = 10,748,177.
Allowable 118,449 psi		
8%		

			BS5500 Allowed Cycles(Curve F) = 6,484,576.
			Membrane-to-Bending Ratio = 0.553
			Bending-to-PL+PB+Q Ratio = 0.644
			Plot Reference:
			17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4	
10,469	0.000 Life	Stress Concentration Factor = 1.350	
psi	0.088 Stress	Strain Concentration Factor = 1.000	
Allowable		Cycles Allowed for this Stress = 1.0000E11	
118,449		"B31" Fatigue Stress Allowable = 78750.0	
psi		Mark1 Fatigue Stress Allowable = 95657.0	
		WRC 474 Mean Cycles to Failure = 24,950,874.	
8%		WRC 474 99% Probability Cycles = 5,796,419.	
		WRC 474 95% Probability Cycles = 8,047,713.	
		BS5500 Allowed Cycles(Curve F) = 5,082,974.	
		Membrane-to-Bending Ratio = 0.559	
		Bending-to-PL+PB+Q Ratio = 0.642	
		Plot Reference:	
		18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4	
Nozzle 1			
Pl	SPL	Primary Membrane Load Case 2	
350	22,200	Min Prin. Stress = -78. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		1) Pl < SPL (SUS,Membrane) Case 2	
	1%		
Qb	SPS	Primary Bending Load Case 2	
367	47,250	Min Prin. Stress = -78. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		2) Qb < SPS (SUS,Bending) Case 2	
	0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2	
612	47,250	Min Prin. Stress = -78. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2	
	1%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2	
373	47,250	Min Prin. Stress = -78. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2	
	0%		
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2	
579	59,200	Min Prin. Stress = -78. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2	
	0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3	
2,068	47,250	Min Prin. Stress = -1811. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3	
	4%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3	
2,354	47,250	Min Prin. Stress = -1811. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3	
	4%		
Membrane	User	Component Evaluation Load Case 3	
2,197	47,250	Min Prin. Stress = -1811. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		8) Membrane < User (OPE,Membrane) Case 3	
	4%		
Bending	User	Component Evaluation Load Case 3	
631	47,250	Min Prin. Stress = -1811. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		9) Bending < User (OPE,Bending) Case 3	
	1%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
2,068	47,250	Min Prin. Stress = -1811. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		15) Pl+Pb+Q < SPS (EXP,Inside) Case 4	

4%

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
2,354	47,250	Min Prin. Stress = -1811. (76% Neg, 0% NegHi)
psi	psi	Plot Reference:
		16) Pl+Pb+Q < SPS (EXP,Outside) Case 4

4%

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
2,068	0.000 Life	Stress Concentration Factor = 1.000
psi	0.017 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
118,449		"B31" Fatigue Stress Allowable = 78750.0
psi		MarkI Fatigue Stress Allowable = 95657.0
		WRC 474 Mean Cycles to Failure = 1.3248E9
		WRC 474 99% Probability Cycles = 3.0777E8
1%		WRC 474 95% Probability Cycles = 4.2730E8
		BS5500 Allowed Cycles(Curve F) = 2.4330E9
		Membrane-to-Bending Ratio = 7.529
		Bending-to-PL+PB+Q Ratio = 0.117
		Plot Reference:
		17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
2,354	0.000 Life	Stress Concentration Factor = 1.000
psi	0.020 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
118,449		"B31" Fatigue Stress Allowable = 78750.0
psi		MarkI Fatigue Stress Allowable = 95657.0
		WRC 474 Mean Cycles to Failure = 8.8296E8
		WRC 474 99% Probability Cycles = 2.0512E8
1%		WRC 474 95% Probability Cycles = 2.8479E8
		BS5500 Allowed Cycles(Curve F) = 1.2733E9
		Membrane-to-Bending Ratio = 7.529
		Bending-to-PL+PB+Q Ratio = 0.117
		Plot Reference:
		18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

[Table of Contents](#)

Stress Intensification Factors

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

7:08pm OCT 25,2021

Stress Intensification Factors

\$X

Branch/Nozzle Sif Summary

	Peak	Primary	Secondary	SSI
Axial :	2.588	1.917	3.833	1.244
Inplane :	1.273	0.943	1.886	1.084
Outplane:	1.248	0.924	1.848	1.052
Torsion :	0.628	0.760	0.931	0.793
Pressure:	5.203	3.854	7.708	1.461

The above stress intensification factors are to be used in a beam-type analysis of the piping system. Inplane, Outplane and Torsional sif's should be used with the matching branch pipe whose diameter and thickness is given below. The axial sif should be used to intensify the axial stress in the branch pipe calculated by F/A. The pressure sif should be used to intensify the nominal pressure stress in the PARENT or HEADER, calculated from PDo/2T. B31 calculations use mean diameters and Section VIII calculations use outside diameters. SSIs are based on peak stress factors and correlated test results.

Pipe OD :	6.625	in.
Pipe Thk:	0.864	in.
Z approx:	22.522	cu.in.
Z exact :	20.025	cu.in.

(SSI = SIF^x)	Axial	Inpl	Outpl	Tors	Pres
SIF/SSI Exponents:	0.684	-0.244	-0.357	0.590	0.818

SIF/SSI exponent based on relationship between primary and peak stress factors from the finite element analysis.

B31.3 Branch Pressure i-factor = 19.771
Header Pressure i-factor = 11.298

The B31.3 pressure i-factors should be used with with F/A, where F is the axial force due to pressure, and A is the area of the pipe wall. This is equivalent to finding the pressure stress from (ip) (PD/4T).

B31.3 (Branch)
Peak Stress Sif 0.000 Axial
1.000 Inplane
1.000 Outplane
1.000 Torsional

B31.1 (Branch)
Peak Stress Sif 0.000 Axial
1.000 Inplane
1.000 Outplane
1.000 Torsional

WRC 330 (Branch)
Peak Stress Sif 0.000 Axial
1.000 Inplane
1.500 Outplane
1.000 Torsional

[Table of Contents](#)

Allowable Loads
FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 7:08pm OCT 25,2021

Allowable Loads \$X

SECONDARY Load Type (Range):	Maximum Individual Occuring	Conservative Simultaneous Occuring	Realistic Simultaneous Occuring
Axial Force (lb.)	192746.	59003.	88504.
Inplane Moment (in. lb.)	501744.	108606.	230388.
Outplane Moment (in. lb.)	511925.	110810.	235063.
Torsional Moment (in. lb.)	1016267.	311097.	466645.
Pressure (psi)	967.75	105.00	105.00

PRIMARY Load Type:	Maximum Individual Occuring	Conservative Simultaneous Occuring	Realistic Simultaneous Occuring
Axial Force (lb.)	181120.	53403.	80104.
Inplane Moment (in. lb.)	471480.	98298.	208521.
Outplane Moment (in. lb.)	481047.	100292.	212752.
Torsional Moment (in. lb.)	584739.	172408.	258611.
Pressure (psi)	909.38	105.00	105.00

NOTES:

- 1) Maximum Individual Occuring Loads are the maximum allowed values of the respective loads if all other load components are zero, i.e. the listed axial force may be applied if the inplane, outplane and torsional moments, and the pressure are zero.
- 2) The Conservative Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A conservative stress combination equation is used that typically produces stresses within 50-70% of the allowable stress.
- 3) The Realistic Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A more realistic stress combination equation is used based on experience at Paulin Research. Stresses are typically produced within 80-105% of the allowable.

- 4) Secondary allowable loads are limits for expansion and operating piping loads.
- 5) Primary allowable loads are limits for weight, primary and sustained type piping loads.
- 6) High D/T low pressure systems may be subject to instability and should be checked when compressive stresses are present.

[Table of Contents](#)

Compressive Stress Summary

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

7:08pm OCT 25,2021

Compressive Stress Summary (psi)

\$X

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress

Pts in Region - No. of nodes in the model region

>5% Compression - 5% or more of Compressive Stress Limit

>50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = $-0.55 \text{ Min}(S_y, kE_t/R)$, Section slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	>5% Compression and Bending	>50% Compression and Bending	Region
1	SUSTAINED	2	-1877.	504	58%	0%	Nozzle 1 Next to Shell
2	OPERATING	3	-1880.	504	76%	0%	Nozzle 1 Next to Shell
3	EXPANSION	4	-1880.	504	76%	0%	Nozzle 1 Next to Shell
4	SUSTAINED	2	-78.	456	0%	0%	Nozzle 1
5	OPERATING	3	-1811.	456	76%	0%	Nozzle 1
6	EXPANSION	4	-1811.	456	76%	0%	Nozzle 1
7	SUSTAINED	2	-752.	960	88%	0%	Shell Next to Nozzle 1
8	OPERATING	3	-1532.	960	97%	0%	Shell Next to Nozzle 1
9	EXPANSION	4	-1532.	960	97%	0%	Shell Next to Nozzle 1

[Table of Contents](#)

Flexibilities

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

7:08pm OCT 25,2021

Flexibilities

\$X

The following stiffnesses should be used in a piping, "beam-type" analysis of the intersection. The stiffnesses should be inserted at the surface of the branch/header or nozzle/vessel junction. The general characteristics used for the branch pipe should be:

Outside Diameter = 6.625 in.

Wall Thickness = 0.864 in.

Axial Translational Stiffness = 5670338. lb./in.

Inplane Rotational Stiffness = 5562630. in.lb./deg

Outplane Rotational Stiffness = 6171660. in.lb./deg

Torsional Rotational Stiffness = 360741056. in.lb./deg

Estimated Radial Shell Displacement due to Allowable Loads

SECONDARY:

Axial (in.) = 0.034 In-Plane (in.) = 0.005 Out-Plane (in.) = 0.004

PRIMARY

Axial (in.) = 0.032 In-Plane (in.) = 0.004 Out-Plane (in.) = 0.004

Secondary Conservative Displacement = 0.012 in.

Secondary Realistic Displacement = 0.020 in.

Primary Conservative Displacement = 0.011 in.

Primary Realistic Displacement = 0.018 in.

Intersection Flexibility Factors for Branch/Nozzle

:

Find axial stiffness: $K = 3EI/(kd)^3$ lb./in.

Find bending and torsional stiffnesses: $K = EI/(kd)$ in.lb.per radian.

The EI product is 0.18772E+10 lb.in.²

The value of (d) to use is: 5.761 in..

The resulting bending stiffness is in units of force x length per radian.

Axial Flexibility Factor (k) = 1.732

Inplane Flexibility Factor (k) = 1.022

Outplane Flexibility Factor (k) = 0.921

Torsional Flexibility Factor (k) = 0.016

[Table of Contents](#)


Finite Element Model

- [Finite Element Model](#)

Area of Discontinuity at Nozzle


- [1\) \$Pl < SPL\$ \(SUS Membrane\) Case 2](#)
- [2\) \$Qb < SPS\$ \(SUS Bending\) Case 2](#)
- [3\) \$Pl+Pb+Q < SPS\$ \(SUS Inside\) Case 2](#)
- [4\) \$Pl+Pb+Q < SPS\$ \(SUS Outside\) Case 2](#)
- [5\) \$S1+S2+S3 < 4S\$ \(SUS \$S1+S2+S3\$ \) Case 2](#)
- [6\) \$Pl+Pb+Q < SPS\$ \(OPE Inside\) Case 3](#)
- [7\) \$Pl+Pb+Q < SPS\$ \(OPE Outside\) Case 3](#)
- [8\) Membrane \$< User\$ \(OPE Membrane\) Case 3](#)
- [9\) Bending \$< User\$ \(OPE Bending\) Case 3](#)
- [15\) \$Pl+Pb+Q < SPS\$ \(EXP Inside\) Case 4](#)
- [16\) \$Pl+Pb+Q < SPS\$ \(EXP Outside\) Case 4](#)
- [17\) \$Pl+Pb+Q+F < 2Sa\$ \(EXP Inside\) Case 4](#)
- [18\) \$Pl+Pb+Q+F < 2Sa\$ \(EXP Outside\) Case 4](#)
- [10\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 5](#)
- [11\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 6](#)
- [12\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 7](#)
- [13\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 8](#)
- [14\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 9](#)
- ---

Finite Element Model



3d


 1) P1 < SPL (SUS Membrane) Case 2




3d(Small)

3d


3d(Deformed)

2) $Q_b < SPS$ (SUS Bending) Case 2


3d(Deformed)

3) $P_l + P_b + Q < SPS$ (SUS Inside) Case 2



3d(Deformed)

4) $P1+Pb+Q < SPS$ (SUS Outside) Case 2


3d(Deformed)

5) $S1+S2+S3 < 4S$ (SUS $S1+S2+S3$) Case 2

3d(Deformed)


6) $P1+Pb+Q < SPS$ (OPE Inside) Case 37) $P1+Pb+Q < SPS$ (OPE Outside) Case 3

8) Membrane < User (OPE Membrane) Case 3




3d(Deformed)

9) Bending < User (OPE Bending) Case 3




3d(Deformed)

15) $P1+Pb+Q < SPS$ (EXP Inside) Case 4


3d(Small)

3d

16) $P1+Pb+Q < SPS$ (EXP Outside) Case 4


3d(Small)

3d

17) $P_l + P_b + Q + F < 2S_a$ (EXP Inside) Case 4

3d(Small)


3d

18) $P_l + P_b + Q + F < 2S_a$ (EXP Outside) Case 4

3d(Small)

3d

10) $P_l + P_b + Q + F < 2S_a$ (SIF Outside) Case 5




3d(Small)

3d

3d(Deformed)

11) $P_l + P_b + Q + F < 2S_a$ (SIF Outside) Case 6




3d(Small)

3d

3d(Deformed)

12) $P_I + P_b + Q + F < 2S_a$ (SIF Outside) Case 7




3d(Small)

3d

3d(Deformed)

13) $P_I + P_b + Q + F < 2S_a$ (SIF Outside) Case 8




3d(Small)

3d

3d(Deformed)

14) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 9



•

3d(Deformed)

3d(Small)

3d

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Sat Oct 23 11:22:38 2021.

- [Model Notes](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Stress Intensification Factors](#)
- [Allowable Loads](#)
- [Compressive Stress Summary](#)
- [Flexibilities](#)
- [Graphical Results](#)

Model Notes

Model Notes

Input Echo:

Description:

V-1264
Nozzle B2

Model Type : Cylindrical Shell

Parent Geometry

Parent Outside Diam. : 30.030 in.
Thickness : 0.394 in.

Parent Properties:

Cold Allowable : 16700.0 psi
Hot Allowable : 14800.0 psi
Material DB # 1071122.
Ultimate Tensile (Amb) : 70000.0 psi
Yield Strength (Amb) : 25000.0 psi
Yield Strength (Hot) : 16400.0 psi
Elastic Modulus (Amb) : 28300000.0 psi
Poissons Ratio : 0.300
Expansion Coefficient : 0.9700E-05 in./in./deg.
Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Nozzle Geometry

Nozzle Outside Diam. : 2.375 in.
Thickness : 0.218 in.
Length : 8.400 in.
Nozzle Tilt Angle : 0.000 deg.
Distance from Top : 29.520 in.
Distance from Bottom : 30.480 in.

Nozzle Properties

Cold Allowable : 16700.0 psi
Hot Allowable : 14800.0 psi
Material DB # 1071622.
Ultimate Tensile (Amb) : 70000.0 psi
Yield Strength (Amb) : 25000.0 psi
Yield Strength (Hot) : 16400.0 psi
Elastic Modulus (Amb) : 28300000.0 psi
Poissons Ratio : 0.300
Expansion Coefficient : 0.9700E-05 in./in./deg.
Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Design Operating Cycles : 7000.
Ambient Temperature (Deg.) : 70.00

Uniform thermal expansion produces no stress in this geometry.
Any thermal loads will come through operating forces and moments applied through the nozzle.

Nozzle Inside Temperature : 500.00 deg.
Nozzle Outside Temperature : 500.00 deg.
Vessel Inside Temperature : 500.00 deg.
Vessel Outside Temperature : 500.00 deg.

Nozzle Pressure : 105.0 psi
Vessel Pressure : 105.0 psi

Operating Pressure : 10.0 psi

The operating pressure is used for secondary and peak stress cases. The design pressure is used for primary cases. The ratio of the operating/design pressure = 0.095

User Defined Load Input Echo for the ATTACHMENT:
Loads are given at the Nozzle/Header Junction
Loads are defined in Local Coordinates

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	630.0	630.0	470.0	310.0	210.0	270.0

FEA Model Loads:
These are the actual Attachment loads applied to the FEA model.
These are the User Defined Loads translated to the end of the nozzle and reported in global coordinates.

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	630.0	630.0	470.0	310.0	539.0	-171.0

The "top" or "positive" end of this model is "free" in the axial and translational directions.

Stresses ARE nodally AVERAGED.

No weld dimensions have been given for the nozzle connection to the shell. This will produce conservative results for external loads and may tend to produce more realistic inside surface pressure stresses.

Vessel Centerline Vector : 0.000 1.000 0.000
Nozzle Orientation Vector : 1.000 0.000 0.000

[Table of Contents](#)

Load Case Report
FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 11:21am OCT 23,2021

Load Case Report \$X

Inner and outer element temperatures are the same throughout the model. No thermal ratcheting calculations will be performed.

THE 7 LOAD CASES ANALYZED ARE:

1 SUSTAINED (Pr Only)

Sustained case run to satisfy local primary membrane and bending stress limits.

```

/----- Loads in Case   1
  Pressure Case       1

2  OPERATING          (Fatigue Calc Performed)

Case run to compute the operating stresses used in
secondary, peak and range calculations as needed.

/----- Loads in Case   2
  Pressure Case       1
  Loads from (Operating)

3  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   3
  Loads from (Axial)

4  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   4
  Loads from (Inplane)

5  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   5
  Loads from (Outplane)

6  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   6
  Loads from (Torsion)

7  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   7
  Pressure Case       1

```

[Table of Contents](#)

```

Solution Data
FEPipe Version 15.0          Jobname: NOZZLE          $P
Released Jan. 2021          11:22am  OCT 23,2021

```

Solution Data

```

Maximum Solution Row Size =    996
Number of Nodes           =   3378
Number of Elements        =   1118
Number of Solution Cases  =     7

```

Summation of Loads per Case

Case #	FX	FY	FZ
1	-74.	72441.	0.
2	556.	73071.	470.
3	29557.	0.	0.
4	0.	0.	0.
5	0.	0.	0.
6	0.	0.	0.
7	-74.	72441.	0.

[Table of Contents](#)

ASME Code Stress Output Plots
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 11:22am OCT 23,2021

ASME Code Stress Output Plots \$X

- 1) $P_l < SPL$ (SUS,Membrane) Case 1
- 2) $Q_b < SPS$ (SUS,Bending) Case 1
- 3) $P_l+P_b+Q < SPS$ (SUS,Inside) Case 1
- 4) $P_l+P_b+Q < SPS$ (SUS,Outside) Case 1
- 5) $S_1+S_2+S_3 < 4S$ (SUS, $S_1+S_2+S_3$) Case 1
- 6) $P_l+P_b+Q < SPS$ (OPE,Inside) Case 2
- 7) $P_l+P_b+Q < SPS$ (OPE,Outside) Case 2
- 8) $P_l+P_b+Q+F < 2S_a$ (EXP,Inside) Case 2
- 9) $P_l+P_b+Q+F < 2S_a$ (EXP,Outside) Case 2
- 10) Membrane < User (OPE,Membrane) Case 2
- 11) Bending < User (OPE,Bending) Case 2
- 12) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 3
- 13) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 4
- 14) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 5
- 15) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 6
- 16) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 7

[Table of Contents](#)

Stress Results - Notes
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 11:22am OCT 23,2021

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = $9.5238097E-02$
 Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. ($P_b=0$)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
 $S_1+S_2+S_3$ evaluation omitted from operating stress.
 Include $S_1+S_2+S_3$ evaluation in primary case evaluation.
 Bending stress NOT included for all $S_1+S_2+S_3$ calculations.

- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 11:22am OCT 23,2021

ASME Overstressed Areas \$X

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 11:22am OCT 23,2021

Highest Primary Stress Ratios \$X

Header Next to Nozzle Weld

Pl	SPL	Primary Membrane Load Case 1
6,340	22,200	Min Prin. Stress = -698. (31% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
28%		

Branch Next to Header Weld

Pl	SPL	Primary Membrane Load Case 1
4,692	22,200	Min Prin. Stress = -880. (58% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
21%		

Branch Transition

Pl	SPL	Primary Membrane Load Case 1
638	22,200	Min Prin. Stress = -359. (14% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
2%		

Header away from Junction

Pl	SPL	Primary Membrane Load Case 1
3,980	22,200	Min Prin. Stress = -17. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
17%		

Branch away from Junction

Pl	SPL	Primary Membrane Load Case 1
713	22,200	Min Prin. Stress = -582. (43% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
3%		

[Table of Contents](#)

Highest Secondary Stress Ratios

FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 11:22am OCT 23,2021

Highest Secondary Stress Ratios \$X

Header Next to Nozzle Weld

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
17,213	47,250	Min Prin. Stress = -7973. (96% Neg, 3% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
36%		

Branch Next to Header Weld

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
31,952	47,250	Min Prin. Stress = -17360. (89% Neg, 22% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
67%		

Branch Transition

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
12,020	47,250	Min Prin. Stress = -10665. (98% Neg, 9% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
25%		

Header away from Junction

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
7,793	47,250	Min Prin. Stress = -3297. (81% Neg, 0% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
16%		

Branch away from Junction

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
7,664	47,250	Min Prin. Stress = -6369. (98% Neg, 0% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
16%		

[Table of Contents](#)

Highest Fatigue Stress Ratios

FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 11:22am OCT 23,2021

Highest Fatigue Stress Ratios \$X

Header Next to Nozzle Weld

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
11,619	0.000 Life	Stress Concentration Factor = 1.350
psi	0.196 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
		"B31" Fatigue Stress Allowable = 39375.0

59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 3,552,189.
19%		WRC 474 99% Probability Cycles = 825,221.
		WRC 474 95% Probability Cycles = 1,145,732.
		BS5500 Allowed Cycles(Curve F) = 464,763.
		Membrane-to-Bending Ratio = 0.283
		Bending-to-PL+PB+Q Ratio = 0.780
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Branch Next to Header Weld		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
21,568	0.018 Life	Stress Concentration Factor = 1.350
psi	0.364 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 382,800.
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 796,443.
36%		WRC 474 99% Probability Cycles = 185,024.
		WRC 474 95% Probability Cycles = 256,887.
		BS5500 Allowed Cycles(Curve F) = 72,664.
		Membrane-to-Bending Ratio = 0.384
		Bending-to-PL+PB+Q Ratio = 0.723
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Branch Transition		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
6,010	0.000 Life	Stress Concentration Factor = 1.000
psi	0.101 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 14,355,947.
10%		WRC 474 99% Probability Cycles = 3,335,077.
		WRC 474 95% Probability Cycles = 4,630,400.
		BS5500 Allowed Cycles(Curve F) = 1,365,009.
		Membrane-to-Bending Ratio = 2.002
		Bending-to-PL+PB+Q Ratio = 0.333
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Header away from Junction		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2
3,896	0.000 Life	Stress Concentration Factor = 1.000
psi	0.066 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 41,808,800.
6%		WRC 474 99% Probability Cycles = 9,712,739.
		WRC 474 95% Probability Cycles = 13,485,121.
		BS5500 Allowed Cycles(Curve F) = 5,008,518.
		Membrane-to-Bending Ratio = 0.344
		Bending-to-PL+PB+Q Ratio = 0.744
		Plot Reference:
		8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Branch away from Junction		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2
3,832	0.000 Life	Stress Concentration Factor = 1.000
psi	0.065 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 57,315,124.
6%		WRC 474 99% Probability Cycles = 13,315,077.
		WRC 474 95% Probability Cycles = 18,486,572.
		BS5500 Allowed Cycles(Curve F) = 5,265,690.
		Membrane-to-Bending Ratio = 12.001
		Bending-to-PL+PB+Q Ratio = 0.077
		Plot Reference:
		8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2

[Table of Contents](#)

Highest Stress Ratios Per Region

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

11:22am OCT 23,2021

Highest Stress Ratios Per Region

\$X

Header Next to Nozzle Weld

Pl 6,340 psi	SPL 22,200 psi	Primary Membrane Load Case 1 Min Prin. Stress = -698. (31% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 1
28%		
Qb 2,331 psi	SPS 47,250 psi	Primary Bending Load Case 1 Min Prin. Stress = -698. (31% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 1
4%		
Pl+Pb+Q 7,990 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 1 Min Prin. Stress = -698. (31% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
16%		
Pl+Pb+Q 5,237 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 1 Min Prin. Stress = -698. (31% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
11%		
S1+S2+S3 8,834 psi	4S 59,200 psi	Part 5 (5.3.2) Load Case 1 Min Prin. Stress = -698. (31% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
14%		
Pl+Pb+Q 14,447 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -7973. (96% Neg, 3% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
30%		
Pl+Pb+Q 17,213 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -7973. (96% Neg, 3% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
36%		
Pl+Pb+Q+F 9,752 psi	Damage Ratio 0.000 Life 0.165 Stress	Primary+Secondary+Peak (Inner) Load Case 2 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 5,942,654. WRC 474 99% Probability Cycles = 1,380,559. WRC 474 95% Probability Cycles = 1,916,759. BS5500 Allowed Cycles(Curve F) = 786,111. Membrane-to-Bending Ratio = 0.368 Bending-to-PL+PB+Q Ratio = 0.731 Plot Reference: 8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Allowable 59,224 psi		
16%		
Pl+Pb+Q+F 11,619 psi	Damage Ratio 0.000 Life 0.196 Stress	Primary+Secondary+Peak (Outer) Load Case 2 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 3,552,189.
Allowable 59,224 psi		

19%			WRC 474 99% Probability Cycles = 825,221. WRC 474 95% Probability Cycles = 1,145,732. BS5500 Allowed Cycles(Curve F) = 464,763. Membrane-to-Bending Ratio = 0.283 Bending-to-PL+PB+Q Ratio = 0.780 Plot Reference: 9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Membrane 6,310 psi	User 47,250 psi		Component Evaluation Load Case 2 Min Prin. Stress = -7973. (96% Neg, 3% NegHi) Plot Reference: 10) Membrane < User (OPE,Membrane) Case 2
13%			
Bending 14,294 psi	User 47,250 psi		Component Evaluation Load Case 2 Min Prin. Stress = -7973. (96% Neg, 3% NegHi) Plot Reference: 11) Bending < User (OPE,Bending) Case 2
30%			
Branch Next to Header Weld			
Pl 4,692 psi	SPL 22,200 psi		Primary Membrane Load Case 1 Min Prin. Stress = -880. (58% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 1
21%			
Qb 2,027 psi	SPS 47,250 psi		Primary Bending Load Case 1 Min Prin. Stress = -880. (58% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 1
4%			
Pl+Pb+Q 6,048 psi	SPS 47,250 psi		Primary+Secondary (Inner) Load Case 1 Min Prin. Stress = -880. (58% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
12%			
Pl+Pb+Q 3,511 psi	SPS 47,250 psi		Primary+Secondary (Outer) Load Case 1 Min Prin. Stress = -880. (58% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
7%			
S1+S2+S3 5,722 psi	4S 59,200 psi		Part 5 (5.3.2) Load Case 1 Min Prin. Stress = -880. (58% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
9%			
Pl+Pb+Q 28,327 psi	SPS 47,250 psi		Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -17360. (89% Neg, 22% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
59%			
Pl+Pb+Q 31,952 psi	SPS 47,250 psi		Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -17360. (89% Neg, 22% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
67%			
Pl+Pb+Q+F 19,121 psi	Damage Ratio 0.009 Life 0.323 Stress		Primary+Secondary+Peak (Inner) Load Case 2 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 765,018. "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 1,251,701. WRC 474 99% Probability Cycles = 290,787. WRC 474 95% Probability Cycles = 403,727. BS5500 Allowed Cycles(Curve F) = 104,284. Membrane-to-Bending Ratio = 0.384 Bending-to-PL+PB+Q Ratio = 0.723 Plot Reference: 8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Allowable 59,224 psi			
32%			
Pl+Pb+Q+F 21,568	Damage Ratio 0.018 Life		Primary+Secondary+Peak (Outer) Load Case 2 Stress Concentration Factor = 1.350

psi	0.364	Stress	Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 382,800. "B31" Fatigue Stress Allowable = 39375.0 Mark1 Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 796,443. WRC 474 99% Probability Cycles = 185,024. WRC 474 95% Probability Cycles = 256,887. BS5500 Allowed Cycles(Curve F) = 72,664. Membrane-to-Bending Ratio = 0.384 Bending-to-PL+PB+Q Ratio = 0.723 Plot Reference: 9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Allowable			
59,224			
psi			
36%			
Membrane	User		Component Evaluation Load Case 2
10,831	47,250		Min Prin. Stress = -17360. (89% Neg, 22% NegHi)
psi	psi		Plot Reference:
			10) Membrane < User (OPE,Membrane) Case 2
22%			
Bending	User		Component Evaluation Load Case 2
28,187	47,250		Min Prin. Stress = -17360. (89% Neg, 22% NegHi)
psi	psi		Plot Reference:
			11) Bending < User (OPE,Bending) Case 2
59%			
Branch Transition			
Pl	SPL		Primary Membrane Load Case 1
638	22,200		Min Prin. Stress = -359. (14% Neg, 0% NegHi)
psi	psi		Plot Reference:
			1) Pl < SPL (SUS,Membrane) Case 1
2%			
Qb	SPS		Primary Bending Load Case 1
536	47,250		Min Prin. Stress = -359. (14% Neg, 0% NegHi)
psi	psi		Plot Reference:
			2) Qb < SPS (SUS,Bending) Case 1
1%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 1
836	47,250		Min Prin. Stress = -359. (14% Neg, 0% NegHi)
psi	psi		Plot Reference:
			3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
1%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 1
1,053	47,250		Min Prin. Stress = -359. (14% Neg, 0% NegHi)
psi	psi		Plot Reference:
			4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
2%			
S1+S2+S3	4S		Part 5 (5.3.2) Load Case 1
1,116	59,200		Min Prin. Stress = -359. (14% Neg, 0% NegHi)
psi	psi		Plot Reference:
			5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
1%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 2
8,628	47,250		Min Prin. Stress = -10665. (98% Neg, 9% NegHi)
psi	psi		Plot Reference:
			6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
18%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 2
12,020	47,250		Min Prin. Stress = -10665. (98% Neg, 9% NegHi)
psi	psi		Plot Reference:
			7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
25%			
Pl+Pb+Q+F	Damage Ratio		Primary+Secondary+Peak (Inner) Load Case 2
4,314	0.000	Life	Stress Concentration Factor = 1.000
psi	0.073	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			Mark1 Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 39,475,240.
			WRC 474 99% Probability Cycles = 9,170,622.
			WRC 474 95% Probability Cycles = 12,732,448.
			BS5500 Allowed Cycles(Curve F) = 3,690,806.
			Membrane-to-Bending Ratio = 59.092
7%			Bending-to-PL+PB+Q Ratio = 0.017

Plot Reference:		
8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
6,010	0.000 Life	Stress Concentration Factor = 1.000
psi	0.101 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
59,224		"B31" Fatigue Stress Allowable = 39375.0
psi		Markl Fatigue Stress Allowable = 47828.5
10%		WRC 474 Mean Cycles to Failure = 14,355,947.
		WRC 474 99% Probability Cycles = 3,335,077.
		WRC 474 95% Probability Cycles = 4,630,400.
		BS5500 Allowed Cycles(Curve F) = 1,365,009.
		Membrane-to-Bending Ratio = 2.002
		Bending-to-PL+PB+Q Ratio = 0.333
Plot Reference:		
9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2		
Membrane	User	Component Evaluation Load Case 2
8,778	47,250	Min Prin. Stress = -10665. (98% Neg, 9% NegHi)
psi	psi	Plot Reference:
		10) Membrane < User (OPE,Membrane) Case 2
	18%	
Bending	User	Component Evaluation Load Case 2
4,107	47,250	Min Prin. Stress = -10665. (98% Neg, 9% NegHi)
psi	psi	Plot Reference:
		11) Bending < User (OPE,Bending) Case 2
	8%	
Header away from Junction		
Pl	SPL	Primary Membrane Load Case 1
3,980	22,200	Min Prin. Stress = -17. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
	17%	
Qb	SPS	Primary Bending Load Case 1
634	47,250	Min Prin. Stress = -17. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 1
	1%	
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 1
4,385	47,250	Min Prin. Stress = -17. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
	9%	
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 1
3,802	47,250	Min Prin. Stress = -17. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
	8%	
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 1
6,717	59,200	Min Prin. Stress = -17. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
	11%	
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
7,793	47,250	Min Prin. Stress = -3297. (81% Neg, 0% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
	16%	
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
7,262	47,250	Min Prin. Stress = -3297. (81% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
	15%	
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2
3,896	0.000 Life	Stress Concentration Factor = 1.000
psi	0.066 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
59,224		"B31" Fatigue Stress Allowable = 39375.0
psi		Markl Fatigue Stress Allowable = 47828.5
		WRC 474 Mean Cycles to Failure = 41,808,800.

6%			WRC 474 99% Probability Cycles = 9,712,739. WRC 474 95% Probability Cycles = 13,485,121. BS5500 Allowed Cycles(Curve F) = 5,008,518. Membrane-to-Bending Ratio = 0.344 Bending-to-PL+PB+Q Ratio = 0.744 Plot Reference: 8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Pl+Pb+Q+F 3,631 psi	Damage Ratio 0.000 Life 0.061 Stress		Primary+Secondary+Peak (Outer) Load Case 2 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 51,801,052. WRC 474 99% Probability Cycles = 12,034,084. WRC 474 95% Probability Cycles = 16,708,049. BS5500 Allowed Cycles(Curve F) = 6,190,345. Membrane-to-Bending Ratio = 0.305 Bending-to-PL+PB+Q Ratio = 0.766 Plot Reference: 9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Allowable 59,224 psi			
6%			
Membrane 2,631 psi	User 47,250 psi		Component Evaluation Load Case 2 Min Prin. Stress = -3297. (81% Neg, 0% NegHi) Plot Reference: 10) Membrane < User (OPE,Membrane) Case 2
	5%		
Bending 6,296 psi	User 47,250 psi		Component Evaluation Load Case 2 Min Prin. Stress = -3297. (81% Neg, 0% NegHi) Plot Reference: 11) Bending < User (OPE,Bending) Case 2
	13%		
Branch away from Junction			
Pl 713 psi	SPL 22,200 psi		Primary Membrane Load Case 1 Min Prin. Stress = -582. (43% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 1
	3%		
Qb 804 psi	SPS 47,250 psi		Primary Bending Load Case 1 Min Prin. Stress = -582. (43% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 1
	1%		
Pl+Pb+Q 1,415 psi	SPS 47,250 psi		Primary+Secondary (Inner) Load Case 1 Min Prin. Stress = -582. (43% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
	2%		
Pl+Pb+Q 1,446 psi	SPS 47,250 psi		Primary+Secondary (Outer) Load Case 1 Min Prin. Stress = -582. (43% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
	3%		
S1+S2+S3 1,229 psi	4S 59,200 psi		Part 5 (5.3.2) Load Case 1 Min Prin. Stress = -582. (43% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
	2%		
Pl+Pb+Q 7,664 psi	SPS 47,250 psi		Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -6369. (98% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
	16%		
Pl+Pb+Q 7,187 psi	SPS 47,250 psi		Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -6369. (98% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
	15%		
Pl+Pb+Q+F 3,832	Damage Ratio 0.000 Life		Primary+Secondary+Peak (Inner) Load Case 2 Stress Concentration Factor = 1.000

psi	0.065	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			MarkI Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 57,315,124.
			WRC 474 99% Probability Cycles = 13,315,077.
6%			WRC 474 95% Probability Cycles = 18,486,572.
			BS5500 Allowed Cycles(Curve F) = 5,265,690.
			Membrane-to-Bending Ratio = 12.001
			Bending-to-PL+PB+Q Ratio = 0.077
			Plot Reference:
			8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Pl+Pb+Q+F	Damage Ratio		Primary+Secondary+Peak (Outer) Load Case 2
3,593	0.000	Life	Stress Concentration Factor = 1.000
psi	0.061	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			MarkI Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 70,121,848.
			WRC 474 99% Probability Cycles = 16,290,251.
			WRC 474 95% Probability Cycles = 22,617,284.
6%			BS5500 Allowed Cycles(Curve F) = 6,385,288.
			Membrane-to-Bending Ratio = 10.294
			Bending-to-PL+PB+Q Ratio = 0.089
			Plot Reference:
			9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Membrane	User		Component Evaluation Load Case 2
7,386	47,250		Min Prin. Stress = -6369. (98% Neg, 0% NegHi)
psi	psi		Plot Reference:
			10) Membrane < User (OPE,Membrane) Case 2
	15%		
Bending	User		Component Evaluation Load Case 2
1,549	47,250		Min Prin. Stress = -6369. (98% Neg, 0% NegHi)
psi	psi		Plot Reference:
			11) Bending < User (OPE,Bending) Case 2
	3%		

[Table of Contents](#)

Stress Intensification Factors
 FEPIPE Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 11:22am OCT 23,2021

Stress Intensification Factors \$X

Branch/Nozzle Sif Summary

	Peak	Primary	Secondary	SSI
Axial :	8.652	6.409	12.817	1.643
Inplane :	2.914	2.159	4.318	1.428
Outplane:	3.449	2.555	5.110	1.329
Torsion :	0.630	0.816	0.933	0.794
Pressure:	1.347	1.583	1.995	1.071

The above stress intensification factors are to be used in a beam-type analysis of the piping system. Inplane, Outplane and Torsional sif's should be used with the matching branch pipe whose diameter and thickness is given below. The axial sif should be used to intensify the axial stress in the branch pipe calculated by F/A. The pressure sif should be used to intensify the nominal pressure stress in the PARENT or HEADER, calculated from PDo/2T. B31 calculations use mean diameters and Section VIII calculations use outside diameters. SSIs are based on peak stress factors and correlated test results.

Pipe OD : 2.375 in.
 Pipe Thk: 0.218 in.
 Z approx: 0.797 cu.in.
 Z exact : 0.731 cu.in.

(SSI = SIF ^x)	Axial	Inpl	Outpl	Tors	Pres
SIF/SSI Exponents:	0.861	0.719	0.758	0.439	1.543

SIF/SSI exponent based on relationship between primary and peak stress factors from the finite element analysis.

B31.3 Branch Pressure i-factor =	20.774
Header Pressure i-factor =	2.729

The B31.3 pressure i-factors should be used with with F/A, where F is the axial force due to pressure, and A is the area of the pipe wall. This is equivalent to finding the pressure stress from (ip) (PD/4T).

B31.3 (Branch)		
Peak Stress Sif	0.000	Axial
	4.338	Inplane
	5.600	Outplane
	1.000	Torsional
B31.1 (Branch)		
Peak Stress Sif	0.000	Axial
	2.286	Inplane
	2.286	Outplane
	2.286	Torsional
WRC 330 (Branch)		
Peak Stress Sif	0.000	Axial
	1.543	Inplane
	1.543	Outplane
	1.000	Torsional

[Table of Contents](#)

Allowable Loads		
FEPipe Version 15.0	Jobname: NOZZLE	\$P
Released Jan. 2021	11:22am OCT 23, 2021	

Allowable Loads	\$X
-----------------	-----

SECONDARY		Maximum	Conservative	Realistic
Load Type (Range):		Individual	Simultaneous	Simultaneous
		Occuring	Occuring	Occuring
Axial Force (lb.)		5448.	1679.	2518.
Inplane Moment (in. lb.)		8001.	1746.	3703.
Outplane Moment (in. lb.)		6760.	1475.	3129.
Torsional Moment (in. lb.)		37019.	11423.	17134.
Pressure (psi)		620.97	105.00	105.00

PRIMARY		Maximum	Conservative	Realistic
Load Type:		Individual	Simultaneous	Simultaneous
		Occuring	Occuring	Occuring
Axial Force (lb.)		5119.	1346.	2019.
Inplane Moment (in. lb.)		7518.	1398.	2965.
Outplane Moment (in. lb.)		6353.	1181.	2505.
Torsional Moment (in. lb.)		19884.	5227.	7841.
Pressure (psi)		367.69	105.00	105.00

NOTES:

- 1) Maximum Individual Occuring Loads are the maximum allowed values of the respective loads if all other load components are zero, i.e. the listed axial force may be applied if the inplane, outplane and torsional moments, and the pressure are zero.
- 2) The Conservative Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A conservative stress combination equation is used that typically produces stresses within 50-70% of the allowable stress.
- 3) The Realistic Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A more realistic stress combination equation is used

based on experience at Paulin Research. Stresses are typically produced within 80-105% of the allowable.

- 4) Secondary allowable loads are limits for expansion and operating piping loads.
- 5) Primary allowable loads are limits for weight, primary and sustained type piping loads.
- 6) High D/T low pressure systems may be subject to instability and should be checked when compressive stresses are present.

[Table of Contents](#)

Compressive Stress Summary

FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
11:22am OCT 23,2021

\$P

Compressive Stress Summary (psi)

\$X

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress
Pts in Region - No. of nodes in the model region
>5% Compression - 5% or more of Compressive Stress Limit
>50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = $-0.55 \text{ Min}(S_y, kE_t/R)$, Section slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	>5% Compression and Bending	>50% Compression and Bending	Region
1	SUSTAINED	1	-698.	888	31%	0%	Header Next to Nozzle Weld
2	OPERATING	2	-7973.	888	96%	3%	Header Next to Nozzle Weld
3	EXPANSION	2	-7973.	888	96%	3%	Header Next to Nozzle Weld
4	OPERATING	2	-7973.	888	96%	3%	Header Next to Nozzle Weld
5	SUSTAINED	1	-17.	840	0%	0%	Header away from Junction
6	OPERATING	2	-3297.	840	81%	0%	Header away from Junction
7	EXPANSION	2	-3297.	840	81%	0%	Header away from Junction
8	OPERATING	2	-3297.	840	81%	0%	Header away from Junction
9	SUSTAINED	1	-880.	840	58%	0%	Branch Next to Header Weld
10	OPERATING	2	-17360.	840	89%	22%	Branch Next to Header Weld
11	EXPANSION	2	-17360.	840	89%	22%	Branch Next to Header Weld
12	OPERATING	2	-17360.	840	89%	22%	Branch Next to Header Weld
13	SUSTAINED	1	-582.	192	43%	0%	Branch away from Junction
14	OPERATING	2	-6369.	192	98%	0%	Branch away from Junction
15	EXPANSION	2	-6369.	192	98%	0%	Branch away from Junction
16	OPERATING	2	-6369.	192	98%	0%	Branch away from Junction
17	SUSTAINED	1	-359.	1272	14%	0%	Branch Transition
18	OPERATING	2	-10665.	1272	98%	9%	Branch Transition
19	EXPANSION	2	-10665.	1272	98%	9%	Branch Transition
20	OPERATING	2	-10665.	1272	98%	9%	Branch Transition

[Table of Contents](#)

Flexibilities

FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
11:22am OCT 23,2021

\$P

Flexibilities

\$X

The following stiffnesses should be used in a piping, "beam-type" analysis of the intersection. The stiff-

nesses should be inserted at the surface of the branch/header or nozzle/vessel junction. The general characteristics used for the branch pipe should be:

Outside Diameter = 2.375 in.
Wall Thickness = 0.218 in.

Axial Translational Stiffness = 234689. lb./in.
Inplane Rotational Stiffness = 34219. in.lb./deg
Outplane Rotational Stiffness = 21211. in.lb./deg
Torsional Rotational Stiffness = 683221. in.lb./deg

Estimated Radial Shell Displacement due to Allowable Loads

SECONDARY:

Axial (in.) = 0.023 In-Plane (in.) = 0.004 Out-Plane (in.) = 0.006

PRIMARY

Axial (in.) = 0.022 In-Plane (in.) = 0.004 Out-Plane (in.) = 0.006

Secondary Conservative Displacement = 0.009 in.

Secondary Realistic Displacement = 0.016 in.

Primary Conservative Displacement = 0.008 in.

Primary Realistic Displacement = 0.012 in.

Intersection Flexibility Factors for Branch/Nozzle

:

Find axial stiffness: $K = 3EI/(kd)^3$ lb./in.

Find bending and torsional stiffnesses: $K = EI/(kd)$ in.lb.per radian.

The EI product is 0.24570E+08 lb.in.²

The value of (d) to use is: 2.157 in..

The resulting bending stiffness is in units of force x length per radian.

Axial Flexibility Factor (k) = 3.151

Inplane Flexibility Factor (k) = 5.810

Outplane Flexibility Factor (k) = 9.373

Torsional Flexibility Factor (k) = 0.291

[Table of Contents](#)


Finite Element Model

- [Finite Element Model](#)

Elements at Discontinuity


- [1\) \$Pl < SPL\$ \(SUS Membrane\) Case 1](#)
- [2\) \$Qb < SPS\$ \(SUS Bending\) Case 1](#)
- [3\) \$Pl+Pb+Q < SPS\$ \(SUS Inside\) Case 1](#)
- [4\) \$Pl+Pb+Q < SPS\$ \(SUS Outside\) Case 1](#)
- [5\) \$S1+S2+S3 < 4S\$ \(SUS \$S1+S2+S3\$ \) Case 1](#)
- [6\) \$Pl+Pb+Q < SPS\$ \(OPE Inside\) Case 2](#)
- [7\) \$Pl+Pb+Q < SPS\$ \(OPE Outside\) Case 2](#)
- [8\) \$Pl+Pb+Q+F < 2Sa\$ \(EXP Inside\) Case 2](#)
- [9\) \$Pl+Pb+Q+F < 2Sa\$ \(EXP Outside\) Case 2](#)
- [10\) Membrane < User \(OPE Membrane\) Case 2](#)
- [11\) Bending < User \(OPE Bending\) Case 2](#)
- [12\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 3](#)
- [13\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 4](#)
- [14\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 5](#)
- [15\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 6](#)
- [16\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 7](#)
- ---

Finite Element Model



3d


1) $P1 < SPL$ (SUS Membrane) Case 1



3d(Small)

3d


3d(Deformed)

2) $Q_b < \text{SPS}$ (SUS Bending) Case 1

3d(Small)

3d


3d(Deformed)

3) $P1+Pb+Q < \text{SPS}$ (SUS Inside) Case 1

3d(Small)

3d


3d(Deformed)

4) $P1+Pb+Q < SPS$ (SUS Outside) Case 1

3d(Small)

3d


3d(Deformed)

5) $S1+S2+S3 < 45$ (SUS $S1+S2+S3$) Case 1


3d(Small)

3d


3d(Deformed)

6) $P1+Pb+Q < SPS$ (OPE Inside) Case 2

3d(Deformed)

7) $P1+Pb+Q < SPS$ (OPE Outside) Case 2


3d(Deformed)

8) $P1+Pb+Q+F < 2Sa$ (EXP Inside) Case 2

3d(Small)

3d

3d(Deformed)


9) $P1+Pb+Q+F < 2Sa$ (EXP Outside) Case 2

3d(Small)

3d

3d(Deformed)

10) Membrane < User (OPE Membrane) Case 2




3d(Small)

3d

3d(Deformed)

11) Bending < User (OPE Bending) Case 2




3d(Small)

3d

3d(Deformed)

12) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 3




3d(Small)

3d

3d(Deformed)

13) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 4




3d(Small)

3d

3d(Deformed)

14) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 5




3d(Small)

3d

3d(Deformed)

15) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 6




3d(Small)

3d

3d(Deformed)

16) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 7



3d(Deformed)

3d(Small)

3d

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Sat Oct 23 10:48:56 2021.

- [Model Notes](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Stress Intensification Factors](#)
- [Allowable Loads](#)
- [Compressive Stress Summary](#)
- [Flexibilities](#)
- [Graphical Results](#)

Model Notes

Model Notes

Input Echo:

Description:

V-1264
Nozzle B3,B4 and S

Model Type : Cylindrical Shell

Parent Geometry

Parent Outside Diam. : 30.030 in.
Thickness : 0.394 in.

Parent Properties:

Cold Allowable : 16700.0 psi
Hot Allowable : 14800.0 psi
Material DB # 1071122.
Ultimate Tensile (Amb) : 70000.0 psi
Yield Strength (Amb) : 25000.0 psi
Yield Strength (Hot) : 16400.0 psi
Elastic Modulus (Amb) : 28300000.0 psi
Poissons Ratio : 0.300
Expansion Coefficient : 0.9700E-05 in./in./deg.
Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Nozzle Geometry

Nozzle Outside Diam. : 3.296 in.
Thickness : 0.656 in.
Length : 8.400 in.
Nozzle Tilt Angle : 0.000 deg.
Distance from Top : 29.520 in.
Distance from Bottom : 30.480 in.

Nozzle Properties

Cold Allowable : 16700.0 psi
Hot Allowable : 14800.0 psi
Material DB # 1070322.
Ultimate Tensile (Amb) : 65000.0 psi
Yield Strength (Amb) : 25000.0 psi
Yield Strength (Hot) : 16400.0 psi
Elastic Modulus (Amb) : 28300000.0 psi
Poissons Ratio : 0.300
Expansion Coefficient : 0.9700E-05 in./in./deg.
Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Design Operating Cycles : 7000.
 Ambient Temperature (Deg.) : 70.00

Uniform thermal expansion produces no stress in this geometry.
 Any thermal loads will come through operating forces and
 moments applied through the nozzle.

Nozzle Inside Temperature : 500.00 deg.
 Nozzle Outside Temperature : 500.00 deg.
 Vessel Inside Temperature : 500.00 deg.
 Vessel Outside Temperature : 500.00 deg.

Nozzle Pressure : 105.0 psi
 Vessel Pressure : 105.0 psi

Operating Pressure : 105.0 psi

The operating pressure is used for secondary and peak stress
 cases. The design pressure is used for primary cases. The ratio
 of the operating/design pressure = 1.000

User Defined Load Input Echo for the ATTACHMENT:
 Loads are given at the End of Nozzle
 Loads are defined in Local Coordinates

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	630.0	630.0	470.0	310.0	210.0	270.0

FEA Model Loads:

These are the actual Attachment loads applied to
 the FEA model.

These are the User Defined Loads translated to the
 end of the nozzle and reported in global coordinates.

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	630.0	630.0	470.0	310.0	210.0	270.0

The "top" or "positive" end of this model is "free" in
 the axial and translational directions.

Stresses ARE nodally AVERAGED.

No weld dimensions have been given for the nozzle
 connection to the shell. This will produce conservative
 results for external loads and may tend to produce more
 realistic inside surface pressure stresses.

Vessel Centerline Vector : 0.000 1.000 0.000
 Nozzle Orientation Vector : 1.000 0.000 0.000

[Table of Contents](#)

Load Case Report
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: NOZZLE
 10:47am OCT 23,2021

\$P

Load Case Report

\$X

Inner and outer element temperatures are the same
 throughout the model. No thermal ratcheting
 calculations will be performed.

THE 7 LOAD CASES ANALYZED ARE:

1 SUSTAINED (Pr Only)

Sustained case run to satisfy local primary
 membrane and bending stress limits.

```

/----- Loads in Case   1
  Pressure Case       1

2  OPERATING          (Fatigue Calc Performed)

Case run to compute the operating stresses used in
secondary, peak and range calculations as needed.

/----- Loads in Case   2
  Pressure Case       1
  Loads from (Operating)

3  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   3
  Loads from (Axial)

4  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   4
  Loads from (Inplane)

5  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   5
  Loads from (Outplane)

6  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   6
  Loads from (Torsion)

7  Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case   7
  Pressure Case       1

```

[Table of Contents](#)

Solution Data
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 10:48am OCT 23,2021

Solution Data

Maximum Solution Row Size = 1440
 Number of Nodes = 3852
 Number of Elements = 1276
 Number of Solution Cases = 7

Summation of Loads per Case

Case #	FX	FY	FZ
1	-250.	72438.	0.
2	380.	73068.	470.
3	108840.	0.	0.
4	0.	0.	0.
5	0.	0.	0.
6	0.	0.	0.
7	-250.	72438.	0.

[Table of Contents](#)

ASME Code Stress Output Plots
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 10:48am OCT 23,2021

ASME Code Stress Output Plots \$X

- 1) $P_l < S_{PL}$ (SUS,Membrane) Case 1
- 2) $Q_b < S_{PS}$ (SUS,Bending) Case 1
- 3) $P_l+P_b+Q < S_{PS}$ (SUS,Inside) Case 1
- 4) $P_l+P_b+Q < S_{PS}$ (SUS,Outside) Case 1
- 5) $S_1+S_2+S_3 < 4S$ (SUS, $S_1+S_2+S_3$) Case 1
- 6) $P_l+P_b+Q < S_{PS}$ (OPE,Inside) Case 2
- 7) $P_l+P_b+Q < S_{PS}$ (OPE,Outside) Case 2
- 8) $P_l+P_b+Q+F < 2S_a$ (EXP,Inside) Case 2
- 9) $P_l+P_b+Q+F < 2S_a$ (EXP,Outside) Case 2
- 10) Membrane < User (OPE,Membrane) Case 2
- 11) Bending < User (OPE,Bending) Case 2
- 12) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 3
- 13) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 4
- 14) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 5
- 15) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 6
- 16) $P_l+P_b+Q+F < 2S_a$ (SIF,Outside) Case 7

[Table of Contents](#)

Stress Results - Notes
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 10:48am OCT 23,2021

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = 1.000000
 Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. ($P_b=0$)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
 $S_1+S_2+S_3$ evaluation omitted from operating stress.
 Include $S_1+S_2+S_3$ evaluation in primary case evaluation.
 Bending stress NOT included for all $S_1+S_2+S_3$ calculations.

- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 10:48am OCT 23,2021

ASME Overstressed Areas \$X

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 10:48am OCT 23,2021

Highest Primary Stress Ratios \$X

Header Next to Nozzle Weld

Pl	SPL	Primary Membrane Load Case 1
4,218	22,200	Min Prin. Stress = -127. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
18%		

Branch Next to Header Weld

Pl	SPL	Primary Membrane Load Case 1
3,463	22,200	Min Prin. Stress = -1083. (76% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
15%		

Branch Transition

Pl	SPL	Primary Membrane Load Case 1
297	22,200	Min Prin. Stress = -338. (4% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
1%		

Header away from Junction

Pl	SPL	Primary Membrane Load Case 1
3,621	22,200	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
16%		

Branch away from Junction

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 1
1,008	47,250	Min Prin. Stress = -637. (52% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
2%		

[Table of Contents](#)

Highest Secondary Stress Ratios

FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 10:48am OCT 23,2021

Highest Secondary Stress Ratios \$X

Header Next to Nozzle Weld

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
23,791	47,250	Min Prin. Stress = -2710. (54% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
50%		

Branch Next to Header Weld

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
10,529	47,250	Min Prin. Stress = -3910. (80% Neg, 0% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
22%		

Branch Transition

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
2,769	47,250	Min Prin. Stress = -1783. (75% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
5%		

Header away from Junction

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
10,962	47,250	Min Prin. Stress = -1291. (11% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
23%		

Branch away from Junction

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
2,780	47,250	Min Prin. Stress = -2022. (81% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
5%		

[Table of Contents](#)

Highest Fatigue Stress Ratios

FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 10:48am OCT 23,2021

Highest Fatigue Stress Ratios \$X

Header Next to Nozzle Weld

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
16,059	0.003 Life	Stress Concentration Factor = 1.350
psi	0.271 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 2,412,290.
		"B31" Fatigue Stress Allowable = 39375.0

59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 1,291,659.
27%		WRC 474 99% Probability Cycles = 300,070.
		WRC 474 95% Probability Cycles = 416,615.
		BS5500 Allowed Cycles(Curve F) = 176,016.
		Membrane-to-Bending Ratio = 0.330
		Bending-to-PL+PB+Q Ratio = 0.752
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2

Branch Next to Header Weld

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2
7,107	0.000 Life	Stress Concentration Factor = 1.350
psi	0.120 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 10,998,750.
12%		WRC 474 99% Probability Cycles = 2,555,156.
		WRC 474 95% Probability Cycles = 3,547,562.
		BS5500 Allowed Cycles(Curve F) = 2,030,785.
		Membrane-to-Bending Ratio = 0.769
		Bending-to-PL+PB+Q Ratio = 0.565
		Plot Reference:
		8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2

Branch Transition

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
1,385	0.000 Life	Stress Concentration Factor = 1.000
psi	0.023 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 6.4626E8
2%		WRC 474 99% Probability Cycles = 1.5013E8
		WRC 474 95% Probability Cycles = 2.0845E8
		BS5500 Allowed Cycles(Curve F) = 5.6546E8
		Membrane-to-Bending Ratio = 4.451
		Bending-to-PL+PB+Q Ratio = 0.183
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2

Header away from Junction

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
5,481	0.000 Life	Stress Concentration Factor = 1.000
psi	0.093 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 13,034,872.
9%		WRC 474 99% Probability Cycles = 3,028,174.
		WRC 474 95% Probability Cycles = 4,204,298.
		BS5500 Allowed Cycles(Curve F) = 1,799,367.
		Membrane-to-Bending Ratio = 1.045
		Bending-to-PL+PB+Q Ratio = 0.489
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2

Branch away from Junction

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
1,390	0.000 Life	Stress Concentration Factor = 1.000
psi	0.023 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Markl Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 6.3878E8
2%		WRC 474 99% Probability Cycles = 1.4840E8
		WRC 474 95% Probability Cycles = 2.0604E8
		BS5500 Allowed Cycles(Curve F) = 5.5497E8
		Membrane-to-Bending Ratio = 4.574
		Bending-to-PL+PB+Q Ratio = 0.179
		Plot Reference:
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2

[Table of Contents](#)

Highest Stress Ratios Per Region

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

10:48am OCT 23,2021

Highest Stress Ratios Per Region

\$X

Header Next to Nozzle Weld

Pl 4,218 psi	SPS 22,200 psi	Primary Membrane Load Case 1 Min Prin. Stress = -127. (0% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 1
18%		
Qb 955 psi	SPS 47,250 psi	Primary Bending Load Case 1 Min Prin. Stress = -127. (0% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 1
2%		
Pl+Pb+Q 5,072 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 1 Min Prin. Stress = -127. (0% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
10%		
Pl+Pb+Q 3,757 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 1 Min Prin. Stress = -127. (0% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
7%		
S1+S2+S3 6,701 psi	4S 59,200 psi	Part 5 (5.3.2) Load Case 1 Min Prin. Stress = -127. (0% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
11%		
Pl+Pb+Q 17,676 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -2710. (54% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
37%		
Pl+Pb+Q 23,791 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -2710. (54% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
50%		
Pl+Pb+Q+F 11,931 psi	Damage Ratio 0.000 Life 0.201 Stress	Primary+Secondary+Peak (Inner) Load Case 2 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 3,537,844. WRC 474 99% Probability Cycles = 821,889. WRC 474 95% Probability Cycles = 1,141,106. BS5500 Allowed Cycles(Curve F) = 429,231. Membrane-to-Bending Ratio = 0.197 Bending-to-PL+PB+Q Ratio = 0.836 Plot Reference: 8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Allowable 59,224 psi		
20%		
Pl+Pb+Q+F 16,059 psi	Damage Ratio 0.003 Life 0.271 Stress	Primary+Secondary+Peak (Outer) Load Case 2 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 2,412,290. "B31" Fatigue Stress Allowable = 39375.0 MarkI Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 1,291,659.
Allowable 59,224 psi		

27%			WRC 474 99% Probability Cycles = 300,070. WRC 474 95% Probability Cycles = 416,615. BS5500 Allowed Cycles(Curve F) = 176,016. Membrane-to-Bending Ratio = 0.330 Bending-to-PL+PB+Q Ratio = 0.752 Plot Reference: 9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Membrane	User	Component Evaluation Load Case 2	
8,280	47,250	Min Prin. Stress = -2710. (54% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		10) Membrane < User (OPE,Membrane) Case 2	
17%			
Bending	User	Component Evaluation Load Case 2	
19,745	47,250	Min Prin. Stress = -2710. (54% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		11) Bending < User (OPE,Bending) Case 2	
41%			
Branch Next to Header Weld			
Pl	SPL	Primary Membrane Load Case 1	
3,463	22,200	Min Prin. Stress = -1083. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		1) Pl < SPL (SUS,Membrane) Case 1	
15%			
Qb	SPS	Primary Bending Load Case 1	
2,041	47,250	Min Prin. Stress = -1083. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		2) Qb < SPS (SUS,Bending) Case 1	
4%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 1	
5,405	47,250	Min Prin. Stress = -1083. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 1	
11%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 1	
2,643	47,250	Min Prin. Stress = -1083. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 1	
5%			
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 1	
4,007	59,200	Min Prin. Stress = -1083. (76% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1	
6%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2	
10,529	47,250	Min Prin. Stress = -3910. (80% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2	
22%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2	
8,905	47,250	Min Prin. Stress = -3910. (80% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2	
18%			
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2	
7,107	0.000 Life	Stress Concentration Factor = 1.350	
psi	0.120 Stress	Strain Concentration Factor = 1.000	
Allowable		Cycles Allowed for this Stress = 1.0000E11	
59,224		"B31" Fatigue Stress Allowable = 39375.0	
psi		Mark1 Fatigue Stress Allowable = 47828.5	
		WRC 474 Mean Cycles to Failure = 10,998,750.	
12%		WRC 474 99% Probability Cycles = 2,555,156.	
		WRC 474 95% Probability Cycles = 3,547,562.	
		BS5500 Allowed Cycles(Curve F) = 2,030,785.	
		Membrane-to-Bending Ratio = 0.769	
		Bending-to-PL+PB+Q Ratio = 0.565	
		Plot Reference:	
		8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2	
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2	
6,011	0.000 Life	Stress Concentration Factor = 1.350	

psi	0.101	Stress	Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 39375.0 Markl Fatigue Stress Allowable = 47828.5 WRC 474 Mean Cycles to Failure = 20,138,978. WRC 474 99% Probability Cycles = 4,678,552. WRC 474 95% Probability Cycles = 6,495,673. BS5500 Allowed Cycles(Curve F) = 3,356,506. Membrane-to-Bending Ratio = 0.376 Bending-to-PL+PB+Q Ratio = 0.727 Plot Reference: 9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Allowable			
59,224			
psi			
10%			
Membrane	User		Component Evaluation Load Case 2
6,117	47,250		Min Prin. Stress = -3910. (80% Neg, 0% NegHi)
psi	psi		Plot Reference:
			10) Membrane < User (OPE,Membrane) Case 2
12%			
Bending	User		Component Evaluation Load Case 2
7,897	47,250		Min Prin. Stress = -3910. (80% Neg, 0% NegHi)
psi	psi		Plot Reference:
			11) Bending < User (OPE,Bending) Case 2
16%			
Branch Transition			
Pl	SPL		Primary Membrane Load Case 1
297	22,200		Min Prin. Stress = -338. (4% Neg, 0% NegHi)
psi	psi		Plot Reference:
			1) Pl < SPL (SUS,Membrane) Case 1
1%			
Qb	SPS		Primary Bending Load Case 1
275	47,250		Min Prin. Stress = -338. (4% Neg, 0% NegHi)
psi	psi		Plot Reference:
			2) Qb < SPS (SUS,Bending) Case 1
0%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 1
344	47,250		Min Prin. Stress = -338. (4% Neg, 0% NegHi)
psi	psi		Plot Reference:
			3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
0%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 1
557	47,250		Min Prin. Stress = -338. (4% Neg, 0% NegHi)
psi	psi		Plot Reference:
			4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
1%			
S1+S2+S3	4S		Part 5 (5.3.2) Load Case 1
424	59,200		Min Prin. Stress = -338. (4% Neg, 0% NegHi)
psi	psi		Plot Reference:
			5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
0%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 2
1,922	47,250		Min Prin. Stress = -1783. (75% Neg, 0% NegHi)
psi	psi		Plot Reference:
			6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
4%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 2
2,769	47,250		Min Prin. Stress = -1783. (75% Neg, 0% NegHi)
psi	psi		Plot Reference:
			7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
5%			
Pl+Pb+Q+F	Damage Ratio		Primary+Secondary+Peak (Inner) Load Case 2
961	0.000	Life	Stress Concentration Factor = 1.000
psi	0.016	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			Markl Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 2.0320E9
			WRC 474 99% Probability Cycles = 4.7206E8
			WRC 474 95% Probability Cycles = 6.5541E8
			BS5500 Allowed Cycles(Curve F) = 3.5129E9
			Membrane-to-Bending Ratio = 5.180
1%			Bending-to-PL+PB+Q Ratio = 0.162

Plot Reference:		
8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2
1,385	0.000 Life	Stress Concentration Factor = 1.000
psi	0.023 Stress	Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11		
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Mark1 Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 6.4626E8
2%		WRC 474 99% Probability Cycles = 1.5013E8
		WRC 474 95% Probability Cycles = 2.0845E8
		BS5500 Allowed Cycles(Curve F) = 5.6546E8
		Membrane-to-Bending Ratio = 4.451
		Bending-to-PL+PB+Q Ratio = 0.183
Plot Reference:		
9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2		
Membrane	User	Component Evaluation Load Case 2
2,330	47,250	Min Prin. Stress = -1783. (75% Neg, 0% NegHi)
psi	psi	Plot Reference:
		10) Membrane < User (OPE,Membrane) Case 2
	4%	
Bending	User	Component Evaluation Load Case 2
684	47,250	Min Prin. Stress = -1783. (75% Neg, 0% NegHi)
psi	psi	Plot Reference:
		11) Bending < User (OPE,Bending) Case 2
	1%	
Header away from Junction		
Pl	SPL	Primary Membrane Load Case 1
3,621	22,200	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 1
	16%	
Qb	SPS	Primary Bending Load Case 1
594	47,250	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 1
	1%	
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 1
4,183	47,250	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 1
	8%	
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 1
3,593	47,250	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 1
	7%	
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 1
6,120	59,200	Min Prin. Stress = -11. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1
	10%	
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
10,184	47,250	Min Prin. Stress = -1291. (11% Neg, 0% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2
	21%	
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
10,962	47,250	Min Prin. Stress = -1291. (11% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2
	23%	
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2
5,092	0.000 Life	Stress Concentration Factor = 1.000
psi	0.086 Stress	Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11		
Allowable		"B31" Fatigue Stress Allowable = 39375.0
59,224		Mark1 Fatigue Stress Allowable = 47828.5
psi		WRC 474 Mean Cycles to Failure = 16,572,259.

8%			WRC 474 99% Probability Cycles = 3,849,956. WRC 474 95% Probability Cycles = 5,345,254. BS5500 Allowed Cycles(Curve F) = 2,244,170. Membrane-to-Bending Ratio = 1.030 Bending-to-PL+PB+Q Ratio = 0.493 Plot Reference: 8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 2	
5,481	0.000 Life	Stress Concentration Factor = 1.000	
psi	0.093 Stress	Strain Concentration Factor = 1.000	
Allowable		Cycles Allowed for this Stress = 1.0000E11	
59,224		"B31" Fatigue Stress Allowable = 39375.0	
psi		MarkI Fatigue Stress Allowable = 47828.5	
		WRC 474 Mean Cycles to Failure = 13,034,872.	
9%		WRC 474 99% Probability Cycles = 3,028,174.	
		WRC 474 95% Probability Cycles = 4,204,298.	
		BS5500 Allowed Cycles(Curve F) = 1,799,367.	
		Membrane-to-Bending Ratio = 1.045	
		Bending-to-PL+PB+Q Ratio = 0.489	
		Plot Reference:	
		9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2	
Membrane	User	Component Evaluation Load Case 2	
6,030	47,250	Min Prin. Stress = -1291. (11% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		10) Membrane < User (OPE,Membrane) Case 2	
12%			
Bending	User	Component Evaluation Load Case 2	
5,876	47,250	Min Prin. Stress = -1291. (11% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		11) Bending < User (OPE,Bending) Case 2	
12%			
Branch away from Junction			
Pl	SPL	Primary Membrane Load Case 1	
383	22,200	Min Prin. Stress = -637. (52% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		1) Pl < SPL (SUS,Membrane) Case 1	
1%			
Qb	SPS	Primary Bending Load Case 1	
733	47,250	Min Prin. Stress = -637. (52% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		2) Qb < SPS (SUS,Bending) Case 1	
1%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 1	
532	47,250	Min Prin. Stress = -637. (52% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 1	
1%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 1	
1,008	47,250	Min Prin. Stress = -637. (52% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 1	
2%			
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 1	
444	59,200	Min Prin. Stress = -637. (52% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 1	
0%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2	
2,115	47,250	Min Prin. Stress = -2022. (81% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 2	
4%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2	
2,780	47,250	Min Prin. Stress = -2022. (81% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 2	
5%			
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 2	
1,058	0.000 Life	Stress Concentration Factor = 1.000	

psi	0.018	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			MarkI Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 1.5023E9
			WRC 474 99% Probability Cycles = 3.4901E8
1%			WRC 474 95% Probability Cycles = 4.8457E8
			BS5500 Allowed Cycles(Curve F) = 2.1757E9
			Membrane-to-Bending Ratio = 5.588
			Bending-to-PL+PB+Q Ratio = 0.152
			Plot Reference:
			8) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 2
Pl+Pb+Q+F	Damage Ratio		Primary+Secondary+Peak (Outer) Load Case 2
1,390	0.000	Life	Stress Concentration Factor = 1.000
psi	0.023	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
59,224			"B31" Fatigue Stress Allowable = 39375.0
psi			MarkI Fatigue Stress Allowable = 47828.5
			WRC 474 Mean Cycles to Failure = 6.3878E8
			WRC 474 99% Probability Cycles = 1.4840E8
2%			WRC 474 95% Probability Cycles = 2.0604E8
			BS5500 Allowed Cycles(Curve F) = 5.5497E8
			Membrane-to-Bending Ratio = 4.574
			Bending-to-PL+PB+Q Ratio = 0.179
			Plot Reference:
			9) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 2
Membrane	User		Component Evaluation Load Case 2
2,416	47,250		Min Prin. Stress = -2022. (81% Neg, 0% NegHi)
psi	psi		Plot Reference:
			10) Membrane < User (OPE,Membrane) Case 2
	5%		
Bending	User		Component Evaluation Load Case 2
1,114	47,250		Min Prin. Stress = -2022. (81% Neg, 0% NegHi)
psi	psi		Plot Reference:
			11) Bending < User (OPE,Bending) Case 2
	2%		

[Table of Contents](#)

Stress Intensification Factors
 FEPIPE Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 10:48am OCT 23,2021

Stress Intensification Factors \$X

Branch/Nozzle Sif Summary

	Peak	Primary	Secondary	SSI
Axial :	20.708	15.339	30.679	3.346
Inplane :	4.584	3.395	6.791	2.767
Outplane:	6.332	4.690	9.380	2.548
Torsion :	0.651	0.936	0.965	1.345
Pressure:	0.911	1.053	1.350	1.631

The above stress intensification factors are to be used in a beam-type analysis of the piping system. Inplane, Outplane and Torsional sif's should be used with the matching branch pipe whose diameter and thickness is given below. The axial sif should be used to intensify the axial stress in the branch pipe calculated by F/A. The pressure sif should be used to intensify the nominal pressure stress in the PARENT or HEADER, calculated from PDo/2T. B31 calculations use mean diameters and Section VIII calculations use outside diameters. SSIs are based on peak stress factors and correlated test results.

Pipe OD :	3.296	in.
Pipe Thk:	0.656	in.
Z approx:	3.591	cu.in.
Z exact :	3.054	cu.in.

(SSI = SIF^x) Axial Inpl Outpl Tors Pres
 SIF/SSI Exponents: 0.901 0.803 0.837 0.154 -0.557

SIF/SSI exponent based on relationship between primary and peak stress factors from the finite element analysis.

B31.3 Branch Pressure i-factor = 34.547
 Header Pressure i-factor = 1.846

The B31.3 pressure i-factors should be used with with F/A, where F is the axial force due to pressure, and A is the area of the pipe wall. This is equivalent to finding the pressure stress from (ip) (PD/4T).

B31.3 (Branch)
 Peak Stress Sif 0.000 Axial
 13.052 Inplane
 16.847 Outplane
 1.000 Torsional

B31.1 (Branch)
 Peak Stress Sif 0.000 Axial
 6.712 Inplane
 6.712 Outplane
 6.712 Torsional

WRC 330 (Branch)
 Peak Stress Sif 0.000 Axial
 4.530 Inplane
 4.530 Outplane
 1.000 Torsional

[Table of Contents](#)

Allowable Loads
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 10:48am OCT 23,2021

Allowable Loads \$X

SECONDARY Load Type (Range):	Maximum Individual Occuring	Conservative Simultaneous Occuring	Realistic Simultaneous Occuring
Axial Force (lb.)	8381.	2572.	3858.
Inplane Moment (in. lb.)	21250.	4611.	9780.
Outplane Moment (in. lb.)	15385.	3338.	7081.
Torsional Moment (in. lb.)	149525.	44491.	66736.
Pressure (psi)	917.95	105.00	105.00

PRIMARY Load Type:	Maximum Individual Occuring	Conservative Simultaneous Occuring	Realistic Simultaneous Occuring
Axial Force (lb.)	7876.	2127.	3190.
Inplane Moment (in. lb.)	19969.	3812.	8087.
Outplane Moment (in. lb.)	14457.	2760.	5855.
Torsional Moment (in. lb.)	72432.	19557.	29335.
Pressure (psi)	552.64	105.00	105.00

NOTES:

- 1) Maximum Individual Occuring Loads are the maximum allowed values of the respective loads if all other load components are zero, i.e. the listed axial force may be applied if the inplane, outplane and torsional moments, and the pressure are zero.
- 2) The Conservative Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A conservative stress combination equation is used that typically produces stresses within 50-70% of the allowable stress.
- 3) The Realistic Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A more realistic stress combination equation is used

based on experience at Paulin Research. Stresses are typically produced within 80-105% of the allowable.

- 4) Secondary allowable loads are limits for expansion and operating piping loads.
- 5) Primary allowable loads are limits for weight, primary and sustained type piping loads.
- 6) High D/T low pressure systems may be subject to instability and should be checked when compressive stresses are present.

[Table of Contents](#)

Compressive Stress Summary

FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
10:48am OCT 23,2021

\$P

Compressive Stress Summary (psi)

\$X

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress
Pts in Region - No. of nodes in the model region
>5% Compression - 5% or more of Compressive Stress Limit
>50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = $-0.55 \text{ Min}(S_y, kE_t/R)$, Section slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	>5% Compression and Bending	>50% Compression and Bending	Region
1	SUSTAINED	1	-127.	840	0%	0%	Header Next to Nozzle Weld
2	OPERATING	2	-2710.	840	54%	0%	Header Next to Nozzle Weld
3	EXPANSION	2	-2710.	840	54%	0%	Header Next to Nozzle Weld
4	OPERATING	2	-2710.	840	54%	0%	Header Next to Nozzle Weld
5	SUSTAINED	1	-11.	1080	0%	0%	Header away from Junction
6	OPERATING	2	-1291.	1080	11%	0%	Header away from Junction
7	EXPANSION	2	-1291.	1080	11%	0%	Header away from Junction
8	OPERATING	2	-1291.	1080	11%	0%	Header away from Junction
9	SUSTAINED	1	-1083.	864	76%	0%	Branch Next to Header Weld
10	OPERATING	2	-3910.	864	80%	0%	Branch Next to Header Weld
11	EXPANSION	2	-3910.	864	80%	0%	Branch Next to Header Weld
12	OPERATING	2	-3910.	864	80%	0%	Branch Next to Header Weld
13	SUSTAINED	1	-637.	168	52%	0%	Branch away from Junction
14	OPERATING	2	-2022.	168	81%	0%	Branch away from Junction
15	EXPANSION	2	-2022.	168	81%	0%	Branch away from Junction
16	OPERATING	2	-2022.	168	81%	0%	Branch away from Junction
17	SUSTAINED	1	-338.	1080	4%	0%	Branch Transition
18	OPERATING	2	-1783.	1080	75%	0%	Branch Transition
19	EXPANSION	2	-1783.	1080	75%	0%	Branch Transition
20	OPERATING	2	-1783.	1080	75%	0%	Branch Transition

[Table of Contents](#)

Flexibilities

FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
10:48am OCT 23,2021

\$P

Flexibilities

\$X

The following stiffnesses should be used in a piping, "beam-type" analysis of the intersection. The stiff-

nesses should be inserted at the surface of the branch/header or nozzle/vessel junction. The general characteristics used for the branch pipe should be:

Outside Diameter = 3.296 in.
Wall Thickness = 0.656 in.

Axial Translational Stiffness = 299488. lb./in.
Inplane Rotational Stiffness = 70892. in.lb./deg
Outplane Rotational Stiffness = 35919. in.lb./deg
Torsional Rotational Stiffness = 1308894. in.lb./deg

Estimated Radial Shell Displacement due to Allowable Loads

SECONDARY:

Axial (in.) = 0.028 In-Plane (in.) = 0.007 Out-Plane (in.) = 0.010

PRIMARY

Axial (in.) = 0.026 In-Plane (in.) = 0.006 Out-Plane (in.) = 0.009

Secondary Conservative Displacement = 0.012 in.

Secondary Realistic Displacement = 0.021 in.

Primary Conservative Displacement = 0.010 in.

Primary Realistic Displacement = 0.017 in.

Intersection Flexibility Factors for Branch/Nozzle

:

Find axial stiffness: $K = 3EI/(kd)^3$ lb./in.

Find bending and torsional stiffnesses: $K = EI/(kd)$ in.lb.per radian.

The EI product is 0.14244E+09 lb.in.²

The value of (d) to use is: 2.640 in..

The resulting bending stiffness is in units of force x length per radian.

Axial Flexibility Factor (k) = 4.265

Inplane Flexibility Factor (k) = 13.284

Outplane Flexibility Factor (k) = 26.219

Torsional Flexibility Factor (k) = 0.720

[Table of Contents](#)


Finite Element Model

- [Finite Element Model](#)

Elements at Discontinuity


- [1\) \$Pl < SPL\$ \(SUS Membrane\) Case 1](#)
- [2\) \$Qb < SPS\$ \(SUS Bending\) Case 1](#)
- [3\) \$Pl+Pb+Q < SPS\$ \(SUS Inside\) Case 1](#)
- [4\) \$Pl+Pb+Q < SPS\$ \(SUS Outside\) Case 1](#)
- [5\) \$S1+S2+S3 < 4S\$ \(SUS \$S1+S2+S3\$ \) Case 1](#)
- [6\) \$Pl+Pb+Q < SPS\$ \(OPE Inside\) Case 2](#)
- [7\) \$Pl+Pb+Q < SPS\$ \(OPE Outside\) Case 2](#)
- [8\) \$Pl+Pb+Q+F < 2Sa\$ \(EXP Inside\) Case 2](#)
- [9\) \$Pl+Pb+Q+F < 2Sa\$ \(EXP Outside\) Case 2](#)
- [10\) Membrane < User \(OPE Membrane\) Case 2](#)
- [11\) Bending < User \(OPE Bending\) Case 2](#)
- [12\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 3](#)
- [13\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 4](#)
- [14\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 5](#)
- [15\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 6](#)
- [16\) \$Pl+Pb+Q+F < 2Sa\$ \(SIF Outside\) Case 7](#)
- ---

Finite Element Model



3d


1) P1 < SPL (SUS Membrane) Case 1



3d(Small)

3d


3d(Deformed)

2) $Q_b < SPS$ (SUS Bending) Case 1

3d(Small)

3d


3d(Deformed)

3) $P1+Pb+Q < SPS$ (SUS Inside) Case 1

3d(Small)

3d


3d(Deformed)

4) $P1+Pb+Q < SPS$ (SUS Outside) Case 1

3d(Small)

3d


3d(Deformed)

5) $S1+S2+S3 < 45$ (SUS $S1+S2+S3$) Case 1

3d(Small)

3d


3d(Deformed)

6) $P1+Pb+Q < SPS$ (OPE Inside) Case 2

3d(Small)

3d


3d(Deformed)

7) $P1+Pb+Q < SPS$ (OPE Outside) Case 2

3d(Small)

3d


3d(Deformed)

8) $P1+Pb+Q+F < 2Sa$ (EXP Inside) Case 2

3d(Small)

3d

3d(Deformed)


9) $P1+Pb+Q+F < 2Sa$ (EXP Outside) Case 2

3d(Small)

3d

3d(Deformed)

10) Membrane < User (OPE Membrane) Case 2




3d(Small)

3d

3d(Deformed)

11) Bending < User (OPE Bending) Case 2




3d(Small)

3d

3d(Deformed)

12) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 3




3d(Small)

3d

3d(Deformed)

13) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 4




3d(Small)

3d

3d(Deformed)

14) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 5




3d(Small)

3d

3d(Deformed)

15) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 6




3d(Small)

3d

3d(Deformed)

16) $P1+Pb+Q+F < 2Sa$ (SIF Outside) Case 7



•

3d(Deformed)

3d(Small)

3d

B 16.5 FLANGE RATING CALCULATION BASED ON EXTERNAL LOADING(STATIC)						
NOZZLE B1						
SL NO	DESCRIPTION		UNIT	VALUE		
1	Internal design pressure	P_D	barg	7.24	105 psig	
2	Internal design temperature	T	$^{\circ}C$	260	500 deg F	
3	Nozzle flange size		Inch	6		
4	Flange class selected	#		300#	adequate	A 182 Gr. F316L
5	Flange rating as per B16.5	P_R	barg	27.22	27.22 barg	
6	Static head	P_S	barg	0		
7	Gasket MOC :- Spiral Wound					
8	Gasket outside diameter	G_{od}	mm	209.55	As per table 21 of ASME B-16.20	
9	Gasket inside diameter	G_{id}	mm	182.6		
10	Axial external load	F	N	7117.5	725.8	Kgf
11	Maximum external longitudinal moment	M_L	N-m	2847.1	290.3	kgf-m
12	Maximum external circumferential moment	M_C	N-m	2169.2	221	kgf-m
13	Maximum external torsional moment	M_T	N-m	3253.82	331.8	kgf-m
14	Effective gasket width	b	mm	6.5		
15	Gasket load reaction diameter	G	mm	196.468		
16	Maximum external moment	M_{fs}	N-mm	3579314.7	Resultant Moment	
		p_m	N/mm ²	2.4		
	MAWP _{Reduction}	P_r	N/mm ²	0.2		
17	MAWP _{Reduction}	P_{eq}	N/mm ²	2.6		
18	MAWP _{Reduction}	P_{eq}	barg	26.385		
18	Code Case 2901 Moment Factor	F_M	-	0.5	As per Table 1 of Code Case 2901	
19	$MAWP_{EXT\ LOAD} = \text{Min. } [P_R, (P_R \times (1+F_M) - MAWP_{REDUCTION}) - P_S]$		barg	14.44		
Provided nozzle flange is safe for external loadings						

19	16 x MFS		N-mm	57269035.4
20	4 x F x G		N-mm	5593450.7
21	$PI \times G^3 \times (P_R - P_D) + F_M \times P_R$		N-mm	80027071.8
22	$16M_E + 4F_E G \leq \pi G^3 [(P_R - P_D) + F_M P_R]$		SAFE	

B 16.5 FLANGE RATING CALCULATION BASED ON EXTERNAL LOADING(STATIC)						
NOZZLE D 2"						
SL NO	DESCRIPTION		UNIT	VALUE		
1	Internal design pressure	P _D	barg	7.24	105 psig	
2	Internal design temperature	T	C°	260	500 deg F	
3	Nozzle flange size		Inch	2		
4	Flange class selected	#		600#	adequate	A 182 Gr. F316L
5	Flange rating as per B16.5	P _R	barg	54.34	54.34 barg	
6	Static head	P _S	barg	0.28559		
7	Gasket MOC :- Spiral Wound					
8	Gasket outside diameter	G _{od}	mm	85.90	As per table 21 of ASME B-16.20	
9	Gasket inside diameter	G _{id}	mm	69.9		
10	Axial external load	F	N	2802.38	285.8	Kgf
11	Maximum external longitudinal moment	M _L	N-m	366.055	37.3	kgf-m
12	Maximum external circumferential moment	M _C	N-m	284.7	29	kgf-m
13	Maximum external torsional moment	M _T	N-m	420.286	42.9	kgf-m
14	Effective gasket width	b	mm	4.0		
15	Gasket load reaction diameter	G	mm	77.900		
16	Maximum external moment	M _{fs}	N-mm	463741.4	Resultant Moment	
		p _m	N/mm2	5.0		
	MAWP _{Reduction}	P _r	N/mm2	0.6		
17	MAWP _{Reduction}	P _{eq}	N/mm2	5.6		
18	MAWP _{Reduction}	P _{eq}	barg	55.841		
18	Code Case 2901 Moment Factor	F _M	-	0.5	As per Table 1 of Code Case 2901	
19	MAWP _{EXT LOAD} = Min. [P _R , (P _R x (1+F _M)-MAWP _{REDUCTION})-P _S		barg	25.38		
Provided nozzle flange is safe for external loadings						

19	16 x MFS		N-mm	7419861.7
20	4 x F x G		N-mm	873221.6
21	PI X G ³ X (P _R - P _D) + F _M X P _R		N-mm	11030004.0
22	$16M_E + 4F_E G \leq \pi G^3 [(P_R - P_D) + F_M P_R]$		SAFE	

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Fri Dec 16 11:57:18 2022.

- [Model Notes](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Compressive Stress Summary](#)
- [Graphical Results](#)

Model Notes

Model Notes

Input Echo:

Description:

PLC-1A, PLC-1B, PLC-1C For Platform #1
 PLC-2A, PLC-2B, PLC-2C, PLC-2D, PLC-2F, PLC-2I For Platform #2
 PLC-3A, PLC-3B, PLC-3C, PLC-3D, PLC-3E For Platform #3

Model Type : Cylindrical Shell

Parent Geometry

Parent Outside Diam. : 30.037 in.
 Thickness : 0.394 in.
 Fillet Along Shell : 0.394 in.

Parent Properties:

Cold Allowable : 16693.8 psi
 Hot Allowable : 14793.9 psi
 Material DB # 1071122.
 Ultimate Tensile (Amb) : 69995.4 psi
 Yield Strength (Amb) : 25004.6 psi
 Yield Strength (Hot) : 16403.8 psi
 Elastic Modulus (Amb) : 28301000.0 psi
 Poissons Ratio : 0.300
 Expansion Coefficient : 0.9700E-05 in./in./deg.
 Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Structural Attachment Type : Longitudinal Lug

Thickness : 0.551 in.
 Height : 16.000 in.
 Length : 7.589 in.
 Rectangular Pad Width : 3.268 in.
 Rectangular Pad Height : 18.756 in.
 Rectangular Pad Thick : 0.394 in.
 Nozzle Tilt Angle : 0.000 deg.
 Distance from Top : 78.740 in.
 Distance from Bottom : 19.685 in.

Nozzle Properties

Cold Allowable : 20000.8 psi
 Hot Allowable : 20000.8 psi
 Material DB # 1016422.
 Ultimate Tensile (Amb) : 69995.4 psi
 Yield Strength (Amb) : 37999.9 psi
 Yield Strength (Hot) : 30994.6 psi
 Elastic Modulus (Amb) : 29402000.0 psi

Poissons Ratio : 0.300
 Expansion Coefficient : 0.7300E-05 in./in./deg.
 Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Design Operating Cycles : 7000.
 Ambient Temperature (Deg.) : 69.98

Thermal Stresses will be introduced into this analysis due to the differences in temperature and/or thermal expansion coefficients. The following temperatures have been specified for the analysis:

Nozzle Inside Temperature : 500.00 deg.
 Nozzle Outside Temperature : 500.00 deg.
 Vessel Inside Temperature : 500.00 deg.
 Vessel Outside Temperature : 500.00 deg.
 Nozzle Pressure : 105.2 psi
 Vessel Pressure : 105.2 psi

Operating Pressure : 10.1 psi

The operating pressure is used for secondary and peak stress cases. The design pressure is used for primary cases. The ratio of the operating/design pressure = 0.097

User Defined Load Input Echo for the ATTACHMENT:

Loads are given at the End of Nozzle
 Loads are defined in Global Coordinates

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	500.0	-3000.0	500.0	0.0	1000.0	7500.0

FEA Model Loads:

These are the actual Attachment loads applied to the FEA model.
 These are the User Defined Loads translated to the end of the nozzle and reported in global coordinates.

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	500.0	-3000.0	500.0	0.0	1000.0	7500.0

The "top" or "positive" end of this model is "free" in the axial and translational directions.

Stresses ARE nodally AVERAGED.

Vessel Centerline Vector : 0.000 1.000 0.000
 Nozzle Orientation Vector : 1.000 0.000 0.000

[Table of Contents](#)

Load Case Report
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 11:56am DEC 16,2022

Load Case Report \$X

Inner and outer element temperatures are the same throughout the model. No thermal ratcheting calculations will be performed.

THE 5 LOAD CASES ANALYZED ARE:

1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range between the installed and the operating states.

/----- Loads in Case 1
 Loads due to Weight

2 SUSTAINED (Wgt+Pr)

Sustained case run to satisfy local primary
membrane and bending stress limits.

/----- Loads in Case 2
 Loads due to Weight
 Pressure Case 1

3 Thermal ONLY

Thermal ONLY case run in the event expansion
stresses exceed the secondary stress allowable.

/----- Loads in Case 3
 Temperature Case 1
 Loads from (Thermal Only)

4 OPERATING

Case run to compute the operating stresses used in
secondary, peak and range calculations as needed.

/----- Loads in Case 4
 Pressure Case 1
 Temperature Case 1
 Loads from (Operating)

5 RANGE (Fatigue Calc Performed)

Case run to get the RANGE of stresses.
as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case 5
 Plus Stress Results from CASE 4
 Minus Stress Results from CASE 1

[Table of Contents](#)

Solution Data
FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 11:56am DEC 16,2022

Solution Data

Maximum Solution Row Size = 1482
Number of Nodes = 3707
Number of Elements = 1252
Number of Solution Cases = 4

Summation of Loads per Case

Case #	FX	FY	FZ
1	0.	0.	0.
2	0.	72568.	0.
3	0.	0.	0.
4	500.	69568.	500.

[Table of Contents](#)

ASME Code Stress Output Plots
FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 11:57am DEC 16,2022

ASME Code Stress Output Plots \$X

- 1) $P_l < S_{PL}$ (SUS,Membrane) Case 2
- 2) $Q_b < S_{PS}$ (SUS,Bending) Case 2
- 3) $P_l+P_b+Q < S_{PS}$ (SUS,Inside) Case 2
- 4) $P_l+P_b+Q < S_{PS}$ (SUS,Outside) Case 2
- 5) $S_1+S_2+S_3 < 4S$ (SUS, $S_1+S_2+S_3$) Case 2
- 6) $P_l+P_b+Q < S_{PS}$ (OPE,Inside) Case 4
- 7) $P_l+P_b+Q < S_{PS}$ (OPE,Outside) Case 4
- 8) Membrane < User (OPE,Membrane) Case 4
- 9) Bending < User (OPE,Bending) Case 4
- 10) $P_l+P_b+Q < S_{PS}$ (EXP,Inside) Case 5
- 11) $P_l+P_b+Q < S_{PS}$ (EXP,Outside) Case 5
- 12) $P_l+P_b+Q+F < 2S_a$ (EXP,Inside) Case 5
- 13) $P_l+P_b+Q+F < 2S_a$ (EXP,Outside) Case 5

[Table of Contents](#)

Stress Results - Notes

FEPipe Version 15.0

Released Jan. 2021

Jobname: NOZZLE

11:57am DEC 16,2022

\$P

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = $9.6528761E-02$
Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. ($P_b=0$)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
S1+S2+S3 evaluation omitted from operating stress.
Include S1+S2+S3 evaluation in primary case evaluation.
Bending stress NOT included for all S1+S2+S3 calculations.
- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas

FEPipe Version 15.0

Released Jan. 2021

Jobname: NOZZLE

11:57am DEC 16,2022

\$P

ASME Overstressed Areas

\$X

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

11:57am DEC 16,2022

Highest Primary Stress Ratios

\$X

Shell SCR at Plate # 1

Pl	SPL	Primary Membrane Load Case 2
3,514	22,191	Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
15%		

Long Plate SCR for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
458	30,995	Min Prin. Stress = -319. (15% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
1%		

Pad SCR for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
2,134	30,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
6%		

Shell in Plate # 1 Vicinity

Pl	SPL	Primary Membrane Load Case 2
3,500	22,191	Min Prin. Stress = -36. (1% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
15%		

Long Plate for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
218	30,995	Min Prin. Stress = -233. (7% Neg, 2% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
0%		

[Table of Contents](#)

Highest Secondary Stress Ratios

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

11:57am DEC 16,2022

Highest Secondary Stress Ratios

\$X

In combination case 5 the max range stress divided by the max component stress is 1.00. The case tensor components are NEVER additive and so the combination case will have LOWER stresses than the largest of any of the individual cases by between 1 and 20%.

Load Case	Combined/Max (Inside)	Combined/Max (Outside)
-----	-----	-----
5	1.000	1.000

Shell SCR at Plate # 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
15,746	47,232	Min Prin. Stress = -7404. (99% Neg, 20% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
33%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
15,746	47,232	Min Prin. Stress = -7404. (99% Neg, 20% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
33%		

Long Plate SCR for Plate # 1

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
24,624	68,995	Min Prin. Stress = -20807. (78% Neg, 56% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
35%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5
24,624	68,995	Min Prin. Stress = -20807. (78% Neg, 56% NegHi)
psi	psi	Plot Reference:
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
35%		

Pad SCR for Plate # 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
13,955	68,995	Min Prin. Stress = -8477. (99% Neg, 6% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
20%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
13,955	68,995	Min Prin. Stress = -8477. (99% Neg, 6% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
20%		

Shell in Plate # 1 Vicinity

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
10,418	47,232	Min Prin. Stress = -6676. (98% Neg, 29% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
22%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5
10,418	47,232	Min Prin. Stress = -6676. (98% Neg, 29% NegHi)
psi	psi	Plot Reference:
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
22%		

Long Plate for Plate # 1

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
24,549	68,995	Min Prin. Stress = -18996. (82% Neg, 30% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
35%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5
24,549	68,995	Min Prin. Stress = -18996. (82% Neg, 30% NegHi)

psi psi Plot Reference:
 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
 35%

[Table of Contents](#)

Highest Fatigue Stress Ratios
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 11:57am DEC 16,2022

Highest Fatigue Stress Ratios \$X

Shell SCR at Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
21,257	0.000 Life	Stress Concentration Factor = 1.350
psi	0.179 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 78719.4
118,449		Markl Fatigue Stress Allowable = 95657.0
psi		WRC 474 Mean Cycles to Failure = 4,399,098.
		WRC 474 99% Probability Cycles = 1,021,970.
17%		WRC 474 95% Probability Cycles = 1,418,897.
		BS5500 Allowed Cycles(Curve F) = 607,209.
		Membrane-to-Bending Ratio = 0.561
		Bending-to-PL+PB+Q Ratio = 0.641
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Long Plate SCR for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
33,243	0.039 Life	Stress Concentration Factor = 1.350
psi	0.396 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 181,117.
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		Markl Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 913,129.
		WRC 474 99% Probability Cycles = 212,132.
39%		WRC 474 95% Probability Cycles = 294,523.
		BS5500 Allowed Cycles(Curve F) = 141,596.
		Membrane-to-Bending Ratio = 2.014
		Bending-to-PL+PB+Q Ratio = 0.332
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

Pad SCR for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
18,839	0.000 Life	Stress Concentration Factor = 1.350
psi	0.224 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.7818E8
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		Markl Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 4,855,318.
		WRC 474 99% Probability Cycles = 1,127,956.
22%		WRC 474 95% Probability Cycles = 1,566,047.
		BS5500 Allowed Cycles(Curve F) = 777,958.
		Membrane-to-Bending Ratio = 0.405
		Bending-to-PL+PB+Q Ratio = 0.712
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Shell in Plate # 1 Vicinity

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
10,418	0.000 Life	Stress Concentration Factor = 1.000
psi	0.088 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 78719.4
118,449		Markl Fatigue Stress Allowable = 95657.0

psi	WRC 474 Mean Cycles to Failure = 16,193,779.
8%	WRC 474 99% Probability Cycles = 3,762,030.
	WRC 474 95% Probability Cycles = 5,223,179.
	BS5500 Allowed Cycles(Curve F) = 2,096,205.
	Membrane-to-Bending Ratio = 0.460
	Bending-to-PL+PB+Q Ratio = 0.685
	Plot Reference:
	12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

Long Plate for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
24,549	0.007 Life	Stress Concentration Factor = 1.000
psi	0.292 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 982,128.
83,994		"B31" Fatigue Stress Allowable = 100003.8
psi		MarkI Fatigue Stress Allowable = 83402.0
29%		WRC 474 Mean Cycles to Failure = 937,972.
		WRC 474 99% Probability Cycles = 217,903.
		WRC 474 95% Probability Cycles = 302,536.
		BS5500 Allowed Cycles(Curve F) = 142,898.
		Membrane-to-Bending Ratio = 0.984
		Bending-to-PL+PB+Q Ratio = 0.504
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

[Table of Contents](#)

Highest Stress Ratios Per Region

FEPipe Version 15.0	Jobname: NOZZLE	\$P
Released Jan. 2021	11:57am DEC 16,2022	

Highest Stress Ratios Per Region

\$X

Shell SCR at Plate # 1

Pl	SPL	Primary Membrane Load Case 2
3,514	22,191	Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
15%		1) Pl < SPL (SUS,Membrane) Case 2
Qb	SPS	Primary Bending Load Case 2
183	47,232	Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
0%		2) Qb < SPS (SUS,Bending) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
3,643	47,232	Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
7%		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
3,407	47,232	Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
7%		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2
5,987	59,176	Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
10%		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
8,860	47,232	Min Prin. Stress = -7404. (99% Neg, 20% NegHi)
psi	psi	Plot Reference:
18%		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4

15,746 psi	47,232 psi	Min Prin. Stress = -7404. (99% Neg, 20% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
33%		
Membrane 6,349 psi	User 47,232 psi	Component Evaluation Load Case 4 Min Prin. Stress = -7404. (99% Neg, 20% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
13%		
Bending 10,642 psi	User 47,232 psi	Component Evaluation Load Case 4 Min Prin. Stress = -7404. (99% Neg, 20% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 4
22%		
Pl+Pb+Q 8,860 psi	SPS 47,232 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -7404. (99% Neg, 20% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
18%		
Pl+Pb+Q 15,746 psi	SPS 47,232 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -7404. (99% Neg, 20% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
33%		
Pl+Pb+Q+F 11,961 psi	Damage Ratio 0.000 Life 0.101 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78719.4 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 27,584,562. WRC 474 99% Probability Cycles = 6,408,260. WRC 474 95% Probability Cycles = 8,897,189. BS5500 Allowed Cycles(Curve F) = 3,407,947. Membrane-to-Bending Ratio = 0.629 Bending-to-PL+PB+Q Ratio = 0.614 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable 118,449 psi		
10%		
Pl+Pb+Q+F 21,257 psi	Damage Ratio 0.000 Life 0.179 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78719.4 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 4,399,098. WRC 474 99% Probability Cycles = 1,021,970. WRC 474 95% Probability Cycles = 1,418,897. BS5500 Allowed Cycles(Curve F) = 607,209. Membrane-to-Bending Ratio = 0.561 Bending-to-PL+PB+Q Ratio = 0.641 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Allowable 118,449 psi		
17%		

Long Plate SCR for Plate # 1

Pl 458 psi	SPL 30,995 psi	Primary Membrane Load Case 2 Min Prin. Stress = -319. (15% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
1%		
Qb 0 psi	SPS 68,995 psi	Primary Bending Load Case 2 Min Prin. Stress = -319. (15% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q 458 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -319. (15% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
0%		
Pl+Pb+Q 458	SPS 68,995	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -319. (15% Neg, 0% NegHi)

psi	psi	Plot Reference:
0%		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
S1+S2+S3 503 psi	4S 80,003 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -319. (15% Neg, 0% NegHi) Plot Reference:
0%		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
Pl+Pb+Q 24,624 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -20807. (78% Neg, 56% NegHi) Plot Reference:
35%		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
Pl+Pb+Q 21,491 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -20807. (78% Neg, 56% NegHi) Plot Reference:
31%		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
Membrane 20,352 psi	User 68,995 psi	Component Evaluation Load Case 4 Min Prin. Stress = -20807. (78% Neg, 56% NegHi) Plot Reference:
29%		8) Membrane < User (OPE,Membrane) Case 4
Bending 11,558 psi	User 68,995 psi	Component Evaluation Load Case 4 Min Prin. Stress = -20807. (78% Neg, 56% NegHi) Plot Reference:
16%		9) Bending < User (OPE,Bending) Case 4
Pl+Pb+Q 24,624 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -20807. (78% Neg, 56% NegHi) Plot Reference:
35%		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
Pl+Pb+Q 21,491 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -20807. (78% Neg, 56% NegHi) Plot Reference:
31%		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
Pl+Pb+Q+F 33,243 psi	Damage Ratio 0.039 Life 0.396 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 181,117. "B31" Fatigue Stress Allowable = 100003.8 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 913,129. WRC 474 99% Probability Cycles = 212,132. WRC 474 95% Probability Cycles = 294,523. BS5500 Allowed Cycles(Curve F) = 141,596. Membrane-to-Bending Ratio = 2.014 Bending-to-PL+PB+Q Ratio = 0.332 Plot Reference:
Allowable 83,994 psi		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
39%		
Pl+Pb+Q+F 29,013 psi	Damage Ratio 0.021 Life 0.345 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 328,311. "B31" Fatigue Stress Allowable = 100003.8 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 1,398,207. WRC 474 99% Probability Cycles = 324,822. WRC 474 95% Probability Cycles = 450,982. BS5500 Allowed Cycles(Curve F) = 212,980. Membrane-to-Bending Ratio = 2.026 Bending-to-PL+PB+Q Ratio = 0.330 Plot Reference:
Allowable 83,994 psi		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
34%		
Pad SCR for Plate # 1		
Pl 2,134 psi	SPL 30,995 psi	Primary Membrane Load Case 2 Min Prin. Stress = -5. (0% Neg, 0% NegHi) Plot Reference:

		1) Pl < SPL (SUS,Membrane) Case 2
6%		
Qb	SPS	Primary Bending Load Case 2
238	68,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
2,218	68,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
3%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
2,100	68,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
3%		
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2
3,648	80,003	Min Prin. Stress = -5. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
4%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
13,034	68,995	Min Prin. Stress = -8477. (99% Neg, 6% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
18%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
13,955	68,995	Min Prin. Stress = -8477. (99% Neg, 6% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
20%		
Membrane	User	Component Evaluation Load Case 4
5,958	68,995	Min Prin. Stress = -8477. (99% Neg, 6% NegHi)
psi	psi	Plot Reference:
		8) Membrane < User (OPE,Membrane) Case 4
8%		
Bending	User	Component Evaluation Load Case 4
12,305	68,995	Min Prin. Stress = -8477. (99% Neg, 6% NegHi)
psi	psi	Plot Reference:
		9) Bending < User (OPE,Bending) Case 4
17%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5
13,034	68,995	Min Prin. Stress = -8477. (99% Neg, 6% NegHi)
psi	psi	Plot Reference:
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
18%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
13,955	68,995	Min Prin. Stress = -8477. (99% Neg, 6% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
20%		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
17,596	0.000 Life	Stress Concentration Factor = 1.350
psi	0.209 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 6.7690E8
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		MarkI Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 6,298,671.
		WRC 474 99% Probability Cycles = 1,463,266.
20%		WRC 474 95% Probability Cycles = 2,031,590.
		BS5500 Allowed Cycles(Curve F) = 954,796.
		Membrane-to-Bending Ratio = 0.422
		Bending-to-PL+PB+Q Ratio = 0.703
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
18,839	0.000 Life	Stress Concentration Factor = 1.350
psi	0.224 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.7818E8

Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		MarkI Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 4,855,318.
22%		WRC 474 99% Probability Cycles = 1,127,956.
		WRC 474 95% Probability Cycles = 1,566,047.
		BS5500 Allowed Cycles(Curve F) = 777,958.
		Membrane-to-Bending Ratio = 0.405
		Bending-to-PL+PB+Q Ratio = 0.712
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Shell in Plate # 1 Vicinity		
Pl	SPL	Primary Membrane Load Case 2
3,500	22,191	Min Prin. Stress = -36. (1% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
15%		
Qb	SPS	Primary Bending Load Case 2
205	47,232	Min Prin. Stress = -36. (1% Neg, 0% NegHi)
psi	psi	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
3,589	47,232	Min Prin. Stress = -36. (1% Neg, 0% NegHi)
psi	psi	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
7%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
3,557	47,232	Min Prin. Stress = -36. (1% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
7%		
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2
5,994	59,176	Min Prin. Stress = -36. (1% Neg, 0% NegHi)
psi	psi	Plot Reference:
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
10%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
10,418	47,232	Min Prin. Stress = -6676. (98% Neg, 29% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
22%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
10,306	47,232	Min Prin. Stress = -6676. (98% Neg, 29% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
21%		
Membrane	User	Component Evaluation Load Case 4
7,840	47,232	Min Prin. Stress = -6676. (98% Neg, 29% NegHi)
psi	psi	Plot Reference:
		8) Membrane < User (OPE,Membrane) Case 4
16%		
Bending	User	Component Evaluation Load Case 4
7,385	47,232	Min Prin. Stress = -6676. (98% Neg, 29% NegHi)
psi	psi	Plot Reference:
		9) Bending < User (OPE,Bending) Case 4
15%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5
10,418	47,232	Min Prin. Stress = -6676. (98% Neg, 29% NegHi)
psi	psi	Plot Reference:
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
22%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
10,306	47,232	Min Prin. Stress = -6676. (98% Neg, 29% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
21%		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
10,418	0.000 Life	Stress Concentration Factor = 1.000

psi	0.088	Stress	Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78719.4 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 16,193,779. WRC 474 99% Probability Cycles = 3,762,030. WRC 474 95% Probability Cycles = 5,223,179. BS5500 Allowed Cycles(Curve F) = 2,096,205. Membrane-to-Bending Ratio = 0.460 Bending-to-PL+PB+Q Ratio = 0.685 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable			
118,449			
psi			
8%			
Pl+Pb+Q+F	Damage Ratio		Primary+Secondary+Peak (Outer) Load Case 5
10,306	0.000	Life	Stress Concentration Factor = 1.000
psi	0.087	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
118,449			"B31" Fatigue Stress Allowable = 78719.4
psi			MarkI Fatigue Stress Allowable = 95657.0
8%			WRC 474 Mean Cycles to Failure = 16,079,411. WRC 474 99% Probability Cycles = 3,735,460. WRC 474 95% Probability Cycles = 5,186,290. BS5500 Allowed Cycles(Curve F) = 2,165,185. Membrane-to-Bending Ratio = 0.902 Bending-to-PL+PB+Q Ratio = 0.526 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Long Plate for Plate # 1			
Pl	SPL		Primary Membrane Load Case 2
218	30,995		Min Prin. Stress = -233. (7% Neg, 2% NegHi)
psi	psi		Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
0%			
Qb	SPS		Primary Bending Load Case 2
0	68,995		Min Prin. Stress = -233. (7% Neg, 2% NegHi)
psi	psi		Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
0%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 2
218	68,995		Min Prin. Stress = -233. (7% Neg, 2% NegHi)
psi	psi		Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
0%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 2
218	68,995		Min Prin. Stress = -233. (7% Neg, 2% NegHi)
psi	psi		Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
0%			
S1+S2+S3	4S		Part 5 (5.3.2) Load Case 2
-265	80,003		Min Prin. Stress = -233. (7% Neg, 2% NegHi)
psi	psi		Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
0%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 4
24,549	68,995		Min Prin. Stress = -18996. (82% Neg, 30% NegHi)
psi	psi		Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
35%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 4
18,669	68,995		Min Prin. Stress = -18996. (82% Neg, 30% NegHi)
psi	psi		Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
27%			
Membrane	User		Component Evaluation Load Case 4
12,197	68,995		Min Prin. Stress = -18996. (82% Neg, 30% NegHi)
psi	psi		Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
17%			
Bending	User		Component Evaluation Load Case 4
14,447	68,995		Min Prin. Stress = -18996. (82% Neg, 30% NegHi)
psi	psi		Plot Reference:

20% 9) Bending < User (OPE,Bending) Case 4

Pl+Pb+Q SPS Primary+Secondary (Inner) Load Case 5
 24,549 68,995 Min Prin. Stress = -18996. (82% Neg, 30% NegHi)
 psi psi Plot Reference:
 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5

35% Pl+Pb+Q SPS Primary+Secondary (Outer) Load Case 5
 18,669 68,995 Min Prin. Stress = -18996. (82% Neg, 30% NegHi)
 psi psi Plot Reference:
 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5

27% Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Inner) Load Case 5
 24,549 0.007 Life Stress Concentration Factor = 1.000
 psi 0.292 Stress Strain Concentration Factor = 1.000
 Allowable Cycles Allowed for this Stress = 982,128.
 83,994 "B31" Fatigue Stress Allowable = 100003.8
 psi MarkI Fatigue Stress Allowable = 83402.0
 WRC 474 Mean Cycles to Failure = 937,972.
 29% WRC 474 99% Probability Cycles = 217,903.
 WRC 474 95% Probability Cycles = 302,536.
 BS5500 Allowed Cycles(Curve F) = 142,898.
 Membrane-to-Bending Ratio = 0.984
 Bending-to-PL+PB+Q Ratio = 0.504
 Plot Reference:
 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Outer) Load Case 5
 18,669 0.000 Life Stress Concentration Factor = 1.000
 psi 0.222 Stress Strain Concentration Factor = 1.000
 Allowable Cycles Allowed for this Stress = 2.1271E8
 83,994 "B31" Fatigue Stress Allowable = 100003.8
 psi MarkI Fatigue Stress Allowable = 83402.0
 WRC 474 Mean Cycles to Failure = 2,395,198.
 22% WRC 474 99% Probability Cycles = 556,437.
 WRC 474 95% Probability Cycles = 772,554.
 BS5500 Allowed Cycles(Curve F) = 324,908.
 Membrane-to-Bending Ratio = 0.318
 Bending-to-PL+PB+Q Ratio = 0.759
 Plot Reference:
 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

[Table of Contents](#)

Compressive Stress Summary
 FEPIPE Version 15.0
 Released Jan. 2021

Jobname: NOZZLE
 11:57am DEC 16,2022

\$P

Compressive Stress Summary (psi)

\$X

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress
 Pts in Region - No. of nodes in the model region
 >5% Compression - 5% or more of Compressive Stress Limit
 >50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = -0.55 Min(Sy, kEt/R), Section
 slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	>5% Compression and Bending	>50% Compression	Region
1	SUSTAINED	2	-36.	1220	1%	0%	Shell in Plate # 1 Vicinity
2	OPERATING	4	-6676.	1220	98%	29%	Shell in Plate # 1 Vicinity
3	EXPANSION	5	-6676.	1220	98%	29%	Shell in Plate # 1 Vicinity
4	SUSTAINED	2	-2.	236	0%	0%	Shell SCR at Plate # 1
5	OPERATING	4	-7404.	236	99%	20%	Shell SCR at Plate # 1
6	EXPANSION	5	-7404.	236	99%	20%	Shell SCR at Plate # 1
7	SUSTAINED	2	-5.	300	0%	0%	Pad SCR for Plate # 1
8	OPERATING	4	-8477.	300	99%	6%	Pad SCR for Plate # 1

9	EXPANSION	5	-8477.	300	99%	6%	Pad SCR for Plate # 1
10	SUSTAINED	2	-319.	32	15%	0%	Long Plate SCR for Plate # 1
11	OPERATING	4	-20807.	32	78%	56%	Long Plate SCR for Plate # 1
12	EXPANSION	5	-20807.	32	78%	56%	Long Plate SCR for Plate # 1
13	SUSTAINED	2	-233.	40	7%	2%	Long Plate for Plate # 1
14	OPERATING	4	-18996.	40	82%	30%	Long Plate for Plate # 1
15	EXPANSION	5	-18996.	40	82%	30%	Long Plate for Plate # 1

[Table of Contents](#)



Finite Element Model

- [Finite Element Model](#)

Area of Discontinuity at Plate



- [1\) PI < SPL \(SUS Membrane\) Case 2](#)
- [2\) Qb < SPS \(SUS Bending\) Case 2](#)
- [3\) PI+Pb+Q < SPS \(SUS Inside\) Case 2](#)
- [4\) PI+Pb+Q < SPS \(SUS Outside\) Case 2](#)
- [5\) S1+S2+S3 < 4S \(SUS S1+S2+S3\) Case 2](#)
- [6\) PI+Pb+Q < SPS \(OPE Inside\) Case 4](#)
- [7\) PI+Pb+Q < SPS \(OPE Outside\) Case 4](#)
- [8\) Membrane < User \(OPE Membrane\) Case 4](#)
- [9\) Bending < User \(OPE Bending\) Case 4](#)
- [10\) PI+Pb+Q < SPS \(EXP Inside\) Case 5](#)
- [11\) PI+Pb+Q < SPS \(EXP Outside\) Case 5](#)
- [12\) PI+Pb+Q+F < 2Sa \(EXP Inside\) Case 5](#)
- [13\) PI+Pb+Q+F < 2Sa \(EXP Outside\) Case 5](#)

Finite Element Model



3d

1) P1 < SPL (SUS Membrane) Case 2





3d(Small)

3d

3d(Deformed)



2) Qb < SPS (SUS Bending) Case 2



3d(Small)

3d



3d(Deformed)

3) $P1+Pb+Q < SPS$ (SUS Inside) Case 2

3d(Small)

3d



3d(Deformed)

4) $P1+Pb+Q < SPS$ (SUS Outside) Case 2

3d(Small)

3d



3d(Deformed)

5) $S1+S2+S3 < 4S$ (SUS $S1+S2+S3$) Case 2

3d(Small)

3d

3d(Deformed)


6) $P1+Pb+Q < SPS$ (OPE Inside) Case 4

3d(Small)


3d

3d(Deformed)


7) P1+Pb+Q < SPS (OPE Outside) Case 4




8) Membrane < User (OPE Membrane) Case 4





9) Bending < User (OPE Bending) Case 4




10) P1+Pb+Q < SPS (EXP Inside) Case 5



11) $P_l + P_b + Q < SPS$ (EXP Outside) Case 512) $P_l + P_b + Q + F < 2S_a$ (EXP Inside) Case 5

13) $P_l + P_b + Q + F < 2S_a$ (EXP Outside) Case 5



3d(Small)

3d

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Fri Dec 16 12:09:50 2022.

- [Model Notes](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Compressive Stress Summary](#)
- [Graphical Results](#)

Model Notes

Model Notes

Input Echo:

Description:

PLC-1D,E,F For Platform #1
 PLC-2E,G,H For Platform #2
 PLC-3F For Platform #3

Model Type : Cylindrical Shell

Parent Geometry

Parent Outside Diam. : 30.037 in.
 Thickness : 0.394 in.
 Fillet Along Shell : 0.394 in.

Parent Properties:

Cold Allowable : 16693.8 psi
 Hot Allowable : 14793.9 psi
 Material DB # 1071122.
 Ultimate Tensile (Amb) : 69995.4 psi
 Yield Strength (Amb) : 25004.6 psi
 Yield Strength (Hot) : 16403.8 psi
 Elastic Modulus (Amb) : 28301000.0 psi
 Poissons Ratio : 0.300
 Expansion Coefficient : 0.9700E-05 in./in./deg.
 Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Structural Attachment Type : "I" Beam

Flange Thickness : 0.394 in.
 Flange Width : 6.496 in.
 Web Thickness : 0.394 in.
 Web Height : 7.913 in.
 Length : 3.329 in.

Rectangular Pad Width : 8.425 in.
 Rectangular Pad Height : 12.795 in.
 Rectangular Pad Thick : 0.394 in.
 Nozzle Tilt Angle : 0.000 deg.
 Distance from Top : 49.213 in.
 Distance from Bottom : 49.212 in.

Nozzle Properties

Cold Allowable : 20000.8 psi
 Hot Allowable : 20000.8 psi
 Material DB # 1016422.
 Ultimate Tensile (Amb) : 69995.4 psi
 Yield Strength (Amb) : 37999.9 psi

Yield Strength (Hot) : 30994.6 psi
 Elastic Modulus (Amb) : 29402000.0 psi
 Poissons Ratio : 0.300
 Expansion Coefficient : 0.7300E-05 in./in./deg.
 Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Design Operating Cycles : 7000.
 Ambient Temperature (Deg.) : 69.98

Thermal Stresses will be introduced into this analysis due to the differences in temperature and/or thermal expansion coefficients. The following temperatures have been specified for the analysis:

Nozzle Inside Temperature : 500.00 deg.
 Nozzle Outside Temperature : 500.00 deg.
 Vessel Inside Temperature : 500.00 deg.
 Vessel Outside Temperature : 500.00 deg.
 Nozzle Pressure : 105.2 psi
 Vessel Pressure : 105.2 psi

Operating Pressure : 10.1 psi

The operating pressure is used for secondary and peak stress cases. The design pressure is used for primary cases. The ratio of the operating/design pressure = 0.097

User Defined Load Input Echo for the ATTACHMENT:
 Loads are given at the End of Nozzle
 Loads are defined in Global Coordinates

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	1000.0	-4000.0	1000.0	0.0	3000.0	12500.0

FEA Model Loads:

These are the actual Attachment loads applied to the FEA model.

These are the User Defined Loads translated to the end of the nozzle and reported in global coordinates.

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	1000.0	-4000.0	1000.0	0.0	3000.0	12500.0

The "top" or "positive" end of this model is "free" in the axial and translational directions.

Stresses ARE nodally AVERAGED.

Vessel Centerline Vector : 0.000 1.000 0.000
 Nozzle Orientation Vector : 1.000 0.000 0.000

[Table of Contents](#)

Load Case Report
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: NOZZLE
 12:08am DEC 16,2022

\$P

Load Case Report

\$X

Inner and outer element temperatures are the same throughout the model. No thermal ratcheting calculations will be performed.

THE 5 LOAD CASES ANALYZED ARE:

1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range between the installed and the operating states.

```

/----- Loads in Case  1
  Loads due to Weight

2  SUSTAINED      (Wgt+Pr)

Sustained case run to satisfy local primary
membrane and bending stress limits.

/----- Loads in Case  2
  Loads due to Weight
  Pressure Case    1

3  Thermal ONLY

Thermal ONLY case run in the event expansion
stresses exceed the secondary stress allowable.

/----- Loads in Case  3
  Temperature Case  1
  Loads from (Thermal Only)

4  OPERATING

Case run to compute the operating stresses used in
secondary, peak and range calculations as needed.

/----- Loads in Case  4
  Pressure Case    1
  Temperature Case  1
  Loads from (Operating)

5  RANGE          (Fatigue Calc Performed)

Case run to get the RANGE of stresses.
as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case  5
  Plus Stress Results from CASE  4
  Minus Stress Results from CASE  1

```

[Table of Contents](#)

```

Solution Data
FEPipe Version 15.0          Jobname: NOZZLE          $P
Released Jan. 2021          12:09am DEC 16,2022

```

Solution Data

```

Maximum Solution Row Size = 1890
Number of Nodes           = 5167
Number of Elements        = 1740
Number of Solution Cases  = 4

```

Summation of Loads per Case

Case #	FX	FY	FZ
1	0.	0.	0.
2	0.	72568.	0.
3	0.	0.	0.
4	1000.	68568.	1000.

[Table of Contents](#)

```

ASME Code Stress Output Plots
FEPipe Version 15.0          Jobname: NOZZLE          $P
Released Jan. 2021          12:09am DEC 16,2022

```

ASME Code Stress Output Plots

\$X

- 1) $P_1 < SPL$ (SUS,Membrane) Case 2
- 2) $Q_b < SPS$ (SUS,Bending) Case 2
- 3) $P_1+P_b+Q < SPS$ (SUS,Inside) Case 2
- 4) $P_1+P_b+Q < SPS$ (SUS,Outside) Case 2
- 5) $S_1+S_2+S_3 < 4S$ (SUS, $S_1+S_2+S_3$) Case 2
- 6) $P_1+P_b+Q < SPS$ (OPE,Inside) Case 4
- 7) $P_1+P_b+Q < SPS$ (OPE,Outside) Case 4
- 8) Membrane < User (OPE,Membrane) Case 4
- 9) Bending < User (OPE,Bending) Case 4
- 10) $P_1+P_b+Q < SPS$ (EXP,Inside) Case 5
- 11) $P_1+P_b+Q < SPS$ (EXP,Outside) Case 5
- 12) $P_1+P_b+Q+F < 2S_a$ (EXP,Inside) Case 5
- 13) $P_1+P_b+Q+F < 2S_a$ (EXP,Outside) Case 5

[Table of Contents](#)

Stress Results - Notes

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

12:09am DEC 16,2022

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = $9.6528761E-02$
Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. ($P_b=0$)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
 $S_1+S_2+S_3$ evaluation omitted from operating stress.
 Include $S_1+S_2+S_3$ evaluation in primary case evaluation.
 Bending stress NOT included for all $S_1+S_2+S_3$ calculations.
- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

12:09am DEC 16,2022

ASME Overstressed Areas

\$X

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

12:09am DEC 16,2022

Highest Primary Stress Ratios

\$X

Shell SCR at Plate # 1

Pl	SPL	Primary Membrane Load Case 2
3,618	22,191	Min Prin. Stress = -3. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
16%		

Circ Plate SCR for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
485	30,995	Min Prin. Stress = -540. (64% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
1%		

Long Plate SCR for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
199	30,995	Min Prin. Stress = -94. (23% Neg, 13% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
0%		

Pad SCR for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
2,108	30,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
6%		

Shell in Plate # 1 Vicinity

Pl	SPL	Primary Membrane Load Case 2
3,465	22,191	Min Prin. Stress = -4. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
15%		

Circ Plate for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
179	30,995	Min Prin. Stress = -132. (99% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
0%		

Long Plate for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
----	-----	------------------------------

20%			11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
Pad SCR for Plate # 1			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4	
22,408	68,995	Min Prin. Stress = -14138. (98% Neg, 9% NegHi)	
psi	psi	Plot Reference:	
32%			7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5	
22,408	68,995	Min Prin. Stress = -14138. (98% Neg, 9% NegHi)	
psi	psi	Plot Reference:	
32%			11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
Shell in Plate # 1 Vicinity			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
18,397	47,232	Min Prin. Stress = -9147. (98% Neg, 49% NegHi)	
psi	psi	Plot Reference:	
38%			6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5	
18,397	47,232	Min Prin. Stress = -9147. (98% Neg, 49% NegHi)	
psi	psi	Plot Reference:	
38%			10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
Circ Plate for Plate # 1			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
18,204	68,995	Min Prin. Stress = -17799. (99% Neg, 58% NegHi)	
psi	psi	Plot Reference:	
26%			6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5	
18,204	68,995	Min Prin. Stress = -17799. (99% Neg, 58% NegHi)	
psi	psi	Plot Reference:	
26%			10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
Long Plate for Plate # 1			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4	
3,716	68,995	Min Prin. Stress = -1039. (99% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
5%			7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5	
3,716	68,995	Min Prin. Stress = -1039. (99% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
5%			11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
Pad for Plate # 1			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
11,809	68,995	Min Prin. Stress = -7721. (99% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
17%			6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5	
11,809	68,995	Min Prin. Stress = -7721. (99% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
17%			10) Pl+Pb+Q < SPS (EXP,Inside) Case 5

Highest Fatigue Stress Ratios
 FEPIPE Version 15.0
 Released Jan. 2021

Jobname: NOZZLE
 12:09am DEC 16,2022

\$P

Highest Fatigue Stress Ratios

\$X

Shell SCR at Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
36,580	0.007 Life	Stress Concentration Factor = 1.350
psi	0.309 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1,003,418.
Allowable		"B31" Fatigue Stress Allowable = 78719.4
118,449		Markl Fatigue Stress Allowable = 95657.0
psi		WRC 474 Mean Cycles to Failure = 818,100.
		WRC 474 99% Probability Cycles = 190,056.
30%		WRC 474 95% Probability Cycles = 263,872.
		BS5500 Allowed Cycles(Curve F) = 119,145.
		Membrane-to-Bending Ratio = 0.504
		Bending-to-PL+PB+Q Ratio = 0.665
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Circ Plate SCR for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
39,907	0.076 Life	Stress Concentration Factor = 1.350
psi	0.475 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 91,518.
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		Markl Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 628,939.
		WRC 474 99% Probability Cycles = 146,111.
47%		WRC 474 95% Probability Cycles = 202,860.
		BS5500 Allowed Cycles(Curve F) = 81,845.
		Membrane-to-Bending Ratio = 34.017
		Bending-to-PL+PB+Q Ratio = 0.029
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

Long Plate SCR for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
19,276	0.000 Life	Stress Concentration Factor = 1.350
psi	0.229 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.1385E8
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		Markl Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 6,109,608.
		WRC 474 99% Probability Cycles = 1,419,344.
22%		WRC 474 95% Probability Cycles = 1,970,609.
		BS5500 Allowed Cycles(Curve F) = 726,280.
		Membrane-to-Bending Ratio = 62.149
		Bending-to-PL+PB+Q Ratio = 0.016
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Pad SCR for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
30,251	0.026 Life	Stress Concentration Factor = 1.350
psi	0.360 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 271,291.
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		Markl Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 1,090,482.
		WRC 474 99% Probability Cycles = 253,334.
36%		WRC 474 95% Probability Cycles = 351,727.
		BS5500 Allowed Cycles(Curve F) = 187,891.
		Membrane-to-Bending Ratio = 0.246
		Bending-to-PL+PB+Q Ratio = 0.803
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Shell in Plate # 1 Vicinity

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
18,397	0.000 Life	Stress Concentration Factor = 1.000
psi	0.155 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 78719.4
118,449		Mark1 Fatigue Stress Allowable = 95657.0
psi		WRC 474 Mean Cycles to Failure = 2,639,187.
		WRC 474 99% Probability Cycles = 613,119.
15%		WRC 474 95% Probability Cycles = 851,250.
		BS5500 Allowed Cycles(Curve F) = 380,717.
		Membrane-to-Bending Ratio = 0.884
		Bending-to-PL+PB+Q Ratio = 0.531
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

Circ Plate for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
18,204	0.000 Life	Stress Concentration Factor = 1.000
psi	0.217 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 3.4832E8
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		Mark1 Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 2,861,712.
		WRC 474 99% Probability Cycles = 664,814.
21%		WRC 474 95% Probability Cycles = 923,024.
		BS5500 Allowed Cycles(Curve F) = 350,453.
		Membrane-to-Bending Ratio = 30.150
		Bending-to-PL+PB+Q Ratio = 0.032
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

Long Plate for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
3,716	0.000 Life	Stress Concentration Factor = 1.000
psi	0.044 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		Mark1 Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 4.1083E8
		WRC 474 99% Probability Cycles = 95,440,648.
4%		WRC 474 95% Probability Cycles = 1.3251E8
		BS5500 Allowed Cycles(Curve F) = 1.0749E8
		Membrane-to-Bending Ratio = 19.489
		Bending-to-PL+PB+Q Ratio = 0.049
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Pad for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
11,809	0.000 Life	Stress Concentration Factor = 1.000
psi	0.141 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 100003.8
83,994		Mark1 Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 7,518,001.
		WRC 474 99% Probability Cycles = 1,746,533.
14%		WRC 474 95% Probability Cycles = 2,424,876.
		BS5500 Allowed Cycles(Curve F) = 1,283,632.
		Membrane-to-Bending Ratio = 0.608
		Bending-to-PL+PB+Q Ratio = 0.622
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

[Table of Contents](#)

Highest Stress Ratios Per Region

\$X

Shell SCR at Plate # 1

P1 3,618 psi	SPL 22,191 psi	Primary Membrane Load Case 2 Min Prin. Stress = -3. (0% Neg, 0% NegHi) Plot Reference: 1) P1 < SPL (SUS,Membrane) Case 2
16%		
Qb 257 psi	SPS 47,232 psi	Primary Bending Load Case 2 Min Prin. Stress = -3. (0% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
0%		
P1+Pb+Q 3,775 psi	SPS 47,232 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -3. (0% Neg, 0% NegHi) Plot Reference: 3) P1+Pb+Q < SPS (SUS,Inside) Case 2
7%		
P1+Pb+Q 3,493 psi	SPS 47,232 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -3. (0% Neg, 0% NegHi) Plot Reference: 4) P1+Pb+Q < SPS (SUS,Outside) Case 2
7%		
S1+S2+S3 5,942 psi	4S 59,176 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -3. (0% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
10%		
P1+Pb+Q 24,003 psi	SPS 47,232 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -14597. (99% Neg, 53% NegHi) Plot Reference: 6) P1+Pb+Q < SPS (OPE,Inside) Case 4
50%		
P1+Pb+Q 27,096 psi	SPS 47,232 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -14597. (99% Neg, 53% NegHi) Plot Reference: 7) P1+Pb+Q < SPS (OPE,Outside) Case 4
57%		
Membrane 11,685 psi	User 47,232 psi	Component Evaluation Load Case 4 Min Prin. Stress = -14597. (99% Neg, 53% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
24%		
Bending 20,076 psi	User 47,232 psi	Component Evaluation Load Case 4 Min Prin. Stress = -14597. (99% Neg, 53% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 4
42%		
P1+Pb+Q 24,003 psi	SPS 47,232 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -14597. (99% Neg, 53% NegHi) Plot Reference: 10) P1+Pb+Q < SPS (EXP,Inside) Case 5
50%		
P1+Pb+Q 27,096 psi	SPS 47,232 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -14597. (99% Neg, 53% NegHi) Plot Reference: 11) P1+Pb+Q < SPS (EXP,Outside) Case 5
57%		
P1+Pb+Q+F 32,404 psi	Damage Ratio 0.003 Life 0.274 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 2,229,020.
Allowable 118,449 psi		"B31" Fatigue Stress Allowable = 78719.4 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 1,234,538.

27%			WRC 474 99% Probability Cycles = 286,800. WRC 474 95% Probability Cycles = 398,191. BS5500 Allowed Cycles(Curve F) = 171,404. Membrane-to-Bending Ratio = 0.613 Bending-to-PL+PB+Q Ratio = 0.620 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5	
36,580	0.007 Life	Stress Concentration Factor = 1.350	
psi	0.309 Stress	Strain Concentration Factor = 1.000	
Allowable		Cycles Allowed for this Stress = 1,003,418.	
118,449		"B31" Fatigue Stress Allowable = 78719.4	
psi		MarkI Fatigue Stress Allowable = 95657.0	
		WRC 474 Mean Cycles to Failure = 818,100.	
30%		WRC 474 99% Probability Cycles = 190,056.	
		WRC 474 95% Probability Cycles = 263,872.	
		BS5500 Allowed Cycles(Curve F) = 119,145.	
		Membrane-to-Bending Ratio = 0.504	
		Bending-to-PL+PB+Q Ratio = 0.665	
		Plot Reference:	
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5	
Circ Plate SCR for Plate # 1			
Pl	SPL	Primary Membrane Load Case 2	
485	30,995	Min Prin. Stress = -540. (64% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		1) Pl < SPL (SUS,Membrane) Case 2	
1%			
Qb	SPS	Primary Bending Load Case 2	
109	68,995	Min Prin. Stress = -540. (64% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		2) Qb < SPS (SUS,Bending) Case 2	
0%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2	
554	68,995	Min Prin. Stress = -540. (64% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2	
0%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2	
554	68,995	Min Prin. Stress = -540. (64% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2	
0%			
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2	
-574	80,003	Min Prin. Stress = -540. (64% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2	
0%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
29,561	68,995	Min Prin. Stress = -29113. (97% Neg, 63% NegHi)	
psi	psi	Plot Reference:	
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4	
42%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4	
27,915	68,995	Min Prin. Stress = -29113. (97% Neg, 63% NegHi)	
psi	psi	Plot Reference:	
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4	
40%			
Membrane	User	Component Evaluation Load Case 4	
28,737	68,995	Min Prin. Stress = -29113. (97% Neg, 63% NegHi)	
psi	psi	Plot Reference:	
		8) Membrane < User (OPE,Membrane) Case 4	
41%			
Bending	User	Component Evaluation Load Case 4	
5,163	68,995	Min Prin. Stress = -29113. (97% Neg, 63% NegHi)	
psi	psi	Plot Reference:	
		9) Bending < User (OPE,Bending) Case 4	
7%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5	
29,561	68,995	Min Prin. Stress = -29113. (97% Neg, 63% NegHi)	

psi	psi	Plot Reference:
42%		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
Pl+Pb+Q 27,915 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -29113. (97% Neg, 63% NegHi) Plot Reference:
40%		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
Pl+Pb+Q+F 39,907 psi	Damage Ratio 0.076 Life 0.475 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 91,518. "B31" Fatigue Stress Allowable = 100003.8 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 628,939. WRC 474 99% Probability Cycles = 146,111. WRC 474 95% Probability Cycles = 202,860. BS5500 Allowed Cycles(Curve F) = 81,845. Membrane-to-Bending Ratio = 34.017 Bending-to-PL+PB+Q Ratio = 0.029 Plot Reference:
Allowable 83,994 psi		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
47%		
Pl+Pb+Q+F 37,685 psi	Damage Ratio 0.061 Life 0.449 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 115,255. "B31" Fatigue Stress Allowable = 100003.8 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 752,263. WRC 474 99% Probability Cycles = 174,761. WRC 474 95% Probability Cycles = 242,637. BS5500 Allowed Cycles(Curve F) = 97,189. Membrane-to-Bending Ratio = 34.017 Bending-to-PL+PB+Q Ratio = 0.029 Plot Reference:
Allowable 83,994 psi		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
44%		
Long Plate SCR for Plate # 1		
Pl 199 psi	SPL 30,995 psi	Primary Membrane Load Case 2 Min Prin. Stress = -94. (23% Neg, 13% NegHi) Plot Reference:
0%		1) Pl < SPL (SUS,Membrane) Case 2
Qb 0 psi	SPS 68,995 psi	Primary Bending Load Case 2 Min Prin. Stress = -94. (23% Neg, 13% NegHi) Plot Reference:
0%		2) Qb < SPS (SUS,Bending) Case 2
Pl+Pb+Q 199 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -94. (23% Neg, 13% NegHi) Plot Reference:
0%		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
Pl+Pb+Q 199 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -94. (23% Neg, 13% NegHi) Plot Reference:
0%		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
S1+S2+S3 209 psi	4S 80,003 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -94. (23% Neg, 13% NegHi) Plot Reference:
0%		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
Pl+Pb+Q 14,051 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -821. (70% Neg, 30% NegHi) Plot Reference:
20%		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
Pl+Pb+Q 14,278 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -821. (70% Neg, 30% NegHi) Plot Reference:

20%			7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
Membrane	User	Component Evaluation Load Case 4	
14,163	68,995	Min Prin. Stress = -821. (70% Neg, 30% NegHi)	
psi	psi	Plot Reference:	
20%			8) Membrane < User (OPE,Membrane) Case 4
Bending	User	Component Evaluation Load Case 4	
437	68,995	Min Prin. Stress = -821. (70% Neg, 30% NegHi)	
psi	psi	Plot Reference:	
0%			9) Bending < User (OPE,Bending) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5	
14,051	68,995	Min Prin. Stress = -821. (70% Neg, 30% NegHi)	
psi	psi	Plot Reference:	
20%			10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5	
14,278	68,995	Min Prin. Stress = -821. (70% Neg, 30% NegHi)	
psi	psi	Plot Reference:	
20%			11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5	
18,969	0.000 Life	Stress Concentration Factor = 1.350	
psi	0.226 Stress	Strain Concentration Factor = 1.000	
Allowable			Cycles Allowed for this Stress = 1.5570E8
83,994		"B31" Fatigue Stress Allowable = 100003.8	
psi		MarkI Fatigue Stress Allowable = 83402.0	
22%			WRC 474 Mean Cycles to Failure = 6,423,192.
			WRC 474 99% Probability Cycles = 1,492,194.
			WRC 474 95% Probability Cycles = 2,071,753.
			BS5500 Allowed Cycles(Curve F) = 762,023.
			Membrane-to-Bending Ratio = 62.149
			Bending-to-PL+PB+Q Ratio = 0.016
			Plot Reference:
			12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5	
19,276	0.000 Life	Stress Concentration Factor = 1.350	
psi	0.229 Stress	Strain Concentration Factor = 1.000	
Allowable			Cycles Allowed for this Stress = 1.1385E8
83,994		"B31" Fatigue Stress Allowable = 100003.8	
psi		MarkI Fatigue Stress Allowable = 83402.0	
22%			WRC 474 Mean Cycles to Failure = 6,109,608.
			WRC 474 99% Probability Cycles = 1,419,344.
			WRC 474 95% Probability Cycles = 1,970,609.
			BS5500 Allowed Cycles(Curve F) = 726,280.
			Membrane-to-Bending Ratio = 62.149
			Bending-to-PL+PB+Q Ratio = 0.016
			Plot Reference:
			13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Pad SCR for Plate # 1			
Pl	SPL	Primary Membrane Load Case 2	
2,108	30,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
6%			1) Pl < SPL (SUS,Membrane) Case 2
Qb	SPS	Primary Bending Load Case 2	
475	68,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
0%			2) Qb < SPS (SUS,Bending) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2	
2,338	68,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
3%			3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2	
1,998	68,995	Min Prin. Stress = -5. (0% Neg, 0% NegHi)	
psi	psi	Plot Reference:	
			4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

	2%			
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2		
3,512	80,003	Min Prin. Stress = -5. (0% Neg, 0% NegHi)		
psi	psi	Plot Reference:		
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2		
	4%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4		
20,825	68,995	Min Prin. Stress = -14138. (98% Neg, 9% NegHi)		
psi	psi	Plot Reference:		
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4		
	30%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4		
22,408	68,995	Min Prin. Stress = -14138. (98% Neg, 9% NegHi)		
psi	psi	Plot Reference:		
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4		
	32%			
Membrane	User	Component Evaluation Load Case 4		
9,337	68,995	Min Prin. Stress = -14138. (98% Neg, 9% NegHi)		
psi	psi	Plot Reference:		
		8) Membrane < User (OPE,Membrane) Case 4		
	13%			
Bending	User	Component Evaluation Load Case 4		
18,874	68,995	Min Prin. Stress = -14138. (98% Neg, 9% NegHi)		
psi	psi	Plot Reference:		
		9) Bending < User (OPE,Bending) Case 4		
	27%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5		
20,825	68,995	Min Prin. Stress = -14138. (98% Neg, 9% NegHi)		
psi	psi	Plot Reference:		
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5		
	30%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5		
22,408	68,995	Min Prin. Stress = -14138. (98% Neg, 9% NegHi)		
psi	psi	Plot Reference:		
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5		
	32%			
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5		
28,114	0.018 Life	Stress Concentration Factor = 1.350		
psi	0.335 Stress	Strain Concentration Factor = 1.000		
		Cycles Allowed for this Stress = 379,071.		
Allowable		"B31" Fatigue Stress Allowable = 100003.8		
83,994		MarkI Fatigue Stress Allowable = 83402.0		
psi		WRC 474 Mean Cycles to Failure = 1,410,160.		
		WRC 474 99% Probability Cycles = 327,599.		
33%		WRC 474 95% Probability Cycles = 454,837.		
		BS5500 Allowed Cycles(Curve F) = 234,078.		
		Membrane-to-Bending Ratio = 0.502		
		Bending-to-PL+PB+Q Ratio = 0.666		
		Plot Reference:		
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5		
30,251	0.026 Life	Stress Concentration Factor = 1.350		
psi	0.360 Stress	Strain Concentration Factor = 1.000		
		Cycles Allowed for this Stress = 271,291.		
Allowable		"B31" Fatigue Stress Allowable = 100003.8		
83,994		MarkI Fatigue Stress Allowable = 83402.0		
psi		WRC 474 Mean Cycles to Failure = 1,090,482.		
		WRC 474 99% Probability Cycles = 253,334.		
36%		WRC 474 95% Probability Cycles = 351,727.		
		BS5500 Allowed Cycles(Curve F) = 187,891.		
		Membrane-to-Bending Ratio = 0.246		
		Bending-to-PL+PB+Q Ratio = 0.803		
		Plot Reference:		
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5		
Shell in Plate # 1 Vicinity				
Pl	SPL	Primary Membrane Load Case 2		
3,465	22,191	Min Prin. Stress = -4. (0% Neg, 0% NegHi)		
psi	psi	Plot Reference:		
		1) Pl < SPL (SUS,Membrane) Case 2		
	15%			

Qb 366 psi	SPS 47,232 psi	Primary Bending Load Case 2 Min Prin. Stress = -4. (0% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q 3,561 psi	SPS 47,232 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -4. (0% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
7%		
Pl+Pb+Q 3,491 psi	SPS 47,232 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -4. (0% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
7%		
S1+S2+S3 5,977 psi	4S 59,176 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -4. (0% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
10%		
Pl+Pb+Q 18,397 psi	SPS 47,232 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -9147. (98% Neg, 49% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
38%		
Pl+Pb+Q 10,330 psi	SPS 47,232 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -9147. (98% Neg, 49% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
21%		
Membrane 9,992 psi	User 47,232 psi	Component Evaluation Load Case 4 Min Prin. Stress = -9147. (98% Neg, 49% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
21%		
Bending 11,193 psi	User 47,232 psi	Component Evaluation Load Case 4 Min Prin. Stress = -9147. (98% Neg, 49% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 4
23%		
Pl+Pb+Q 18,397 psi	SPS 47,232 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -9147. (98% Neg, 49% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
38%		
Pl+Pb+Q 10,330 psi	SPS 47,232 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -9147. (98% Neg, 49% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
21%		
Pl+Pb+Q+F 18,397 psi	Damage Ratio 0.000 Life 0.155 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78719.4 Mark1 Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 2,639,187. WRC 474 99% Probability Cycles = 613,119. WRC 474 95% Probability Cycles = 851,250. BS5500 Allowed Cycles(Curve F) = 380,717. Membrane-to-Bending Ratio = 0.884 Bending-to-PL+PB+Q Ratio = 0.531 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable 118,449 psi		
15%		
Pl+Pb+Q+F 10,330 psi	Damage Ratio 0.000 Life 0.087 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78719.4 Mark1 Fatigue Stress Allowable = 95657.0
Allowable 118,449		

psi		WRC 474 Mean Cycles to Failure = 17,436,496.
8%		WRC 474 99% Probability Cycles = 4,050,730.
		WRC 474 95% Probability Cycles = 5,624,008.
		BS5500 Allowed Cycles(Curve F) = 2,150,209.
		Membrane-to-Bending Ratio = 0.410
		Bending-to-PL+PB+Q Ratio = 0.709
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Circ Plate for Plate # 1		
Pl	SPL	Primary Membrane Load Case 2
179	30,995	Min Prin. Stress = -132. (99% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
0%		
Qb	SPS	Primary Bending Load Case 2
29	68,995	Min Prin. Stress = -132. (99% Neg, 0% NegHi)
psi	psi	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
202	68,995	Min Prin. Stress = -132. (99% Neg, 0% NegHi)
psi	psi	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
0%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
202	68,995	Min Prin. Stress = -132. (99% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
0%		
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2
-101	80,003	Min Prin. Stress = -132. (99% Neg, 0% NegHi)
psi	psi	Plot Reference:
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
18,204	68,995	Min Prin. Stress = -17799. (99% Neg, 58% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
26%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
17,061	68,995	Min Prin. Stress = -17799. (99% Neg, 58% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
24%		
Membrane	User	Component Evaluation Load Case 4
17,632	68,995	Min Prin. Stress = -17799. (99% Neg, 58% NegHi)
psi	psi	Plot Reference:
		8) Membrane < User (OPE,Membrane) Case 4
25%		
Bending	User	Component Evaluation Load Case 4
973	68,995	Min Prin. Stress = -17799. (99% Neg, 58% NegHi)
psi	psi	Plot Reference:
		9) Bending < User (OPE,Bending) Case 4
1%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5
18,204	68,995	Min Prin. Stress = -17799. (99% Neg, 58% NegHi)
psi	psi	Plot Reference:
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
26%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
17,061	68,995	Min Prin. Stress = -17799. (99% Neg, 58% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
24%		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
18,204	0.000 Life	Stress Concentration Factor = 1.000
psi	0.217 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 3.4832E8

Allowable			"B31" Fatigue Stress Allowable = 100003.8
83,994			MarkI Fatigue Stress Allowable = 83402.0
psi			WRC 474 Mean Cycles to Failure = 2,861,712.
21%			WRC 474 99% Probability Cycles = 664,814.
			WRC 474 95% Probability Cycles = 923,024.
			BS5500 Allowed Cycles(Curve F) = 350,453.
			Membrane-to-Bending Ratio = 30.150
			Bending-to-PL+PB+Q Ratio = 0.032
			Plot Reference:
			12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5	
17,061	0.000 Life	Stress Concentration Factor = 1.000	
psi	0.203 Stress	Strain Concentration Factor = 1.000	
		Cycles Allowed for this Stress = 1.2614E9	
Allowable		"B31" Fatigue Stress Allowable = 100003.8	
83,994		MarkI Fatigue Stress Allowable = 83402.0	
psi		WRC 474 Mean Cycles to Failure = 3,504,644.	
20%		WRC 474 99% Probability Cycles = 814,176.	
		WRC 474 95% Probability Cycles = 1,130,397.	
		BS5500 Allowed Cycles(Curve F) = 425,688.	
		Membrane-to-Bending Ratio = 30.150	
		Bending-to-PL+PB+Q Ratio = 0.032	
		Plot Reference:	
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5	
Long Plate for Plate # 1			
Pl	SPL	Primary Membrane Load Case 2	
97	30,995	Min Prin. Stress = -98. (50% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		1) Pl < SPL (SUS,Membrane) Case 2	
	0%		
Qb	SPS	Primary Bending Load Case 2	
0	68,995	Min Prin. Stress = -98. (50% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		2) Qb < SPS (SUS,Bending) Case 2	
	0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2	
97	68,995	Min Prin. Stress = -98. (50% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2	
	0%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2	
97	68,995	Min Prin. Stress = -98. (50% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2	
	0%		
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2	
-100	80,003	Min Prin. Stress = -98. (50% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2	
	0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
3,611	68,995	Min Prin. Stress = -1039. (99% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4	
	5%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4	
3,716	68,995	Min Prin. Stress = -1039. (99% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4	
	5%		
Membrane	User	Component Evaluation Load Case 4	
3,659	68,995	Min Prin. Stress = -1039. (99% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		8) Membrane < User (OPE,Membrane) Case 4	
	5%		
Bending	User	Component Evaluation Load Case 4	
188	68,995	Min Prin. Stress = -1039. (99% Neg, 50% NegHi)	
psi	psi	Plot Reference:	
		9) Bending < User (OPE,Bending) Case 4	
	0%		

Pl+Pb+Q 3,611 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -1039. (99% Neg, 50% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
5%		
Pl+Pb+Q 3,716 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -1039. (99% Neg, 50% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
5%		
Pl+Pb+Q+F 3,611 psi	Damage Ratio 0.000 Life 0.043 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 100003.8 Mark1 Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 4.4931E8 WRC 474 99% Probability Cycles = 1.0438E8 WRC 474 95% Probability Cycles = 1.4492E8 BS5500 Allowed Cycles(Curve F) = 1.2403E8 Membrane-to-Bending Ratio = 19.489 Bending-to-PL+PB+Q Ratio = 0.049 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable 83,994 psi		
4%		
Pl+Pb+Q+F 3,716 psi	Damage Ratio 0.000 Life 0.044 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 100003.8 Mark1 Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 4.1083E8 WRC 474 99% Probability Cycles = 95,440,648. WRC 474 95% Probability Cycles = 1.3251E8 BS5500 Allowed Cycles(Curve F) = 1.0749E8 Membrane-to-Bending Ratio = 19.489 Bending-to-PL+PB+Q Ratio = 0.049 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Allowable 83,994 psi		
4%		
Pad for Plate # 1		
Pl 1,679 psi	SPL 30,995 psi	Primary Membrane Load Case 2 Min Prin. Stress = 0. (0% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
5%		
Qb 196 psi	SPS 68,995 psi	Primary Bending Load Case 2 Min Prin. Stress = 0. (0% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q 1,859 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = 0. (0% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
2%		
Pl+Pb+Q 1,507 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = 0. (0% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
2%		
S1+S2+S3 3,047 psi	4S 80,003 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = 0. (0% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
3%		
Pl+Pb+Q 11,809 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -7721. (99% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
17%		

Pl+Pb+Q 9,347 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -7721. (99% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
13%		
Membrane 4,805 psi	User 68,995 psi	Component Evaluation Load Case 4 Min Prin. Stress = -7721. (99% Neg, 0% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
6%		
Bending 7,904 psi	User 68,995 psi	Component Evaluation Load Case 4 Min Prin. Stress = -7721. (99% Neg, 0% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 4
11%		
Pl+Pb+Q 11,809 psi	SPS 68,995 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -7721. (99% Neg, 0% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
17%		
Pl+Pb+Q 9,347 psi	SPS 68,995 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -7721. (99% Neg, 0% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
13%		
Pl+Pb+Q+F 11,809 psi	Damage Ratio 0.000 Life 0.141 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 100003.8 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 7,518,001. WRC 474 99% Probability Cycles = 1,746,533. WRC 474 95% Probability Cycles = 2,424,876. BS5500 Allowed Cycles(Curve F) = 1,283,632. Membrane-to-Bending Ratio = 0.608 Bending-to-PL+PB+Q Ratio = 0.622 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable 83,994 psi		
14%		
Pl+Pb+Q+F 9,347 psi	Damage Ratio 0.000 Life 0.111 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 100003.8 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 16,557,389. WRC 474 99% Probability Cycles = 3,846,501. WRC 474 95% Probability Cycles = 5,340,458. BS5500 Allowed Cycles(Curve F) = 2,588,731. Membrane-to-Bending Ratio = 0.521 Bending-to-PL+PB+Q Ratio = 0.658 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Allowable 83,994 psi		
11%		

[Table of Contents](#)

Compressive Stress Summary
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
12:09am DEC 16,2022

\$P

Compressive Stress Summary (psi)

\$X

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress
Pts in Region - No. of nodes in the model region
>5% Compression - 5% or more of Compressive Stress Limit
>50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = $-0.55 \text{ Min}(S_y, kE t/R)$, Section slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	Compression and Bending		Region
					>5%	>50%	
1	SUSTAINED	2	-4.	1292	0%	0%	Shell in Plate # 1 Vicinity
2	OPERATING	4	-9147.	1292	98%	49%	Shell in Plate # 1 Vicinity
3	EXPANSION	5	-9147.	1292	98%	49%	Shell in Plate # 1 Vicinity
4	SUSTAINED	2	-3.	580	0%	0%	Shell SCR at Plate # 1
5	OPERATING	4	-14597.	580	99%	53%	Shell SCR at Plate # 1
6	EXPANSION	5	-14597.	580	99%	53%	Shell SCR at Plate # 1
7	SUSTAINED	2	-5.	796	0%	0%	Pad SCR for Plate # 1
8	OPERATING	4	-14138.	796	98%	9%	Pad SCR for Plate # 1
9	EXPANSION	5	-14138.	796	98%	9%	Pad SCR for Plate # 1
10	SUSTAINED	2	0.	32	0%	0%	Pad for Plate # 1
11	OPERATING	4	-7721.	32	99%	0%	Pad for Plate # 1
12	EXPANSION	5	-7721.	32	99%	0%	Pad for Plate # 1
13	SUSTAINED	2	-540.	124	64%	0%	Circ Plate SCR for Plate # 1
14	OPERATING	4	-29113.	124	97%	63%	Circ Plate SCR for Plate # 1
15	EXPANSION	5	-29113.	124	97%	63%	Circ Plate SCR for Plate # 1
16	SUSTAINED	2	-132.	12	99%	0%	Circ Plate for Plate # 1
17	OPERATING	4	-17799.	12	99%	58%	Circ Plate for Plate # 1
18	EXPANSION	5	-17799.	12	99%	58%	Circ Plate for Plate # 1
19	SUSTAINED	2	-94.	30	23%	13%	Long Plate SCR for Plate # 1
20	OPERATING	4	-821.	30	70%	30%	Long Plate SCR for Plate # 1
21	EXPANSION	5	-821.	30	70%	30%	Long Plate SCR for Plate # 1
22	SUSTAINED	2	-98.	2	50%	50%	Long Plate for Plate # 1
23	OPERATING	4	-1039.	2	99%	50%	Long Plate for Plate # 1
24	EXPANSION	5	-1039.	2	99%	50%	Long Plate for Plate # 1

[Table of Contents](#)



Finite Element Model

- [Finite Element Model](#)

Area of Discontinuity at Plate

- [1\) \$P_l < S_{PL}\$ \(SUS Membrane\) Case 2](#)
- [2\) \$Q_b < S_{PS}\$ \(SUS Bending\) Case 2](#)
- [3\) \$P_l + P_b + Q < S_{PS}\$ \(SUS Inside\) Case 2](#)
- [4\) \$P_l + P_b + Q < S_{PS}\$ \(SUS Outside\) Case 2](#)
- [5\) \$S_1 + S_2 + S_3 < 4S\$ \(SUS \$S_1 + S_2 + S_3\$ \) Case 2](#)
- [6\) \$P_l + P_b + Q < S_{PS}\$ \(OPE Inside\) Case 4](#)
- [7\) \$P_l + P_b + Q < S_{PS}\$ \(OPE Outside\) Case 4](#)
- [8\) Membrane \$< \text{User}\$ \(OPE Membrane\) Case 4](#)
- [9\) Bending \$< \text{User}\$ \(OPE Bending\) Case 4](#)
- [10\) \$P_l + P_b + Q < S_{PS}\$ \(EXP Inside\) Case 5](#)
- [11\) \$P_l + P_b + Q < S_{PS}\$ \(EXP Outside\) Case 5](#)
- [12\) \$P_l + P_b + Q + F < 2S_a\$ \(EXP Inside\) Case 5](#)
- [13\) \$P_l + P_b + Q + F < 2S_a\$ \(EXP Outside\) Case 5](#)
- ---



Finite Element Model



3d

1) P1 < SPL (SUS Membrane) Case 2



3,618
3,101
2,067
1,292
517
0



3d(Small)

3d



3d(Deformed)

2) $Q_b < SPS$ (SUS Bending) Case 2

3d(Small)

3d



3d(Deformed)



3) $P1+Pb+Q < SPS$ (SUS Inside) Case 2

3d(Small)

3d

3d(Deformed)



4) $P1+Pb+Q < SPS$ (SUS Outside) Case 25) $S1+S2+S3 < 4S$ (SUS $S1+S2+S3$) Case 2

6) $P1+Pb+Q < SPS$ (OPE Inside) Case 4

3d(Small)

3d

3d(Deformed)


7) $P1+Pb+Q < SPS$ (OPE Outside) Case 4

3d(Small)


3d



3d(Deformed)



8) Membrane < User (OPE Membrane) Case 4



9) Bending < User (OPE Bending) Case 4



10) $P_l + P_b + Q < SPS$ (EXP Inside) Case 511) $P_l + P_b + Q < SPS$ (EXP Outside) Case 5

12) $P1+Pb+Q+F < 2Sa$ (EXP Inside) Case 513) $P1+Pb+Q+F < 2Sa$ (EXP Outside) Case 5

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Tue Nov 29 17:36:28 2022.

- [Model Notes](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Compressive Stress Summary](#)
- [Graphical Results](#)

Model Notes

Model Notes

Input Echo:

Description:

Ladder Cleat

Model Type : Cylindrical Shell

Parent Geometry

Parent Outside Diam. : 30.037 in.
Thickness : 0.394 in.

Parent Properties:

Cold Allowable : 16700.0 psi
Hot Allowable : 14800.0 psi
Material DB # 1071122.
Ultimate Tensile (Amb) : 70000.0 psi
Yield Strength (Amb) : 25000.0 psi
Yield Strength (Hot) : 16400.0 psi
Elastic Modulus (Amb) : 28300000.0 psi
Poissons Ratio : 0.300
Expansion Coefficient : 0.9700E-05 in./in./deg.
Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Structural Attachment Type : Longitudinal Lug

Thickness : 0.394 in.
Height : 6.000 in.
Length : 12.283 in.

Rectangular Pad Width : 2.441 in.
Rectangular Pad Height : 7.992 in.
Rectangular Pad Thick : 0.394 in.
Nozzle Tilt Angle : 0.000 deg.
Distance from Top : 47.244 in.
Distance from Bottom : 51.181 in.

Nozzle Properties

Cold Allowable : 20000.0 psi
Hot Allowable : 20000.0 psi
Material DB # 1016422.
Ultimate Tensile (Amb) : 70000.0 psi
Yield Strength (Amb) : 38000.0 psi
Yield Strength (Hot) : 31000.0 psi
Elastic Modulus (Amb) : 29400000.0 psi
Poissons Ratio : 0.300
Expansion Coefficient : 0.7300E-05 in./in./deg.
Weight Density : 0.0000E+00 lb./cu.in. (NOT USED)

Design Operating Cycles : 7000.
Ambient Temperature (Deg.) : 69.98

Thermal Stresses will be introduced into this analysis due to the differences in temperature and/or thermal expansion coefficients. The following temperatures have been specified for the analysis:

Nozzle Inside Temperature : 500.00 deg.
Nozzle Outside Temperature : 500.00 deg.
Vessel Inside Temperature : 500.00 deg.
Vessel Outside Temperature : 500.00 deg.
Nozzle Pressure : 105.0 psi
Vessel Pressure : 105.0 psi

Operating Pressure : 10.0 psi

The operating pressure is used for secondary and peak stress cases. The design pressure is used for primary cases. The ratio of the operating/design pressure = 0.095

User Defined Load Input Echo for the ATTACHMENT:

Loads are given at the End of Nozzle

Loads are defined in Global Coordinates

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	300.0	-760.0	210.0	316.0	87.5	52.5

FEA Model Loads:

These are the actual Attachment loads applied to the FEA model.

These are the User Defined Loads translated to the end of the nozzle and reported in global coordinates.

Forces(lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	300.0	-760.0	210.0	316.0	87.5	52.5

The "top" or "positive" end of this model is "free" in the axial and translational directions.

Stresses ARE nodally AVERAGED.

No weld dimensions have been given for the nozzle connection to the shell. This will produce conservative results for external loads and may tend to produce more realistic inside surface pressure stresses.

Vessel Centerline Vector : 0.000 1.000 0.000
Nozzle Orientation Vector : 1.000 0.000 0.000

[Table of Contents](#)

Load Case Report
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
5:35pm NOV 29, 2022

\$P

Load Case Report

\$X

Inner and outer element temperatures are the same throughout the model. No thermal ratcheting calculations will be performed.

THE 5 LOAD CASES ANALYZED ARE:

1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range between the installed and the operating states.

```

/----- Loads in Case 1
  Loads due to Weight

2  SUSTAINED      (Wgt+Pr)

Sustained case run to satisfy local primary
membrane and bending stress limits.

/----- Loads in Case 2
  Loads due to Weight
  Pressure Case 1

3  Thermal ONLY

Thermal ONLY case run in the event expansion
stresses exceed the secondary stress allowable.

/----- Loads in Case 3
  Temperature Case 1
  Loads from (Thermal Only)

4  OPERATING

Case run to compute the operating stresses used in
secondary, peak and range calculations as needed.

/----- Loads in Case 4
  Pressure Case 1
  Temperature Case 1
  Loads from (Operating)

5  RANGE          (Fatigue Calc Performed)

Case run to get the RANGE of stresses.
as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case 5
  Plus Stress Results from CASE 4
  Minus Stress Results from CASE 1

```

[Table of Contents](#)

```

Solution Data
FEPipe Version 15.0      Jobname: NOZZLE      $P
Released Jan. 2021      5:35pm   NOV 29,2022

```

Solution Data

```

Maximum Solution Row Size = 1500
Number of Nodes           = 4939
Number of Elements        = 1660
Number of Solution Cases  = 4

```

Summation of Loads per Case

Case #	FX	FY	FZ
1	0.	0.	0.
2	0.	72464.	0.
3	0.	0.	0.
4	300.	71704.	210.

[Table of Contents](#)

```

ASME Code Stress Output Plots
FEPipe Version 15.0      Jobname: NOZZLE      $P
Released Jan. 2021      5:36pm   NOV 29,2022

```

ASME Code Stress Output Plots

\$X

- 1) $P_1 < SPL$ (SUS,Membrane) Case 2
- 2) $Q_b < SPS$ (SUS,Bending) Case 2
- 3) $P_1+P_b+Q < SPS$ (SUS,Inside) Case 2
- 4) $P_1+P_b+Q < SPS$ (SUS,Outside) Case 2
- 5) $S_1+S_2+S_3 < 4S$ (SUS, $S_1+S_2+S_3$) Case 2
- 6) $P_1+P_b+Q < SPS$ (OPE,Inside) Case 4
- 7) $P_1+P_b+Q < SPS$ (OPE,Outside) Case 4
- 8) Membrane < User (OPE,Membrane) Case 4
- 9) Bending < User (OPE,Bending) Case 4
- 10) $P_1+P_b+Q < SPS$ (EXP,Inside) Case 5
- 11) $P_1+P_b+Q < SPS$ (EXP,Outside) Case 5
- 12) $P_1+P_b+Q+F < 2S_a$ (EXP,Inside) Case 5
- 13) $P_1+P_b+Q+F < 2S_a$ (EXP,Outside) Case 5

[Table of Contents](#)

Stress Results - Notes

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

5:36pm NOV 29,2022

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = 9.5238097E-02
Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. ($P_b=0$)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
 $S_1+S_2+S_3$ evaluation omitted from operating stress.
 Include $S_1+S_2+S_3$ evaluation in primary case evaluation.
 Bending stress NOT included for all $S_1+S_2+S_3$ calculations.
- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

5:36pm NOV 29,2022

ASME Overstressed Areas

\$X

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

5:36pm NOV 29,2022

Highest Primary Stress Ratios

\$X

Shell SCR at Plate # 1

Pl	SPL	Primary Membrane Load Case 2
3,497	22,200	Min Prin. Stress = -3. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
15%		

Long Plate SCR for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
383	31,000	Min Prin. Stress = -408. (18% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
1%		

Pad SCR for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
2,143	31,000	Min Prin. Stress = -6. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
6%		

Shell in Plate # 1 Vicinity

Pl	SPL	Primary Membrane Load Case 2
3,479	22,200	Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
15%		

Long Plate for Plate # 1

Pl	SPL	Primary Membrane Load Case 2
212	31,000	Min Prin. Stress = -211. (1% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
0%		

[Table of Contents](#)

Highest Secondary Stress Ratios

FEPipe Version 15.0

Jobname: NOZZLE

\$P

Released Jan. 2021

5:36pm NOV 29,2022

Highest Secondary Stress Ratios

\$X

In combination case 5 the max range stress divided by the max component stress is 1.00. The case tensor components are NEVER additive and so the combination case will have LOWER stresses than the largest of any of the individual cases by between 1 and 20%.

Load Case	Combined/Max (Inside)	Combined/Max (Outside)
-----	-----	-----
5	1.000	1.000

Shell SCR at Plate # 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
8,938	47,250	Min Prin. Stress = -2506. (88% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
18%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
8,938	47,250	Min Prin. Stress = -2506. (88% Neg, 0% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
18%		

Long Plate SCR for Plate # 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
33,333	69,000	Min Prin. Stress = -23236. (99% Neg, 31% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
48%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
33,333	69,000	Min Prin. Stress = -23236. (99% Neg, 31% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
48%		

Pad SCR for Plate # 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
9,656	69,000	Min Prin. Stress = -5815. (98% Neg, 0% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
13%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
9,656	69,000	Min Prin. Stress = -5815. (98% Neg, 0% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
13%		

Shell in Plate # 1 Vicinity

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
10,517	47,250	Min Prin. Stress = -4060. (82% Neg, 15% NegHi)
psi	psi	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
22%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 5
10,517	47,250	Min Prin. Stress = -4060. (82% Neg, 15% NegHi)
psi	psi	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
22%		

Long Plate for Plate # 1

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
26,790	69,000	Min Prin. Stress = -16496. (99% Neg, 33% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
38%		

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 5
26,790	69,000	Min Prin. Stress = -16496. (99% Neg, 33% NegHi)
psi	psi	Plot Reference:
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 5

38%

[Table of Contents](#)

Highest Fatigue Stress Ratios
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: NOZZLE
 5:36pm NOV 29,2022

\$P

Highest Fatigue Stress Ratios

\$X

Shell SCR at Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
12,067	0.000 Life	Stress Concentration Factor = 1.350
psi	0.102 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 78750.0
118,449		Markl Fatigue Stress Allowable = 95657.0
psi		WRC 474 Mean Cycles to Failure = 26,145,738.
		WRC 474 99% Probability Cycles = 6,074,002.
10%		WRC 474 95% Probability Cycles = 8,433,107.
		BS5500 Allowed Cycles(Curve F) = 3,319,496.
		Membrane-to-Bending Ratio = 0.436
		Bending-to-PL+PB+Q Ratio = 0.696
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Long Plate SCR for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
45,000	0.139 Life	Stress Concentration Factor = 1.350
psi	0.536 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 50,444.
Allowable		"B31" Fatigue Stress Allowable = 100000.0
83,994		Markl Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 507,219.
		WRC 474 99% Probability Cycles = 117,834.
53%		WRC 474 95% Probability Cycles = 163,600.
		BS5500 Allowed Cycles(Curve F) = 57,082.
		Membrane-to-Bending Ratio = 0.459
		Bending-to-PL+PB+Q Ratio = 0.685
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Pad SCR for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
13,036	0.000 Life	Stress Concentration Factor = 1.350
psi	0.155 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 100000.0
83,994		Markl Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 14,452,905.
		WRC 474 99% Probability Cycles = 3,357,602.
15%		WRC 474 95% Probability Cycles = 4,661,674.
		BS5500 Allowed Cycles(Curve F) = 2,348,264.
		Membrane-to-Bending Ratio = 0.501
		Bending-to-PL+PB+Q Ratio = 0.666
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Shell in Plate # 1 Vicinity

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 5
10,517	0.000 Life	Stress Concentration Factor = 1.000
psi	0.089 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11

Allowable	"B31" Fatigue Stress Allowable = 78750.0
118,449	Markl Fatigue Stress Allowable = 95657.0
psi	WRC 474 Mean Cycles to Failure = 15,136,993.
8%	WRC 474 99% Probability Cycles = 3,516,524.
	WRC 474 95% Probability Cycles = 4,882,321.
	BS5500 Allowed Cycles(Curve F) = 2,037,817.
	Membrane-to-Bending Ratio = 0.908
	Bending-to-PL+PB+Q Ratio = 0.524
	Plot Reference:
	13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5

Long Plate for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 5
26,790	0.015 Life	Stress Concentration Factor = 1.000
psi	0.319 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 472,458.
Allowable		"B31" Fatigue Stress Allowable = 100000.0
83,994		Markl Fatigue Stress Allowable = 83402.0
psi		WRC 474 Mean Cycles to Failure = 1,027,272.
31%		WRC 474 99% Probability Cycles = 238,649.
		WRC 474 95% Probability Cycles = 331,339.
		BS5500 Allowed Cycles(Curve F) = 109,950.
		Membrane-to-Bending Ratio = 0.161
		Bending-to-PL+PB+Q Ratio = 0.862
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5

[Table of Contents](#)

Highest Stress Ratios Per Region

FEPipe Version 15.0	Jobname: NOZZLE	\$P
Released Jan. 2021	5:36pm NOV 29,2022	

Highest Stress Ratios Per Region

\$X

Shell SCR at Plate # 1

Pl	SPL	Primary Membrane Load Case 2
3,497	22,200	Min Prin. Stress = -3. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
15%		
Qb	SPS	Primary Bending Load Case 2
163	47,250	Min Prin. Stress = -3. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
3,626	47,250	Min Prin. Stress = -3. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
7%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
3,387	47,250	Min Prin. Stress = -3. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
7%		
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2
5,926	59,200	Min Prin. Stress = -3. (0% Neg, 0% NegHi)
psi	psi	Plot Reference:
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
10%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
4,084	47,250	Min Prin. Stress = -2506. (88% Neg, 0% NegHi)
psi	psi	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
8%		

Pl+Pb+Q 8,938 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -2506. (88% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
18%		
Membrane 2,873 psi	User 47,250 psi	Component Evaluation Load Case 4 Min Prin. Stress = -2506. (88% Neg, 0% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
6%		
Bending 6,341 psi	User 47,250 psi	Component Evaluation Load Case 4 Min Prin. Stress = -2506. (88% Neg, 0% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 4
13%		
Pl+Pb+Q 4,084 psi	SPS 47,250 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -2506. (88% Neg, 0% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
8%		
Pl+Pb+Q 8,938 psi	SPS 47,250 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -2506. (88% Neg, 0% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
18%		
Pl+Pb+Q+F 5,513 psi	Damage Ratio 0.000 Life 0.047 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78750.0 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 2.9410E8 WRC 474 99% Probability Cycles = 68,322,360. WRC 474 95% Probability Cycles = 94,858,344. BS5500 Allowed Cycles(Curve F) = 81,105,912. Membrane-to-Bending Ratio = 0.659 Bending-to-PL+PB+Q Ratio = 0.603 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable 118,449 psi		
4%		
Pl+Pb+Q+F 12,067 psi	Damage Ratio 0.000 Life 0.102 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78750.0 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 26,145,738. WRC 474 99% Probability Cycles = 6,074,002. WRC 474 95% Probability Cycles = 8,433,107. BS5500 Allowed Cycles(Curve F) = 3,319,496. Membrane-to-Bending Ratio = 0.436 Bending-to-PL+PB+Q Ratio = 0.696 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Allowable 118,449 psi		
10%		
Long Plate SCR for Plate # 1		
Pl 383 psi	SPL 31,000 psi	Primary Membrane Load Case 2 Min Prin. Stress = -408. (18% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
1%		
Qb 0 psi	SPS 69,000 psi	Primary Bending Load Case 2 Min Prin. Stress = -408. (18% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q 383 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -408. (18% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
0%		

Pl+Pb+Q 383 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -408. (18% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
0%		
S1+S2+S3 -476 psi	4S 80,000 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -408. (18% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
0%		
Pl+Pb+Q 28,072 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -23236. (99% Neg, 31% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
40%		
Pl+Pb+Q 33,333 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -23236. (99% Neg, 31% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
48%		
Membrane 16,836 psi	User 69,000 psi	Component Evaluation Load Case 4 Min Prin. Stress = -23236. (99% Neg, 31% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
24%		
Bending 27,695 psi	User 69,000 psi	Component Evaluation Load Case 4 Min Prin. Stress = -23236. (99% Neg, 31% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 4
40%		
Pl+Pb+Q 28,072 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -23236. (99% Neg, 31% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
40%		
Pl+Pb+Q 33,333 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -23236. (99% Neg, 31% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
48%		
Pl+Pb+Q+F 37,898 psi	Damage Ratio 0.062 Life 0.451 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 112,947. "B31" Fatigue Stress Allowable = 100000.0 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 773,681. WRC 474 99% Probability Cycles = 179,737. WRC 474 95% Probability Cycles = 249,545. BS5500 Allowed Cycles(Curve F) = 95,565. Membrane-to-Bending Ratio = 1.164 Bending-to-PL+PB+Q Ratio = 0.462 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable 83,994 psi		
45%		
Pl+Pb+Q+F 45,000 psi	Damage Ratio 0.139 Life 0.536 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 50,444. "B31" Fatigue Stress Allowable = 100000.0 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 507,219. WRC 474 99% Probability Cycles = 117,834. WRC 474 95% Probability Cycles = 163,600. BS5500 Allowed Cycles(Curve F) = 57,082. Membrane-to-Bending Ratio = 0.459 Bending-to-PL+PB+Q Ratio = 0.685 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Allowable 83,994 psi		
53%		
Pad SCR for Plate # 1		
Pl	SPL	Primary Membrane Load Case 2

2,143 psi	31,000 psi	Min Prin. Stress = -6. (0% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
6%		
Qb 220 psi	SPS 69,000 psi	Primary Bending Load Case 2 Min Prin. Stress = -6. (0% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q 2,227 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -6. (0% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
3%		
Pl+Pb+Q 2,077 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -6. (0% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
3%		
S1+S2+S3 3,624 psi	4S 80,000 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -6. (0% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
4%		
Pl+Pb+Q 6,193 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -5815. (98% Neg, 0% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
8%		
Pl+Pb+Q 9,656 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -5815. (98% Neg, 0% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
13%		
Membrane 3,837 psi	User 69,000 psi	Component Evaluation Load Case 4 Min Prin. Stress = -5815. (98% Neg, 0% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
5%		
Bending 7,130 psi	User 69,000 psi	Component Evaluation Load Case 4 Min Prin. Stress = -5815. (98% Neg, 0% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 4
10%		
Pl+Pb+Q 6,193 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -5815. (98% Neg, 0% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
8%		
Pl+Pb+Q 9,656 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -5815. (98% Neg, 0% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
13%		
Pl+Pb+Q+F 8,360 psi	Damage Ratio 0.000 Life 0.100 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11
Allowable 83,994 psi		"B31" Fatigue Stress Allowable = 100000.0 MarkI Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 64,753,364. WRC 474 99% Probability Cycles = 15,043,081. WRC 474 95% Probability Cycles = 20,885,722. BS5500 Allowed Cycles(Curve F) = 8,902,927. Membrane-to-Bending Ratio = 0.651 Bending-to-PL+PB+Q Ratio = 0.606 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
9%		
Pl+Pb+Q+F 13,036	Damage Ratio 0.000 Life	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.350

psi	0.155	Stress	Strain Concentration Factor = 1.000
Allowable			Cycles Allowed for this Stress = 1.0000E11
83,994			"B31" Fatigue Stress Allowable = 100000.0
psi			MarkI Fatigue Stress Allowable = 83402.0
			WRC 474 Mean Cycles to Failure = 14,452,905.
15%			WRC 474 99% Probability Cycles = 3,357,602.
			WRC 474 95% Probability Cycles = 4,661,674.
			BS5500 Allowed Cycles(Curve F) = 2,348,264.
			Membrane-to-Bending Ratio = 0.501
			Bending-to-PL+PB+Q Ratio = 0.666
			Plot Reference:
			13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Shell in Plate # 1 Vicinity			
Pl	SPL		Primary Membrane Load Case 2
3,479	22,200		Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi		Plot Reference:
			1) Pl < SPL (SUS,Membrane) Case 2
15%			
Qb	SPS		Primary Bending Load Case 2
133	47,250		Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi		Plot Reference:
			2) Qb < SPS (SUS,Bending) Case 2
0%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 2
3,550	47,250		Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi		Plot Reference:
			3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
7%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 2
3,505	47,250		Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi		Plot Reference:
			4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
7%			
S1+S2+S3	4S		Part 5 (5.3.2) Load Case 2
5,947	59,200		Min Prin. Stress = -2. (0% Neg, 0% NegHi)
psi	psi		Plot Reference:
			5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
10%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 4
6,712	47,250		Min Prin. Stress = -4060. (82% Neg, 15% NegHi)
psi	psi		Plot Reference:
			6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
14%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 4
10,517	47,250		Min Prin. Stress = -4060. (82% Neg, 15% NegHi)
psi	psi		Plot Reference:
			7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
22%			
Membrane	User		Component Evaluation Load Case 4
5,750	47,250		Min Prin. Stress = -4060. (82% Neg, 15% NegHi)
psi	psi		Plot Reference:
			8) Membrane < User (OPE,Membrane) Case 4
12%			
Bending	User		Component Evaluation Load Case 4
6,141	47,250		Min Prin. Stress = -4060. (82% Neg, 15% NegHi)
psi	psi		Plot Reference:
			9) Bending < User (OPE,Bending) Case 4
12%			
Pl+Pb+Q	SPS		Primary+Secondary (Inner) Load Case 5
6,712	47,250		Min Prin. Stress = -4060. (82% Neg, 15% NegHi)
psi	psi		Plot Reference:
			10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
14%			
Pl+Pb+Q	SPS		Primary+Secondary (Outer) Load Case 5
10,517	47,250		Min Prin. Stress = -4060. (82% Neg, 15% NegHi)
psi	psi		Plot Reference:
			11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
22%			

Pl+Pb+Q+F 6,712 psi	Damage Ratio 0.000 Life 0.057 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78750.0 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 60,238,392. WRC 474 99% Probability Cycles = 13,994,192. WRC 474 95% Probability Cycles = 19,429,452. BS5500 Allowed Cycles(Curve F) = 7,839,911. Membrane-to-Bending Ratio = 1.408 Bending-to-PL+PB+Q Ratio = 0.415 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable 118,449 psi 5%		
Pl+Pb+Q+F 10,517 psi	Damage Ratio 0.000 Life 0.089 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 78750.0 MarkI Fatigue Stress Allowable = 95657.0 WRC 474 Mean Cycles to Failure = 15,136,993. WRC 474 99% Probability Cycles = 3,516,524. WRC 474 95% Probability Cycles = 4,882,321. BS5500 Allowed Cycles(Curve F) = 2,037,817. Membrane-to-Bending Ratio = 0.908 Bending-to-PL+PB+Q Ratio = 0.524 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Allowable 118,449 psi 8%		
Long Plate for Plate # 1		
Pl 212 psi	SPL 31,000 psi	Primary Membrane Load Case 2 Min Prin. Stress = -211. (1% Neg, 0% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
0%		
Qb 0 psi	SPS 69,000 psi	Primary Bending Load Case 2 Min Prin. Stress = -211. (1% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
0%		
Pl+Pb+Q 212 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -211. (1% Neg, 0% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
0%		
Pl+Pb+Q 212 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -211. (1% Neg, 0% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
0%		
S1+S2+S3 -210 psi	4S 80,000 psi	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -211. (1% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
0%		
Pl+Pb+Q 26,790 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -16496. (99% Neg, 33% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 4
38%		
Pl+Pb+Q 26,751 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -16496. (99% Neg, 33% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 4
38%		
Membrane 11,204 psi	User 69,000 psi	Component Evaluation Load Case 4 Min Prin. Stress = -16496. (99% Neg, 33% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 4
16%		
Bending	User	Component Evaluation Load Case 4

25,600 psi	69,000 psi	Min Prin. Stress = -16496. (99% Neg, 33% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 4
37%		
Pl+Pb+Q 26,790 psi	SPS 69,000 psi	Primary+Secondary (Inner) Load Case 5 Min Prin. Stress = -16496. (99% Neg, 33% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 5
38%		
Pl+Pb+Q 26,751 psi	SPS 69,000 psi	Primary+Secondary (Outer) Load Case 5 Min Prin. Stress = -16496. (99% Neg, 33% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 5
38%		
Pl+Pb+Q+F 26,790 psi	Damage Ratio 0.015 Life 0.319 Stress	Primary+Secondary+Peak (Inner) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 472,458. "B31" Fatigue Stress Allowable = 100000.0 Markl Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 1,027,272. WRC 474 99% Probability Cycles = 238,649. WRC 474 95% Probability Cycles = 331,339. BS5500 Allowed Cycles(Curve F) = 109,950. Membrane-to-Bending Ratio = 0.161 Bending-to-PL+PB+Q Ratio = 0.862 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 5
Allowable 83,994 psi		
31%		
Pl+Pb+Q+F 26,751 psi	Damage Ratio 0.015 Life 0.318 Stress	Primary+Secondary+Peak (Outer) Load Case 5 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 475,610. "B31" Fatigue Stress Allowable = 100000.0 Markl Fatigue Stress Allowable = 83402.0 WRC 474 Mean Cycles to Failure = 1,015,441. WRC 474 99% Probability Cycles = 235,901. WRC 474 95% Probability Cycles = 327,523. BS5500 Allowed Cycles(Curve F) = 110,432. Membrane-to-Bending Ratio = 0.192 Bending-to-PL+PB+Q Ratio = 0.839 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 5
Allowable 83,994 psi		
31%		

[Table of Contents](#)

Compressive Stress Summary
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
5:36pm NOV 29,2022

\$P

Compressive Stress Summary (psi) \$X

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress
Pts in Region - No. of nodes in the model region
>5% Compression - 5% or more of Compressive Stress Limit
>50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = -0.55 Min(Sy, kEt/R), Section
slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	>5% Compression and Bending	>50% Compression and Bending	Region
1	SUSTAINED	2	-2.	1108	0%	0%	Shell in Plate # 1 Vicinity
2	OPERATING	4	-4060.	1108	82%	15%	Shell in Plate # 1 Vicinity
3	EXPANSION	5	-4060.	1108	82%	15%	Shell in Plate # 1 Vicinity
4	SUSTAINED	2	-3.	348	0%	0%	Shell SCR at Plate # 1
5	OPERATING	4	-2506.	348	88%	0%	Shell SCR at Plate # 1
6	EXPANSION	5	-2506.	348	88%	0%	Shell SCR at Plate # 1

7	SUSTAINED	2	-6.	424	0%	0%	Pad SCR for Plate # 1
8	OPERATING	4	-5815.	424	98%	0%	Pad SCR for Plate # 1
9	EXPANSION	5	-5815.	424	98%	0%	Pad SCR for Plate # 1
10	SUSTAINED	2	-408.	32	18%	0%	Long Plate SCR for Plate # 1
11	OPERATING	4	-23236.	32	99%	31%	Long Plate SCR for Plate # 1
12	EXPANSION	5	-23236.	32	99%	31%	Long Plate SCR for Plate # 1
13	SUSTAINED	2	-211.	104	1%	0%	Long Plate for Plate # 1
14	OPERATING	4	-16496.	104	99%	33%	Long Plate for Plate # 1
15	EXPANSION	5	-16496.	104	99%	33%	Long Plate for Plate # 1

Table of Contents


Finite Element Model

- [Finite Element Model](#)



Area of Discontinuity at Plate

- [1\) Pl < SPL \(SUS Membrane\) Case 2](#)
- [2\) Qb < SPS \(SUS Bending\) Case 2](#)
- [3\) Pl+Pb+Q < SPS \(SUS Inside\) Case 2](#)
- [4\) Pl+Pb+Q < SPS \(SUS Outside\) Case 2](#)
- [5\) S1+S2+S3 < 4S \(SUS S1+S2+S3\) Case 2](#)
- [6\) Pl+Pb+Q < SPS \(OPE Inside\) Case 4](#)
- [7\) Pl+Pb+Q < SPS \(OPE Outside\) Case 4](#)
- [8\) Membrane < User \(OPE Membrane\) Case 4](#)
- [9\) Bending < User \(OPE Bending\) Case 4](#)
- [10\) Pl+Pb+Q < SPS \(EXP Inside\) Case 5](#)
- [11\) Pl+Pb+Q < SPS \(EXP Outside\) Case 5](#)
- [12\) Pl+Pb+Q+F < 2Sa \(EXP Inside\) Case 5](#)
- [13\) Pl+Pb+Q+F < 2Sa \(EXP Outside\) Case 5](#)

Finite Element Model





3d

1) $P1 < SPL$ (SUS Membrane) Case 2

3d(Deformed)

3d(Small)



3d

2) $Qb < SPS$ (SUS Bending) Case 2

3d(Deformed)

3d(Small)



3d

3) $P1+Pb+Q < SPS$ (SUS Inside) Case 2

3d(Small)

3d



3d(Deformed)

4) $P1+Pb+Q < SPS$ (SUS Outside) Case 2

3d(Small)

3d



3d(Deformed)

5) $S1+S2+S3 < 4S$ (SUS $S1+S2+S3$) Case 2

3d(Small)

3d



3d(Deformed)

6) $P1+Pb+Q < SPS$ (OPE Inside) Case 4

3d(Small)

3d

3d(Deformed)



7) $P1+Pb+Q < SPS$ (OPE Outside) Case 4

3d(Small)

3d

3d(Deformed)

8) Membrane < User (OPE Membrane) Case 4




3d(Small)


3d

3d(Deformed)


9) Bending < User (OPE Bending) Case 4




10) P1+Pb+Q < SPS (EXP Inside) Case 5




11) $P_l + P_b + Q < SPS$ (EXP Outside) Case 5



12) $P_l + P_b + Q + F < 2S_a$ (EXP Inside) Case 5



13) $P1+Pb+Q+F < 2Sa$ (EXP Outside) Case 5



3d(Small)

3d