



Customer Document title:

General Arrangement DrawingFlowserve Document title: **General Arrangement Drawing**Flowserve Document No.: **1408912-003-2500-01**Document Revision No.: **B**Flowserve Order No.: **1408912**Flowserve Serial No.: **1408912CHP003A/B**Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**Quantity: **2**Customer Name: **World Energy Paramount**Customer Tag No: **18P1879 A/B**Customer PO No.: **4505555756**End User: **AIR PRODUCTS LLC****Please complete and return:**


Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
- ☐ **APPROVED. RE-SUBMIT AS FINAL.**
- ☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
- ☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
- ☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
- ☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
B	Information Only	Lakshmikantha, Gowda	09-Nov-22





Customer Document title:

2.2 Material Certificate of Compliance

Flowserve Document title: **2.2 Material Certificate of Compliance**

Flowserve Document No.: **1408912-003-1002-01**

Document Revision No.: **0**

Flowserve Order No.: **1408912**

Flowserve Serial No.: **1408912CHP003A/B**

Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**

Quantity: **2**

Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**

Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:

Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
☐ **APPROVED. RE-SUBMIT AS FINAL.**
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final	Shaw, Amie	28-Feb-23



Pump Division
Chesapeake Virginia
Quality Assurance Department

Internet: TMomtsios@flowserve.com phone: 757-485-8052 fax: 757-485-8191

COMPONENT: SHAFT

2.2 Certificate of Compliance European Standard EN 10204

Material: ASTM A276 Type 316/316L Stainless Steel

Flowserve certifies that the 316/316L SS parts supplied meet the requirements of ASTM A276.
Below are typical properties based on historical test data for the material:

Composition in Wt %

Cr	16.13
Ni	10.13
Mo	2.022
Si	.564
Cu	.310
Mn	.1660
S	.024
Co	.092
P	.028
N	.065
C	.015
Fe	bal

Yield strength	42,700 psi
Tensile strength	91,300 psi
Elongation	52.4 %
RA	75.5%

A handwritten signature in black ink, appearing to read "Tom Momtsios", is written over a horizontal line.

Tom Momtsios
Quality Assurance, Chesapeake Operations



Pump Division
Chesapeake Virginia

Quality Assurance Department

Internet: TMomtsios@flowserve.com phone: 757-485-8052 fax: 757-485-8191

COMPONENT: IMPELLER,COVER

2.2 Certificate of Compliance European Standard EN 10204

Material: ASTM A744 CF-8M Stainless Steel

Flowserve certifies that the cast steel parts supplied meet the requirements of ASTM A744.
Below are typical properties based on historical test data for the material:

Composition in Wt %

Cr	18.74
Ni	9.18
Mo	2.12
Si	1.37
Cu	.30
Mn	.79
S	.002
P	.024
C	.044
Fe	Bal

Yield strength	43,200 psi
Tensile strength	90,900 psi
Elongation	46 %

A handwritten signature in black ink, appearing to read "Tom Momtsios", is written over a horizontal line.

Tom Momtsios
Quality Assurance, Chesapeake Operations



Pump Division
Chesapeake Virginia

Quality Assurance Department

Internet: tmomtsios@flowserve.com phone: 757-485-8000 fax: 757-485-8194

COMPONENT: CASING

2.2 Certificate of Compliance European Standard EN 10204

Material : ASTM A395 Ductile Cast Iron

Flowserve certifies that the ductile cast iron parts supplied meet the requirements of ASTM A395 60-40-18.

Below are actual typical properties for the material based on melt number D8045-65 which was poured on Feb. 14, 2008:

Carbon	3.92 %
Silicon	2.75 %
Phosphorus	0.036 %
Sulfur	0.008 %
Fe	BAL

Yield strength	46,298 psi
Tensile strength	66,277 psi
Elongation	21.0 %
Hardness	154 HB

A handwritten signature in cursive script that reads "Logan Coard".

Logan Coard
Quality Assurance, Chesapeake Operations



Customer Document title:

Certificate of Conformance

Flowserve Document title: **Certificate of Conformance**
Flowserve Document No.: **1408912-003-1008-01**
Document Revision No.: **0**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:

Document Reviewed by:		Document Reviewed date:	
<input type="checkbox"/> APPROVED. NO ACTION REQUIRED <input type="checkbox"/> APPROVED. RE-SUBMIT AS FINAL. <input type="checkbox"/> APPROVED WITH COMMENTS. DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL. <input type="checkbox"/> REJECTED. CORRECT AND RE-SUBMIT FOR APPROVAL. <input type="checkbox"/> FOR INFORMATION. REVIEW NOT REQUIRED <input type="checkbox"/> AS-BUILT			

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered Approved, no action.
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final	Shaw, Amie	28-Feb-23



Certificate of Conformance

Customer Name:	World Energy Paramount
Customer PO No.:	4505555756
Customer Tag No:	18P1879 A/B
Flowserve Order:	1408912
Pump Type/Size:	MARK 3 STANDARD / 2K3X2-13RV
Flowserve Serial: No.:	1408912CHP003A/B
Quantity:	2

This is to certify that the equipment, component parts, etc., on subject order or contract have been manufactured by Flowserve or manufactured in whole or in part by contractors under the supervision of Flowserve, and comply with all requirements specified by order or contract referenced above.

Logan Coard

Quality Assurance, Chesapeake Operations



Customer Document title:

Certificate of Hydrostatic Test

Flowserve Document title: **Certificate of Hydrostatic Test**
Flowserve Document No.: **1408912-003-1010-01**
Document Revision No.: **0**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:

Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
☐ **APPROVED. RE-SUBMIT AS FINAL.**
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Information Only	Shaw, Amie	28-Feb-23



Certificate of Hydrostatic Test

Customer Name:	World Energy Paramount
Customer PO No.:	4505555756
Customer Tag No:	18P1879 A/B
Flowserve Order:	1408912
Pump Type/Size:	MARK 3 STANDARD / 2K3X2-13RV
Flowserve Serial: No.:	1408912CHP003A/B
Quantity:	2

This is to certify that the following units have been successfully hydrostatic tested to pressures quoted and found to be satisfactorily sound.

Part Type	Part Number	Material	Hold Time	PSI #
CASING	BY40035N	ASTM A395	10 MIN	375
COVER	SM-DY52028A-D4-XXGXX	ASTM A744 CF8M	10 MIN	675

Logan Coard

Quality Assurance, Chesapeake Operations



Customer Document title:

Certificate of Impeller Balance

Flowserve Document title: **Certificate of Impeller Balance**
Flowserve Document No.: **1408912-003-1012-01**
Document Revision No.: **0**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:

Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
☐ **APPROVED. RE-SUBMIT AS FINAL.**
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final	Shaw, Amie	28-Feb-23



Certificate of Impeller Balance – 6.3

Customer Name:	World Energy Paramount
Customer PO No.:	4505555756
Customer Tag No:	18P1879 A/B
Flowserve Order:	1408912
Pump Type/Size:	MARK 3 STANDARD / 2K3X2-13RV
Flowserve Serial: No.:	1408912CHP003A/B
Quantity:	2
Equipment Service:	water pump

It is hereby certified that balance to ISO – 1940-11 G 6.3 was performed on the impellers for the units described.

Part Type	Part Number	Material Spec.	Balance Grade
Impeller	SM-MY49112A130-D4-XXGXX	ASTM A744 CF8M	6.3

Logan Coard

Quality Assurance, Chesapeake Operations



Customer Document title:

Certificate of Noise Compliance

Flowserve Document title: **Certificate of Noise Compliance**

Flowserve Document No.: **1408912-003-1014-01**

Document Revision No.: **0**

Flowserve Order No.: **1408912**

Flowserve Serial No.: **1408912CHP003A/B**

Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**

Quantity: **2**

Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**

Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:

Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
- ☐ **APPROVED. RE-SUBMIT AS FINAL.**
- ☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
- ☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
- ☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
- ☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final	Shaw, Amie	28-Feb-23



Certificate of Noise Compliance

Customer Name:	World Energy Paramount
Customer PO No.:	4505555756
Flowserve Order:	1408912
Pump Type/Size:	MARK 3 STANDARD / 2K3X2-13RV
Flowserve Serial: No.:	1408912CHP003A/B
Quantity:	2

This is to certify that the noise level for pump and driver will not exceed 85 dBa free field when measured 3 ft. away from any surface of the equipment.

Logan Coard

Quality Assurance, Chesapeake Operations



Customer Document title:

Cross Section

Flowserve Document title: **Cross Section**
Flowserve Document No.: **1408912-003-1016-01**
Document Revision No.: **B**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:


Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
☐ **APPROVED. RE-SUBMIT AS FINAL**
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	For Review	Lakshmikantha, Gowda	06-Mar-23



ITEM ID	ITEM NAME	ITEM DESCRIPTION	ITEM QTY
1	ITEM 1	ITEM 1 DESCRIPTION	1
2	ITEM 2	ITEM 2 DESCRIPTION	2
3	ITEM 3	ITEM 3 DESCRIPTION	3
4	ITEM 4	ITEM 4 DESCRIPTION	4
5	ITEM 5	ITEM 5 DESCRIPTION	5
6	ITEM 6	ITEM 6 DESCRIPTION	6
7	ITEM 7	ITEM 7 DESCRIPTION	7
8	ITEM 8	ITEM 8 DESCRIPTION	8
9	ITEM 9	ITEM 9 DESCRIPTION	9
10	ITEM 10	ITEM 10 DESCRIPTION	10
11	ITEM 11	ITEM 11 DESCRIPTION	11
12	ITEM 12	ITEM 12 DESCRIPTION	12
13	ITEM 13	ITEM 13 DESCRIPTION	13
14	ITEM 14	ITEM 14 DESCRIPTION	14
15	ITEM 15	ITEM 15 DESCRIPTION	15
16	ITEM 16	ITEM 16 DESCRIPTION	16
17	ITEM 17	ITEM 17 DESCRIPTION	17
18	ITEM 18	ITEM 18 DESCRIPTION	18
19	ITEM 19	ITEM 19 DESCRIPTION	19
20	ITEM 20	ITEM 20 DESCRIPTION	20
21	ITEM 21	ITEM 21 DESCRIPTION	21
22	ITEM 22	ITEM 22 DESCRIPTION	22
23	ITEM 23	ITEM 23 DESCRIPTION	23
24	ITEM 24	ITEM 24 DESCRIPTION	24
25	ITEM 25	ITEM 25 DESCRIPTION	25
26	ITEM 26	ITEM 26 DESCRIPTION	26
27	ITEM 27	ITEM 27 DESCRIPTION	27
28	ITEM 28	ITEM 28 DESCRIPTION	28
29	ITEM 29	ITEM 29 DESCRIPTION	29
30	ITEM 30	ITEM 30 DESCRIPTION	30
31	ITEM 31	ITEM 31 DESCRIPTION	31
32	ITEM 32	ITEM 32 DESCRIPTION	32
33	ITEM 33	ITEM 33 DESCRIPTION	33
34	ITEM 34	ITEM 34 DESCRIPTION	34
35	ITEM 35	ITEM 35 DESCRIPTION	35
36	ITEM 36	ITEM 36 DESCRIPTION	36
37	ITEM 37	ITEM 37 DESCRIPTION	37
38	ITEM 38	ITEM 38 DESCRIPTION	38
39	ITEM 39	ITEM 39 DESCRIPTION	39
40	ITEM 40	ITEM 40 DESCRIPTION	40
41	ITEM 41	ITEM 41 DESCRIPTION	41
42	ITEM 42	ITEM 42 DESCRIPTION	42
43	ITEM 43	ITEM 43 DESCRIPTION	43
44	ITEM 44	ITEM 44 DESCRIPTION	44
45	ITEM 45	ITEM 45 DESCRIPTION	45
46	ITEM 46	ITEM 46 DESCRIPTION	46
47	ITEM 47	ITEM 47 DESCRIPTION	47
48	ITEM 48	ITEM 48 DESCRIPTION	48
49	ITEM 49	ITEM 49 DESCRIPTION	49
50	ITEM 50	ITEM 50 DESCRIPTION	50
51	ITEM 51	ITEM 51 DESCRIPTION	51
52	ITEM 52	ITEM 52 DESCRIPTION	52
53	ITEM 53	ITEM 53 DESCRIPTION	53
54	ITEM 54	ITEM 54 DESCRIPTION	54
55	ITEM 55	ITEM 55 DESCRIPTION	55
56	ITEM 56	ITEM 56 DESCRIPTION	56
57	ITEM 57	ITEM 57 DESCRIPTION	57
58	ITEM 58	ITEM 58 DESCRIPTION	58
59	ITEM 59	ITEM 59 DESCRIPTION	59
60	ITEM 60	ITEM 60 DESCRIPTION	60
61	ITEM 61	ITEM 61 DESCRIPTION	61
62	ITEM 62	ITEM 62 DESCRIPTION	62
63	ITEM 63	ITEM 63 DESCRIPTION	63
64	ITEM 64	ITEM 64 DESCRIPTION	64
65	ITEM 65	ITEM 65 DESCRIPTION	65
66	ITEM 66	ITEM 66 DESCRIPTION	66
67	ITEM 67	ITEM 67 DESCRIPTION	67
68	ITEM 68	ITEM 68 DESCRIPTION	68
69	ITEM 69	ITEM 69 DESCRIPTION	69
70	ITEM 70	ITEM 70 DESCRIPTION	70
71	ITEM 71	ITEM 71 DESCRIPTION	71
72	ITEM 72	ITEM 72 DESCRIPTION	72
73	ITEM 73	ITEM 73 DESCRIPTION	73
74	ITEM 74	ITEM 74 DESCRIPTION	74
75	ITEM 75	ITEM 75 DESCRIPTION	75
76	ITEM 76	ITEM 76 DESCRIPTION	76
77	ITEM 77	ITEM 77 DESCRIPTION	77
78	ITEM 78	ITEM 78 DESCRIPTION	78
79	ITEM 79	ITEM 79 DESCRIPTION	79
80	ITEM 80	ITEM 80 DESCRIPTION	80
81	ITEM 81	ITEM 81 DESCRIPTION	81
82	ITEM 82	ITEM 82 DESCRIPTION	82
83	ITEM 83	ITEM 83 DESCRIPTION	83
84	ITEM 84	ITEM 84 DESCRIPTION	84
85	ITEM 85	ITEM 85 DESCRIPTION	85
86	ITEM 86	ITEM 86 DESCRIPTION	86
87	ITEM 87	ITEM 87 DESCRIPTION	87
88	ITEM 88	ITEM 88 DESCRIPTION	88
89	ITEM 89	ITEM 89 DESCRIPTION	89
90	ITEM 90	ITEM 90 DESCRIPTION	90
91	ITEM 91	ITEM 91 DESCRIPTION	91
92	ITEM 92	ITEM 92 DESCRIPTION	92
93	ITEM 93	ITEM 93 DESCRIPTION	93
94	ITEM 94	ITEM 94 DESCRIPTION	94
95	ITEM 95	ITEM 95 DESCRIPTION	95
96	ITEM 96	ITEM 96 DESCRIPTION	96
97	ITEM 97	ITEM 97 DESCRIPTION	97
98	ITEM 98	ITEM 98 DESCRIPTION	98
99	ITEM 99	ITEM 99 DESCRIPTION	99
100	ITEM 100	ITEM 100 DESCRIPTION	100

Page 66 of 253



Customer Document title:

Nozzle Loads

Flowserve Document title: **Nozzle Loads**
Flowserve Document No.: **1408912-003-1044-01**
Document Revision No.: **0**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC****Please complete and return:**

Document Reviewed by:		Document Reviewed date:	
<input type="checkbox"/> APPROVED. NO ACTION REQUIRED <input type="checkbox"/> APPROVED. RE-SUBMIT AS FINAL. <input type="checkbox"/> APPROVED WITH COMMENTS. DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL. <input type="checkbox"/> REJECTED. CORRECT AND RE-SUBMIT FOR APPROVAL. <input type="checkbox"/> FOR INFORMATION. REVIEW NOT REQUIRED <input type="checkbox"/> AS-BUILT			

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final	Morris, Tamika	27-Jan-22

- a) Determine the appropriate casing "Material Group No." from figure 3-2.
- b) Find the "Casing material correction factor" in Figure 4-14 based upon the "Material Group No." and operating temperature. Interpolation may be used to determine the correction factor for a specific temperature.
- c) Find the "Baseplate correction factor" in Figure 4-15. The correction factor depends upon how the baseplate is to be installed.
- d) Locate the pump model being evaluated in Figure 4-19 and multiply each load rating by the casing correction factor. Record the "adjusted Figure 4-19 loads".
- e) Locate the pump model being evaluated in Figures 4-20 and 4-21 and multiply each load rating by the baseplate correction factor. Record the adjusted Figure 4-20 and 4-21 loads.
- f) Compare the "adjusted Figure 4-19 loads" to the values shown in figure 4-18. The lower of these two values should be used as the adjusted figure 4-18 values. *(The HI standard also asks that figure 4-18 loads be reduced if figure 4-20 or 4-21 values are lower. Flowserve does not follow this step.)*
- g) Calculate the applied loads at the casing flanges according to the coordinate system found in figure 4-16. The 12 forces and moments possible are Fxs, Fys, Fzs, Mxs, Mys, Mzs, Fxd, Fyd, Fzd, Mxd, Myd and Mzd. For example, Fxd designates Force in the "x" direction on the discharge flange. Mys designates the Moment about the "y"-axis on the suction flange.
- h) Figure 4-17 gives the acceptance criteria equations. For long coupled pumps, equation sets 1 through 5 must be satisfied. For close coupled and C-face pumps, only equation sets 1 and 2 must be satisfied.
 - i) Equation set 1. Each applied load is divided by the corresponding adjusted figure 4-18 value. The absolute value of each ratio must be less than or equal to one.
 - j) Equation set 2. The summation of the absolute values of each ratio must be less than or equal to two. The ratios are the applied load divided by the adjusted figure 4-19 values.
 - k) Equation sets 3 and 4. These equations are checking for coupling misalignment due to nozzle loading in each axis. Each applied load is divided by the corresponding adjusted load from figure 4-20 and 4-21. The result of each equation must be between one and negative one.
 - l) Equation set 5. This equation calculates the total shaft movement from the results of equations 3 and 4. The result must be less than or equal to one.

4.6.4 Allowable nozzle loads

Flowserve chemical process pumps meet or exceed the allowable nozzle loads given by ANSI/HI 9.6.2. The following paragraphs describe how to calculate the allowable loads for each pump type and how to determine if the applied loads are acceptable. The first configuration covered is ASME B73.1M pumps, including the Mark 3 Standard, Sealmatic, Lo-Flo, Recessed Impeller, and Unitized Self-Priming pumps. The second configuration covered is the ASME B73.2M vertical, Mark 3 In-Line pump.

4.6.4.1 Mark 3 horizontal pumps (ASME B73.1M)

The following steps are based upon ANSI/HI 9.6.2. All information necessary to complete the evaluation is given below. For complete details please review the standard.

Figure 4-14: Casing Material Correction Factors

Temp °C	Temp °F	Material Group No.														
		1.0	1.1	2.1	2.2	2.4	2.8	3.2	3.4	3.5	3.7	3.8	3.17	Ti	Cr	
		DCI	Carbon Steel	Austenitic Steels				Nickel and Nickel Alloys							Ti, Ti- Pd, Zr	High Chrome -18 to 171°C (0 to 340°F)
				Type 304 and 304L	Type 316 and 316L	Type 321	CD- 4MCu	Nickel	Monel	Inconel	Hast B.	Hast C.	Alloy 20			
-129	-200			1.00	1.00	1.00		0.50					0.83			
-73	-100			1.00	1.00	1.00	1.00	0.50	0.83	0.93	1.00	1.00	0.83	0.89		
-29	-20	0.89	1.00	1.00	1.00	1.00	1.00	0.50	0.83	0.93	1.00	1.00	0.83	0.89	0.65	
38	100	0.89	1.00	1.00	1.00	1.00	1.00	0.50	0.83	0.93	1.00	1.00	0.83	0.89	0.65	
93	200	0.83	0.94	0.83	0.86	0.93	1.00	0.50	0.74	0.88	1.00	1.00	0.72	0.86	0.65	
150	300	0.78	0.91	0.75	0.78	0.83	0.92	0.50	0.69	0.82	1.00	1.00	0.65	0.81	0.65	
205	400	0.73	0.88	0.69	0.72	0.69	0.85	0.50	0.67	0.77	0.98	0.98	0.58	0.69	0.65	
260	500	0.69	0.83	0.63	0.67	0.64	0.80	0.50	0.66	0.74	0.92	0.92	0.54	0.57		
315	600	0.65	0.76	0.60	0.63	0.60	0.77	0.50	0.66	0.74	0.84	0.84	0.50	0.45		
344	650	0.63	0.74	0.60	0.62	0.60			0.66	0.73	0.82	0.82		0.39		
370	700		0.74	0.59	0.60	0.58			0.66	0.73	0.79	0.79		0.33		

Figure 4-15: Baseplate correction factors

Base Type	Grouted	Bolted	Stilt Mounted
Type A	1.0	0.7	0.65
Type B - Polybase	1.0	n/a	0.95
Type C	n/a	1.0	1.0
Type D	1.0	0.8	0.75
Type E - PIP	1.0	0.95	n/a
Type T5000	1.0	n/a	n/a
Polysield - baseplate/foundation	1.0	n/a	n/a


Figure 4-16: Coordinate system


Figure 4-17: Acceptance criteria equations

Set	Equations	Figure	Remarks
1	$\left \frac{F_{xs}}{F_{xs_adj}} \right \leq 1.0, \left \frac{F_{ys}}{F_{ys_adj}} \right \leq 1.0, \left \frac{F_{zs}}{F_{zs_adj}} \right \leq 1.0, \left \frac{M_{xs}}{M_{xs_adj}} \right \leq 1.0, \left \frac{M_{ys}}{M_{ys_adj}} \right \leq 1.0, \left \frac{M_{zs}}{M_{zs_adj}} \right \leq 1.0,$ $\left \frac{F_{xd}}{F_{xd_adj}} \right \leq 1.0, \left \frac{F_{yd}}{F_{yd_adj}} \right \leq 1.0, \left \frac{F_{zd}}{F_{zd_adj}} \right \leq 1.0, \left \frac{M_{xd}}{M_{xd_adj}} \right \leq 1.0, \left \frac{M_{yd}}{M_{yd_adj}} \right \leq 1.0, \left \frac{M_{zd}}{M_{zd_adj}} \right \leq 1.0$	Adjusted 4-18	Maximum individual loading
2	$\left \frac{F_{xs}}{F_{xs_adj}} \right + \left \frac{F_{ys}}{F_{ys_adj}} \right + \left \frac{F_{zs}}{F_{zs_adj}} \right + \left \frac{M_{xs}}{M_{xs_adj}} \right + \left \frac{M_{ys}}{M_{ys_adj}} \right + \left \frac{M_{zs}}{M_{zs_adj}} \right +$ $\left \frac{F_{xd}}{F_{xd_adj}} \right + \left \frac{F_{yd}}{F_{yd_adj}} \right + \left \frac{F_{zd}}{F_{zd_adj}} \right + \left \frac{M_{xd}}{M_{xd_adj}} \right + \left \frac{M_{yd}}{M_{yd_adj}} \right + \left \frac{M_{zd}}{M_{zd_adj}} \right \leq 2.0$	Adjusted 4-19	Nozzle stress, bolt stress, pump slippage
3	$A = \frac{F_{ys}}{F_{ys_adj}} + \frac{M_{xs}}{M_{xs_adj}} + \frac{M_{ys}}{M_{ys_adj}} + \frac{M_{zs}}{M_{zs_adj}} +$ $\frac{F_{yd}}{F_{yd_adj}} + \frac{M_{xd}}{M_{xd_adj}} + \frac{M_{yd}}{M_{yd_adj}} + \frac{M_{zd}}{M_{zd_adj}}$ $-1.0 \leq A \leq 1.0$	Adjusted 4-20	y-axis movement
4	$B = \frac{F_{xs}}{F_{xs_adj}} + \frac{F_{zs}}{F_{zs_adj}} + \frac{M_{xs}}{M_{xs_adj}} + \frac{M_{ys}}{M_{ys_adj}} + \frac{M_{zs}}{M_{zs_adj}} +$ $\frac{F_{xd}}{F_{xd_adj}} + \frac{F_{yd}}{F_{yd_adj}} + \frac{F_{zd}}{F_{zd_adj}} + \frac{M_{xd}}{M_{xd_adj}} + \frac{M_{yd}}{M_{yd_adj}} + \frac{M_{zd}}{M_{zd_adj}}$ $-1.0 \leq B \leq 1.0$	Adjusted 4-21	z-axis movement
5	$\sqrt{A^2 + B^2} \leq 1.0$	-	Combined axis

Figure 4-18: Maximum individual loading

Pump size	Suction Flange						Discharge Flange					
	Forces N (lbf)			Moments Nm (lbf-ft)			Forces N (lbf)			Moments Nm (lbf-ft)		
	Fxs	Fys	Fzs	Mxs	Mys	Mzs	Fxd	Fyd	Fzd	Mxd	Myd	Mzd
1K 1.5x1-LF4	4 670 (1 050)	3 336 (750)	3 336 (750)	976 (720)	231 (170)	231 (170)	3 558 (800)	6 005 (1350)	13 344 (3 000)	556 (410)	556 (410)	556 (410)
1K 1.5x1-6	4 670 (1 050)	3 336 (750)	3 336 (750)	976 (720)	231 (170)	231 (170)	3 558 (800)	6 005 (1350)	13 344 (3 000)	556 (410)	556 (410)	556 (410)
1K 3x1.5-6	4 670 (1 050)	5 516 (1 240)	5 560 (1 250)	1 220 (900)	664 (490)	664 (490)	3 558 (800)	6 005 (1 350)	13 344 (3 000)	678 (500)	746 (550)	692 (510)
1K 3x2-6 and US-6	4 670 (1 050)	4 670 (1 050)	4 670 (1 050)	1 220 (900)	298 (220)	298 (220)	3 558 (800)	6 005 (1 350)	13 344 (3 000)	678 (500)	1 356 (1 000)	692 (510)
1K 1.5x1-8 and LF8	4 670 (1 050)	5 382 (1 210)	5 382 (1 210)	976 (720)	258 (190)	258 (190)	3 558 (800)	6 005 (1 350)	13 344 (3 000)	488 (360)	488 (360)	488 (360)
1K 1.5x1.5US-8	4 670 (1 050)	5 382 (1 210)	5 382 (1 210)	976 (720)	258 (190)	258 (190)	3 558 (800)	6 005 (1 350)	13 344 (3 000)	488 (360)	488 (360)	488 (360)
1K 3x1.5-8	4 670 (1 050)	5 516 (1 240)	5 560 (1 250)	1 220 (900)	664 (490)	664 (490)	3 558 (800)	6 005 (1 350)	13 344 (3 000)	597 (440)	597 (440)	597 (440)
2K 3x2-8 and US-8	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	814 (600)	814 (600)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	895 (660)	895 (660)	895 (660)
2K 4x3-8 and US-8	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	475 (350)	475 (350)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	1 980 (1 460)	936 (690)
2K 2x1-10A and LF10	10 408 (2 340)	4 270 (960)	4 270 (960)	1 722 (1 270)	298 (220)	298 (220)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	895 (660)	895 (660)	895 (660)
2K 2x1.5US-10A	10 408 (2 340)	4 270 (960)	4 270 (960)	1 722 (1 270)	298 (220)	298 (220)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	895 (660)	895 (660)	895 (660)
2K 2x2R-10	10 408 (2 340)	4 270 (960)	4 270 (960)	1 722 (1 270)	298 (220)	298 (220)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	895 (660)	895 (660)	895 (660)
2K 3x1.5-10A	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	570 (420)	570 (420)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	502 (370)	502 (370)	502 (370)
2K 3x2-10A	12 010 (2 700)	6 005 (1 350)	6 583 (1 480)	1 763 (1 300)	420 (310)	420 (310)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	759 (560)	759 (560)	759 (560)
2K 3x2US-10	12 010 (2 700)	6 005 (1 350)	6 583 (1 480)	1 763 (1 300)	420 (310)	420 (310)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	759 (560)	759 (560)	759 (560)
2K 3x3R-10	12 010 (2 700)	6 005 (1 350)	6 583 (1 480)	1 763 (1 300)	420 (310)	420 (310)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	759 (560)	759 (560)	759 (560)
2K 4x3-10 and 10H	10 230 (2 300)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	420 (310)	420 (310)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	1 980 (1 460)	936 (690)
2K 4x3US-10H	10 230 (2 300)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	420 (310)	420 (310)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	1 980 (1 460)	936 (690)
2K 6x4-10 and 10H	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	1 492 (1 100)	1 492 (1 100)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	2 034 (1 500)	936 (690)
2K 3x1.5-13 and LF13	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	909 (670)	909 (670)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	719 (530)	719 (530)	719 (530)
2K 3x2-13	8 540 (1 920)	5 471 (1 230)	5 471 (1 230)	1 763 (1 300)	475 (350)	475 (350)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	1 722 (1 270)	936 (690)
2K 3x2US-13	8 540 (1 920)	5 471 (1 230)	5 471 (1 230)	1 763 (1 300)	475 (350)	475 (350)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	1 722 (1 270)	936 (690)
2K 4x3-13 and 13HH	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	542 (400)	542 (400)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	2 034 (1 500)	936 (690)
2K 4x3US-13	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	542 (400)	542 (400)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	2 034 (1 500)	936 (690)
2K 4x3R-13	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	542 (400)	542 (400)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	2 034 (1 500)	936 (690)
2K 6x4-13A	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	1 492 (1 100)	1 492 (1 100)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	2 034 (1 500)	936 (690)
2K 6x4US-13A	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	1 492 (1 100)	1 492 (1 100)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	2 034 (1 500)	936 (690)
2K 6x4R-13	12 010 (2 700)	6 005 (1 350)	6 672 (1 500)	1 763 (1 300)	1 492 (1 100)	1 492 (1 100)	6 227 (1 400)	6 005 (1 350)	14 456 (3 250)	1 627 (1 200)	2 034 (1 500)	936 (690)
3K 8x6-14A	15 568 (3 500)	14 145 (3 180)	8 896 (2 000)	2 034 (1 500)	1 587 (1 170)	1 587 (1 170)	6 672 (1 500)	13 344 (3 000)	15 568 (3 500)	1 695 (1 250)	3 851 (2 840)	3 851 (2 840)
3K 10x8-14	15 568 (3 500)	14 145 (3 180)	8 896 (2 000)	2 034 (1 500)	2 712 (2 000)	2 915 (2 150)	6 672 (1 500)	13 344 (3 000)	15 568 (3 500)	1 695 (1 250)	3 851 (2 840)	3 851 (2 840)
3K 6x4-16	15 568 (3 500)	12 721 (2 860)	8 006 (1 800)	1 831 (1 350)	1 431 (1 055)	1 431 (1 055)	6 005 (1 350)	12 010 (2 700)	14 011 (3 150)	1 526 (1 125)	3 465 (2 555)	3 465 (2 555)
3K 8x6-16A	15 568 (3 500)	14 145 (3 180)	8 896 (2 000)	2 034 (1 500)	2 007 (1 480)	2 007 (1 480)	6 672 (1 500)	13 344 (3 000)	15 568 (3 500)	1 695 (1 250)	3 851 (2 840)	3 851 (2 840)
3K 10x8-16 and 16H	15 568 (3 500)	14 145 (3 180)	8 896 (2 000)	2 034 (1 500)	1 532 (1 130)	1 532 (1 130)	6 672 (1 500)	13 344 (3 000)	15 568 (3 500)	1 695 (1 250)	3 851 (2 840)	3 851 (2 840)
3K 10x8-17	15 568 (3 500)	14 145 (3 180)	8 896 (2 000)	2 034 (1 500)	1 532 (1 130)	1 532 (1 130)	6 672 (1 500)	13 344 (3 000)	15 568 (3 500)	1 695 (1 250)	3 851 (2 840)	3 851 (2 840)
3K 12x10-18HD	8000 (1800)	5340 (1200)	6670 (1500)	6100 (4500)	4610 (3400)	2980 (2200)	5340 (1200)	6670 (1500)	4450 (1000)	5020 (3700)	3800 (2800)	2440 (1800)

Figure 4-19: Maximum combined loading

Pump size	Suction Flange						Discharge Flange					
	Forces N (lbf)			Moments Nm (lbf-ft)			Forces N (lbf)			Moments Nm (lbf-ft)		
	Fxs	Fys	Fzs	Mxs	Mys	Mzs	Fxd	Fyd	Fzd	Mxd	Myd	Mzd
1K 1.5x1-LF4	8 985 (2 020)	3 336 (750)	3 336 (750)	2 481 (1 830)	231 (170)	231 (170)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	556 (410)	556 (410)	556 (410)
1K 1.5x1-6	8 985 (2 020)	3 336 (750)	3 336 (750)	2 481 (1 830)	231 (170)	231 (170)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	556 (410)	556 (410)	556 (410)
1K 3x1.5-6	8 985 (2 020)	5 516 (1 240)	9 385 (2 110)	3 105 (2 290)	664 (490)	664 (490)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	746 (550)	746 (550)	692 (510)
1K 3x2-6 and US-6	8 985 (2 020)	4 670 (1 050)	4 670 (1 050)	3 105 (2 290)	298 (220)	298 (220)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	1 397 (1 030)	1 397 (1 030)	692 (510)
1K 1.5x1-8 and LF8	8 985 (2 020)	5 382 (1 210)	5 382 (1 210)	2 481 (1 830)	258 (190)	258 (190)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	488 (360)	488 (360)	488 (360)
1K 1.5x1.5US-8	8 985 (2 020)	5 382 (1 210)	5 382 (1 210)	2 481 (1 830)	258 (190)	258 (190)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	488 (360)	488 (360)	488 (360)
1K 3x1.5-8	8 985 (2 020)	5 516 (1 240)	7 295 (1 640)	3 105 (2 290)	664 (490)	664 (490)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	597 (440)	597 (440)	597 (440)
2K 3x2-8 and US-8	12 010 (2 700)	6 005 (1 350)	11 076 (2 490)	5 058 (3 730)	814 (600)	814 (600)	8 763 (1 970)	6 005 (1 350)	27 756 (6 240)	895 (660)	895 (660)	895 (660)
2K 4x3-8 and US-8	12 010 (2 700)	6 005 (1 350)	8 184 (1 840)	5 058 (3 730)	475 (350)	475 (350)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	1 980 (1 460)	1 980 (1 460)	936 (690)
2K 2x1-10A and LF10	10 408 (2 340)	4 270 (960)	4 270 (960)	4 936 (3 640)	298 (220)	298 (220)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	895 (660)	895 (660)	895 (660)
2K 2x1.5US-10A	10 408 (2 340)	4 270 (960)	4 270 (960)	4 936 (3 640)	298 (220)	298 (220)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	895 (660)	895 (660)	895 (660)
2K 2x2R-10	10 408 (2 340)	4 270 (960)	4 270 (960)	4 936 (3 640)	298 (220)	298 (220)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	895 (660)	895 (660)	895 (660)
2K 3x1.5-10A	12 010 (2 700)	6 005 (1 350)	8 496 (1 910)	5 058 (3 730)	570 (420)	570 (420)	8 629 (1 940)	6 005 (1 350)	27 756 (6 240)	502 (370)	502 (370)	502 (370)
2K 3x2-10A	12 010 (2 700)	6 005 (1 350)	6 583 (1 480)	5 058 (3 730)	420 (310)	420 (310)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	759 (560)	759 (560)	759 (560)
2K 3x2US-10	12 010 (2 700)	6 005 (1 350)	6 583 (1 480)	5 058 (3 730)	420 (310)	420 (310)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	759 (560)	759 (560)	759 (560)
2K 3x3R-10	12 010 (2 700)	6 005 (1 350)	6 583 (1 480)	5 058 (3 730)	420 (310)	420 (310)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	759 (560)	759 (560)	759 (560)
2K 4x3-10 and 10H	10 230 (2 300)	6 005 (1 350)	7 295 (1 640)	5 058 (3 730)	420 (310)	420 (310)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	1 980 (1 460)	1 980 (1 460)	936 (690)
2K 4x3US-10H	10 230 (2 300)	6 005 (1 350)	7 295 (1 640)	5 058 (3 730)	420 (310)	420 (310)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	1 980 (1 460)	1 980 (1 460)	936 (690)
2K 6x4-10 and 10H	12 010 (2 700)	6 005 (1 350)	27 756 (6 240)	5 058 (3 730)	1 492 (1 100)	1 492 (1 100)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	4 204 (3 100)	4 204 (3 100)	936 (690)
2K 3x1.5-13 and LF13	12 010 (2 700)	6 005 (1 350)	13 611 (3 060)	5 058 (3 730)	909 (670)	909 (670)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	719 (530)	719 (530)	719 (530)
2K 3x2-13	8 540 (1 920)	5 471 (1 230)	5 471 (1 230)	5 058 (3 730)	475 (350)	475 (350)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	1 980 (1 460)	1 980 (1 460)	936 (690)
2K 3x2US-13	8 540 (1 920)	5 471 (1 230)	5 471 (1 230)	5 058 (3 730)	475 (350)	475 (350)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	1 980 (1 460)	1 980 (1 460)	936 (690)
2K 4x3-13 and 13HH	12 010 (2 700)	6 005 (1 350)	10 631 (2 390)	5 058 (3 730)	542 (400)	542 (400)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	2 346 (1 730)	2 346 (1 730)	936 (690)
2K 4x3US-13	12 010 (2 700)	6 005 (1 350)	10 631 (2 390)	5 058 (3 730)	542 (400)	542 (400)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	2 346 (1 730)	2 346 (1 730)	936 (690)
2K 4x3R-13	12 010 (2 700)	6 005 (1 350)	10 631 (2 390)	5 058 (3 730)	542 (400)	542 (400)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	2 346 (1 730)	2 346 (1 730)	936 (690)
2K 6x4-13A	12 010 (2 700)	6 005 (1 350)	27 756 (6 240)	5 058 (3 730)	6 753 (4 980)	1 492 (1 100)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	2 915 (2 150)	2 915 (2 150)	936 (690)
2K 6x4US-13A	12 010 (2 700)	6 005 (1 350)	27 756 (6 240)	5 058 (3 730)	6 753 (4 980)	1 492 (1 100)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	2 915 (2 150)	2 915 (2 150)	936 (690)
2K 6x4R-13	12 010 (2 700)	6 005 (1 350)	27 756 (6 240)	5 058 (3 730)	6 753 (4 980)	1 492 (1 100)	8 985 (2 020)	6 005 (1 350)	27 756 (6 240)	2 915 (2 150)	2 915 (2 150)	936 (690)
3K 8x6-14A	28 289 (6 360)	14 145 (3 180)	22 596 (5 080)	12 163 (8 970)	1 587 (1 170)	1 587 (1 170)	28 289 (6 360)	14 145 (3 180)	59 870 (13 460)	9 194 (6 780)	5 221 (3 850)	3 851 (2 840)
3K 10x8-14	28 289 (6 360)	14 145 (3 180)	59 870 (13 460)	12 163 (8 970)	3 322 (2 450)	2 915 (2 150)	28 289 (6 360)	14 145 (3 180)	59 870 (13 460)	12 163 (8 970)	9 790 (7 220)	3 851 (2 840)
3K 6x4-16	28 289 (6 360)	14 145 (3 180)	20 327 (4 570)	12 163 (8 970)	1 431 (1 055)	1 431 (1 055)	25 465 (5 725)	12 720 (2 860)	53 888 (12 115)	8 272 (6 100)	4 699 (3 465)	3 465 (2 555)
3K 8x6-16A	28 289 (6 360)	14 145 (3 180)	29 713 (6 680)	12 163 (8 970)	2 007 (1 480)	2 007 (1 480)	28 289 (6 360)	14 145 (3 180)	59 870 (13 460)	8 895 (6 560)	5 044 (3 720)	3 851 (2 840)
3K 10x8-16 & 16HH	28 289 (6 360)	14 145 (3 180)	22 818 (5 130)	12 163 (8 970)	1 532 (1 130)	1 532 (1 130)	28 289 (6 360)	14 145 (3 180)	59 870 (13 460)	12 163 (8 970)	12 285 (9 060)	3 851 (2 840)
3K 10x8-17	28 289 (6 360)	14 145 (3 180)	22 818 (5 130)	12 163 (8 970)	1 532 (1 130)	1 532 (1 130)	28 289 (6 360)	14 145 (3 180)	59 870 (13 460)	12 163 (8 970)	12 285 (9 060)	3 851 (2 840)
3K 12x10-18HD	8000 (1800)	5340 (1200)	6670 (1500)	6100 (4500)	4610 (3400)	2980 (2200)	5340 (1200)	6670 (1500)	4450 (1000)	5020 (3700)	3800 (2800)	2440 (1800)

Figure 4-20: Maximum Y-axis loading for shaft deflection

Pump size	Suction Flange						Discharge Flange					
	Forces N (lbf)			Moments Nm (lbf·ft)			Forces N (lbf)			Moments Nm (lbf·ft)		
	Fxs	Fys	Fzs	Mxs	Mys	Mzs	Fxd	Fyd	Fzd	Mxd	Myd	Mzd
Group 1		-8 896 (-2 000)		1 220.4 (900)	1 627.2 (1 200)	1 695 (1 250)		6 672 (1 500)		-678 (-500)	2 034 (1 500)	1 695 (1 250)
→ Group 2		-15 568 (-3 500)		1 762.8 (1 300)	1 762.8 (1 300)	4 068 (3 000)		11 120 (2 500)		-1 627 (-1 200)	2 034 (1 500)	4 068 (3 000)
Group 3		-22 240 (-5 000)		2 034 (1 500)	2 712 (2 000)	5 424 (4 000)		13 344 (3 000)		-1 695 (-1 250)	6 780 (5 000)	5 424 (4 000)

Figure 4-21: Maximum Z-axis loading for shaft deflection

Pump size	Suction Flange						Discharge Flange					
	Forces N (lbf)			Moments Nm (lbf·ft)			Forces N (lbf·ft)			Moments Nm (lbf·ft)		
	Fxs	Fys	Fzs	Mxs	Mys	Mzs	Fxd	Fyd	Fzd	Mxd	Myd	Mzd
Group 1	4 670 (1 050)		-5 560 (-1 250)	2 034 (1 500)	1 627 (1 200)	-3 390 (-2 500)	3 558 (800)	8 896 (2 000)	-13 344 (-3 000)	-2 034 (-1 500)	1 356 (1 000)	-3 390 (-2 500)
→ Group 2	15 568 (3 500)		-6 672 (-1 500)	2 034 (1 500)	1 763 (1 300)	-4 746 (-3 500)	6 227 (1 400)	11 120 (2 500)	-14 456 (-3 250)	-2 034 (-1 500)	2 915 (2 150)	-4 746 (-3 500)
Group 3	15 568 (3 500)		-8 896 (-2 000)	2 034 (1 500)	5 560 (4 100)	-5 424 (-4 000)	6 672 (1 500)	17 792 (4 000)	-15 568 (-3 500)	-2 034 (-1 500)	6 780 (5 000)	-5 424 (-4 000)



Customer Document title:

Standard Performance Curve

Flowserve Document title: **Standard Performance Curve**
Flowserve Document No.: **1408912-003-1060-01**
Document Revision No.: **A**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC****Please complete and return:**

Document Reviewed by:		Document Reviewed date:	
<input type="checkbox"/> APPROVED. NO ACTION REQUIRED <input type="checkbox"/> APPROVED. RE-SUBMIT AS FINAL. <input type="checkbox"/> APPROVED WITH COMMENTS. DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL. <input type="checkbox"/> REJECTED. CORRECT AND RE-SUBMIT FOR APPROVAL. <input type="checkbox"/> FOR INFORMATION. REVIEW NOT REQUIRED <input type="checkbox"/> AS-BUILT			

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.


Rev	Revision Description	Released	Release Date
A	For Review	Shaw, Amie	22-May-23

Customer : AIR PRODUCTS & CHEMICALS INC
 Item number : 18-P-1879A/B
 Service : Storm Water Tank Pump
 Flowserve reference : 3425718151
 Pump size & type / Stages : 2K3x2-13RV M3 ST / 1
 Based on curve no. : MIII7400DV
 Impeller diameter : 11.00 in



Capacity : 250.0 USgpm
 Head : 109.30 ft
 Density / Specific gravity : - / 1.000
 Pump speed : 1,750 rpm
 Ns / Nss : 707 / 7,890 (US units)
 Test tolerance : ANSI/HI 14.6 Grade 2B
 Date : December 3, 2021

CURVES ARE APPROXIMATE. PUMP IS GUARANTEED FOR ONE SET OF CONDITIONS; CAPACITY, HEAD, AND EFFICIENCY.
 MCSF PROVIDES MECHANICAL PROTECTION ONLY. MINIMUM THERMAL FLOW MUST BE CALCULATED FOR THE SPECIFIC FLUID AND OPERATING CONDITIONS.





Customer Document title:

Flowserve Hydraulic Data Sheet

Flowserve Document title: **Flowserve Hydraulic Data Sheet**
Flowserve Document No.: **1408912-003-5008-01**
Document Revision No.: **A**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:

Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
☐ **APPROVED. RE-SUBMIT AS FINAL.**
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.


Rev	Revision Description	Released	Release Date
A	For Review		23-Jan-23

Customer	: AIR PRODUCTS & CHEMICALS INC	Pump / Stages	: 2K3x2-13RV M3 ST / 1
Customer reference	: WEP RFQ A8KM-4-602A-RQ	Based on curve no.	: MIII7400DV
Item number	: 18-P-1879A/B	Flowserve reference	: 3425718151
Service	: Storm Water Tank Pump	Date	: December 3, 2021

Operating Conditions	Materials / Specification
Capacity (rated/normal)	: 250.0 USgpm / -
Water capacity (CQ=1.00)	: -
Total developed head	: 109.30 ft
Water head (CH=1.00)	: -
NPSHa/NPSHa less margin	: 32.2 ft / -
Maximum suction pressure	: 15.0 psig
Liquid	Other Requirements
Liquid type	: Other
Liquid description	: Storm Water
Temperature	: 80 °F
Density / Specific gravity	: - / 1.000
Solid Size - Actual / Limit	: - / 0.4060 in
Viscosity / Vapor pressure	: 1.00 cP / 0.40 psia
	Hydraulic selection : No specification
	Construction : No specification
	Test tolerance : ANSI/HI 14.6 Grade 2B
	Driver Sizing : Max Power(MCSF to EOC) not using SF
	Seal configuration : Single Seal

Performance	
Hydraulic power	: 6.90 hp
Pump speed	: 1,750 rpm
Pump overall efficiency (CE=1.00)	: 64.1 %
NPSH required (NPSH3)	: 4.7 ft
Rated brake power	: 10.8 hp
Maximum brake power	: 13.6 hp
Driver power rating	: 15.0 hp / 11.2 kW
Casing working pressure	: 71.0 psig
(based on shut off @ cut dia/rated SG)	
Maximum allowable	: 250.0 psig
Hydrostatic test pressure	: 375.0 psig
Estimated rated seal chamber pressure	: 4.0 psig
Impeller diameter	
Rated	: 11.00 in
Maximum	: 13.00 in
Minimum	: 9.00 in
Ns / Nss	: 707 / 7,890 (US units)
Minimum continuous flow	: 27.2 USgpm
Maximum head at rated diameter	: 129.47 ft
Flow at BEP	: 247.7 USgpm
Flow as % of BEP	: 100.9 %
Efficiency at normal flow	: -
Impeller diameter ratio (rated/max)	: 84.6 %
Head rise to shut off	: 18.4 %
Total head ratio (rated / max) / (max / rated)	: 62.7 % / 159.4 %

CURVES ARE APPROXIMATE. PUMP IS GUARANTEED FOR ONE SET OF CONDITIONS: CAPACITY, HEAD, AND EFFICIENCY.
MCSF PROVIDES MECHANICAL PROTECTION ONLY. MINIMUM THERMAL FLOW MUST BE CALCULATED FOR THE SPECIFIC FLUID AND OPERATING CONDITIONS.





Customer Document title:

PMI Test Report

Flowserve Document title: **PMI Test Report**
Flowserve Document No.: **1408912-003-3020-01**
Document Revision No.: **0**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:

Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
☐ **APPROVED. RE-SUBMIT AS FINAL.**
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final	Shaw, Amie	28-Feb-23

POSITIVE MATERIAL IDENTIFICATION (PMI) REPORT



Project No./Order : 3206805
Customer : AIR PRODUCTS LLC
Customer PO/Order No. : 4505555756
Job No. :
Customer Tag No. : 18-P-1879A/B
Source : Olympus XRF S/N 501048

Part No.			Part Name		Material	Heat No.		Qty.	ID
SM-MY49112A130-D4-XXGXX			IMPELLER		D4	N/A		1	B
Cr	Ni	Mo	Cu	W	Fe	Mn	Al	Ti	
19.04	9.83	2.27							

Result	Inspector	TestDate
PASS	LM	7/11/2022

Part No.			Part Name		Material	Heat No.		Qty.	ID
SM-MY49112A130-D4-XXGXX			IMPELLER		D4	N/A		1	A
Cr	Ni	Mo	Cu	W	Fe	Mn	Al	Ti	
18.85	9.58	2.17							

Result	Inspector	TestDate
PASS	LM	7/11/2022

Comments:

Signature:

Date: 2/24/2023

POSITIVE MATERIAL IDENTIFICATION (PMI) REPORT



Project No./Order : 3203260
Customer : AIR PRODUCTS LLC
Customer PO/Order No. : 4505555756
Job No. :
Customer Tag No. : 18-P-1879A/B
Source : Olympus XRF S/N 501048

Part No.			Part Name		Material	Heat No.		Qty.	ID
SM-CY21361AB-316-XXGXX			SHAFT		316SS	N/A		1	A
Cr	Ni	Mo	Cu	W	Fe	Mn	Al	Ti	
16.16	9.94	2.1							

Result	Inspector	TestDate
PASS	LM	8/29/2022

Comments:

Signature: 

Date: 2/24/2023

POSITIVE MATERIAL IDENTIFICATION (PMI) REPORT



Project No./Order : 3203259
Customer : AIR PRODUCTS LLC
Customer PO/Order No. : 4505555756
Job No. :
Customer Tag No. : 18-P-1879A/B
Source : Olympus XRF S/N 501048

Part No.			Part Name		Material	Heat No.		Qty.	ID
SM-CY21361AB-316-XXGXX			SHAFT		316SS	N/A		1	A
Cr	Ni	Mo	Cu	W	Fe	Mn	Al	Ti	
16.05	10.35	2.08							

Result	Inspector	TestDate
PASS	LM	8/29/2022

Comments:

Signature: _

A handwritten signature in blue ink, appearing to read "Scott Hefner", written over a horizontal line.

Date: 2/24/2023

POSITIVE MATERIAL IDENTIFICATION (PMI) REPORT



Project No./Order : 3206804
Customer : AIR PRODUCTS LLC
Customer PO/Order No. : 4505555756
Job No. :
Customer Tag No. : 18-P-1879A/B
Source : Olympus XRF S/N 501048

Part No.			Part Name		Material	Heat No.		Qty.	ID
SM-DY52028A-D4-XXGXX			COVER		D4	N/A		1	B
Cr	Ni	Mo	Cu	W	Fe	Mn	Al	Ti	
18.77	9.63	2.07							

Result	Inspector	TestDate
PASS	LM	7/11/2022

Part No.			Part Name		Material	Heat No.		Qty.	ID
SM-DY52028A-D4-XXGXX			COVER		D4	N/A		1	A
Cr	Ni	Mo	Cu	W	Fe	Mn	Al	Ti	
18.69	9.79	2.26							

Result	Inspector	TestDate
PASS	LM	7/11/2022

Comments:

Signature:

Date: 2/24/2023



Customer Document title:

Performance Test Report

Flowserve Document title: **Performance Test Report**
Flowserve Document No.: **1408912-003-4006-01**
Document Revision No.: **0**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC**

Please complete and return:

Document Reviewed by:		Document Reviewed date:	
<input type="checkbox"/> APPROVED. NO ACTION REQUIRED <input type="checkbox"/> APPROVED. RE-SUBMIT AS FINAL. <input type="checkbox"/> APPROVED WITH COMMENTS. DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL. <input type="checkbox"/> REJECTED. CORRECT AND RE-SUBMIT FOR APPROVAL. <input type="checkbox"/> FOR INFORMATION. REVIEW NOT REQUIRED <input type="checkbox"/> AS-BUILT			

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final	Shaw, Amie	28-Feb-23



3900 Cook Boulevard, Chesapeake, VA 23323

Performance Report

Curve No.

00037114

Test Date	Tested By	Certified
11/16/2022	SWEBSTER	10157338

Digitally signed by 10157338
DN: cn=10157338, ou=CHP
Date: 2022.11.21 08:15:29 -0500



Customer: AIR PRODUCTS LLC
PO #: 4505555756
Customer Tag: 18-P-1879 A
Order #: 1408912
Line Item #: 3
Job #: 3206764
Serial #: 1408912CHP003A
Pump Line: MK3
Pump Size: 2K3X2-13RV

Speed Ratio:
Impeller Type: RV
Imp. Dia. (in): 11
Impeller Mat.: D4
Casing Mat.: DCI
Test Media: Water
Test Driver #: M140
Test Driver (hp): 20
Test Driver Speed (RPM): 1765
Vibration: Unfiltered RMS

Flow (gpm): 250
Head (ft): 109.3
Eff. (%): 64.1
Power (hp): 10.78
RPM: 1750
NPSHR (ft): 4.7
Specific Gravity: 1.000
Viscosity: 1.000
Customer Driver: 15 HP
Criteria: 2B

Rated Values

	Flow (gpm)	Head (ft)	Power (hp)	Eff. (%)	IN Horiz.	IN Vert.	IN Axial	OUT Horiz.	OUT Vert.	OUT Axial
Point 1	0.0	120.7	5.6	0.0						
Point 2	27.2	121.8	6.1	13.6	0.02	0.03	0.02	0.02	0.03	
Point 3	83.6	123.2	7.4	35.0	0.03	0.02	0.02	0.03	0.02	
Point 4	139.9	121.1	8.7	49.1	0.02	0.03	0.03	0.04	0.03	
Point 5	195.4	114.7	10.1	56.0	0.03	0.03	0.02	0.03	0.02	
Point 6	250.5	108.1	11.3	60.6	0.03	0.02	0.02	0.04	0.02	
Point 7	308.4	100.3	12.6	61.8	0.03	0.03	0.02	0.04	0.03	
Point 8	365.1	90.8	13.8	60.5	0.04	0.03	0.03	0.04	0.04	



Notes:	Noise: 79dB 6'; 80dB 3' from pump
--------	-----------------------------------



3900 Cook Boulevard, Chesapeake, VA 23323

Performance Report

Curve No.

00037116

Test Date	Tested By	Certified
11/16/2022	SWEBSTER 10157338	11/16/2022

Digitally signed by 10157338
DN: cn=10157338, ou=CHP
Date: 2022.11.21 08:16:20 -05'00'



Customer: AIR PRODUCTS LLC
PO #: 4505555756
Customer Tag: 18-P-1879 B
Order #: 1408912
Line Item #: 3
Job #: 3206764
Serial #: 1408912CHP003B
Pump Line: MK3
Pump Size: 2K3X2-13RV

Speed Ratio:
Impeller Type: RV
Imp. Dia. (in): 11
Impeller Mat.: D4
Casing Mat.: DCI
Test Media: Water
Test Driver #: M140
Test Driver (hp): 20
Test Driver Speed (RPM): 1765
Vibration: Unfiltered RMS

Flow (gpm): 250
Head (ft): 109.3
Eff. (%): 64.1
Power (hp): 10.78
RPM: 1750
NPSHR (ft): 4.7
Specific Gravity: 1.000
Viscosity: 1.000
Customer Driver: 15 HP
Criteria: 2B

Rated Values

	Flow (gpm)	Head (ft)	Power (hp)	Eff. (%)	IN Horiz.	IN Vert.	IN Axial	OUT Horiz.	OUT Vert.	OUT Axial
Point 1	0.0	119.3	5.6	0.0						
Point 2	27.2	120.5	6.1	13.6	0.02	0.03	0.03	0.02	0.03	
Point 3	83.5	122.5	7.4	34.7	0.03	0.02	0.02	0.02	0.03	
Point 4	139.9	120.5	8.7	48.7	0.03	0.03	0.02	0.03	0.03	
Point 5	194.4	115.5	10.0	56.9	0.04	0.03	0.02	0.02	0.03	
Point 6	250.6	109.1	11.2	61.7	0.03	0.02	0.02	0.03	0.02	
Point 7	308.3	101.5	12.7	62.3	0.02	0.03	0.02	0.03	0.03	
Point 8	366.7	93.6	13.9	62.3	0.04	0.03	0.02	0.04	0.03	



Notes:	Noise: 79db 6'; 80db. 3' from pump
--------	------------------------------------



Customer Document title:

Coupling DrawingFlowserve Document title: **Coupling Drawing**Flowserve Document No.: **1408912-003-5700-01**Document Revision No.: **C**Flowserve Order No.: **1408912**Flowserve Serial No.: **1408912CHP003A/B**Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**Quantity: **2**Customer Name: **World Energy Paramount**Customer Tag No: **18P1879 A/B**Customer PO No.: **4505555756**End User: **AIR PRODUCTS LLC****Please complete and return:**

Document Reviewed by:


Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
- ☐ **APPROVED. RE-SUBMIT AS FINAL.**
- ☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
- ☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
- ☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
- ☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
C	For Information		23-May-23

REVISIONS	



A. TORSIONAL DATA (CALC.)

WT = 12.10 lbs [5.50 kg]
WR~2 = 28 lbs-in² [81939.2 kg-mm²]
K1 = 7.103E~5 in-lbs/rad [8.028E~4 Nm/rad]
(BASED ON 1/3 SHAFT PENETRATION
FACTOR IN BOTH HUBS)

B. CUSTOMER DATA:

P.O. NO.: 347960
LINE ITEM NO.: 4
CUSTOMER NAME: FLOWSERVE CORP. CHESAPEAKE

C. CUSTOMER NOTES

FLOWSERVE DOCUMENT TITLE: COUPLING DWG
FLOWSERVE DOCUMENT NO.: 1408912-003-5700-01
DOCUMENT REVISION NO.: 0
FLOWSERVE ORDER NO.: 1408912
FLOWSERVE SERIAL NO.: 1408912CHP002A/B
PUMP TYPE/SIZE: MARK 3 GRP 2 / 2K3X2-13RV
CUSTOMER: WORLD ENERGY PARAMOUNT
CUSTOMER TAG NO.: 18-P-1879A/B
CUSTOMER PO NO.: 4505555756
EQUIPMENT OWNER: AIR PRODUCTS LLC
CUSTOMER MATERIAL NO.: 74800236

D. N

COUPLING FURNISHED WITH TOMALOY DISCPACKS

ITEM NO. 4: LAMINATION THK.: 0.140/0.157 [3.56/3.99]

8	BUSHINGS	16	10999	POWDER METAL (F-0008-30)
7	WASHERS	16	10731	POWDER METAL (FC-0208-80 HT)
6	LOCKNUTS	16	16504	IFI GRADE C
5	BOLTS	16	10728	SAE GRADE 8
4	DISC PACKS	2	10954	TOMALOY
3	CENTER MEMBER	1	23947	CARBON STEEL
2	HUB	1	26492	CARBON STEEL
1	HUB	1	26492	CARBON STEEL

ITEM NO.	DESCRIPTION	QTY.	DWG. NO.	MATERIALS OF CONSTRUCTION
BILL OF MATERIAL				

CERTIFIED DRAWING

CUSTOMER P.O. #: 347960
REXNORD ORDER #: 2009965-50
SAP MTL.# 10110036
REV. #: -
PER: SWD DATE: JAN-30-2023

CAD GENERATED DRAWING
All drawings are the property of Rexnord Industries LLC
and may not be reproduced, utilized or disclosed for any
purpose except as authorized in writing by
Rexnord Industries LLC. These commodities, technology or
software are subject to the United States export
regulations. Diversion contrary to U.S. law and other
relevant export controls is prohibited.

Rexnord
COUPLING GROUP
WWW.REXNORD.COM
Thomas
Flexible Couplings

FLOWSERVE CORP. CHESAPEAKE

inch [mm] OR [mm]	DR. SWD 01-30-2023	SECTIONAL ASSEMBLY STANDARD 163 DBZ-C COUPLING	DRAWING NO. C007412
	DSGN.		PROPOSAL NO.
	CHK. SWD 01-30-2023		ORDER NO.
	SCALE 1.5 : 1		N/A

2009965-50



Customer Document title:

Mechanical Seal Drawing

Flowserve Document title: **Mechanical Seal Drawing**
Flowserve Document No.: **1408912-003-5800-01**
Document Revision No.: **A**
Flowserve Order No.: **1408912**
Flowserve Serial No.: **1408912CHP003A/B**
Pump Type/Size: **MARK 3 STANDARD / 2K3X2-13RV**
Quantity: **2**
Customer Name: **World Energy Paramount**

Customer Tag No: **18P1879 A/B**
Customer PO No.: **4505555756**

End User: **AIR PRODUCTS LLC****Please complete and return:**

Document Reviewed by:


Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
☐ **APPROVED. RE-SUBMIT AS FINAL.**
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered **Approved, no action.**
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.


Rev	Revision Description	Released	Release Date
A	Information Only	Shaw, Amie	23-Jan-23

NO:	D0112258	REV:	—
-----	----------	------	---



[F]	FLUSH	3/8	NPT
[Q]	QUENCH	1/4	NPT
[D]	DRAIN	1/4	NPT


NOTES:

1. FOR INSTALLATION AND OPERATING INSTRUCTIONS SEE FIS190.
2.  DISENGAGE SETTING DEVICES BEFORE START-UP.
3. END VIEW IS FOR REFERENCE ONLY. FEATURES AND FEATURE LOCATIONS MAY VARY BY METHOD OF MANUFACTURE.
4. PATENT PENDING.

REVISION: -	DATE: 21-JAN-2012	BY: MRAMASAMY	CHKD: MRAMASAMY	ECN NO:
REVISION NOTE: RELEASE TO MANUFACTURE.				

THIS DRAWING AND ANY DESIGN, DEVELOPMENT, INVENTION OR COPYRIGHT WHICH IT MAY EMBODY OR REPRESENT ARE THE PROPERTY OF FLOWSERVE CORPORATION. THIS DRAWING MAY NOT BE REPRODUCED, NOR ANY SUBJECT MATTER SHOWN HEREIN MAY BE MANUFACTURED, WITHOUT WRITTEN PERMISSION FROM AN AUTHORIZED AGENT OF FLOWSERVE CORPORATION.

DIM'S ARE REF UNLESS SPECIFIED OTHERWISE.	C/A2 JULY 2009
DIM'S IN: INCHES [MM]	



BILL OF MATERIAL NO: C2CPX1875EAXVB				1 SUGGESTED SPARE PARTS 2 CODE/BSQ [X]/OFF STD [W]	
NO	PARTCODE	QTY	DESCRIPTION	MATERIAL	1 2
1	C0011866DB	1	SLEEVE ASSEMBLY	316	X
5	C0012107NL	3	PIN SQ. HEAD	ALLOY C-276	X
11	C0011308DB	1	GLAND SINGLE-CW	316	X
13	568141GU	1	SEAT GASKET	FLUOROELASTOMER	X
13.1	568141GU	1	SEAT GASKET	FLUOROELASTOMER	X
14	C0011928YO	1	STATIONARY FACE	SILICON CARBIDE	X
15	K23C1875C33	1	ROTATING FACE	SILICON CARBIDE	X
16	MIAX88403CM	14	COIL SPRING	ALLOY C-276	X
18	MYC04110AAC	1	GLAND GASKET	PTFE, BoS04 FILLED (FDA GRADE)	X
19	568134GU	1	SLEEVE GASKET	FLUOROELASTOMER	X
24	C0010316KR3	1	GLAND BUSHING	CARBON (FDA GRADE)	X
40	C0012104CK	4	SHCS #10-24 X 3/8	18-8	X
57	4R0426X902	4	SSCP 1/4"-20 X 1/4	17-4 H900	X
57.1	MLA36788233	2	SSQDP #10-24 X 7/32	ALLOY C-276	X
58	C0010378DB	1	DRIVE COLLAR	316	X
76	568141GU	1	ROT. FACE GASKET	FLUOROELASTOMER	X
100	C0011990DB	1	STATIONARY FACE SUPPORT	316	X
103	C0012106CK	4	SETTING DEVICE	18-8	X
111	UR243CK	1	SNAP RING	18-8	X
183	C0012052OF	1	VIBRATION DAMPER	FLEXIBLE GRAPHITE	X

Pump Tag: 18-P-1879 A/B

Site Location: World Energy,
Paramount, CA USA

SEAL TYPE: ISCZ-PX		SEAL SIZE: 1.875	
SEAL CONFIG: SINGLE INSIDE-CARTRIDGE			
MATL CODE: 5Z4Z			
EQUIP MFR: FLOWSERVE		INSTR: FIS190	
EQUIP MODEL: MK III GR 1K CBL/FML			
EQUIP DWG:			
SCALE: TO SCALE		PARTS LIST NO: L0000060	
DRAWN: MRAMASAMY		REF DWG: D0106758	
DATE: 21-JAN-2012		FORM DWG: F0012781	
CHKD: MRAMASAMY		DRAWING NO: SHEET: 1 OF: 1 REV: -	
APPVD:		D0112258	
JOR NO: 12KAI 0702		Page 1 of 253	

THIS DOCUMENT AND ANY DESIGN, DEVELOPMENT, INVENTION OR COPYRIGHT WHICH IT MAY EMBODY OR REPRESENT ARE THE PROPERTY OF FLOWSERVE CORPORATION. THIS DOCUMENT MAY NOT BE REPRODUCED. NOR ANY SUBJECT MATTER SHOWN HEREIN BE MANUFACTURED, WITHOUT WRITTEN PERMISSION FROM AN AUTHORIZED AGENT OF FLOWSERVE CORPORATION.