



WORLD ENERGY PARAMOUNT
World Energy Renewables Project
Paramount, California

MECHANICAL EQUIPMENT DATASHEET
Document Number A8KM-18-096-540066-A
Revision 1, 27-Feb-2023

EN23076-FLUOR-XXX-XXXXX



WORLD ENERGY RENEWABLES PROJECT

MECHANICAL EQUIPMENT DATA SHEET FOR 18-P-354A/B

SLOP OIL PUMP

Document Number A8KM-18-096-540066-A



Fluor Project No: A8KM

1	27-Feb-2023	Issued as Built	11	GGU	EPE	
0	3-Jan-2023	Issued as Built	11	GGU	EPE	
D	14-Oct-2021	Issued for Purchase	11	CP	JF AD ME	BT
C	25-May-2021	Issued for Quotation	10	JDM	JF AD ME	BT
B	11-May-2021	Issued for Client Review	10	CP	JDM AD ME	BT
A	27-Apr-2021	Issued for Internal Review	10	CP	JDM	
REV	DATE	DESCRIPTION	PAGES	ORIG	CHK'D	APPV'D

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.



<div><div>FLUOR®</div><div>worldenergy</div></div>		API 610				Contract: A8KM			
		CENTRIFUGAL PUMP DATA SHEET				Item No: 18-P-354A/B			
		Doc. No.: A8KM-18-096-540066-A				Revision: 1		Date: 27-Feb-23	
						Unit: Renewable Jet Fuel Unit B			
Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.				P.O. No.: 4505606431		Inquiry No.: 4-601D-RQ			
				Sheet	2	of	11	REV	
1	CLIENT: World Energy Paramount				PROJECT: World Energy Renewables Project				
2	SERVICE: Slop Oil Pump		FACILITY: World Energy Paramount		SITE: Paramount, CA				
3	NO. REQ'D: 2x100% (Note 2.1)		PUMP SIZE: 1HPX11A-1-2		API TYPE: OH2		NO. STAGES: One (1)		
4	MANUFACTURER: Flowserve		MODEL: HPX		SERIAL NO.: 21HE1044-1045				0
5	APPLICABLE TO: <input type="radio"/> PROPOSALS <input type="radio"/> PURCHASE <input checked="" type="radio"/> AS-BUILT								1
7	GENERAL								
8	PUMPS OPERATE IN: N/A		NO. MOTOR DRIVEN: Two (2)		NO. TURBINE DRIVEN: N/A				
9	WITH:		PUMP ITEM NO.: 18-P-354A/B		PUMP ITEM NO.:				
10	GEAR ITEM NO.: N/A		MOTOR ITEM NO.: 18-P-354AM/BM		TURBINE ITEM NO.:				
11	GEAR PROVIDED BY:		MOTOR PROVIDED BY: Pump Supplier		TURBINE PROVIDED BY:				
12	GEAR MOUNTED BY:		MOTOR MOUNTED BY: Pump Supplier		TURBINE MOUNTED BY:				
13	GEAR DATA SHEET NO.:		MOTOR DATA SHEET NO.: Attached		TURBINE DATA SHEET NO.:				
14	LIQUID CHARACTERISTICS								
15	UNITS		MAXIMUM		RATED		MINIMUM		
16	LIQUID TYPE OR NAME:		Slop Oil (Saturated Liquid)						SERVICE: INTERMITTENT*
17	VAPOR PRESSURE: psi (a)				19.7				*IF INTERMITTENT, NO. OF STARTS / DAY: ~1 /week
18	RELATIVE DENSITY:				0.686				CORROSION DUE TO: (6.12.1.9): Note 2.8
19	SPECIFIC HEAT: BTU/lbm °F				0.538		0.467		EROSION DUE TO: (6.12.1.9):
20	VISCOSITY: cP				0.73				H ₂ S CONCENTRATION (ppmw) (6.12.1.12): Note 2.8
21	OPERATING CONDITIONS (6.1.2)								WET (YES / NO):
22	UNITS		MAXIMUM		RATED		NORMAL		MINIMUM
23	NPSH _a DATUM:		C.L. IMPELLER (Note 2.2)						CHLORIDE CONCENTRATION (ppmw):
24	PUMPING TEMP.: °F		185		136		35		PARTICULATE SIZE (DIA. IN MICRONS):
25	FLOW: gpm				20				10
26	DISCHARGE PRESS: psi(g)				20.2				PARTICULATE CONCENTRATION (ppmw):
27	SUCTION PRESSURE: psi(g)		110.0		8.1				MECHANICAL DESIGN TEMPERATURE (°F) 300
28	DIFFERENTIAL PRESS.: psi				12.2				The range of fluids in the slop oil is 0.668 to 0.758 SG and 0.49 to 3.47 cP viscosity.
29	DIFFERENTIAL HEAD: ft				41				Note 2.9 System static head is a minus 33.6 ft. (-33.6 ft.).
30	NPSH _a : ft		(Note 2.2)		10.3		Excludes Req'd 3-ft. Margin		
31	HYDRAULIC POWER: hp				0.1 (Note 2.8)				
32	SITE AND UTILITY DATA (6.1.2)								
33	LOCATION:				COOLING WATER: SOURCE: COOLING TOWER				
34	OUTDOOR		UNHEATED		SUPPLY TEMP.: 80 °F		MAX. ALLOW. RETURN TEMP.: 120 °F		
35	MOUNTED AT: GRADE		<input type="radio"/> TROPICALIZATION REQ'D		NORM. PRESS.: 45 psi(g)		DESIGN PRESS.: 120 psi(g)		
36	ELECTRICAL AREA CLASSIFICATION: <input type="radio"/> NON HAZARDOUS				MAXIMUM RETURN PRESSURE: 35 psi(g)				
37	CLASS: CL. I, B/C/D		DIVISION: 2		TEMP CODE: T3C		MAXIMUM ALLOWABLE ΔP: 10 psi		
38	SITE DATA:				CHLORIDE CONCENTRATION: < 840 ppm				DESIGN T: 150 °F
39	ELEVATION (MSL): 69 ft		BAROMETER: 14.7 psia		INSTRUMENT AIR: MAX.: N/A psi(g)				MIN.: psi(g)
40	RANGE OF AMBIENT TEMPS: MIN. / MAX.: 35 / 105 °F				MECH. DESIGN: psi(g)				°F
41	RELATIVE HUMIDITY: MIN. / MAX.: Average = / 54 %				STEAM:				
42	UNUSUAL CONDITIONS:								
43									
44	UTILITY CONDITIONS:								
45	ELECTRICITY: DRIVERS		HEATING		CONTROL		INSTRUMENTS		
46	VOLTAGE: 460		120		120		24 VDC		
47	PHASE: 3		1		1				
48	HERTZ: 60		60		60				
49									
50	NOTES								
51	2.1 2 x 100% pumps; 1 operating and 1 spare.								
52	2.2 Pump centerline is 1.7' above top of foundation.								
53	Deleted.								
54	2.3 Pump Control Method: On/Off (HLL/LLL) on Gap Level Control with manual throttle valve. Pump also has an interlock which prevents it from								
55	starting on HIL, which is below LLL, to prevent potentially pumping amine to the API separator.								
56	2.4 Governing Project Specification: A8KM-PP-000-50626-A, Centrifugal Pumps for Petroleum and Natural Gas Industries - API 610.								
57	2.5 Performance Curve for Rich Amine Upset Case @ 3.3cP on Sheet 11.								
58	2.6 Deleted.								
59	2.7 The pump destination is the new API Separator by WEP. A pressure drop allowance is included for the destination as no details known for the API configuration at this stage of the project.								
60	2.8 Motor Sizing Basis is for a Rich Amine upset at 159°F, 1.048 SG, 3.3 cP to the destination. The maximum rich amine CO2 and H2S loadings are 0.1571								
61	lbmol/lbmol and 0.0063 lbmol/lbmol, respectively. Rich amine properties shall be confirmed per the Dow final design.								

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

 		API 610 CENTRIFUGAL PUMP DATA SHEET				Contract:		A8KM		REV
						Item No:		18-P-354A/B		
		Revision:		1	Date:	27-Feb-23				
		Unit:		Renewable Jet Fuel Unit B						
		P.O. No.:		4505606431						
		Doc. No.: A8KM-18-096-540066-A				Inquiry No.:		4-601D-RQ		
		Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.				Sheet		3	of	11

PERFORMANCE										DRIVER (7.1.5)																																																																									
PROPOSAL CURVE NO.: 1HPX11A-1-2 RPM 1740 TEST CURVE NO.: IMPELLER DIA.: RATED: 8.03 MAX: 10.63 MIN: 7.48 in RATED POWER: 2.64 hp EFFICIENCY: 5.9 % RATED CURVE BEP FLOW: (at rated impeller dia.) 19.7 gpm MIN. FLOW: THERMAL : 7.8 gpm STABLE : 7.9 gpm PREFERRED OPERATING REGION: (6.1.12) 13.8 to 23.7 gpm ALLOWABLE OPERATING REGION: 7.9 to 28 gpm MAX. HEAD @ RATED IMPELLER: 64.62 ft MAX. POWER @ RATED IMPELLER: (6.8.9) 2.67 hp NPSHR at CL IMPELLER for RATED FLOW : 3.1 ft CL PUMP TO LOWER SIDE OF BASEPLATE: 1.7 ft NPSH MARGIN at RATED FLOW : 7.2 ft SPECIFIC SPEED: gpm,rpm,ft 315 SUCTION SPECIFIC SPEED LIMITATION: gpm,rpm,ft (Note 3.1) SUCTION SPECIFIC SPEED: (6.1.9): gpm,rpm,ft 4050 MAX. ALLOW. SOUND PRESS. LEVEL / EST.: (6.1.14) @ 3 ft 85 / <85 dBA MAX. ALLOW. SOUND POWER LEVEL / EST.: (6.1.14) @ 3 ft / dBA MAX. DISCHARGE PRESSURE: (6.3.2) 139.36 psig BASIS: (6.3.2.a, b or c)										DRIVER TYPE: INDUCTION MOTOR GEAR: NO VARIABLE SPEED REQUIRED: NO SOURCE OF VARIABLE SPEED: N/A OTHER: TEFC / IP55 MANUFACTURER: TECO NAMEPLATE POWER: 5 hp NOMINAL RPM: 1800 RATED LOAD RPM: 1745 FRAME OR MODEL: 184T ORIENTATION: HORIZONTAL LUBE: GREASE BEARING TYPE: ANTI-FRICTION RADIAL: (Qty / Brg. Number) 1 / 6306ZC35C THRUST: (Qty / Brg. Number) 1 / 6306ZC35C STARTING METHOD: CLOSED VALVE (UNLOADED) START DRIVER DATA SHEET: ATTACHED ACCESSORIES:																																																																									
CONSTRUCTION																																																																																			
API PUMP TYPE: OH2 [Based on API 610 Definitions] NOZZLE CONNECTIONS: (6.4.2) <table border="1"> <thead> <tr> <th></th> <th>SIZE</th> <th>FACING</th> <th>RATING</th> <th>POSITION</th> </tr> </thead> <tbody> <tr> <td>SUCTION</td> <td>2"</td> <td>RF</td> <td>300</td> <td>END</td> </tr> <tr> <td>DISCHARGE</td> <td>1"</td> <td>RF</td> <td>300</td> <td>TOP</td> </tr> </tbody> </table> PRESSURE CASING AUX. CONNECTIONS: (6.4.1.2)(6.4.3.1)(6.4.3.2)(6.4.3.12) <table border="1"> <thead> <tr> <th></th> <th>NO.</th> <th>SIZE</th> <th>TYPE</th> <th>FACING</th> <th>RATING</th> <th>POSITION</th> </tr> </thead> <tbody> <tr> <td>BALANCE/LEAK OFF</td> <td>--</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>DRAIN (Note 3.2)</td> <td>1</td> <td>0.75"</td> <td>BW</td> <td>RF</td> <td>300</td> <td>BOTTOM</td> </tr> <tr> <td>VENT (IF NOT SELF VENT)</td> <td>SELF</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>PRESSURE GAUGE</td> <td>--</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>TEMP GAUGE</td> <td>--</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>WARM-UP LINE*</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> *VENDOR TO ADVISE WARM-UP FLOW IF REQUIRED: gpm DRAIN VALVE SUPPLIED BY: SUPPLIER DRAINS MANIFOLDED: N/A VENT VALVE SUPPLIED BY: VENTS MANIFOLDED: N/A THREADED CONNS FOR PIPELINE SERVICE & < 50°C:(6.4.3.2) N/A SPECIAL FITTINGS FOR TRANSITIONING: (6.4.3.3) NO CYLINDRICAL THREADS REQUIRED: (6.4.3.8) NO GUSSET SUPPORT REQUIRED: (6.4.3.10) YES MACHINED AND STUDDED CONNECTIONS: (6.4.3.12) NO TYPE VS6 DRAIN CONN.: (9.3.13.5) N/A DRAIN TO SKID EDGE: YES BOLTING CONFORMANCE:: (6.1.29.1) YES (ISO 261, ISO 262, ISO 724, ISO 965 OR ANSI/ASME B1.1) ASME B1.1 SEAL FLUSH CASING CONNS. w/ SECONDARY SEALING REQD: (6.4.3.3) NO AUX. PIPING TERMINATIONS: RFWN											SIZE	FACING	RATING	POSITION	SUCTION	2"	RF	300	END	DISCHARGE	1"	RF	300	TOP		NO.	SIZE	TYPE	FACING	RATING	POSITION	BALANCE/LEAK OFF	--						DRAIN (Note 3.2)	1	0.75"	BW	RF	300	BOTTOM	VENT (IF NOT SELF VENT)	SELF						PRESSURE GAUGE	--						TEMP GAUGE	--						WARM-UP LINE*							CASING MOUNTING: CENTERLINE CASING TYPE: Volute OH3 BACKPULLOUT LIFING DEVICE REQ'D: (9.1.2.6) NO CASE PRESSURE RATING: (Note 3.3) MAWP: (6.3.5) 535 psig @ 300 °F HYDROTEST: (8.3.2.6) 900 psig @ AMB °F Hydrotest at 1.5 x MAWP of the Pump Assembly. HYDROTEST OH PUMP AS ASSEMBLY: YES SUCTION PRESS. REGIONS DESIGNED FOR MAWP: YES ROTATION: (VIEWED FROM COUPLING END) CCW - IMPELLERS INDIVIDUALLY SECURED: N/A - BOLT OH 3/4/5 PUMP TO PAD / FOUNDATION: N/A - PROVIDE SOLEPLATE FOR OH 3/4/5 PUMPS: N/A ROTOR: SHAFT FLEXIBILITY INDEX (SFI): (9.1.1.3) 82.35 FIRST CRITICAL SPEED, WET: (MULTI-STAGE) N/A RPM COMPONENT BALANCE TO ISO 1940 G1.0: (6.9.4.4) YES SHRINK FIT LIMITED MOVEMENT IMPELLERS: (9.2.2.3) N/A COUPLING & GUARD: (7.2.2) (Note 3.4) MANUFACTURER: Thomas MODEL: Series 71 RATING: (POWER/100 RPM) 1.47 SPACER LENGTH: 5.5 in ACTUAL SF AT MOTOR NAMEPLATE: 5.31 RIGID: N/A COUPLING WITH HYDRAULIC FIT: (7.2.10) NO COUPLING BALANCED TO ISO 1940-1 G6.3: (7.2.3) G2.5 COUPLING WITH PROPRIETARY CLAMPING DEVICE: (7.2.11) N/A COUPLING IN COMPLIANCE WITH: (7.2.4) API 610 COMPLIANT COUPLING GUARD STANDARD PER: (7.2.13.a) ANSI B15.1 WINDOW ON COUPLING GUARD: YES									
	SIZE	FACING	RATING	POSITION																																																																															
SUCTION	2"	RF	300	END																																																																															
DISCHARGE	1"	RF	300	TOP																																																																															
	NO.	SIZE	TYPE	FACING	RATING	POSITION																																																																													
BALANCE/LEAK OFF	--																																																																																		
DRAIN (Note 3.2)	1	0.75"	BW	RF	300	BOTTOM																																																																													
VENT (IF NOT SELF VENT)	SELF																																																																																		
PRESSURE GAUGE	--																																																																																		
TEMP GAUGE	--																																																																																		
WARM-UP LINE*																																																																																			
NOTES																																																																																			
3.1	Suction specific speeds greater than 11,000 for hydrocarbons and 9,000 for water (USC units) require specific approval by the Buyer.																																																																																		
3.2	Terminate drain piping with bellow seal gate valve at edge-of-skid. Bellow seal gate valves shall be per Project specification, A8KM-PP-000-60027-A, Bellow Seal Valve Criteria. Customer connections shall be flanged.																																																																																		
3.3	Nameplate for MAWP at mechanical design temperature.																																																																																		
3.4	Coupling guards shall be non-sparking.																																																																																		
3.5	Deleted.																																																																																		
	Deleted.																																																																																		

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

 		API 610 CENTRIFUGAL PUMP DATA SHEET		Contract:		A8KM		
				Item No:		18-P-354A/B		
		Doc. No.: A8KM-18-096-540066-A		Revision:		1	Date:	27-Feb-23
		Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.		Unit:		Renewable Jet Fuel Unit B		
				P.O. No.:		4505606431		
		Inquiry No.:		4-601D-RQ				
		Sheet	4	of	11		REV	



1	CONSTRUCTION (CONT'D)							
2	MATERIAL (6.12.1.1)				BASEPLATE OR SOLE PLATE			
3	APPENDIX H CLASS:	A-8: 316L SS / 316L SS		API BASEPLATE NUMBER:				
4	MINIMUM DESIGN METAL TEMP: (6.12.4.1)	32	°F	BASEPLATE CONSTRUCTION: (7.3.14)				FULL TOP DECKING
5	REDUCED HARDNESS MATERIALS REQ'D: (6.12.1.12.1)	NO		BASEPLATE DRAINAGE: (7.3.1)				ENTIRE BASEPLATE DRAIN RIM
6	APPLICABLE HARDNESS STANDARD: (6.12.1.12.3)	N/A		MOUNTING:				GROUTED
7	BARREL:	--		NON-GROUT CONSTRUCTION: (7.3.13)				NOT REQUIRED
8	CASE:	A351 Gr. CF3M		VERTICAL LEVELING SCREWS:				REQUIRED
9	DIFFUSERS:	N/A		HORIZONTAL DRIVER POSITIONING SCREWS:				REQUIRED
10	IMPELLER:	A351 Gr. CF3M		SUPPLIED WITH: - GROUT VENT HOLES				YES
11	IMPELLER / CASE WEAR RING:	A743 Gr. CF3M or A276 Type 316L		- DRAIN CONNECTION				YES
12	SHAFT:	A276 Type 316L		MOUNTING PADS SIZED FOR BASEPLATES LEVELING: (7.3.5)				YES
13	BOWL (IF VS TYPE):	--		MOUNTING PADS OR SOLE PLATE TO BE MACHINED: (7.3.6)				YES
14	INSPECTION CLASS: (API/ISO TABLE 14)	LEVEL 2		PROVIDE SPACER PLATE UNDER ALL EQUIP. FEET: (7.3.6)				
15	BEARINGS AND LUBRICATION (6.10.1)				OTHER: Furnish two (2) diagonally opposed grounding provisions per Note 6.9			
16	BEARING (TYPE / NUMBER):							
17	RADIAL:	BALL	/	6212-C3				
18	THRUST:	BALL	/	7311 BECBM				
19	REVIEW AND APPROVE THRUST BEARING SIZE: (9.2.5.2.4)	NO						
20	LUBRICATION TYPE: (6.11.3)(6.11.4)(9.2.6.1)	Slinger						
21	PRESSURE LUBE SYSTEM TO ISO 10438-		(9.2.6.4)	N/A				
22	ISO 10438 DATA SHEETS ATTACHED							
23	PRESSURIZED LUBE OIL SYSTEM MTD. ON PUMP BASEPLATE:	N/A						
24	LOCATION OF PRESSURIZED LUBE OIL SYSTEM MOUNTED ON BASEPLATE:							
25								
26	INTERCONNECTING PIPING PROVIDED BY:	N/A						
27	OIL VISC. ISO GRADE:	ISO VG 68						
28	CONSTANT LEVEL OILER: (6.10.2.2)	REQUIRED						
29	INSTRUMENTATION				SEAL SUPPORT SYSTEM MOUNTING			
30	SEE ATTACHED API-670 DATA SHEET:	NO		BARRIER/BUFFER RESERV. MTD ON PUMP BASEPL.:(7.5.1.4)				YES
31	ACCELEROMETER OR VELOMETER: (7.4.2.1):	NO		IDENTIFY LOCATION ON BASEPLATE:				
32	QUANTITY:							
33	MOUNTING LOCATIONS:			INTERCONNECTING PIPING BY:				SUPPLIER
34	DETECTORS REQUIRED:			RESERVOIR(S) SHIPPED SEPARATELY:				YES
35	THRD'D PROVISIONS ONLY PER ANSI/API 670: (6.10.2.10)			MECHANICAL SEAL (6.8)				
36	QUANTITY:			SEE ATTACHED API 682 DATA SHEET:				SEE PAGE 7
37	MOUNTING LOCATIONS:			ADDITIONAL CENTRAL FLUSH PORT: (6.8.9)				
38				HEATING OR COOLING JACKET REQ'D:				N/A
39	FLAT SURFACE REQ'D FOR MAGNETIC P/U's: (6.10.2.11)	NO		MAX. CHAMBER PRESS.: (6.8.13)				STATIC: DYN.: psig
40	QUANTITY:			SEAL CATEGORY: (6.8.1)				Category 2 (API-610)
41	MOUNTING LOCATIONS:			HEATING AND COOLING				
42				COOLING REQUIRED: (6.1.17)				See Page 8 Seals
43	VIBRATION PROXIMITY PROBES FOR HYDRODYNAMIC BEARINGS:			COOLING WATER PIPING PLAN:				Plan M
44	PROVISION-ONLY FOR VIB. PROBES: (7.4.2.2)	N/A		CLG WATER PIPING CONSTR.:				See Page 8 Seals
45	QUANTITY PER RADIAL BEARING:			FITTINGS TYPE:				
46	QUANTITY PER THRUST BEARING:			COOLING WATER PIPING MATERIALS:				
47	VIBR. MONITORS & CABLES SUPPLIED BY: (7.4.2.4)			CLG WTR REQmnts: (BOTH ENDS IF DOUBLE ENDED)				
48				BEARING HOUSING(S):				gpm
49	TEMP. DETECTORS FOR HYDRODYNAMIC BEARINGS: (7.4.2.3)			SEAL SUPPORT: (HX, BUFFER, BARRIER, ETC.)				gpm
50	PROVISION-ONLY FOR TEMPERATURE PROBES:	N/A		TOTAL COOLING WATER:				gpm
51	RADIAL BEARING TEMPERATURE PROBES:	N/A		HEATING MEDIUM:				N/A
52	QUANTITY PER RADIAL BEARING:			OTHER:				
53	THRUST BEARING TEMPERATURE PROBES:	N/A		HEATING MEDIUM PIPING CONSTRUCTION:				
54	QUANTITY PER THRUST BEARING ACTIVE SIDE:			PIPING & APPURTENANCES				
55	QUANTITY PER THRUST BEARING INACTIVE SIDE:			MANIFOLD PIPING SYS. FOR PURCHASER CONN.: (7.5.1.6)				
56	THRD'D T/W's FOR GEARBOX TEMP GAGES: (9.1.3.6)	N/A		VENTS:				N/A
57	PRESSURE GAGE TYPE:			DRAINS:				N/A
58	TEMP. MONITORS & CABLES SUPPLIED BY: (7.4.2.4)			COOLING WATER:				N/A
59				TAG ALL ORIFICES: (7.5.2.4)				YES
60				SOCKET WELD CONN. ON SEAL GLAND: (7.5.2.8)				NO



<div><div>FLUOR®</div><div>worldenergy</div></div>		API 610				Contract: A8KM													
		CENTRIFUGAL PUMP DATA SHEET				Item No: 18-P-354A/B													
		Doc. No.: A8KM-18-096-540066-A				Revision: 1		Date: 27-Feb-23											
						Unit: Renewable Jet Fuel Unit B													
		Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.				P.O. No.: 4505606431		Inquiry No.: 4-601D-RQ											
Sheet		5		of		11		REV											
SURFACE PREPARATION AND PAINT										INSPECTION & TEST									
MANUFACTURER'S STANDARD: NO										SHOP INSPECTION: (8.1.1) YES									
OTHER (SEE BELOW) YES										PERFORMANCE CURVE & DATA APPROVAL PRIOR TO SHIPMENT: YES									
SPECIFICATION NUMBER: A8KM-PP-00-500520-A										TEST WITH SUBSTITUTE SEAL: (8.3.3.2.b)									
PUMP: Meets ISO 12944-5, C4 Environment (Only Carbon Steel Parts Painted)										MATERIAL CERT. REQUIRED: (6.12.1.8) CASING: YES 0									
PUMP SURFACE PREPARATION: SSPC-SP 1 + SSPC-SP 10										IMPELLER: YES 0									
PRIMER: Inorganic Zinc // Galvosil 15680										SHAFT: YES 0									
FINISH COAT: Polyurethane // Hempathane HS 55610										OTHER: See Note 6.3 YES 0									
BASEPLATE OR SOLE PLATE: Meets ISO 12944-5, C4 Environment										CASTING REPAIR PROCED. APPROVAL REQ'D: (6.12.2.5)(6.12.3.1) Note 6.7									
SURFACE PREPARATION: SSPC-SP 1 + SSPC-SP 10										INSPECTION REQ'D FOR CONN. WELDS: (6.12.3.4.d,e) 0									
PRIMER: Inorganic Zinc // Galvosil 15680										MAG PARTICLE: NO 0									
FINISH COAT: High Build Epoxy // Hempadur Mastic 45880										5%RT Butt Weld Connections to Casing RADIOGRAPHY: YES 0									
DETAILS OF LIFTING DEVICES: Calcs & NDE Req'd for Lifts > 20,000 LBS										LIQUID PENETRANT: YES									
SHIPMENT: (8.4.1) (Note 6.8)										ULTRASONIC: NO									
EXPORT BOXING REQUIRED										INSPECTION REQUIRED FOR CASTINGS: (TABLE 14 Level II)									
OUTDOOR STORAGE UP TO 6 MONTHS: YES										MAG PARTICLE: NO									
SPARE ROTOR ASSEMBLY PACKAGED FOR:										RADIOGRAPHY: NO									
ROTOR STORAGE ORIENTATION: (9.2.8.2) N/A										LIQUID PENETRANT: YES									
SHIP'G & STORAGE CONTAINER FOR VERT. STORAGE: (9.2.8.3) N/A										ULTRASONIC: NO									
N2 PURGE: (9.2.8.4) N/A										HARDNESS TEST REQUIRED: (8.2.2.7) (NACE SERVICES) NO									
SPARE PARTS: (Note 6.1)										ADDITIONAL SUBSURFACE EXAMINATION: (6.12.1.5)(8.2.1.3) YES									
START-UP: YES										FOR: Auxiliary Piping									
NORMAL MAINTENANCE: YES										METHOD: Follow Table 14 Level II for Socket or Butt Welding									
										PMI TESTING REQUIRED: (8.2.2.8) YES									
WEIGHTS lb										COMPONENTS TO BE TESTED: See Note 6.4									
ITEM No. PUMP DRIVER ACCESSORY BASE TOTAL										RESIDUAL UNBALANCE TEST: (J.4.1.2) NON-WIT									
18-P-354A/B 310.8 101.0 771.6 1565.3 2748.7										NOTIFICATION OF SUCCESSFUL SHOP PRELIM. TEST:(8.1.1.c)(8.3.3.5) NO 0									
										BASEPLATE TEST: (7.3.21) NO									
										HYDROSTATIC TEST OF CASING/HEAD: NON-WIT									
										HYDROSTATIC TEST OF BOWLS & COLUMN: (9.3.13.2) N/A									
										PERFORMANCE TEST: (Note 6.5) NON-WIT									
OTHER PURCHASER REQUIREMENTS										TEST IN COMPLIANCE WITH: (8.3.3.2) 8.3.3.2									
COORDINATION MEETING REQUIRED: (10.1.3) YES										TEST DATA POINTS TO: (8.3.3.3) 8.3.3.3									
MAXIMUM DISCHARGE PRESSURE TO INCLUDE:										TEST TOLERANCES TO: (8.3.3.4) TABLE 16									
MAX RELATIVE DENSITY: YES										NPSH TEST PTS./RETEST: (8.3.4.3.1)(8.3.4.3.4) N/A									
OPERATION TO TURBINE TRIP SPEED OR ASD OVERSPEED: N/A										NPSH TEST-1ST STAGE ONLY: (8.3.4.3.2) N/A									
MAX DIA. IMPELLERS AND / OR NO. OF STAGES: NO										NPSH TESTING TO HI 1.6 : (8.3.4.3.3)									
CONNECTION DESIGN APPROVAL: (9.2.1.4) (BB Pumps) N/A										PERFORMANCE TEST LIMITED TO 110% SITE NPSHA: (8.3.3.6) NO									
TORSIONAL ANALYSIS / REPORT: (6.9.2.10) (REQ'D IF GEAR OR VFD) N/A										RETEST ON SEAL LEAKAGE: (8.3.3.2.d) NO									
PROGRESS REPORTS: YES										RETEST REQUIRED AFTER FINAL HEAD ADJ.: (8.3.3.7.b)(Multistg) N/A									
OUTLINE OF PROCEDURE FOR OPTIONAL TESTS: (10.2.5) YES										COMPLETE UNIT TEST: (8.3.4.4.1) N/A									
ADDITIONAL DATA REQUIRING 20 YEARS RETENTION: (8.2.1.1) NO										SOUND LEVEL TEST: (8.3.4.5) FOR INFORMATION ONLY NON-WIT									
LATERAL ANALYSIS REQUIRED: (9.1.3.4)(9.2.4.1.3) N/A										CLEANLINESS PRIOR TO FINAL ASSEMBLY: (8.2.2.6) NON-WIT									
MODAL ANALYSIS REQUIRED FOR VS PUMPS: (9.3.9.2) N/A										LOCATION OF CLEANLINESS INSPECTION: @ SUPPLIERS									
DYNAMIC BALANCE ROTOR ASSEMBLY TO ISO G1.0: (9.2.4.2.3) NO										NOZZLE LOAD TEST: NO									
INSTALLATION LIST IN PROPOSAL: (10.2.3.I) NO										CHECK FOR CO-PLANAR MOUNTING PAD SURFACES: NON-WIT									
VFD STEADY STATE DAMPED RESPONSE ANALYSIS: (6.9.2.3) N/A										MECH. RUN TEST AT RATED CAPACITY UNTIL OIL TEMP STABLE: (8.3.4.2.1) NON-WIT									
TRANSIENT TORSIONAL RESPONSE: (6.9.2.4) N/A										4 HR. MECH RUN TEST AT RATED CAPACITY AFTER OIL TEMP STABLE: N/A									
BEARING SELECTION & LIFE CALCS PER (6.10.1.1) & (6.10.1.6): YES										1 HR. MECH RUN TEST AT RATED CAPACITY: (8.3.4.2.2) NON-WIT									
IGNITION HAZARD ASSESSMENT TO EN 13463-1 FOR EXPLOSIVE ATM: (7.2.15) N/A										BEARING HSG. RESONANCE TEST: (8.3.4.7) N/A									
CASING RETIREMENT THICKNESS DWG: (10.3.2.3) NO										STRUCTURAL RESONANCE TEST: (9.3.9.2) N/A									
FLANGES REQ'D IN PLACE OF SOCKET WELD UNIONS: (7.5.2.8) YES										REMOVE / INSPECT HYDRODYN. BRGS. AFTER TEST: (9.2.7.5) N/A									
INCLUDE PLOTTED VIBRATION SPECTRA FOR PERF. TEST: (6.9.3.3) YES										AUXILIARY EQUIPMENT TEST: (8.3.4.6) NO									
CONNECTION BOLTING: (7.5.1.7) SS										EQUIP. TO BE INCLUDED IN AUX. TESTS:									
CADMIUM PLATED BOLTS PROHIBITED: YES										LOCATION OF AUX. EQUIPMENT TEST:									
VENDOR TO KEEP REPAIR AND HT RECORDS: (8.2.1.1.c) YES										IMPACT TEST: (6.12.4.3) PER EN 13445 N/A									
VENDOR TO SUBMIT TEST PROCEDURES: (8.3.1.1) YES										PER ASME SECTION VIII N/A									
VENDOR SUBMIT INSPECTION CHECK LIST:(8.1.5) YES										REMOVE CASING AFTER TEST: N/A									
TEST REQUIREMENTS PER 8.3.3.5a THROUGH 8.3.3.5d: YES																			
DISASSEMBLE AND INSPECT AFTER TEST: (8.3.3.8) NO																			

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

<div><div>FLUOR®</div><div>worldenergy</div></div>		API 610		Contract:		A8KM																									
		CENTRIFUGAL PUMP DATA SHEET		Item No:		18-P-354A/B																									
		Doc. No.: A8KM-18-096-540066-A		Revision:		1	Date:	27-Feb-23																							
				Unit:		Renewable Jet Fuel Unit B																									
		Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.		P.O. No.:		4505606431																									
		Inquiry No.:		4-601D-RQ																											
		Sheet	6	of	11	REV																									
1	PRESSURE VESSEL DESIGN CODE REFERENCES																														
2	THESE REFERENCES MUST BE LISTED BY THE MANUFACTURER:																														
3	CASTING FACTORS USED IN DESIGN: (TABLE 3)																														
4	SOURCE OF MATERIAL PROPERTIES:																														
5																															
6	WELDING AND REPAIRS																														
7	THESE REFERENCES MUST BE LISTED BY THE PURCHASER (DEFAULT TO TABLE 11 IF NO PURCHASER PREFERENCE IS STATED)																														
8	ALTERNATIVE WELDING CODES AND STANDARDS:																														
9	WELDING REQUIREMENT: (APPLICABLE CODE OR STANDARD)																														
10	WELDER/OPERATOR QUALIFICATION:																														
11	WELDING PROCEDURE QUALIFICATION:																														
12	NON-PRESSURE RETAINING STRUCTURAL WELDING SUCH AS BASEPLATES OR SUPPORTS:																														
13	MAGNETIC PARTICLE OR LIQUID PENETRANT EXAMINATION OF PLATE EDGES:																														
14	POSTWELD HEAT TREATMENT:																														
15	POSTWELD HEAT TREATMENT OF CASING FABRICATION WELDS:																														
16																															
17	MATERIAL INSPECTION																														
18	THESE REFERENCES MUST BE LISTED BY THE PURCHASER																														
19	ALTERNATIVE MATERIAL INSPECTIONS AND ACCEPTANCE CRITERIA:																														
20																															
21	<table><tr><td>TYPE OF INSPECTION</td><td>METHOD</td><td>FOR FABRICATIONS</td><td>FOR CASTINGS</td></tr><tr><td>RADIOGRAPHY</td><td></td><td></td><td></td></tr><tr><td>ULTRASONIC INSPECTION</td><td></td><td></td><td></td></tr><tr><td>MAGNETIC PARTICLE INSPECTION</td><td></td><td></td><td></td></tr><tr><td>LIQUID PENETRANT INSPECTION</td><td></td><td></td><td></td></tr><tr><td>VISUAL INSPECTION (ALL SURFACES)</td><td></td><td></td><td></td></tr></table>							TYPE OF INSPECTION	METHOD	FOR FABRICATIONS	FOR CASTINGS	RADIOGRAPHY				ULTRASONIC INSPECTION				MAGNETIC PARTICLE INSPECTION				LIQUID PENETRANT INSPECTION				VISUAL INSPECTION (ALL SURFACES)			
TYPE OF INSPECTION	METHOD	FOR FABRICATIONS	FOR CASTINGS																												
RADIOGRAPHY																															
ULTRASONIC INSPECTION																															
MAGNETIC PARTICLE INSPECTION																															
LIQUID PENETRANT INSPECTION																															
VISUAL INSPECTION (ALL SURFACES)																															
22																															
23																															
24																															
25																															
26																															
27																															
28	NOTES																														
29	6.1	Provide a Start-up Spare Parts List and 2-yrs. Operating Spares List, inclusive of coupling and motor parts.																													
30	6.2	Pump Supplier shall provide pump performance curves, General Arrangement drawing sized for the driver, completed data sheets &																													
31		Bill of Material, and un-priced Sub-Supplier buyouts																													
32	6.3	CMTR's are required for pressure casings & covers, impellers, wear rings & shaft. Include all QA documents in Quality Data Books.																													
33	6.4	PMI of alloy pressure containment parts, incl. seal glands, pipe & valves, is required.																													
34	6.5	Mechanical run testing is required																													
35		Mechanical run test shall be until oil temperature stabilization at Rated point, for at least one (1) hour for single-stage																													
36		pumps, with vibration recordings at 10-minute intervals.																													
37		Deleted.																													
38	6.6	Deleted.																													
39		Deleted.																													
40	6.7	Minor defects of a surface nature in the pressure casting (amounting to less than 20% of the wall thickness and less than 10 in ² [65 cm ²] in total area) may be repaired without Buyer's approval. See Project Pump Specification A8KM-PP-000-50626-A.																													
41																															
42	6.8	Export Boxing is required for Ocean Transit only. Supplier shall include as applicable to their scope and place of manufacture in relation to																													
43		destination of equipment. All boxing shall be protective of the weather elements.																													
44	6.9	Baseplate grounding tabs shall be 1/4" thick steel with at least one (1) 9/16" dia. hole provided. If two (2) are provided, they shall be																													
45		9/16" dia. spaced 1-3/4" on center. Where Stainless Steel grounding pads are provided, they shall be threaded with one (1) 1/2"-13 hole, or																													
46		either two (2), or four (4), 1/2"-13 holes, all spaced 1-3/4" on center.																													
47																															
48																															
49																															
50																															
51																															
52																															
53																															
54																															
55																															
56																															
57																															
58																															
59																															
60																															
61																															

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

 		API 682 MECHANICAL SEAL DATA SHEET				Contract:		A8KM		REV
						Item No:		18-P-354A/B		
		Revision:		1		Date:		27-Feb-23		
		Unit:		Renewable Jet Fuel Unit B		P.O. No.:		4505606431		
		Doc. No.: A8KM-18-096-540066-A				Inquiry No.:		4-601D-RQ		
		Note: This data sheet has been modified from that in the annex of API Standard 682, Third Edition. (See Note 9.3)				Sheet		7 of 11		
1	Client:		World Energy Paramount		Project:		World Energy Renewables Project			
2	Service:		Slop Oil Pump		Facility:		World Energy Paramount			
3	No. Seals Required per Pump:		Two (2)		Site:		Paramount, CA			
4	NOTES: Information Below to be Completed : <input type="radio"/> By Purchaser <input checked="" type="radio"/> By Manufacturer <input checked="" type="checkbox"/> By Manufacturer or Purchaser									
5	Seal Specification - (Ref. 4.1, Figures 1 to 6)									
6	CATEGORY	<input type="radio"/> Seal Category 1		<input checked="" type="radio"/> Seal Category 2		<input type="radio"/> Seal Category 3		Seal Code (Annex D)		23A-FIN-050-11/53B
7	TYPE (CODE CW)	<input checked="" type="checkbox"/> Type A (3.1.90)		<input checked="" type="checkbox"/> Type B (3.1.91)		<input checked="" type="checkbox"/> Alternate Stationary (Type A&B)				
8		<input checked="" type="checkbox"/> Type C (3.1.92)		<input checked="" type="checkbox"/> Alternate Rotating (Type C)		<input checked="" type="checkbox"/> Single Spring (Type A)				
9	ARRANGEMENT	Default Configuration		Alternate Design		Flush Plans (See Annex G)				
10	1 (3.1.2)	Single	<input checked="" type="checkbox"/> 1CW-FX		<input checked="" type="checkbox"/> 1CW-FL <input checked="" type="checkbox"/> Dist. Flush		<input checked="" type="checkbox"/> 01 <input checked="" type="checkbox"/> 13 <input checked="" type="checkbox"/> 23 <input checked="" type="checkbox"/> 50 <input checked="" type="checkbox"/> 62			
11					<input checked="" type="checkbox"/> Alternative Bush		<input checked="" type="checkbox"/> 02 <input checked="" type="checkbox"/> 14 <input checked="" type="checkbox"/> 31 <input checked="" type="checkbox"/> 51			
12							<input checked="" type="checkbox"/> 11 <input checked="" type="checkbox"/> 21 <input checked="" type="checkbox"/> 32 <input checked="" type="checkbox"/> 61			
13	2 (3.1.3)	Buffer	Liquid <input checked="" type="checkbox"/> 2CW-CW		<input checked="" type="checkbox"/> FX <input checked="" type="checkbox"/> Dist. Flush		<input checked="" type="checkbox"/> 01 <input checked="" type="checkbox"/> 13 <input checked="" type="checkbox"/> 23 <input checked="" type="checkbox"/> 41 <input checked="" type="checkbox"/> 62 <input checked="" type="checkbox"/> 75			
14					<input checked="" type="checkbox"/> Tangential LBO Connection		<input checked="" type="checkbox"/> 02 <input checked="" type="checkbox"/> 14 <input checked="" type="checkbox"/> 31 <input checked="" type="checkbox"/> 52 <input checked="" type="checkbox"/> 71 <input checked="" type="checkbox"/> 76			
15			Gas <input checked="" type="checkbox"/> 2CW-CS		<input checked="" type="checkbox"/> 2NC-CS <input checked="" type="checkbox"/> FX <input checked="" type="checkbox"/> Dist. Flush		<input checked="" type="checkbox"/> 11 <input checked="" type="checkbox"/> 21 <input checked="" type="checkbox"/> 32 <input checked="" type="checkbox"/> 61 <input checked="" type="checkbox"/> 72			
16	3 (3.1.4)	Barrier	Liquid <input checked="" type="checkbox"/> 3CW-FB		<input checked="" type="checkbox"/> 3CW-BB <input checked="" type="checkbox"/> FX		<input checked="" type="checkbox"/> 01 <input checked="" type="checkbox"/> 13 <input checked="" type="checkbox"/> 53A <input checked="" type="checkbox"/> 54 <input checked="" type="checkbox"/> 74			
17					<input checked="" type="checkbox"/> 3CW-FF <input checked="" type="checkbox"/> Tang. LBO Conn.		<input checked="" type="checkbox"/> 02 <input checked="" type="checkbox"/> 14 <input checked="" type="checkbox"/> 53B <input checked="" type="checkbox"/> 61			
18			Gas <input checked="" type="checkbox"/> 3NC-BB		<input checked="" type="checkbox"/> 3NC-FF <input checked="" type="checkbox"/> 3NC-FB		<input checked="" type="checkbox"/> 11 <input checked="" type="checkbox"/> 32 <input checked="" type="checkbox"/> 53C <input checked="" type="checkbox"/> 62			
19	SLEEVE-SHAFT DRIVE		<input checked="" type="checkbox"/> Set-Screw Onto Shaft		<input checked="" type="checkbox"/> Alternative (6.1.3.15)		Specify :			
20	MATERIALS (REFERENCE 6.1.6 & ANNEX B) (Note 7.3)									
21	SECONDARY SEALS		SEAL FACES		METAL BELLOWS		SPRINGS		METAL PARTS	
22	<input checked="" type="checkbox"/> FKM <input checked="" type="checkbox"/> FFKM		<input checked="" type="checkbox"/> CARBON vs SIC		<input checked="" type="checkbox"/> UNS N10276 (TypeB)		<input checked="" type="checkbox"/> UNS N10276		<input checked="" type="checkbox"/> UNS S31600 / S31635	
23	<input checked="" type="checkbox"/> Spiral Wound Gasket		<input checked="" type="checkbox"/> SIC vs SIC		<input checked="" type="checkbox"/> UNS N07718 (TypeC)		or UNS N06455		<input checked="" type="checkbox"/> UNS N10276	
24	<input checked="" type="checkbox"/> EPM / EPDM <input checked="" type="checkbox"/> NBR		<input checked="" type="checkbox"/> SS-SIC <input checked="" type="checkbox"/> RB-SIC		<input checked="" type="checkbox"/> UNS N08020		<input checked="" type="checkbox"/> UNS S31600		<input checked="" type="checkbox"/> UNS N08020	
25	<input checked="" type="checkbox"/> Other :		<input checked="" type="checkbox"/> vs		<input checked="" type="checkbox"/> Other :		or UNS S31635		<input checked="" type="checkbox"/> Other :	
26	MECHANICAL SEAL DATA									
27	<input checked="" type="radio"/> Seal Vendor : Flowserve				<input checked="" type="checkbox"/> Dynamic Sealing Pressure Rating (3.1.27) :		750		psig	
28	<input type="radio"/> Data Requirements Form (Annex J)				<input checked="" type="checkbox"/> Static Sealing Pressure Rating (3.1.84) :		1050		psig	
29	<input checked="" type="checkbox"/> Size / Type : 2.500 / 2.500				<input checked="" type="checkbox"/> Maximum Allowable Temperature (3.1.51) :		185		°F	
30	<input checked="" type="checkbox"/> Seal Drawing No.: D0574896				<input checked="" type="radio"/> Min. Design Metal Temperature (6.1.6.11.1) :		32		°F	
31	<input checked="" type="checkbox"/> Vendor's Seal Code : QBBW/QBQW				<input type="checkbox"/> Generated Heat at Normal Conditions :				BTU/hr	
32	<input type="checkbox"/> Modified Faces For Pump Performance Test				<input type="checkbox"/> Heat Soak at Normal Conditions :				BTU/hr	
33	<input type="checkbox"/> Alternative Seal For Pump Performance Test				<input type="checkbox"/> Total Seal Axial Thrust on Shaft :				lb	
34	SEAL CHAMBER DATA (REFERENCE 6.1.2.4)									
35	<input checked="" type="checkbox"/> API 610		<input checked="" type="checkbox"/> ASME B73.1&2		<input checked="" type="checkbox"/> Cylindrical		<input checked="" type="checkbox"/> Tapered		<input checked="" type="checkbox"/> ISO 3069-C <input checked="" type="checkbox"/> Other :	
36	<input type="radio"/> Bolt-On Chamber (6.1.2.5)		<input checked="" type="checkbox"/> Seal Chamber Flush Port Req'd		<input checked="" type="checkbox"/> Seal Chamber Vent Req'd					
37	<input checked="" type="checkbox"/> Floating Throat Bushing		<input checked="" type="checkbox"/> Fixed Throat Bushing		<input checked="" type="checkbox"/> Chamber Heating		<input checked="" type="checkbox"/> Chamber Cooling			
38	PUMP DATA									
39	<input checked="" type="checkbox"/> Manufacturer : FLOWERVE		<input checked="" type="checkbox"/> Model : HPX		<input checked="" type="checkbox"/> Size : 1HPX11A		<input checked="" type="checkbox"/> Case Material : A351 Gr. CF3M			
40	Pump Operating Pressure :		<input checked="" type="radio"/> Discharge Press. (Rated) :		20.2		psig		<input checked="" type="radio"/> Suction Press. (Rated) :	
41	Seal Chamber Press.:		<input checked="" type="checkbox"/> Norm.: 11.15 psig		<input type="checkbox"/> Min/Max (MDSP 3.1.53):				<input type="checkbox"/> MSSP (3.1.55) :	
42	Shaft:		<input checked="" type="checkbox"/> Horizontal		<input checked="" type="checkbox"/> Vertical		<input checked="" type="checkbox"/> Diameter : 49.5		<input checked="" type="checkbox"/> Shaft Speed : 1740 RPM	
43	<input checked="" type="checkbox"/> Shaft Rotation (Viewed From Driver) :		<input checked="" type="checkbox"/> CCW		<input type="checkbox"/> CW					
44	NOTES									
45	7.1	Deleted.								
46	7.2	Seal Manufacturer shall consider the Liquid Characteristics and Operating Conditions on sheet 2.								
47	7.3	Seal Manufacturer shall recommend seal face material, elastomers and spring material based on pumped fluid properties.								
48	7.4	Refer to 8ES-2DG1 – WEP Instrumentation & Electrical Standard Vendor List, for Instrumentation.								
49	7.5	Baseplates shall be sized for mounting of seal flush systems on-base. Seal flush systems shall not interfere with pump maintenance.								
50		Plan 53 systems shall be pre-piped and removed for shipping.								
51	7.6	Deleted.								
52		Deleted.								
53										
54										
55										

 		API 682 MECHANICAL SEAL DATA SHEET				Contract: A8KM	
		Doc. No.: A8KM-18-096-540066-A				Item No: 18-P-354A/B	
		Note: This data sheet has been modified from that in the annex of API Standard 682, Third Edition. (See Note 9.3)				Revision: 1 Date: 27-Feb-23	
						Unit: Renewable Jet Fuel Unit B	
		P.O. No.: 4505606431				Inquiry No.: 4-601D-RQ	
		Sheet 8 of 11				REV	

FLUID DATA							
PUMPED STREAM (PLANS 01, 02, 11, 12, 13, 14, 21, 23, 31, 41) <input checked="" type="radio"/> Type or Name : Hydrocarbons or Amine Conc'n : 100 % <input type="radio"/> Dissolved Contaminant <input checked="" type="radio"/> H ₂ S : (Note 2.8) ppmw <input type="radio"/> Wet <input checked="" type="radio"/> Cl ₂ : 0 ppm <input type="radio"/> Other: @ wt% <input type="radio"/> Solid Contaminant : <input type="radio"/> Conc'n (Mass Fract. or PPM) : <input checked="" type="radio"/> Fluid Temp.: Min °F Norm 135.9 °F Max 185 °F <input checked="" type="radio"/> Spec. Gravity : @ Norm. Temp.: 0.686 @ Min. Temp.: Note 2.8 <input checked="" type="radio"/> Vapor Pressure : @ Norm Temp.: 19.7 psi(a) <input type="radio"/> Atmospheric Boiling Point : °F <input checked="" type="radio"/> Viscosity : Normal : 0.73 cP Max.: Note 2.8 cP				<input checked="" type="radio"/> Hazardous <input checked="" type="radio"/> Flammable <input type="radio"/> <input type="radio"/> Fluid Solid at Ambient <input type="radio"/> Solidifies @ : °F <input type="radio"/> Pour Point : °F <input type="radio"/> Pumped Stream Solidifies Under Shear <input type="radio"/> Pumped Stream Contains Agents That Polymerize Specify Agents : @ Temp : °F <input type="radio"/> Pumped Stream Can Plate Out or Decompose : Specify Conditions : <input checked="" type="radio"/> Pumped Stream is Regulated For Fugitive or Other Emissions Regulation Level : wt% <input type="radio"/> Special Pump Cleaning Procedures : <input type="radio"/> Alt. Process Fluids (incl. Commissioning) Specify :			
FLUSH FLUID (PLAN 32) <input type="radio"/> Type or Name : Conc'n : % <input type="radio"/> Seal Vendor Review Required <input type="radio"/> Fluid Temp : Min °F Norm °F Max °F <input type="radio"/> Spec. Gravity : @ Norm. Temp.: @ Max. Temp.:				<input type="radio"/> Vapor Press: @ Norm. Temp: psi(a) @ Max. Temp: psi(a) <input type="radio"/> Viscosity @ Normal Temperature : cP <input type="radio"/> Atmospheric Boiling Point: °F <input type="checkbox"/> Flow Rate Req'd Max. / Min.: / gpm <input type="checkbox"/> Pressure Req'd Max. / Min.: / psig			
QUENCH MEDIUM (PLAN 62) <input checked="" type="checkbox"/> Type or Name :				<input checked="" type="checkbox"/> Supply Temperature Max. / Min. : / °F <input type="checkbox"/> Flow Rate Req'd (@STP for gas) Max. / Min. : / gpm			
BUFFER / BARRIER MEDIUM (PLAN 52, 53, 54, 72, 74) <input checked="" type="checkbox"/> Type or Name : DURACLEAR 5-F <input checked="" type="radio"/> Purchaser Selection <input type="checkbox"/> Seal Vendor Selection <input checked="" type="radio"/> Seal Vendor Review <input type="checkbox"/> Purchaser Review <input type="checkbox"/> Flow Rate Req'd (@STP for Gas) Max. / Min.: / gpm <input checked="" type="checkbox"/> Supply Pressure Max. / Min.: / psig <input checked="" type="checkbox"/> Fluid Temperature : Min.: °F Normal : °F Max.: °F				<input checked="" type="checkbox"/> Specific Gravity: @ Normal Temperature : @ Max. Temp. : <input checked="" type="checkbox"/> Vapor Pressure at : Normal Temp.: psia Max. Temp.: psia <input checked="" type="checkbox"/> Atmospheric Boiling Point : °F <input checked="" type="checkbox"/> Viscosity at Normal Pump Temperature : cP <input checked="" type="checkbox"/> Specific Heat Capacity at Const. Press.: BTU/lb°F <input checked="" type="checkbox"/> Cooling / Heating Required : Yes			
SITE AND UTILITIES							
<input checked="" type="radio"/> Control Voltage : V : 120 Ph : 1 Hz : 60 <input checked="" type="radio"/> Area Class: Cl.: I Gr.: B/C/D Div.: 2 <input checked="" type="radio"/> Design Ambient (Min. / Max.): 35 / 105 °F <input type="radio"/> ATEX (Ex Directive 94/9/EC) : Gr.: Cat.: T-CLASS: T3C				<input checked="" type="radio"/> Cooling Water Supply Temp. Norm.: 80 °F <input checked="" type="radio"/> Cl ⁻ : < 840 ppmw <input checked="" type="radio"/> Cooling Water Supply Press. Norm./Design: 45 / 120 psi(g) <input checked="" type="radio"/> Cooling Water Allowable Pressure Drop : 10.0 psi <input checked="" type="radio"/> Cooling Water AllowableTemp. Rise : 40.0 °F			
ACCESSORIES (Clauses 8 and 9)							
GENERAL <input type="radio"/> Joint User / Vendor Layout of Equipment (8.1.3) <input type="radio"/> Pipe Taper Threads (8.2.13) <input type="radio"/> ISO 7 <input type="radio"/> ASME B1.20.1 <input type="radio"/> Special Requirements For Hazardous Service Define : <input type="radio"/> Special Cleaning and Decontamination Requirements <input type="radio"/> Utility Manifold Connections Required (8.2.24) <input type="radio"/> Type and Spec. of Heat Tracing (8.3.9.1.1) : <input type="radio"/> Thermal Relief Valves Required (9.8.3) PLAN 11, 12, 13, 14, 21, 23, 31, 32 and 41 SYSTEMS <input checked="" type="radio"/> Connecting Line Supplier : PUMP SUPPLIER <input type="radio"/> Tubing <input checked="" type="radio"/> Piping (8.3.5.2) 316LSS BW RF(BW Case conn.) <input checked="" type="radio"/> Restriction Orifice Nipple in Flush Line (8.3.5.4) <input type="radio"/> Cyclone Separator Supplier : <input type="radio"/> Plan 32 Equipment Supplier : <input type="radio"/> Plan 32 Flow Indicator <input type="radio"/> Plan 32 Temp. Indicator <input type="radio"/> Plan 23 Temp. Indicator				COOLING SYSTEMS (PLAN 21,22,23,41,52,53B,53C) (Note 8.3) <input checked="" type="radio"/> Heat Exchanger Supplier : SEAL SUPPLIER <input checked="" type="checkbox"/> Water Cooled <input checked="" type="checkbox"/> Air Cooled <input type="radio"/> ISO 15649 <input checked="" type="radio"/> Equipment Reference / Code : <input checked="" type="radio"/> Cooling Water Line Supplier: PUMP SUPPLIER <input type="radio"/> Tubing <input type="radio"/> Galvanized Piping (8.2.21) <input type="radio"/> Gal CS Piping <input checked="" type="radio"/> Sight Flow Indicators (8.2.22) <input type="radio"/> Open <input checked="" type="radio"/> Closed <input checked="" type="checkbox"/> Cooling Water Flow Requirement & Equipment Pressure Drop: <input type="checkbox"/> Primary Equipment : gpm ΔP : psi <input checked="" type="checkbox"/> Secondary Equipment : gpm ΔP : psi PLAN 72 and 74 SYSTEMS <input type="radio"/> Equipment Supplier : <input type="radio"/> High Flow Alarm Switch (8.3.10.5) PLAN 75 and 76 SYSTEMS <input type="radio"/> Equipment Supplier : <input type="radio"/> High Level Alarm Switch For Plan 75 (8.3.9.3.3) <input type="radio"/> Test Connection (8.3.9.3.4)			
NOTES							
8.1 Pump Supplier has unit responsibility for the furnishing of all instruments & equipment associated with seal flush Plans.							
8.2 Orifice size shall be stamped on each orifice, with direction of flow indicated. Orifice assembly shall be tagged with Buyer's orifice tag number.							
8.3 Cooling Water Piping shall be per Material Pipe Class, TAAG2.							
Deleted.							
Deleted.							




Contract:		A8KM			
Item No:		18-P-354A/B			
Revision:		1	Date:		27-Feb-23
Unit:		Renewable Jet Fuel Unit B			
P.O. No.:		4505606431			
Inquiry No.:		4-601D-RQ			
Sheet	9	of	11		REV

Doc. No.: A8KM-18-096-540066-A

Note: This data sheet has been modified from that in the annex of API Standard 682, Third Edition. (See Note 9.3)

[illegible]

	LOW VOLTAGE MOTOR (IEEE 841) DATA SHEET U.S. CUSTOMARY UNITS		Contract: A8KM		Rev
	APPLICABLE MOTOR SPECIFICATION A8KM-PP-000-50670-A		Item No: 18-P-354AM/BM	Date: 27-Feb-23	
			Revision: 1		
	Doc. No.: A8KM-18-096-540066-A		Unit: Renewable Jet Fuel Unit B	P.O. No.: 4505606431	
		Sheet 10 of 10			

1	APPLICABLE TO <input type="radio"/> PROPOSAL <input checked="" type="radio"/> PURCHASE <input type="radio"/> AS BUILT					
2	CLIENT: World Energy Paramount	SERVICE: Slop Oil Pump				
3	PLANT: World Energy Paramount	MOTOR TAG NO. / NO. REQ'D: 18-P-354AM/BM / Two (2)				
4	SITE: Paramount, CA	DRIVEN EQUIPMENT TYPE / TAG NO. Centrifugal Pump / 18-P-354A/B				
5	DESIGN DATA AND ACCESSORY EQUIPMENT					
6	NAMEPLATE 5 HP 1.15 S.F. 1800 RPM POWER (VOLTAGE/PHASE/HERTZ) 460 / 3 / 60					
7	ROTATION (WHEN FACING MOTOR OPPOSITE DRIVE END): <input type="radio"/> CW <input type="radio"/> CCW Fans shall be bi-directional					
8	INSULATION CLASS: <input type="radio"/> B <input checked="" type="radio"/> F <input type="radio"/> H <input type="radio"/> VPI TEMP. RISE CLASS B / °C over 40 °C AMBIENT					
9	AREA CLASSIFICATION: <input checked="" type="radio"/> CLASS I , GROUP B/C/D DIV. 2 <input checked="" type="radio"/> T-RATING T3C / °F					
10	<input type="radio"/> UNCLASSIFIED <input type="radio"/>					
11	LOCATION: <input type="radio"/> INDOOR <input checked="" type="radio"/> OUTDOOR <input type="radio"/> SHELTERED UNUSUAL CONDITIONS: <input type="radio"/> DUST <input type="radio"/> OTHER					
12	AMBIENT TEMPERATURE: MAX 105 °F / MIN. 35 °F ALTITUDE 69 ft					
13	ENCLOSURE: <input checked="" type="radio"/> TOTALLY-ENCLOSED FAN-COOLED <input type="radio"/> TOTALLY-ENCLOSED NONVENTILATED <input type="radio"/> EXPLOSION PROOF					
14	MOUNTING METHOD: <input checked="" type="radio"/> FOOT <input type="radio"/> FLANGE, TYPE:					
15	MOUNTING ARRANGEMENT: <input checked="" type="radio"/> HORIZONTAL <input type="radio"/> VERTICAL SHAFT DOWN <input type="radio"/> VERTICAL SHAFT UP					
16	BEARING TYPE: <input checked="" type="radio"/> BALL <input type="radio"/> ROLLER BEARING LUBRICATION: <input checked="" type="radio"/> GREASE <input type="radio"/> OIL <input type="radio"/> PURE OIL MIST					
17	CONNECTION TO LOAD: <input checked="" type="radio"/> DIRECT CONNECTED <input type="radio"/> V-BELT <input type="radio"/> THROUGH GEAR <input type="radio"/> CLOSE COUPLED					
18	EQUIPMENT OPERATION: <input type="radio"/> CONTINUOUS <input type="radio"/> SPARED CONTINUOUS <input checked="" type="radio"/> INTERMITTENT-CYCLES / DAY					
19	SOUND PRESSURE LEVEL REQUIREMENTS: 85 dBA @ 3 FEET					
20	STARTING: <input checked="" type="radio"/> FULL VOLTAGE <input checked="" type="radio"/> REDUCED VOLTAGE, 80 % OF VOLTAGE Starting Voltage Dip Allowance					
21	<input type="radio"/> UNLOADED <input checked="" type="radio"/> LOADED <input type="radio"/> CAPACITORS FOR POWER FACTOR CORRECTION					
22	<input type="radio"/> SPACE HEATERS V PHASE °F MAX. TEMP					
23	<input checked="" type="radio"/> OVERSIZE TERMINAL BOX <input checked="" type="radio"/> DRAIN PLUGS Terminal Box shall be the largest feasible for the motor frame.					
24	<input checked="" type="radio"/> SS NAMEPLATE <input type="radio"/> AUXILIARY NAMEPLATE					
25	TEST <input checked="" type="radio"/> ROUTINE <input type="radio"/> COMPLETE <input checked="" type="radio"/> VIBRATION <input checked="" type="radio"/> REPORT <input checked="" type="radio"/> FOOT FLATNESS					
26	REMARKS: 10.1) This data sheet applies to motors 1/2 hp through 500 hp with anti-friction bearings.					
27	10.2) Deleted.					
28	10.3) IP55 degree of protection is required.					
29						
30	INFORMATION BELOW TO BE COMPLETED BY VENDOR					
31	MOTOR MFR. TECO	MODEL AEHH8B	SERIAL NO.		0	
32	NAMEPLATE HP 5	FULL LOAD RPM 1745	FRAME 184T	WEIGHT 101 LB	0	
33	MOTOR OUTLINE DRAWING NO. 31049U593010				0	
34	ROTOR CAGE MATERIAL OF CONSTRUCTION		MOTOR WINDING MATERIAL			
35	BEARING MANUFACTURER		SIZE 6306ZC35C		0	
36	VERTICAL MOTOR THRUST BEARING: TYPE	CAPACITY: UP LBS DOWN LBS	LOCATION			
37						
38	LOAD	FULL	3/4	1/2	OTHER	
39	AMPERES	6.12	-	-		
40	EFFICIENCY, %	89.5	88.5	88.5		
41	POWER FACTOR	85.5	81.5	71.5		
42	SPEED, RPM	1745	-	-		
43	LOCKED ROTOR AMPS* 46 AMPS					0
44	FULL LOAD TORQUE* 15.04 FT-LB					0
45	LOCKED ROTOR TORQUE* 185 %					0
46	PULL UP TORQUE* 140 %					0
47	BREAKDOWN TORQUE* 285 %					0
48	ACCEL. TIME W/ LOAD (0 TO FULL SPEED)* 15.08 SEC.					0
49	STALL TIMES AT ZERO RPM* - HOT / COLD 25 / 35 SEC.					0
50	NUMBER OF CONSECUTIVE STARTS* HOT: 1 / COLD: 2 PER HOUR					0
51	* INDICATED AT RATED VOLTAGE					
52	INFORMATION BELOW TO BE PROVIDED BY VENDOR AFTER PURCHASE (REFER TO RFQ/PO DOCUMENTS)					
53	<input checked="" type="radio"/> SAFE TIME - CURRENT CURVE MAX. SURFACE TEMP. DURING NORMAL STARING OR OPERATION OF:					
54	<input checked="" type="radio"/> SPEED - TORQUE CURVE <input type="radio"/> ROTOR °F <input type="radio"/> STATOR °F <input type="radio"/> ENCLOSURE °F					
55	<input checked="" type="radio"/> SAFE LOCKED ROTOR TIME HOT COLD					
56	NOTES:					
57	10.4 Average relative humidity is 54%.					
	10.5 Motor nameplate shall indicate service factor, area classification and T-rating. T-rating relates to both external and internal components.					
	10.6 Deleted.					
	10.7 All motors shall be rated for Cl. I, Div. 2, Gr. B,C,D and a T3C temperature code for project uniformity.					

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

FLUOR®




PUMP DATASHEET
ANNEX

Contract:		A8KM			
Item No:		18-P-354A/B			
Revision:		1	Date:		27-Feb-23
Unit:		Renewable Jet Fuel Unit B			
P.O. No.:		4505606431			
Inquiry No.:		4-601D-RQ			
Sheet	11	of	11		REV

PROPOSAL PUMP CURVES

RATED CASE: 0.73 cP



RICH AMINE UPSET CASE

