



WORLD ENERGY PARAMOUNT

World Energy Renewables Project

Paramount, California

MECHANICAL EQUIPMENT DATASHEET

Document Number A8KM-18-096-540064-A

Rev. G, 16-MAR-2023

EN203076-FLUOR-XXX-XXXXX



World Energy Renewables Project

RENEWABLE JET FUEL UNIT B

MECHANICAL EQUIPMENT DATA SHEET FOR 18-P-355A/B

STRIPPER REFLUX PUMP

Document Number A8KM-18-096-540064-A


Fluor Project No: A8KM

G	11-Jan-2023	As-Built	8	AGU	CGO	
F	12-Jan-2023	Issued for Approval	8	AGU	CGO	
E	28-Nov-2022	Issued for Approval	6	AGU	CGO	
D	14-Oct-2021	Issued for Purchase	11	CP	JF AD ME	BT
C	26-May-2021	Issued for Quotation	10	JF	JPK AD ME	BT
B	12-May-2021	Issued for Client Review	10	JF	JPK AD ME	BT
A1	11-May-2021	Re-Issued for Internal Review	10	JF	JPK	
A1	11-May-2021	Issued for Internal Review	10	JF	JPK	
REV	DATE	DESCRIPTION	PAGES	ORIG	CHK'D	APPV'D



These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

SULZER CONFIDENTIAL


PAB1004565270010-01\_Z22\_000\_05048w3 di-gep-4 MARTSAR 2023-03-17T10:30:48 1.000 NP

		<b>API 610</b> <b>CENTRIFUGAL PUMP DATA SHEET</b>		<b>Contract:</b> A8KM																					
				<b>Item No:</b> 18-P-355A/B																					
				<b>Revision:</b> G <b>Date:</b> 16-Mar-23																					
				<b>Unit:</b> Renewable Jet Fuel Unit B																					
		<b>Doc. No.:</b> A8KM-18-096-540064-A		<b>P.O. No.:</b>																					
		Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.		<b>Inquiry No.:</b> 4-601D-RQ																					
		Sheet 2 of 8		REV																					
<b>CLIENT:</b> World Energy Paramount <b>PROJECT:</b> World Energy Renewables Project																									
<b>SERVICE:</b> Stripper Reflux Pump <b>FACILITY:</b> World Energy Renewables Plant <b>SITE:</b> Paramount, CA																									
<b>NO. REQ'D:</b> 2 x 100% (Note 2.1) <b>PUMP SIZE:</b> 2x3x7.5A-1 <b>API TYPE:</b> OH2 <b>NO. STAGES:</b> One (1)																									
<b>MANUFACTURER:</b> Sulzer <b>MODEL:</b> OHH <b>SERIAL NO.:</b> 649501 / 649502																									
<b>APPLICABLE TO:</b> <input type="radio"/> PROPOSALS <input type="radio"/> PURCHASE <input checked="" type="radio"/> AS-BUILT																									
GENERAL																									
<b>PUMPS OPERATE IN:</b> N/A <b>NO. MOTOR DRIVEN:</b> Two (2) <b>NO. TURBINE DRIVEN:</b> N/A																									
<b>WITH:</b> <b>PUMP ITEM NO.:</b> 18-P-355A/B <b>PUMP ITEM NO.:</b>																									
<b>GEAR ITEM NO.:</b> N/A <b>MOTOR ITEM NO.:</b> 18-P-355AM/BM <b>TURBINE ITEM NO.:</b>																									
<b>GEAR PROVIDED BY:</b> <b>MOTOR PROVIDED BY:</b> Pump Supplier <b>TURBINE PROVIDED BY:</b>																									
<b>GEAR MOUNTED BY:</b> <b>MOTOR MOUNTED BY:</b> Pump Supplier <b>TURBINE MOUNTED BY:</b>																									
<b>GEAR DATA SHEET NO.:</b> <b>MOTOR DATA SHEET NO.:</b> Attached <b>TURBINE DATA SHEET NO.:</b>																									
LIQUID CHARACTERISTICS																									
<b>UNITS</b> <b>MAXIMUM</b> <b>RATED</b> <b>MINIMUM</b>				<b>SERVICE:</b> CONTINUOUS																					
<b>LIQUID TYPE OR NAME:</b> Stripper Reflux				<b>*IF INTERMITTENT, NO. OF STARTS / DAY:</b>																					
<b>VAPOR PRESSURE:</b> psi (a)      35.2				<b>CORROSION DUE TO: (6.12.1.9):</b>																					
<b>RELATIVE DENSITY:</b> 0.665      0.643				<b>EROSION DUE TO: (6.12.1.9):</b>																					
<b>SPECIFIC HEAT:</b> BTU/lbm °F				<b>H<sub>2</sub>S CONCENTRATION (ppmw) (6.12.1.12):</b> 166																					
<b>VISCOSITY:</b> cP      0.44      0.34				<b>WET (YES / NO):</b> YES																					
OPERATING CONDITIONS (6.1.2)																									
<b>UNITS</b> <b>MAXIMUM</b> <b>RATED</b> <b>NORMAL</b> <b>MINIMUM</b>				<b>CHLORIDE CONCENTRATION (ppmw):</b>																					
<b>NPSHa DATUM:</b> C.L. IMPELLER (Note 2.2)				<b>PARTICULATE SIZE (DIA. IN MICRONS):</b>																					
<b>PUMPING TEMP.:</b> °F      160      110				<b>PARTICULATE CONCENTRATION (ppmw):</b>																					
<b>FLOW:</b> gpm      131.3      114.2      39.6				<b>MECHANICAL DESIGN TEMPERATURE (°F):</b> 300																					
<b>DISCHARGE PRESS:</b> psi(g)      82.6				<b>Flash vapor at atmospheric pressure is 3 - 4 wt%</b>																					
<b>SUCTION PRESSURE:</b> psig(g)      106.2      24.6				<b>Pump is in wet sour service</b>																					
<b>DIFFERENTIAL PRESS.:</b> psi      58.0				<b>Water and HCl are present</b>																					
<b>DIFFERENTIAL HEAD:</b> ft      201.1																									
<b>NPSH<sub>A</sub>:</b> ft      (Note 2.2)      14.4      Excludes Req'd Margin																									
<b>HYDRAULIC POWER:</b> hp      4.4																									
SITE AND UTILITY DATA (6.1.2)																									
<b>LOCATION:</b> OUTDOOR      UNHEATED				<b>COOLING WATER:</b> SOURCE: COOLING TOWER																					
<b>MOUNTED AT:</b> GRADE <input type="radio"/> TROPICALIZATION REQ'D				<b>SUPPLY TEMP.:</b> 80 °F <b>MAX. ALLOW. RETURN TEMP.:</b> 120 °F																					
<b>ELECTRICAL AREA CLASSIFICATION:</b> <input type="radio"/> NON HAZARDOUS				<b>NORM. PRESS.:</b> 45 psi(g) <b>DESIGN PRESS.:</b> 120 psi(g)																					
<b>CLASS:</b> CL. I, B/C/D <b>DIVISION:</b> 2 <b>TEMP CODE:</b> T3C				<b>MAXIMUM RETURN PRESSURE:</b> 35 psi(g)																					
<b>SITE DATA:</b>				<b>MAXIMUM ALLOWABLE ΔP:</b> 10 psi																					
<b>ELEVATION (MSL):</b> 69 ft <b>BAROMETER:</b> 14.7 psia				<b>CHLORIDE CONCENTRATION:</b> < 840 ppm <b>DESIGN T:</b> 150 °F																					
<b>RANGE OF AMBIENT TEMPS: MIN. / MAX.:</b> 35 / 105 °F				<b>INSTRUMENT AIR: MAX.:</b> psi(g) <b>MIN.:</b> psi(g)																					
<b>RELATIVE HUMIDITY: MIN. / MAX.:</b> Average = / 54 %				<b>MECH. DESIGN:</b> psi(g)      °F																					
<b>UNUSUAL CONDITIONS:</b>				<b>STEAM:</b>																					
<b>UTILITY CONDITIONS:</b>				<table border="1"> <thead> <tr> <th colspan="2">DRIVERS</th> <th colspan="2">HEATING</th> </tr> </thead> <tbody> <tr> <td>TEMP:</td> <td>°F</td> <td>MAX.:</td> <td></td> </tr> <tr> <td></td> <td></td> <td>MIN.:</td> <td></td> </tr> <tr> <td>PRESS.:</td> <td>psig</td> <td>MAX.:</td> <td></td> </tr> <tr> <td></td> <td></td> <td>MIN.:</td> <td></td> </tr> </tbody> </table>		DRIVERS		HEATING		TEMP:	°F	MAX.:				MIN.:		PRESS.:	psig	MAX.:				MIN.:	
DRIVERS		HEATING																							
TEMP:	°F	MAX.:																							
		MIN.:																							
PRESS.:	psig	MAX.:																							
		MIN.:																							
<table border="1"> <thead> <tr> <th>ELECTRICITY:</th> <th>DRIVERS</th> <th>HEATING</th> <th>CONTROL</th> <th>INSTRUMENTS</th> </tr> </thead> <tbody> <tr> <td>VOLTAGE:</td> <td>460</td> <td>120</td> <td>120</td> <td>24 VDC</td> </tr> <tr> <td>PHASE:</td> <td>3</td> <td>1</td> <td>1</td> <td></td> </tr> <tr> <td>HERTZ:</td> <td>60</td> <td>60</td> <td>60</td> <td></td> </tr> </tbody> </table>				ELECTRICITY:	DRIVERS	HEATING	CONTROL	INSTRUMENTS	VOLTAGE:	460	120	120	24 VDC	PHASE:	3	1	1		HERTZ:	60	60	60			
ELECTRICITY:	DRIVERS	HEATING	CONTROL	INSTRUMENTS																					
VOLTAGE:	460	120	120	24 VDC																					
PHASE:	3	1	1																						
HERTZ:	60	60	60																						
NOTES																									
2.1 2 x 100% pumps; 1 operating and 1 spare.																									
2.2 NPSHa calculation based on 3' above grade. Please see Sheet 3 for actual as-built pump centerline from bottom baseplate. G																									
2.3 Minimum NPSH margin shall be the greater of 2 feet or 15% of NPSHA (UOP Specification) G																									
Deleted.																									
2.3 Pump Control Method: Level control cascading to flow control.																									
2.4 This is a UOP Pump Service. Governing Project Specifications are: #1; Honeywell/UOP Standard Specification 5-11-13, Centrifugal Pumps.																									
#2; Project Specification A8KM-PP-000-50626-A, Centrifugal Pumps for Petroleum and Natural Gas Industries - API 610.																									
Deleted. G																									
2.6 The head-capacity curve shall continuously rise to minimum continuous stable flow (UOP Specification).																									


These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

 		API 610 CENTRIFUGAL PUMP DATA SHEET				Contract: A8KM		
		Doc. No.: A8KM-18-096-540064-A				Item No: 18-P-355A/B		
						Revision: G Date: 16-Mar-23		
		Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.				Unit: Renewable Jet Fuel Unit B		
						P.O. No.: 4-601D-RQ		
				Sheet	3	of	8	REV
<b>PERFORMANCE</b>					<b>DRIVER (7.1.5)</b>			
PROPOSAL CURVE NO.: OHH 52-1-1-11 RPM 3520					DRIVER TYPE: INDUCTION MOTOR			
TEST CURVE NO.: M-13409 / M-13410					GEAR: NO			
IMPELLER DIA.: RATED: 7.36 MAX: 7.5 MIN: 4.5 in					VARIABLE SPEED REQUIRED: NO			
RATED POWER: 8.69 hp EFFICIENCY: 51.65 %					SOURCE OF VARIABLE SPEED: N/A			
RATED CURVE BEP FLOW: (at rated impeller dia.) 160.3 gpm					OTHER: TEFC / IP56			
MIN. FLOW: THERMAL : gpm STABLE : 32.56 gpm					MANUFACTURER: ABB			
PREFERRED OPERATING REGION: (6.1.12) 112.2 to 192.3 gpm					NAMEPLATE POWER: 15 hp			
ALLOWABLE OPERATING REGION: 32.56 to 200 gpm					NOMINAL RPM: 3600			
MAX. HEAD @ RATED IMPELLER: 222.6 ft					RATED LOAD RPM: 3520			
MAX. POWER @ RATED IMPELLER: (6.8.9) 11.3 hp					FRAME OR MODEL: 256T			
NPSHR at CL IMPELLER for RATED FLOW : 5.9 ft					ORIENTATION: HORIZONTAL			
CL PUMP TO LOWER SIDE OF BASEPLATE: 1.67 ft					LUBE: GREASE			
NPSH MARGIN at RATED FLOW : 8.5 ft					BEARING TYPE: ANTI-FRICTION			
SPECIFIC SPEED: gpm,rpm,ft 847					RADIAL: (Qty / Brg. Number) / 45BC03X30X			
SUCTION SPECIFIC SPEED LIMITATION gpm,rpm,ft (Note 3.1)					THRUST: (Qty / Brg. Number) / 45BC03X30X			
SUCTION SPECIFIC SPEED: (6.1.9): gpm,rpm,ft 10410					STARTING METHOD: CLOSED VALVE (UNLOADED) START			
MAX. ALLOW. SOUND PRESS. LEVEL / EST.: (6.1.14) @ 3 ft 85 / 70 dBA					DRIVER DATA SHEET: ATTACHED			
MAX. ALLOW. SOUND POWER LEVEL / EST.: (6.1.14) @ 3 ft / dBA					ACCESSORIES:			
MAX. DISCHARGE PRESSURE: (6.3.2) 170.3 psig								
BASIS: (6.3.2.a, b or c)								
<b>CONSTRUCTION</b>								
API PUMP TYPE: OH2 [Based on API 610 Definitions]					CASING MOUNTING: CENTERLINE			
NOZZLE CONNECTIONS: (6.4.2)					CASING TYPE:			
					OH3 BACKPULLOUT LIFING DEVICE REQ'D: (9.1.2.6) NO			
					CASE PRESSURE RATING: (Note 3.3)			
					MAWP: (6.3.5) 640 psig @ 300 °F			
					HYDROTEST: (8.3.2.6) 960 psig @ °F			
					Hydrotest at 1.5 x MAWP of the Pump Assembly.			
					HYDROTEST OH PUMP AS ASSEMBLY: YES			
					SUCTION PRESS. REGIONS DESIGNED FOR MAWP: YES			
					ROTATION: (VIEWED FROM COUPLING END)			
					- IMPELLERS INDIVIDUALLY SECURED: N/A			
					- BOLT OH 3/4/5 PUMP TO PAD / FOUNDATION: N/A			
					- PROVIDE SOLEPLATE FOR OH 3/4/5 PUMPS: N/A			
					ROTOR:			
					SHAFT FLEXIBILITY INDEX (SFI): (9.1.1.3) 85 (Note 6.11)			
					FIRST CRITICAL SPEED, WET: (MULTI-STAGE) N/A RPM			
					COMPONENT BALANCE TO ISO 1940 G1.0: (6.9.4.4) YES			
					SHRINK FIT LIMITED MOVEMENT IMPELLERS: (9.2.2.3) N/A			
					COUPLING & GUARD: (7.2.2) (Notes 3.4)			
					MANUFACTURER: Rexnord			
					MODEL: Series 71			
					RATING: (POWER/100 RPM)			
					SPACER LENGTH: 5 in			
					ACTUAL SF AT MOTOR NAMEPLATE: 1.5 minimum			
					RIGID: N/A			
					COUPLING WITH HYDRAULIC FIT: (7.2.10) NO			
					COUPLING BALANCED TO ISO 1940-1 G6.3: (7.2.3) G2.5			
					COUPLING WITH PROPRIETARY CLAMPING DEVICE: (7.2.1) N/A			
					COUPLING IN COMPLIANCE WITH: (7.2.4) API 610 COMPLIANT			
					COUPLING GUARD STANDARD PER: (7.2.13.a) ANSI B15.1			
					WINDOW ON COUPLING GUARD: YES			
<b>NOTES</b>								
3.1 Suction specific speeds greater than 11,000 for hydrocarbons and 9,000 for water (USC units) require specific approval by the Buyer.								
3.2 Terminate drain piping with valve by others.								
Deleted.								
3.3 Nameplate for MAWP at mechanical design temperature.								
3.4 Coupling guards shall be non-sparking.								
3.5 Deleted.								
Deleted.								

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

		<b>API 610</b> <b>CENTRIFUGAL PUMP DATA SHEET</b>		<b>Contract:</b> A8KM	
		Doc. No.: A8KM-18-096-540064-A  Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.		<b>Item No:</b> 18-P-355A/B	
				<b>Revision:</b> G	<b>Date:</b> 16-Mar-23
				<b>Unit:</b> Renewable Jet Fuel Unit B	
				<b>P.O. No.:</b>	
		<b>Inquiry No.:</b> 4-601D-RQ		<b>Sheet</b> 4 <b>of</b> 8 <b>REV</b>	
<b>CONSTRUCTION (CONT'D)</b>					
<b>MATERIAL (6.12.1.1)</b>			<b>BASEPLATE OR SOLE PLATE</b>		
APPENDIX H CLASS: <b>S-8: CS / 316L SS</b>			API BASEPLATE NUMBER:		
MINIMUM DESIGN METAL TEMP: (6.12.4.1) <b>32</b> °F			BASEPLATE CONSTRUCTION: (7.3.14) <b>FULL TOP DECKING</b>		
REDUCED HARDNESS MATERIALS REQ'D: (6.12.1.12.1) <b>YES</b>			BASEPLATE DRAINAGE: (7.3.1) <b>Sloping Deck Drain Pan</b>		
APPLICABLE HARDNESS STANDARD: (6.12.1.12.3) <b>MR0103</b>			MOUNTING: <b>GROUTED</b>		
BARREL:			NON-GROUT CONSTRUCTION: (7.3.13) <b>NOT REQUIRED</b>		
CASE: <b>A216 GR. WCB (PWHT)</b>			VERTICAL LEVELING SCREWS: <b>REQUIRED</b>		
DIFFUSERS:			HORIZONTAL DRIVER POSITIONING SCREWS: <b>REQUIRED</b>		
IMPELLER: <b>A743/A351 GR.CF3M</b>			SUPPLIED WITH: - GROUT VENT HOLES <b>YES</b>		
IMPELLER / CASE WEAR RING: <b>316L / C6HF // A890 GR.1B NACE</b>			- DRAIN CONNECTION <b>YES</b>		
SHAFT: <b>A276 TYPE 316 COND. A</b>			MOUNTING PADS SIZED FOR BASEPLATES LEVELING: (7.3.5) <b>YES</b>		
BOWL (IF VS TYPE):			MOUNTING PADS OR SOLE PLATE TO BE MACHINED: (7.3.6) <b>YES</b>		
INSPECTION CLASS: (API/ISO TABLE 14) <b>LEVEL 2</b>			PROVIDE SPACER PLATE UNDER ALL EQUIP. FEET: (7.3.6)		
<b>BEARINGS AND LUBRICATION (6.10.1)</b>			OTHER: <b>Furnish two (2) diagonally opposed grounding provisions per Note 6.9.</b>		
BEARING (TYPE / NUMBER):			<b>NOTES</b>		
RADIAL: <b>BALL</b> / <b>6310</b>			COATINGS REQ'D: (6.12.1.10) <b>--</b>		
THRUST: <b>BALL</b> / <b>7311</b>			4.1) SYNTHETIC OIL REQ'D: (6.10.2.12) <b>NO</b>		
REVIEW AND APPROVE THRUST BEARING SIZE: (9.2.5.2.4) <b>NO</b>			4.2) PROVISIONS FOR PURE OR PURGE MIST: (6.11.3) <b>IF STD</b>		
LUBRICATION TYPE: (6.11.3)(6.11.4)(9.2.6.1) <b>Ring Oil</b>			4.3) PRESS. / CIRC. LUBE SYSTEM: 9.2.6.1		
PRESSURE LUBE SYSTEM TO ISO 10438- (9.2.6.4) <b>N/A</b>			4.4) CONST. LEVEL OILER PREFERENCE: (6.10.2.2) <b>(Note 4.6)</b>		
ISO 10438 DATA SHEETS ATTACHED			<b>4.5) Bearing housing isolators shall be Inpro or Equal.</b>		
PRESSURIZED LUBE OIL SYSTEM MTD. ON PUMP BASEPLATE: <b>N/A</b>			<b>4.6) Bearing housing oilers shall be Trico 8-oz. constant-level sight feed.</b>		
LOCATION OF PRESSURIZED LUBE OIL SYSTEM MOUNTED ON BASEPLATE:			Provide a minimum 1" NPS bullseye level gauge.		
INTERCONNECTING PIPING PROVIDED BY: <b>N/A</b>			<b>4.7) Oil drains shall be furnished with an ESCO single-piece sight glass.</b>		
OIL VISC. ISO GRADE: <b>68</b>			<b>4.8) Pumps with A/F bearings shall have a minimum 1" diameter flat surface for a magnetic-based vibration transducer (UOP specification).</b>		
CONSTANT LEVEL OILER: (6.10.2.2) <b>REQUIRED</b>					
<b>INSTRUMENTATION</b>			<b>SEAL SUPPORT SYSTEM MOUNTING</b>		
SEE ATTACHED API-670 DATA SHEET: <b>NO</b>			BARRIER/BUFFER RESERV. MTD ON PUMP BASEPL.: (7.5.1.4) <b>YES</b>		
ACCELEROMETER OR VELOMETER: (7.4.2.1):			IDENTIFY LOCATION ON BASEPLATE:		
QUANTITY:					
MOUNTING LOCATIONS:			INTERCONNECTING PIPING BY: <b>SUPPLIER</b>		
DETECTORS REQUIRED:			RESERVOIR(S) SHIPPED SEPARATELY: <b>YES</b>		
THRD'D PROVISIONS ONLY PER ANSI/API 670: (6.10.2.10)			<b>MECHANICAL SEAL (6.8)</b>		
QUANTITY:			SEE ATTACHED API 682 DATA SHEET: <b>SEE PAGE 7</b>		
MOUNTING LOCATIONS:			ADDITIONAL CENTRAL FLUSH PORT: (6.8.9)		
			HEATING OR COOLING JACKET REQ'D:		
FLAT SURFACE REQ'D FOR MAGNETIC P/U's: (6.10.2.11) <b>YES (Note 4.8)</b>			MAX. CHAMBER PRESS.: (6.8.13) STATIC: DYN.: psig		
QUANTITY: <b>TWO</b>			SEAL CATEGORY: (6.8.1) <b>Category 2</b>		
MOUNTING LOCATIONS:			<b>HEATING AND COOLING</b>		
			COOLING REQUIRED: (6.1.17) <b>YES</b>		
VIBRATION PROXIMITY PROBES FOR HYDRODYNAMIC BEARINGS:			COOLING WATER PIPING PLAN: <b>Plan M</b>		
PROVISION-ONLY FOR VIB. PROBES: (7.4.2.2) <b>NO</b>			CLG WATER PIPING CONSTR.: <b>TAAG2</b>		
			FITTINGS TYPE:		
QUANTITY PER THRUST BEARING:			COOLING WATER PIPING MATERIALS: <b>Killed CS</b>		
VIBR. MONITORS & CABLES SUPPLIED BY: (7.4.2.4)			CLG WTR REQMTS: (BOTH ENDS IF DOUBLE ENDED)		
			BEARING HOUSING(S): gpm		
TEMP. DETECTORS FOR HYDRODYNAMIC BEARINGS: (7.4.2.3)			SEAL SUPPORT: (HX, BUFFER, BARRIER, ETC.) gpm		
PROVISION-ONLY FOR TEMPERATURE PROBES: <b>N/A</b>			TOTAL COOLING WATER: gpm		
RADIAL BEARING TEMPERATURE PROBES: <b>N/A</b>			HEATING MEDIUM: <b>N/A</b>		
QUANTITY PER RADIAL BEARING:			OTHER:		
THRUST BEARING TEMPERATURE PROBES: <b>N/A</b>			HEATING MEDIUM PIPING CONSTRUCTION:		
QUANTITY PER THRUST BEARING ACTIVE SIDE:			<b>PIPING &amp; APPURTENANCES</b>		
QUANTITY PER THRUST BEARING INACTIVE SIDE:			MANIFOLD PIPING SYS. FOR PURCHASER CONN.: (7.5.1.6)		
THRD'D T/W's FOR GEARBOX TEMP GAGES: (9.1.3.6) <b>N/A</b>			VENTS: <b>N/A</b>		
PRESSURE GAGE TYPE:			DRAINS: <b>N/A</b>		
TEMP. MONITORS & CABLES SUPPLIED BY: (7.4.2.4)			COOLING WATER: <b>YES</b>		
			TAG ALL ORIFICES: (7.5.2.4) <b>N/A</b>		
			SOCKET WELD CONN. ON SEAL GLAND: (7.5.2.8) <b>NO</b>		


These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

		<b>API 610</b>				<b>Contract:</b>		<b>A8KM</b>		
		<b>CENTRIFUGAL PUMP DATA SHEET</b>				<b>Item No:</b>		<b>18-P-355A/B</b>		
		Doc. No.: A8KM-18-096-540064-A				<b>Revision:</b>		<b>G      Date: 16-Mar-23</b>		
						<b>Unit:</b>		<b>Renewable Jet Fuel Unit B</b>		
		Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.				<b>P.O. No.:</b>				
<b>Inquiry No.:</b>						<b>4-601D-RQ</b>				
				<b>Sheet</b>		<b>5</b>	<b>of</b>		<b>8</b>	<b>REV</b>

<b>SURFACE PREPARATION AND PAINT</b>						<b>INSPECTION &amp; TEST</b>																			
2	MANUFACTURER'S STANDARD:					NO					SHOP INSPECTION: (8.1.1)					YES									
3	OTHER (SEE BELOW)					YES					PERFORMANCE CURVE & DATA APPROVAL PRIOR TO SHIPMENT:					YES									
4	SPECIFICATION NUMBER:					A8KM-PP-00-500520-A					TEST WITH SUBSTITUTE SEAL: (8.3.3.2.b)					NO									
5	PUMP: Meets ISO 12944-5, C4 Environment										MATERIAL CERT. REQUIRED: (6.12.1.8)					CASING: YES									
6	PUMP SURFACE PREPARATION:					SSPC-SP 10)										IMPELLER: YES									
7	PRIMER:					Hempadur AvantGuard 750										SHAFT: YES									
8	FINISH COAT:					Hempathane 55610										OTHER: See Note 6.3					YES				
9	BASEPLATE OR SOLE PLATE: Meets ISO 12944-5, C4 Environment										CASTING REPAIR PROCED. APPROVAL REQ'D: (6.12.2.5)(6.12.3.1)					Note 6.7									
10	SURFACE PREPARATION:					SSPC-SP 10)					INSPECTION REQ'D FOR CONN. WELDS: (6.12.3.4.d.e)														
11	PRIMER:					Hempadur AvantGuard 750										MAG PARTICLE: YES									
12	FINISH COAT:					Hempathane 55610										(BW Piping) RADIOGRAPHY: YES									
13	DETAILS OF LIFTING DEVICES:															LIQUID PENETRANT: NO									
14	SHIPMENT: (8.4.1)					(Note 6.8)										ULTRASONIC: NO									
15	EXPORT BOXING REQUIRED										INSPECTION REQUIRED FOR CASTINGS: (TABLE 14)														
16	OUTDOOR STORAGE UP TO 6 MONTHS:					YES										MAG PARTICLE: YES									
17	SPARE ROTOR ASSEMBLY PACKAGED FOR:															RADIOGRAPHY: YES									
18	ROTOR STORAGE ORIENTATION: (9.2.8.2)					N/A										LIQUID PENETRANT: YES									
19	SHIP'G & STORAGE CONTAINER FOR VERT. STORAGE: (9.2.8.3)					N/A										ULTRASONIC: YES									
20	N2 PURGE: (9.2.8.4)					N/A					HARDNESS TEST REQUIRED: (8.2.2.7) (NACE SERVICES)					YES									
21	SPARE PARTS: (Note 6.1)										ADDITIONAL SUBSURFACE EXAMINATION: (6.12.1.5)(8.2.1.3)					NO									
22	START-UP:					YES					FOR:														
23	NORMAL MAINTENANCE:					YES					METHOD:														
24											PMI TESTING REQUIRED: (8.2.2.8)					YES									
25											COMPONENTS TO BE TESTED:					See Note 6.4									
26											RESIDUAL UNBALANCE TEST: (J.4.1.2)					NO									
27											NOTIFICATION OF SUCCESSFUL SHOP PRELIM. TEST: (8.1.1.c)(8.3.3.5)					NO									
28											BASEPLATE TEST: (7.3.21)					NO									
29											HYDROSTATIC TEST OF CASING/HEAD:					NON-WIT									
30											HYDROSTATIC TEST OF BOWLS & COLUMN: (9.3.13.2)					N/A									
31											PERFORMANCE TEST: (Note 6.5)					NON-WIT									
32	COORDINATION MEETING REQUIRED: (10.1.3)					YES					TEST IN COMPLIANCE WITH: (8.3.3.2)					8.3.3.2									
33	MAXIMUM DISCHARGE PRESSURE TO INCLUDE:										TEST DATA POINTS TO: (8.3.3.3)					8.3.3.3									
34	MAX RELATIVE DENSITY:					YES					TEST TOLERANCES TO: (8.3.3.4)					TABLE 16									
35	OPERATION TO TURBINE TRIP SPEED OR ASD OVERSPEED:					N/A					NPSH TEST PTS./RETEST: (8.3.4.3.1)(8.3.4.3.4)					N/A									
36	MAX DIA. IMPELLERS AND / OR NO. OF STAGES:					NO					NPSH TEST-1ST STAGE ONLY: (8.3.4.3.2)					N/A									
37	CONNECTION DESIGN APPROVAL: (9.2.1.4) (BB Pumps)					N/A					NPSH TESTING TO HI 1.6 : (8.3.4.3.3)					NON-WIT									
38	TORSIONAL ANALYSIS / REPORT: (6.9.2.10) (REQ'D IF GEAR OR VFD)					N/A					PERFORMANCE TEST LIMITED TO 110% SITE NPSHA: (8.3.3.6)					NO									
39	PROGRESS REPORTS:					YES					RETEST ON SEAL LEAKAGE: (8.3.3.2.d)					NO									
40	OUTLINE OF PROCEDURE FOR OPTIONAL TESTS: (10.2.5)					YES					RETEST REQUIRED AFTER FINAL HEAD ADJ.: (8.3.3.7.b)(Multistg)					N/A									
41	ADDITIONAL DATA REQUIRING 20 YEARS RETENTION: (8.2.1.1)					NO					COMPLETE UNIT TEST: (8.3.4.4.1)					N/A									
42	LATERAL ANALYSIS REQUIRED: (9.1.3.4)(9.2.4.1.3)					N/A					SOUND LEVEL TEST: (8.3.4.5) FOR INFORMATION ONLY					NON-WIT									
43	MODAL ANALYSIS REQUIRED FOR VS PUMPS: (9.3.9.2)					N/A					CLEANLINESS PRIOR TO FINAL ASSEMBLY: (8.2.2.6)					NON-WIT									
44	DYNAMIC BALANCE ROTOR ASSEMBLY TO ISO G1.0: (9.2.4.2.3)					N/A					LOCATION OF CLEANLINESS INSPECTION:					@ SUPPLIERS									
45	INSTALLATION LIST IN PROPOSAL: (10.2.3.I)					NO					NOZZLE LOAD TEST:					NO									
46	VFD STEADY STATE DAMPED RESPONSE ANALYSIS: (6.9.2.3)					N/A					CHECK FOR CO-PLANAR MOUNTING PAD SURFACES:					NON-WIT									
47	TRANSIENT TORSIONAL RESPONSE: (6.9.2.4)					N/A					MECH. RUN TEST AT RATED CAPACITY UNTIL OIL TEMP STABLE: (8.3.4.2.1)					NON-WIT									
48	BEARING SELECTION & LIFE CALCS PER (6.10.1.1) & (6.10.1.6):					YES					1 HR. MECH RUN TEST AT RATED CAPACITY AFTER OIL TEMP STABLE:					YES									
49	IGNITION HAZARD ASSESSMENT TO EN 13463-1 FOR EXPLOSIVE ATM: (7.2.15)					N/A					4 HR. MECH RUN TEST AT RATED CAPACITY: (8.3.4.2.2)					N/A									
50	CASING RETIREMENT THICKNESS DWG: (10.3.2.3)					NO					BEARING HSG. RESONANCE TEST: (8.3.4.7)					N/A									
51	FLANGES REQ'D IN PLACE OF SOCKET WELD UNIONS: (7.5.2.8)					YES					STRUCTURAL RESONANCE TEST: (9.3.9.2)					N/A									
52	INCLUDE PLOTTED VIBRATION SPECTRA FOR PERF. TEST: (6.9.3.3)					YES					REMOVE / INSPECT HYDRODYN. BRGS. AFTER TEST: (9.2.7.5)					N/A									
53	CONNECTION BOLTING: (7.5.1.7)					PAINTED					AUXILIARY EQUIPMENT TEST: (8.3.4.6)					N/A									
54	CADMIUM PLATED BOLTS PROHIBITED:					YES					EQUIP. TO BE INCLUDED IN AUX. TESTS:														
55	VENDOR TO KEEP REPAIR AND HT RECORDS: (8.2.1.1.c)					YES					LOCATION OF AUX. EQUIPMENT TEST:														
56	VENDOR TO SUBMIT TEST PROCEDURES: (8.3.1.1)					YES																			
57	VENDOR SUBMIT INSPECTION CHECK LIST: (8.1.5)					YES																			
58	TEST REQUIREMENTS PER 8.3.3.5a THROUGH 8.3.3.5d:					YES					IMPACT TEST: (6.12.4.3) PER EN 13445					N/A									
59	DISASSEMBLE AND INSPECT AFTER TEST: (8.3.3.8)					NO					PER ASME SECTION VIII					N/A									
60											REMOVE CASING AFTER TEST:					N/A									

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.



		<b>API 610</b> <b>CENTRIFUGAL PUMP DATA SHEET</b>		Contract:		A8KM		
				Item No:		18-P-355A/B		
		Doc. No.: A8KM-18-096-540064-A		Revision:		G	Date:	16-Mar-23
				Unit:		Renewable Jet Fuel Unit B		
		Note: This data sheet has been modified from that in the annex of API Standard 610, 11th Edition.		P.O. No.:				
		Inquiry No.:		4-601D-RQ				
		Sheet	6	of	8	REV		

<b>PRESSURE VESSEL DESIGN CODE REFERENCES</b>																											
THESE REFERENCES MUST BE LISTED BY THE MANUFACTURER:																											
CASTING FACTORS USED IN DESIGN: (TABLE 3)																											
SOURCE OF MATERIAL PROPERTIES:																											
<b>WELDING AND REPAIRS</b>																											
THESE REFERENCES MUST BE LISTED BY THE PURCHASER (DEFAULT TO TABLE 11 IF NO PURCHASER PREFERENCE IS STATED)																											
ALTERNATIVE WELDING CODES AND STANDARDS:																											
WELDING REQUIREMENT: (APPLICABLE CODE OR STANDARD)		DEFAULT PER TABLE 11																									
WELDER/OPERATOR QUALIFICATION:																											
WELDING PROCEDURE QUALIFICATION:																											
NON-PRESSURE RETAINING STRUCTURAL WELDING SUCH AS BASEPLATES OR SUPPORTS:																											
MAGNETIC PARTICLE OR LIQUID PENETRANT EXAMINATION OF PLATE EDGES:																											
POSTWELD HEAT TREATMENT:																											
POSTWELD HEAT TREATMENT OF CASING FABRICATION WELDS:																											
<b>MATERIAL INSPECTION</b>																											
THESE REFERENCES MUST BE LISTED BY THE PURCHASER		DEFAULT TO TABLE 14: YES																									
ALTERNATIVE MATERIAL INSPECTIONS AND ACCEPTANCE CRITERIA:																											
<table border="1"> <thead> <tr> <th>TYPE OF INSPECTION</th> <th>METHOD</th> <th>FOR FABRICATIONS</th> <th>FOR CASTINGS</th> </tr> </thead> <tbody> <tr> <td>RADIOGRAPHY</td> <td></td> <td></td> <td></td> </tr> <tr> <td>ULTRASONIC INSPECTION</td> <td></td> <td></td> <td></td> </tr> <tr> <td>MAGNETIC PARTICLE INSPECTION</td> <td></td> <td></td> <td></td> </tr> <tr> <td>LIQUID PENETRANT INSPECTION</td> <td></td> <td></td> <td></td> </tr> <tr> <td>VISUAL INSPECTION (ALL SURFACES)</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				TYPE OF INSPECTION	METHOD	FOR FABRICATIONS	FOR CASTINGS	RADIOGRAPHY				ULTRASONIC INSPECTION				MAGNETIC PARTICLE INSPECTION				LIQUID PENETRANT INSPECTION				VISUAL INSPECTION (ALL SURFACES)			
TYPE OF INSPECTION	METHOD	FOR FABRICATIONS	FOR CASTINGS																								
RADIOGRAPHY																											
ULTRASONIC INSPECTION																											
MAGNETIC PARTICLE INSPECTION																											
LIQUID PENETRANT INSPECTION																											
VISUAL INSPECTION (ALL SURFACES)																											
<b>NOTES</b>																											
6.1	Provide a Start-up Spare Parts List and 2-yrs. Operating Spares List, inclusive of coupling and motor parts.																										
6.2	Pump Supplier shall provide pump performance curves, General Arrangement drawing sized for the driver, completed data sheets & Bill of Material, and un-priced Sub-Supplier buyouts.																										
6.3	CMTR's are required for pressure casings & covers, impellers, wear rings & shaft. Include all QA documents in Quality Data Books.																										
6.4	PMI is required for alloy pressure containing parts, including seal glands, pipe, and valves, per Project Specification A8KM-PP-000-500512-A, Positive Material Identification.																										
6.5	Mechanical run testing is required for each pump. Mechanical run test shall be one (1) hour at Rated point for single-stage pumps, with vibration recordings at 10 minute intervals.																										
6.6	Deleted.																										
6.7	Deleted.																										
6.7	Minor defects of a surface nature in the pressure casting (amounting to less than 20% of the wall thickness and less than 10 in <sup>2</sup> [65 cm <sup>2</sup> ] in total area) may be repaired without Buyer's approval. See Project Pump Specification A8KM-PP-000-50626-A.																										
6.8	Export Boxing is required for Ocean Transit only. Supplier shall include as applicable to their scope and place of manufacture in relation to destination of equipment. All boxing shall be protective of the weather elements.																										
6.9	Baseplate grounding tabs or lugs shall be 1/4" thick steel with at least one (1) 9/16" dia. hole provided. If two (2) are provided, they shall be 9/16" dia. spaced 1-3/4" on center. Where Stainless Steel grounding pads are provided, they shall be threaded with one (1) 1/2"-13 hole, or either two (2), or four (4), 1/2"-13 holes, all spaced 1-3/4" on center.																										
6.10	Pumps must comply with Honeywell UOP Pump Specification 5-11-13 CENTRIFUGAL PUMPS dated 06Jul16 and Motor specification 7-12-6 ELECTRIC MOTORS dated 03Jun15. (UOP Pump service)																										
6.11	The value of the overhung pump shaft flexibility, ISF, for the given pump size factor, Kt, shall not exceed 1.2 times the equation (K.5) (US units). (UOP Specification)																										

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.






 		<b>PUMP DATASHEET ANNEX</b>		Contract: A8KM	
				Item No: 18-P-355A/B	
				Revision: G	Date: 16-Mar-23
				Unit: Renewable Jet Fuel Unit B	
				P.O. No.:	
				Inquiry No.: 4-601D-RQ	
Sheet 7 of 8		REV			

TESTED PUMP CURVE No: M-13409    PUMP TAG & SERIAL NO: 18-P-355 A    6496501				
<b>SULZER</b> Curva de prueba <b>M-13409</b> Test Curve		1er Paso 1st Stage	Series Series	No. Or 100456527-0010-01
Cliente Customer AIR PRODUCTS AND CHEMICALS	Impulsor Impeller D10692	Modelo Pattern 213OHH-01		Sulzer Comm.Nr.
Orden Compra 4505551384	Difusor Diffuser D10690	Modelo Pattern 214OHH-01		Tipo Type 2x3x7.5A-1 OHH
No. Identif. Ident No. 18-P-355 A	D2 Diseño. D2 design. Ø7.36 in		Venas Vane Ø7.36 in	Reporte No. Test Report No. 207/22
No. Serie Item No. 649501	D2 mín. D2 min. Ø4.50 in		D2 máx. D2 max. Ø7.50 in	Fecha dated ..
Nombre Name Gerardo Endoqui	D2 mín. D2 min. Ø4.50 in		D2 máx. D2 max. Ø7.50 in	m 3520    1/min.    i=    1    Stufen Stages
Fecha Date 2022-07-09	D2 mín. D2 min. Ø4.50 in		D2 máx. D2 max. Ø7.50 in	DN <sub>s</sub> 3 in    DN <sub>d</sub> 2 in

F-BP-002

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

**FLUOR®**





**PUMP DATASHEET  
ANNEX**

Contract:	A8KM		
Item No:	18-P-355A/B		
Revision:	G	Date:	16-Mar-23
Unit:	Renewable Jet Fuel Unit B		
P.O. No.:			
Inquiry No.:	4-601D-RQ		
Sheet	8	of	8

REV

TESTED PUMP CURVE No: M-13410 PUMP TAG & SERIAL NO: 18-P-355 B 6496502

<b>SULZER</b>		1er Paso 1st Stage	Series	No. Or 100456527-0010-02
Curva de prueba Test Curve <b>M-13410</b>		Impulsor Impeller	D10692	Sulzer Comm.Nr.
Cliente Customer: AIR PRODUCTS AND CHEMICALS		Modelo Pattern	213OHH-01	Tipo Type 2x3x7.5A-1 OHH
Orden Compra 4505551384		Difusor Diffuser	D10690	
No. Identif. Ident No. 18-P-355 B		Modelo Pattern	214OHH-01	
No. Serie Item No. 649502		D2 Diseño D2 design. Ø7.36 in	Venas Vane Ø7.36 in	Reporte No. Test Report No. 208/22
Nombre Name Gerardo Endoqui		D2 mín. D2 min. Ø4.50 in		n= 3520 1/min. j= 1 Stufen Stages
Fecha Date 2022-07-09		D2 max. D2 max. Ø7.50 in		DN <sub>s</sub> 3 in DN <sub>d</sub> 2 in



F-BP-002

These documents contain confidential and proprietary information of Fluor Enterprises, Inc. They are provided under a Secrecy or Confidentiality Agreement with Fluor and are to be used solely in accordance with the provisions of the relevant agreement. These documents are copyrighted as an unpublished work. Copyright resides with Fluor Corporation. All Rights Reserved. Unauthorized copying, reproduction or use of these documents may result in copyright infringement or other crimes punishable in both civil and criminal courts.

SULZER CONFIDENTIAL

PAB1004565270010-01\_Z22\_000\_05048w3 di-gep-4 MARTSAR 2023-03-17T10:30:48 1.000 NP