

Flowserve Pump Division, 3900 Cook Boulevard, Chesapeake, VA 23323, USA Phone: (+1) 757 485-8000

chpdoc@flowserve.com

Customer Document title:

Standard Performance Curve

Flowserve Document title: Standard Performance Curve

Flowserve Document No.: 1400944-012-1060-01

Document Revision No.: **0** PROJECT - WORPAR

Flowserve Order No.: 1400944 ITEM NBR - P682B.1/1-P682B.1/2
Flowserve Serial No.: 1400944CHP012A/D

eBN

eB NBR - 100212952.000

Pump Type/Size: MARK 3 STANDARD / 2K4X3-10RV

DATE - 22.10.2021

Quantity: 4

Customer Name: DESMET BALLESTRA NORTH AMERICA

DESMET TAG#: P682B.1/1, CUSTOMER TAG#: 19-P-765A, DESMET TAG#: P682B.1/2,

Customer Tag No: CUSTOMER TAG#: 19-P-765B, DESMET TAG#: P682B.2/1, CUSTOMER TAG#: 19-P-865A,

DESMET TAG#: P682B.2/2, CUSTOMER TAG#: 19-P-865B

Customer PO No.: 28493

End User: DESMET BALLESTRA NORTH AMERICA

Please complete and return:				
Document Reviewed by:	Document Reviewed date:			
,				
☐ APPROVED. NO ACTION REQUIRED				
□ APPROVED. RE-SUBMIT AS FINAL.				
☐ APPROVED WITH COMMENTS. DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.				
□ REJECTED. CORRECT AND RE-SUBMIT FOR APPROVAL.				
☐ FOR INFORMATION . REVIEW NOT REQUIRED				
☐ AS-BUILT				

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered <u>Approved</u>, no action.
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Ī	Rev	Revision Description	Released	Release Date
		Final		14-Sep-21



Pump size & type / Stages : 2K4x3-10RV M3 ST

Based on curve no. : MIII7900DV Impeller diameter : 9.63 in

Customer : DESMET PROCESS & TECHNOLOGY ...

Item number : P682B.1/1, 1/2, 2/1, 2/2
Service : Bleached Oil Filter Tank

Flowserve reference : 1989206898

Date : August 26, 202

: August 26, 2021

Capacity : 526.5 USgpm
Head : 357.61 ft
Density / Specific gravity : - / 0.880
Pump speed : 3,550 rpm

 Ns / Nss
 : 1,118 / 12,960 (US units)

 Test tolerance
 : ANSI/HI 14.6 Grade 1B

CURVES ARE APPROXIMATE, PUMP IS GUARANTEED FOR ONE SET OF CONDITIONS; CAPACITY, HEAD, AND EFFICIENCY....

