



Customer Document title:

Standard Performance Curve

Flowserve Document title: **Standard Performance Curve**Flowserve Document No.: **1400944-002-1060-01**

PROJECT - WORPAR

Document Revision No.: **0**

ITEM NBR - PW502.1/1-PW502.1/2

Flowserve Order No.: **1400944**

PW502.2/1-PW502.2/2

Flowserve Serial No.: **1400944CHP002A/D**

eB NBR - 100212852.000

Pump Type/Size: **MARK 3 STANDARD / 2K4X3-10OP**

DATE - 22.10.2021

Quantity: **4**Customer Name: **DESMET BALLESTRA NORTH AMERICA**

DESMET TAG#: PW502.1/1, CUSTOMER TAG#: 19-P-754A, DESMET TAG#: PW502.1/2,

Customer Tag No: CUSTOMER TAG #: 19-P-754B, DESMET TAG#: PW502.2/1, CUSTOMER TAG#: 19-P-854A, DESMET TAG#: PW502.2/2, CUSTOMER TAG#: 19-P-854B

Customer PO No.: **28493**End User: **DESMET BALLESTRA NORTH AMERICA****Please complete and return:**

Document Reviewed by:		Document Reviewed date:	
-----------------------	--	-------------------------	--

- APPROVED. NO ACTION REQUIRED**
- APPROVED. RE-SUBMIT AS FINAL.**
- APPROVED WITH COMMENTS. DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.**
- REJECTED. CORRECT AND RE-SUBMIT FOR APPROVAL.**
- FOR INFORMATION. REVIEW NOT REQUIRED**
- AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered Approved, no action.
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final		14-Sep-21

Customer	: DESMET PROCESS & TECHNOLOGY ...	Capacity	: 445.7 USgpm
Item number	: PW502.1/1, 1/2, 2/1, 2/2	Head	: 273.00 ft
Service	: Degummed Oil Surge	Density / Specific gravity	: - / 0.887
Flowserve reference	: 1989206898	Pump speed	: 3,550 rpm
Date	: August 25, 2021	Ns / Nss	: 1,083 / 11,220 (US units)
		Test tolerance	: ANSI/HI 14.6 Grade 1B

CURVES ARE APPROXIMATE, PUMP IS GUARANTEED FOR ONE SET OF CONDITIONS; CAPACITY, HEAD, AND EFFICIENCY....

