



Customer Document title:

Certificate of Hydrostatic Test

Flowserve Document title: **Certificate of Hydrostatic Test**Flowserve Document No.: **1400944-013-1010-01**Document Revision No.: **0**Flowserve Order No.: **1400944**Flowserve Serial No.: **1400944CHP013A/D**Pump Type/Size: **MARK 3 STANDARD / 2K4X3-10RV**Quantity: **4**Customer Name: **DESMET BALLESTRA NORTH AMERICA**

Customer Tag No: **DESMET TAG#: PW582D.1/1, World Energy TAG#:19-P-773A, DESMET TAG#: PW582D.1/2, World Energy TAG#:19-P-773B, DESMET TAG#:PW582D.2/1, World Energy TAG#:19-P-873A, DESMET TAG#: PW582D.2/2, World Energy TAG#:19-P-873B**

Customer PO No.: **28493**End User: **DESMET BALLESTRA NORTH AMERICA**

Please complete and return:

Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**
☐ **APPROVED. RE-SUBMIT AS FINAL**
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered Approved, no action.
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final		09-Jun-22



Certificate of Hydrostatic Test

Customer Name:	DESMET BALLESTRA NORTH AMERICA
Customer PO No.:	28493
Customer Tag No:	DESMET TAG#: PW582D.1/1, World Energy TAG#:19-P-773A, DESMET TAG#: PW582D.1/2, World Energy TAG#:19-P-773B, DESMET TAG#:PW582D.2/1, World Energy TAG#:19-P-873A,
Flowserve Order:	1400944
Pump Type/Size:	MARK 3 STANDARD / 2K4X3-10RV
Flowserve Serial: No.:	1400944CHP013A/D
Quantity:	4

This is to certify that the following units have been successfully hydrostatic tested to pressures quoted and found to be satisfactorily sound.

Part Type	Part Number	Material	Hold Time	PSI #
CASING	SM-CY22235A-DAAA-D4-XXGXX	D4	10 MIN	413
COVER	SM-DY53440A-D4-XXGXX	D4	10 MIN	675

Logan Coard

Quality Assurance, Chesapeake Operations