



Customer Document title:

## Certificate of Impeller Balance

Flowserve Document title: **Certificate of Impeller Balance**Flowserve Document No.: **1400944-013-1012-01**Document Revision No.: **0**Flowserve Order No.: **1400944**Flowserve Serial No.: **1400944CHP013A/D**Pump Type/Size: **MARK 3 STANDARD / 2K4X3-10RV**Quantity: **4**Customer Name: **DESMET BALLESTRA NORTH AMERICA**

Customer Tag No: **DESMET TAG#: PW582D.1/1, World Energy TAG#:19-P-773A, DESMET TAG#: PW582D.1/2, World Energy TAG#:19-P-773B, DESMET TAG#:PW582D.2/1, World Energy TAG#:19-P-873A, DESMET TAG#: PW582D.2/2, World Energy TAG#:19-P-873B**

Customer PO No.: **28493**End User: **DESMET BALLESTRA NORTH AMERICA**

### Please complete and return:

Document Reviewed by:

Document Reviewed date:

- ☐ **APPROVED. NO ACTION REQUIRED**  
☐ **APPROVED. RE-SUBMIT AS FINAL**  
☐ **APPROVED WITH COMMENTS.** DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL.  
☐ **REJECTED.** CORRECT AND RE-SUBMIT FOR APPROVAL.  
☐ **FOR INFORMATION.** REVIEW NOT REQUIRED  
☐ **AS-BUILT**

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered Approved, no action.
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final		09-Jun-22



## Certificate of Impeller Balance – 2.5

Customer Name:	DESMET BALLESTRA NORTH AMERICA
Customer PO No.:	28493
Customer Tag No:	DESMET TAG#: PW582D.1/1, World Energy TAG#:19-P-773A, DESMET TAG#: PW582D.1/1, World Energy TAG#:19-P-773A
Flowserve Order:	1400944
Pump Type/Size:	MARK 3 STANDARD / 2K4X3-10RV
Flowserve Serial: No.:	1400944CHP013A/D
Quantity:	4

It is hereby certified that balance to ISO – 1940-11 G 2.5 was performed on the impellers for the units described.

Part Type	Part Number	Material Spec.	Balance Grade
Impeller	SM-MY35641AA100-D4-XXGXX	D4	2.5

Logan Coard

Quality Assurance, Chesapeake Operations