

Flowserve Pump Division, 3900 Cook Boulevard, Chesapeake, VA 23323, USA Phone: (+1) 757 485-8000

chpdoc@flowserve.com

Customer Document title:

## **Standard Performance Curve**

Flowserve Document title: Standard Performance Curve

Flowserve Document No.: 1400944-017-1060-01 PROJECT - WORPAR

Document Revision No.: 0 ITEM NBR - PW503E.2/1-PW503E.2/2

Flowserve Order No.: **1400944** eB NBR - 100213002.000 Flowserve Serial No.: **1400944CHP017A/B** DATE - 22.10.2021

Pump Type/Size: MARK 3 STANDARD /

Quantity: 2

Customer Name: DESMET BALLESTRA NORTH AMERICA

Customer Tag No: DESMET TAG#: PW503E.2/1, CUSTOMER TAG#: 19-P-875A, DESMET TAG#:

PW503E.2/2, CUSTOMER TAG#: 19-P-875B

Customer PO No.: 28493

End User: DESMET BALLESTRA NORTH AMERICA

Please complete and ret	ırn:			
Document Reviewed by:		Document Reviewed date:		
□ APPROVED. NO ACTION REQUIRED □ APPROVED. RE-SUBMIT AS FINAL. □ APPROVED WITH COMMENTS. DOCUMENT WILL BE MODIFIED AND RESUBMITTED AS FINAL. □ REJECTED. CORRECT AND RE-SUBMIT FOR APPROVAL. □ FOR INFORMATION. REVIEW NOT REQUIRED □ AS-BUILT				

- Return any documents sent for review with your comments by the stated return date. All documents not returned two weeks after requested Return date will be considered <u>Approved</u>, no action.
- Purchaser's comments and/or corrections within the scope of contract will be made on the first completed document submitted by Flowserve Corp. and returned.
- Corrections, alterations, additions and/or modifications outside scope of contract or made after first submittal may require an additional engineering service charge.
- Items conditionally approved or with deferred approval by purchaser must be specifically stated otherwise delivery may be affected.

Rev	Revision Description	Released	Release Date
	Final		14-Sep-21



Pump size & type / Stages : 2K4x3-10RV M3 ST

Based on curve no. : MIII7900DV : 8.25 in Impeller diameter

Customer : DESMET PROCESS & TECHNOLOGY ...

Item number : PW503E.2/1, 2/2

Service : Enzyme Reactor Discharge

Flowserve reference : 1989206898

Date : August 27, 2021 Capacity : 468.1 USgpm Head : 251.00 ft Density / Specific gravity : - / 0.888

Pump speed : 3,550 rpm

Ns / Nss : 1,118 / 12,960 (US units) Test tolerance : ANSI/HI 14.6 Grade 1B

CURVES ARE APPROXIMATE, PUMP IS GUARANTEED FOR ONE SET OF CONDITIONS; CAPACITY, HEAD, AND EFFICIENCY...

