

FORM U-1 MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS

#91686

as required by the provisions of the ASME Code rules, Section VIII, Division 1

1. Manufactured and certified by Pfautler (United States), Inc., 1000 West avenue, Rochester, NY 14692
(name and address of manufacturer)2. Manufactured for Polaroid Corp., Waltham, MA
(name and address of purchaser)3. Location of installation Polaroid Corp., Waltham, MA
(name and address)4. Type: Vertical R188-0085 *NA R188-0085 44831 1988
(horiz. or vert., tank) (mfr's. serial no.) (CRN) (drawing no.) (Nat'l. Bd. no.) (year built)5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction and workmanship conform to ASME Code, Section VIII, Division 1: 1986
(year)1986
(addenda (date):)CC1970
(Code Case no.)NA
(special service per UG-120(d))

Items 6-11 inclusive to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

6. Shell: SA 516 Gr. 70 3/8" 0 5' 5 1/2" 6' 4"
(mat'l. (spec. no., grade)) (nom. thickness (in.)) (corr. allow. (in.)) (dia. ID (ft. & in.)) (length (overall)) (ft. & in.)7. Seams: #1, UW-12 None 70 NA NA #1&2, UW-12 None 1
(long. (dbl., singl.)) (RT (spot or full)) (eff. (%)) (HT temp. (°F)) (time) (girth (dbl., singl.)) (RT (spot, partial, or full)) (no. of courses)8. Heads: (a) NA (b) SA 516 Gr. 70
(mat'l. (spec. no., grade)) (mat'l. (spec. no., grade))

	Location (top, bottom, ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (convex or concave)
(a)	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
(b)	Bottom	7/16"	0	66"	4"	NA	NA	NA	NA	Concave

If removable, bolts used (describe other fastenings): NA
(mat'l., spec. no., gr., size, no.)9. Type of jacket: Fig. 9-2 Type 5 Proof test: NA10. Jacket closure: Fig. 9-5 (b-2) If bar, give dimensions: NA If bolted, describe or sketch.
(describe as ogee & weld, bar, etc.)11. MAWP: 90/90 w/FV at max. temp. 450 Min. temp.: NA Hydro., ~~pneu. or comb.~~ test press.: 135
(psi) (°F) (when less than -20°F) (psi)

Items 12 and 13 to be completed for tube sections.

12. Tubesheets: (Items 12 and 13 not applicable.)
(stationary mat'l. (spec. no., gr.)) (dia. (in.) (subject to pressure)) (nom. thickness (in.)) (corr. allow. (in.)) (attachment (welded, bolted))
(floating mat'l. (spec. no., gr.)) (dia. (in.)) (nom. thickness (in.)) (corr. allow. (in.)) (attachment)13. Tubes: NA NA NA NA NA
(mat'l. (spec. no., gr.)) (OD (in.)) (nom. thickness (in. or gauge)) (no.) (type (straight or U))

Items 14-17 inclusive to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

14. Shell: SA 285 Gr. C 11/16" 0 5' 0" 5' 8"
(mat'l. (spec. no., gr.)) (nom. thickness (in.)) (corr. allow. (in.)) (dia. ID (ft. & in.)) (length (overall)) (ft. & in.)15. Seams: #1, UW-12 None 70 NA NA #1, UW-12 None 1
(long. (dbl., singl.)) (RT (spot or full)) (eff. (%)) (HT temp. (°F)) (time) (girth (dbl., singl.)) (RT (spot, partial, or full)) (no. of courses)16. Heads: (a) SA 285 Gr. C (b) SA 285 Gr. C
(mat'l. (spec. no., grade)) (mat'l. (spec. no., grade))

	Location (top, bottom, ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (convex or concave)
(a)	Top	5/8"	0	NA	NA	2:1	NA	NA	NA	Both
(b)	Bottom	5/8"	0	NA	NA	2:1	NA	NA	NA	Both

If removable, bolts used (describe other fastenings): NA
(mat'l., spec. no., gr., size, no.)17. MAWP: 100/FV at max. temp. 450 Min. temp.: NA Hydro., ~~pneu. or comb.~~ test press.: 100
(psi) (°F) (when less than -20°F) (psi)

Items on reverse side to be completed for all vessels where applicable.

FORM U-1 (back)

18. Nozzles, inspection and safety valve openings:

Purpose (inlet, outlet, drain, etc.)	Number	Dia. or Size	Type	Mat'l.	Nom. Thickness	Reinforcement Material	How Attached	Location
Manhole	1	30"	Clmp Flg	SA 836	.56"	Integral	W	NA
Inlet	5	4" 8"	LJ Flg	SA 836	CL 150	Integral	W	NA
Outlet	1	4"	LJ Flg	SA 836	CL 150	Integral	W	NA
Jkt Conn	10	1 1/2" 2" 3"	Scd Cplg	SA 216 Gr. WCA	3000#	Integral	W	NA
Jkt Conn	2	1/2"	Scd Cplg	SA 105	3000#	Integral	W	NA

19. Supports: Skirt No Lugs 4 Legs 0 Other NA Attached Welded to jacket shell
(yes or no) (no.) (no.) (describe) (where and how)

20. Remarks: Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: NA
(name of part, item number, mfr's name and identifying stamp)

Model RA60-1000, 1000 gallon jacketed glassed steel vessel for chemical service.
Inner vessel hydrotested in vertical position.

(*not applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization no. 408 expires 12-31 19 88

Date 4/15/88 Name Pfaudler (United States), Inc. Signed [Signature]
(manufacturer) (representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Pfaudler (United States), Inc. at Rochester, NY

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the state or province of New York and employed by Hartford Steam Boiler I. & I. Company

of Hartford, CT have inspected the pressure vessel described in this Manufacturers' Data Report on 4/18, 19 88, and state that, to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4/18/88 Signed Russell B. Miller Commissions N.B.# 6658
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) state, prov. and no.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME BOILER AND PRESSURE VESSEL CODE.

"U" Certificate of Authorization no. _____ expires _____, 19 _____

Date _____ Name _____ Signed _____
(assembler that certified and constructed field assembly) (by representative)


CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the state or province of _____ and employed by _____

of _____ have compared the statements in this Manufacturers' Data Report with the described pressure vessel and state that parts referred to as data items _____ not included in the certificate of shop inspection, have been inspected by me and that to the best of my knowledge and belief, the manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) state, prov. and no.)



VENDOR'S DRAWING REVIEW

1 ☐ Approved —
Manufacturing may proceed.

2 ☒ Approved except as noted —
Make changes and
Submit final drawing —
Manufacturing may proceed.

3 ☐ Not Approved —
Correct and resubmit.

4 ☐ Review not required —
Manufacturing may proceed.

Approval of this drawing does not
relieve Supplier from full compliance
with Contract or Purchase Order
requirements.

APPROVED DATE

R. Whalen 2-11-68

POLAROID CORPORATION
CHEM. ENG. DEPT.
WALTHAM, MASS.

BASE MATERIAL		
YES/NO	SA-285, GRC	
JACKET	SA-515, GR.65 (12) SA-516, GR 70	
SEALER	SA-515, GR.65 (12) SA-516, GR 70	
THICKNESSES	VEEDER	JACKET
HD-TOP/FRONT	5/8" S.E.	
HD-BOT/REAR	5/8" S.E.	7/16" FAD
SH-EL	11/16"	3/8"
SEALER		3/8"
DESIGN & INSPECTION		
SPECIFICATION	VEEDER	JACKET
ASME CODE	YES	YES
DESIGN & STAMP		
DESIGN P.C. 1 PSI	100/FV	90/90%
DESIGN T.E. 1/2"	450°	450°
HYDRO TEST PSI	100	135
RADIOGRAPH	NO	NO
DESIGN T.E. 1/2"		

SEE OPERATING LIMITATIONS, INSTALLATION
A MAINTENANCE INSTRUCTIONS P/N 81-100

FOR INSTALLATION IN AREAS NOT SUBJECT
TO WIND OR SEISMIC LOADS. SPECIFIC GRAVITY
OF VESSEL CONTENTS NOT TO EXCEED 1.2

FV-FULL VACUUM
 ■ WITH FULL VACUUM IN VESSEL

VESEL FINISH & ACCESSORY MATLS.

VERCEL 5015

ACCESSORIES AS SPECIFIED
TANTALUM

PLUGS	TANTALUM
EX LER	EURAN

CASSETS	CRT-AF	REFERENCES
---------	--------	------------

PAINT P. AUDLER	AE-7049
-----------------	---------

BLUE PER DATA	3131581
CALLED	3133165

5R.159	3133185
CAP RATED 1,000 GAL.	3133350

CAP. FULL	1,125 GAL.	3136248
-----------	------------	---------

WT. UNKN. 5,000#	3142043
7,750#	

WT. JKTED	7,350#
WT. LADDER	9,500#

WISCONSIN 7,000	PROG CODE
-----------------	-----------

TITLE

RA-60-1000 REACTOR
40% - 70% HUMIDITY

60" x 72" JCWVA

POLAROID CORP

CUSTOMER POLAROID CORP.
100 DOWNEY BLVD

ADDRESS 100 DUCHANEZ BLVD.
NEW YORK 10014

CONFIDENTIAL 310-26-DEO For 2 Mrs.
SAME

ADDRESS SANTE

CUST. ORDER NO. 5879101

FOUNDED

HOODLER

ER, N.Y. APPROVAL

R188-0085 TOTAL

FOR APPL - REGISTRATION 1/3

1. The first step is to identify the problem or question that needs to be answered. This involves understanding the context and the specific requirements of the task.

VESSEL AND/OR JACKET
COMPONENTS WELDED IN
ACCORDANCE WITH WELD
PROCEDURE IN SECTION
D-2-1.1 OF THE
ROCHESTER WELDING MANUAL

TAG W/EQUIPMENT
D2001 NB-B1

-GLASS LINED EQUIPMENT-
FINAL DIMENSIONS MAY VARY DUE TO
HIGH TEMPERATURE PROCESSING.

PFAUDLER
CHESTER, N.Y.
R188-0085
APPROVAL

FOR APPL - REGISTRATION 1/3

[illegible]